



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 27.03.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 26.03.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 26-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 26.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 27-Mar-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60293	70295	53698	26400	2983	213669
Peak Shortage (MW)	0	0	0	153	0	153
Energy Met (MU)	1245	1657	1416	553	55	4926
Hydro Gen (MU)	144	57	88	24	11	324
Wind Gen (MU)	61	87	33	-	-	181
Solar Gen (MU)*	206.52	146.53	145.49	4.24	1.27	504
Energy Shortage (MU)	0.18	0.36	0.00	0.08	0.15	0.77
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	60293	73751	68183	27136	3128	223731
Time Of Maximum Demand Met	19:00	10:27	11:22	18:48	18:09	10:26

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.022	0.00	0.00	2.85	2.85	86.43	10.73

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8267	0	168.5	67.9	-0.6	628	0.00
	Haryana	7534	0	159.6	105.9	-1.2	241	0.00
	Rajasthan	14473	0	292.8	55.8	-12.2	296	0.00
	Delhi	4213	0	86.2	79.1	-0.4	217	0.00
	UP	21522	0	396.1	99.0	1.0	564	0.18
	Uttarakhand	2132	0	42.1	31.9	-0.9	128	0.00
	HP	1832	0	34.6	21.8	-0.8	435	0.00
	J&K(UT) & Ladakh(UT)	2868	0	57.4	49.8	-0.7	402	0.00
	Chandigarh	210	0	3.9	4.0	0.0	12	0.00
WR	Railways_NR ISTS	198	0	4.1	3.9	0.2	31	0.00
	Chhattisgarh	6369	0	146.6	80.3	0.6	412	0.00
	Gujarat	23206	0	473.8	185.0	0.1	497	0.00
	MP	14071	205	277.9	157.0	-2.2	786	0.36
	Maharashtra	29627	0	676.2	249.5	0.0	696	0.00
	Goa	789	0	16.6	15.5	0.5	73	0.00
	DNHDDPDCL	1365	0	31.5	31.5	0.0	69	0.00
	AMNSIL	781	0	15.6	7.5	0.3	304	0.00
	BALCO	532	0	12.7	12.7	0.0	0	0.00
SR	RIL JAMNAGAR	264	0	6.1	6.3	-0.2	0	0.00
	Andhra Pradesh	12572	0	249.0	76.3	-0.5	439	0.00
	Telangana	16090	0	323.0	169.9	-0.9	915	0.00
	Karnataka	16616	0	323.6	135.7	-2.8	952	0.00
	Kerala	4776	0	97.4	76.9	0.7	463	0.00
	Tamil Nadu	19328	0	412.6	263.7	0.5	1334	0.00
	Puducherry	464	0	10.4	9.9	-0.1	43	0.00
ER	Bihar	5900	153	115.1	107.6	0.7	327	0.08
	DVC	3357	0	72.5	-37.5	-0.2	462	0.00
	Jharkhand	2119	0	41.1	29.5	0.2	159	0.00
	Odisha	5521	0	112.5	29.5	0.9	414	0.00
	West Bengal	10014	0	210.2	61.2	-1.3	285	0.00
	Sikkim	107	0	1.9	1.8	0.0	16	0.00
	Railways_ER ISTS	13	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	172	0	3.0	2.9	0.0	14	0.00
	Assam	1841	0	34.1	27.6	0.4	130	0.00
	Manipur	216	0	2.9	2.7	0.2	31	0.15
	Meghalaya	344	0	5.9	4.6	0.0	75	0.00
	Mizoram	152	0	1.9	1.7	-0.1	16	0.00
	Nagaland	163	0	2.5	2.4	0.0	27	0.00
	Tripura	282	0	4.9	4.4	-0.1	24	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.2	-10.9	-23.4	-25.8
Day Peak (MW)	-400.0	-966.9	-1009.0	-1373.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	52.0	-227.8	271.3	-109.5	14.1	0.0
Actual(MU)	26.5	-222.5	288.7	-116.0	14.0	-9.4
O/D/U/D(MU)	-25.5	5.4	17.4	-6.5	-0.1	-9.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3523	8730	2422	4055	586	19316	46
State Sector	8064	6900	6036	1672	139	22810	54
Total	11587	15629	8458	5727	725	42126	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	816	1632	760	736	10	3953	74
Lignite	28	14	44	0	0	87	2
Hydro	144	57	88	24	11	324	6
Nuclear	26	50	76	0	0	152	3
Gas, Naptha & Diesel	8	28	9	0	24	68	1
RES (Wind, Solar, Biomass & Others)	284	235	222	6	1	748	14
Total	1305	2015	1199	765	46	5331	100

Share of RES in total generation (%)	21.76	11.67	18.48	0.76	2.79	14.03
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.72	16.98	32.17	3.89	26.56	22.95

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.037
Based on State Max Demands	1.074

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	223731	10:26	11
Non-Solar hr	211937	19:17	153

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES							Import=(+ve) /Export =(-ve) for NET (MU)	
							Date of Reporting: 27-Mar-2025	
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	1032	579	0.0	0.2	-0.2
4	765 kV	SASARAM-FATEHPUR	1	346	449	0.0	4.4	-4.4
5	765 kV	GAYA-BALIA	1	75	409	0.0	4.6	-4.6
6	400 kV	PUSAULI-VARANASI	1	0	170	0.0	2.6	-2.6
7	400 kV	PUSAULI -ALLAHABAD	1	78	21	0.3	0.0	0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	742	292	2.2	0.0	2.2
9	400 kV	PATNA-BALIA	2	352	517	0.0	5.7	-5.7
10	400 kV	NAUBATPUR-BALIA	2	279	325	0.0	1.3	-1.3
11	400 kV	BIHARSHARIFF-BALIA	2	536	90	3.7	0.0	3.7
12	400 kV	MOTIHARI-GORAKHPUR	2	263	270	0.0	2.2	-2.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	1.7	0.0	1.7
14	220 kV	SAHUPURI-KARAMNESA	1	5	50	0.0	0.0	0.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						8.5	23.5	-15.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	695	424	1.2	0.0	1.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	715	1340	0.0	5.7	-5.7
3	765 kV	JHARSUGUDA-DURG	2	0	1400	0.0	26.4	-26.4
4	400 kV	JHARSUGUDA-RAIGARH	4	0	761	0.0	12.7	-12.7
5	400 kV	RANCHI-SIPAT	2	141	433	0.0	3.4	-3.4
6	220 kV	BUDHIPADAR-RAIGARH	1	0	127	0.0	1.8	-1.8
7	220 kV	BUDHIPADAR-KORBA	2	23	130	0.0	1.0	-1.0
ER-WR						1.2	51.0	-49.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	731	0.0	17.4	-17.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1014	0.0	24.2	-24.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	3270	0.0	59.4	-59.4
4	400 kV	TALCHER-I/C	2	842	0	14.0	0.0	14.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	101.0	-101.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	277	115	2.9	0.3	2.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	455	94	5.1	0.0	5.1
3	220 kV	ALIPURDUAR-SALAKATI	2	95	0	1.2	0.0	1.2
ER-NER						9.2	0.3	8.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	958	0	23.4	0.0	23.4
NER-NR						23.4	0.0	23.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2017	0.0	48.3	-48.3
2	HVDC	VINDHYACHAL B/B	-	50	0	1.3	0.0	1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1455	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	915	1514	4.5	6.5	-2.1
5	765 kV	GWALIOR-PHAGI	2	996	972	4.7	9.2	-4.5
6	765 kV	JABALPUR-ORAI	2	525	614	0.9	0.0	0.9
7	765 kV	GWALIOR-ORAI	1	702	0	10.4	0.0	10.4
8	765 kV	SATNA-ORAI	1	0	858	0.0	14.8	-14.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1872	0	31.4	0.0	31.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	2232	0.0	30.3	-30.3
11	400 kV	ZERDA-KANKROLI	1	469	0	7.4	0.0	7.4
12	400 kV	ZERDA -BHINMAL	1	324	0	5.1	0.0	5.1
13	400 kV	VINDHYACHAL -RIHAND	1	963	0	21.5	0.0	21.5
14	400 kV	RAPP-SHUJALPUR	2	902	64	9.7	0.0	9.6
15	400 kV	NEEMUCH-Chittorgarh	2	805	91	8.7	0.1	8.6
16	220 kV	BHANPURA-RANPUR	1	0	148	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	123	0	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	97	0	1.0	0.0	1.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						107.9	149.5	-41.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	962	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	6628	0.0	118.7	-118.7
3	765 kV	SOLAPUR-RAICHUR	2	301	1483	0.5	14.0	-13.5
4	765 kV	WARDHA-NIZAMABAD	2	0	3099	0.0	46.7	-46.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3182	0.0	49.2	-49.2
6	400 kV	KOLHAPUR-KUDGI	2	1114	0	19.2	0.0	19.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.3	0.0	2.3
WR-SR						22.0	252.5	-230.5
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	332	-37	118	2.83		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-294	28	-157	-3.76		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-238	-115	-203	-4.88		
	NER	132kV GELEPHU-SALAKATI	-23	0	-17	-0.40		
	NER	132kV MOTANGA-RANGIA	11	-10	0	0.01		
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	1.19		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-0.92		
	ER	NEPAL IMPORT (FROM BIHAR)	-313	0	-168	-4.03		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-586	14	-275	-6.61		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-942	-890	-933	-22.39		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1373	-811	-1077	-25.84		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-67	0	-43	-1.04		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 27-Mar-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.39	6.85	0.00	0.00	0.10	0.00	0.00	7.34
Nepal	4.13	0.00	3.90	0.00	0.00	3.15	0.00	0.00	11.18
Bangladesh	23.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.11
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.24	0.39	10.75	0.00	0.00	3.25	0.00	0.00	41.63

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.36
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.36	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.36

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.36	-0.39	-6.85	0.00	0.00	-0.10	0.00	0.00	-5.98
Nepal	-4.13	0.00	-3.90	0.00	0.00	-3.15	0.00	0.00	-11.18
Bangladesh	-23.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.11
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.88	-0.39	-10.75	0.00	0.00	-3.25	0.00	0.00	-40.27

Date of Reporting: 27-Mar-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.08	192589	5850	8314	184	10601	2255	166168	2126	184091	195498	-1252
0:15	50.03	192716	5837	8370	182	10897	2269	166407	2134	184164	196096	-1586
0:30	50.03	192183	5819	8327	177	10781	2260	166066	2107	183679	195537	-1580
0:45	50.03	191737	5851	8325	174	11163	2267	165364	2081	183238	195225	-1583
1:00	49.98	190417	5846	8182	172	10629	2269	164732	2077	182063	193907	-1574
1:15	50.03	189080	5824	8025	173	10174	2270	163995	2093	180882	192554	-1579
1:30	49.98	187709	5797	7972	180	9575	2244	163307	2077	179557	191152	-1566
1:45	49.98	187098	5846	7819	176	9129	2201	163318	2057	179103	190546	-1507
2:00	50.03	185726	5823	7736	174	8477	2210	162786	2089	177816	189295	-1491
2:15	50.03	184985	5825	7746	170	7983	2198	162416	2110	177069	188448	-1477
2:30	50.03	184135	5811	7580	164	7809	2191	161957	2118	176391	187630	-1494
2:45	49.98	183503	5804	7484	161	7608	2197	161425	2117	175858	186796	-1475
3:00	49.98	182953	5825	7483	160	7541	2203	161103	2121	175310	186436	-1465
3:15	49.98	182695	5849	7365	160	7485	2191	161080	2149	175170	186279	-1474
3:30	49.98	182774	5849	7137	160	7585	2194	161321	2098	175477	186344	-1485
3:45	49.93	182834	5809	6804	162	7499	2203	161664	2100	175868	186241	-1485
4:00	49.98	182486	5838	6602	163	7431	2204	161589	2132	175721	185959	-1504
4:15	49.88	183925	5800	6482	163	8361	2206	162313	2166	177280	187491	-1523
4:30	49.98	184625	5846	6427	161	8246	2184	162993	2169	178037	188026	-1202
4:45	50.03	184841	5828	6282	162	8661	2182	162828	2095	178397	188038	-979
5:00	50.03	186138	5823	6239	164	9554	2173	163409	2123	179735	189485	-1036
5:15	50.03	188272	5847	6101	166	10061	2191	165118	2119	182005	191603	-1038
5:30	49.98	189960	5795	5914	167	10961	2197	166173	2116	183879	193323	-1055
5:45	49.93	191605	5822	5723	174	12435	2211	166628	2147	185708	195140	-1133
6:00	50.03	192916	5845	5607	161	13931	2225	166703	2109	187148	196581	-1165
6:15	49.83	195570	5833	5516	158	16197	2262	167371	2147	189896	199484	-1513
6:30	49.88	199700	5839	5522	406	19529	2307	167796	2170	193772	203569	-1595
6:45	49.98	201908	5848	5558	1205	21499	2314	167080	2203	195145	205707	-1585
7:00	50.03	202634	5868	5498	2991	21920	2315	165453	2195	194145	206240	-1540
7:15	50.03	204521	5893	5429	5963	22241	2285	163847	2187	193129	207845	-1555
7:30	50.03	205137	5907	5218	9907	21410	2259	161650	2210	190012	208561	-1584
7:45	50.08	206479	5935	4948	14614	20440	2232	159130	2244	186917	209543	-1590
8:00	50.08	206098	5905	4739	19869	17717	2229	156452	2247	181490	209158	-1851
8:15	49.98	208476	5909	4139	25437	15907	2220	155788	2250	178900	211650	-2043
8:30	50.03	210891	5893	3592	30857	14754	2230	154187	2302	176442	213815	-2059
8:45	50.03	213149	5902	3192	35692	13755	2231	153339	2282	174265	216393	-2073
9:00	50.08	215478	5831	2972	40619	12338	2215	152428	2292	171887	218695	-2121
9:15	49.98	219267	5843	2713	44038	11180	2207	154070	2307	172516	222358	-2005
9:30	50.03	220500	5838	2482	47833	10758	2186	152698	2276	170185	224071	-2037
9:45	50.03	222619	5923	2333	51231	10479	2179	151819	2321	169055	226285	-2027
10:00	50.03	222638	5844	2283	54426	10089	2185	148595	2393	165929	225815	-2035
10:15	49.98	223153	5798	2164	56805	10003	2250	146886	2444	164184	226350	-2143
10:30	50.03	223355	5810	2221	58830	9835	2261	145326	2393	162304	226676	-2174
10:45	49.98	222874	5794	2314	60342	9735	2300	143227	2363	160218	226075	-2181
11:00	49.98	222454	5791	2331	61700	9654	2316	141555	2345	158423	225692	-2124
11:15	49.98	221414	5888	2488	62654	9292	2332	139902	2390	156272	224946	-2177
11:30	50.03	220982	5869	2591	63292	9531	2359	138534	2430	155099	224606	-2185
11:45	49.98	220644	5873	2747	63851	9482	2383	137929	2353	154046	224618	-2163
12:00	50.03	219516	5875	2945	63704	9221	2423	136747	2407	152867	223322	-2192
12:15	49.93	217806	5834	3137	63764	8910	2445	135493	2329	150905	221912	-2175
12:30	49.98	217925	5769	3441	64019	9102	2586	134638	2378	150465	221933	-2171
12:45	49.98	216665	5855	3708	64051	9168	2607	133044	2391	148906	220824	-2147
13:00	50.03	213616	5741	4200	63352	9248	2709	129641	2358	146064	217249	-2147
13:15	49.98	210700	5785	4458	63487	8837	2737	126513	2375	142755	214192	-2160
13:30	49.98	210176	5795	4810	62511	8923	2782	126670	2399	142855	213890	-2201
13:45	49.98	210584	5801	4990	61955	8784	2787	127751	2366	143639	214434	-2139
14:00	50.03	211287	5768	5192	61121	9192	2840	128754	2356	144974	215223	-2173
14:15	49.98	211676	5779	5221	59941	8995	2935	130243	2337	146514	215451	-2182
14:30	49.93	213253	5806	5716	58265	9705	3107	132323	2359	149272	217281	-2191
14:45	49.98	213788	5787	6058	56740	9787	3131	133793	2364	150990	217660	-2200
15:00	50.03	213935	5810	6333	54644	10037	3128	135500	2306	152958	217758	-2176
15:15	49.93	213469	5818	6591	52287	9773	3184	137831	2292	154591	217776	-2203
15:30	49.98	214275	5810	6829	49263	9692	3197	141423	2315	158183	218529	-2181
15:45	49.98	214438	5809	7101	45906	10271	2941	144158	2303	161431	218489	-2200
16:00	50.03	214297	5835	7345	42402	10765	3269	146195	2249	164550	218060	-2172
16:15	50.03	213034	5847	7517	38416	11216	3474	148310	2218	167101	216998	-2180
16:30	49.88	214689	5847	7899	34454	11295	3486	146938	2206	172336	212125	-2148
16:45	49.88	214478	5826	8470	29900	12080	3591	154154	2189	176108	216210	-2016
17:00	49.98	211981	5798	8553	25455	12605	3607	156224	2218	177973	214460	-1779
17:15	49.98	209943	5833	8764	20962	13473	3660	157541	2138	180217	212371	-1705
17:30	50.03	208631	5805	9155	16328	14337	3631	159298	2233	183148	210787	-1627
17:45	50.03	206276	5777	9331	12057	15918	3451	159719	2141	184888	208394	-1506
18:00	50.08	205152	5783	9348	8260	17786	3444	160142	2241	187544	207004	-1361
18:15	50.08	202152	5811	7666	4253	19985	3403	160469	2160	190233	203747	-1014
18:30	50.03	207124	5777	9852	2801	23033	3417	161665	2165	194471	208710	-960
18:45	49.98	209074	5806	9777	1499	25004	3481	162541	2236	197798	210344	-981
19:00	50.03	210917	5826	10010	935	25860	3468	164088	2253	199972	212440	-982
19:15	50.00	211348	5820	10392	919	25841	3423	164484	2253	200037	213132	-916
19:30	50.00	211489	5842	10490	894	25868	3387	164625	2236	200105	213342	-944
19:45	50.00	210621	5830	10457	902	25377	3364	164168	2233	199262	212331	-904
20:00	50.05	208435	5847	10531	904	24351	3367	162856	2196	197000	210052	-931
20:15	50.00	205934	5836	10605	610	21070	3321	163635	2239	194719	207316	-974
20:30	50.00	203742	5879	10586	571	19012	3261	163972	2315	192585	205596	-984
20:45	49.95	203181	5861	10516	570	17767	3281	164734	2217	192095	204946	-966
21:00	50.00	201775	5832	10500	573	16997	3264	164180	2257	190702	203603	-950
21:15	49.90	201008	5852	10273	538	16046	3237	164464	2244	190197	202654	-994
21:30	50.00	201061	5824	9927	508	15408	3305	165609	2272	190626	202853	-997
21:45	50.05	200631	5844	9616	516	14810	3274	166143	2276	190499	202479	-994
22:00	50.00	200016	5828	9429	512	14046	3333	166302	2253	190075	201703	-962
22:15	50.00	202039	5821	9413	511	14376	3248	168166	2250	192115	203785	-942
22:30	50.00	202621</										