



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 16.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 15.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 15-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 15.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 16-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71800	62512	50878	27515	3717	216422
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1543	1433	1318	573	71	4938
Hydro Gen (MU)	397	78	185	94	34	788
Wind Gen (MU)	20	160	273	-	-	453
Solar Gen (MU)*	156.17	126.72	120.30	1.19	0.97	405
Energy Shortage (MU)	0.21	0.00	0.00	0.00	0.00	0.21
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	72538	64091	60768	27844	3689	216482
Time Of Maximum Demand Met	21:51	19:39	11:36	20:00	20:24	20:54

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.063	0.42	2.23	9.55	12.20	67.43	20.37

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	12958	0	265.8	152.3	-2.4	573	0.00
	Haryana	11280	0	240.3	179.9	-2.4	462	0.00
	Rajasthan	11218	0	230.5	74.1	-7.0	505	0.00
	Delhi	6220	0	126.3	115.3	-1.5	214	0.00
	UP	27456	0	530.8	214.0	0.2	470	0.00
	Uttarakhand	2507	0	51.6	21.1	1.8	360	0.21
	HP	1677	0	35.9	-5.1	-0.3	33	0.00
	J&K(UT) & Ladakh(UT)	2628	0	50.7	27.1	-1.3	168	0.00
	Chandigarh	355	0	6.9	6.9	0.0	22	0.00
	Railways NR ISTS	199	0	4.0	3.9	0.2	31	0.00
WR	Chhattisgarh	5240	0	118.2	73.8	-0.3	250	0.00
	Gujarat	19165	0	423.1	141.6	-3.8	575	0.00
	MP	11223	0	243.0	113.8	0.0	637	0.00
	Maharashtra	25106	0	566.0	199.8	-3.2	750	0.00
	Goa	580	0	14.5	11.9	2.0	91	0.00
	DNHDDPDCL	1382	0	32.3	32.4	-0.1	55	0.00
	AMNSIL	829	0	18.3	8.6	0.3	294	0.00
	BALCO	531	0	12.7	12.7	0.0	28	0.00
	RIL JAMNAGAR	240	0	4.8	4.9	-0.1	0	0.00
	Andhra Pradesh	12376	0	255.1	56.0	0.5	909	0.00
SR	Telangana	15215	0	293.6	158.7	-0.5	602	0.00
	Karnataka	14059	0	264.8	45.5	-1.0	585	0.00
	Kerala	3892	0	78.0	32.0	-2.1	241	0.00
	Tamil Nadu	18853	0	415.5	157.7	1.6	1217	0.00
	Puducherry	529	0	10.7	10.1	0.0	77	0.00
ER	Bihar	7357	0	137.5	137.7	-4.8	0	0.00
	DVC	3082	0	65.0	-31.4	-0.7	0	0.00
	Jharkhand	1976	0	36.6	31.7	-3.7	0	0.00
	Odisha	6208	0	131.9	55.1	-0.6	0	0.00
	West Bengal	9842	0	200.9	82.6	-0.8	0	0.00
	Sikkim	85	0	1.4	1.1	0.3	0	0.00
NER	Railways ER ISTS	13	0	0.1	0.1	0.0	0	0.00
	Arunachal Pradesh	205	0	3.8	3.6	-0.1	38	0.00
	Assam	2505	0	48.3	42.0	0.7	167	0.00
	Manipur	191	0	2.6	3.2	-0.6	22	0.00
	Meghalaya	330	0	4.9	2.1	0.0	189	0.00
	Mizoram	119	0	2.2	0.9	-0.3	2	0.00
	Nagaland	185	0	3.3	2.8	0.0	15	0.00
	Tripura	309	0	6.0	4.0	0.1	47	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	49.5	16.0	-23.3	-24.8
Day Peak (MW)	2286.0	878.1	-984.0	-1229.9

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	241.3	-236.4	59.5	-71.0	6.6	0.0
Actual(MU)	220.3	-234.1	66.3	-69.8	7.7	-9.7
O/D/UD(MU)	-21.0	2.2	6.8	1.1	1.1	-9.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4068	15687	7998	5610	422	33785	53
State Sector	5374	11632	9747	3559	199	30511	47
Total	9442	27319	17745	9169	621	64296	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	771	1311	570	610	12	3274	62
Lignite	17	16	34	0	0	67	1
Hydro	397	78	185	94	34	788	15
Nuclear	30	54	65	0	0	149	3
Gas, Naptha & Diesel	21	20	4	0	21	66	1
RES (Wind, Solar, Biomass & Others)	184	288	445	3	1	921	17
Total	1419	1767	1304	707	67	5265	100

Share of RES in total generation (%)	12.96	16.27	34.13	0.46	1.44	17.49
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	43.01	23.75	53.31	13.74	51.82	35.28

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.057
Based on State Max Demands	1.099

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	213289	11:00	0
Non-Solar hr	216482	20:54	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 16-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	310	0.0	7.2	-7.2
2	HVDC	PUSAULI-BB	-	0	47	0.0	1.9	-1.9
3	765 kV	GAYA-VARANASI	2	556	614	0.0	1.9	-1.9
4	765 kV	SASARAM-FATEHPUR	1	203	311	0.0	1.0	-1.0
5	765 kV	GAYA-BALIA	1	0	740	0.0	8.6	-8.6
6	400 kV	PUSAULI-VARANASI	1	0	143	0.0	2.7	-2.7
7	400 kV	PUSAULI-ALLAHABAD	1	38	32	0.1	0.0	0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	537	0.0	8.8	-8.8
9	400 kV	PATNA-BALIA	2	135	751	0.0	5.9	-5.9
10	400 kV	NAUBATPUR-BALIA	2	89	228	0.0	1.3	-1.3
11	400 kV	BIHARSHARIFF-BALIA	2	215	232	0.6	0.0	0.6
12	400 kV	MOTIHARI-GORAKHPUR	2	10	416	0.0	5.9	-5.9
13	400 kV	BIHARSHARIFF-SAHUPURI	2	173	256	0.0	1.3	-1.3
14	220 kV	SAHUPURI-KARAMNESA	1	0	110	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.9	-0.9
ER-NR						1.2	48.4	-47.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1554	0	18.1	0.0	18.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1380	710	20.2	0.0	20.2
3	765 kV	JHARSUGUDA-DURG	2	48	535	0.0	4.4	-4.4
4	400 kV	JHARSUGUDA-RAIGARH	4	451	160	3.1	0.0	3.1
5	400 kV	RANCHI-SIPAT	2	322	261	4.3	0.0	4.3
6	400 kV	JEYPORE-JAGDALPUR	2	5	319	0.0	3.5	-3.5
7	220 kV	BUDHIPADAR-RAIGARH	1	99	58	0.3	0.0	0.3
8	220 kV	BUDHIPADAR-KORBA	2	55	169	0.0	1.0	-1.0
ER-WR						45.9	8.9	37.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	209	0	5.0	0.0	5.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1760	0.0	32.3	-32.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2947	0.0	47.7	-47.7
4	400 kV	TALCHER-I/C	2	302	756	0.0	1.8	-1.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						5.0	80.0	-75.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	90	324	0.0	2.7	-2.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	727	0.0	10.8	-10.8
3	220 kV	ALIPURDUAR-SALAKATI	2	0	139	0.0	2.0	-2.0
ER-NER						0.0	15.6	-15.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.6	-8.6
NER-NR						0.0	8.6	-8.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2021	0.0	48.0	-48.0
2	HVDC	VINDHYACHAL-B/B	-	46	0	1.3	0.0	1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1451	0.0	25.2	-25.2
4	765 kV	GWALIOR-AGRA	2	555	1736	0.8	23.1	-22.4
5	765 kV	GWALIOR-PHAGI	2	1092	1229	4.6	14.4	-9.8
6	765 kV	JABALPUR-ORAI	2	90	896	0.0	21.0	-21.0
7	765 kV	GWALIOR-ORAI	1	620	39	8.8	0.0	8.8
8	765 kV	SATNA-ORAI	1	0	877	0.0	15.8	-15.8
9	765 kV	BANASKANTHA-CHITORGARH	2	1441	1036	8.9	4.5	4.4
10	765 kV	VINDHYACHAL-VARANASI	2	74	2652	0.0	42.9	-42.9
11	400 kV	ZERDA-KANKROLI	1	351	49	2.3	0.1	2.2
12	400 kV	ZERDA-BHINMAL	1	202	34	1.4	0.0	1.3
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	415	336	3.1	2.3	0.8
15	400 kV	NEEMUCH-Chittorgarh	2	373	367	2.0	2.8	-0.7
16	220 kV	BHANPURA-RANPUR	1	0	136	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	121	15	0.8	0.0	0.8
19	220 kV	MALANPUR-AURAIYA	1	91	25	0.4	0.1	0.3
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						34.3	205.2	-170.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	302	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGAULUR	2	0	2503	0.0	21.2	-21.2
3	765 kV	SOLAPUR-RAICHUR	2	1441	440	16.9	0.8	16.1
4	765 kV	WARDHAN-NIZAMABAD	2	0	2568	0.0	33.6	-33.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2519	0.0	31.7	-31.7
6	400 kV	KOLHAPUR-KUDGI	2	2035	0	35.8	0.0	35.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	101	1.8	0.0	1.8
WR-SR						61.7	87.2	-25.5

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1428	1080	1296	31.11	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	837	381	634	15.21	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	110	40	70	1.69	
	NER	132kV GELEPHU-SALAKATI	28	0	19	0.45	
	NER	132kV MOTANGA-RANGIA	53	0	43	1.02	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-38	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-38	0	-16	-0.38	
	ER	NEPAL IMPORT (FROM BIHAR)	213	74	121	2.91	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	656	480	563	13.52	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-954	-939	-943	-22.63	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1230	-862	-1033	-24.80	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-30	0	-27	-0.64	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 16-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.20	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.20
Bangladesh	23.38	0.08	0.00	0.00	0.00	0.00	0.00	0.00	23.46
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.58	0.08	0.00	0.00	0.00	0.00	0.00	0.00	23.66

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	46.76	0.00	1.17	0.00	0.00	0.17	0.00	0.00	48.10
Nepal	8.44	0.08	0.00	0.00	0.00	7.31	0.00	0.00	15.83
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	55.20	0.08	1.17	0.00	0.00	7.48	0.00	0.00	63.93

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	46.76	0.00	1.17	0.00	0.00	0.17	0.00	0.00	48.10
Nepal	8.24	0.08	0.00	0.00	0.00	7.31	0.00	0.00	15.63
Bangladesh	-23.38	-0.08	0.00	0.00	0.00	0.00	0.00	0.00	-23.46
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	31.62	0.00	1.17	0.00	0.00	7.48	0.00	0.00	40.27

Date of Reporting: 16-Jul-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)

Date of Reporting: 16-Jul-2025

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).
 ** Hydro generation is excluding Bhutan hydro.
 ***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:
 1. The information provided is for general informational purposes only.
 2. The data is provided "as is" without any guarantees or warranties.
 3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
 4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
 5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
 6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.