



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 02.10.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 01.10.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 1-अक्टूबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 01.10.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 02-Oct-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	74215	59087	42776	23625	2892	202595
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1595	1314	1057	571	55	4593
Hydro Gen (MU)	331	105	161	105	33	734
Wind Gen (MU)	4	148	215	-	-	367
Solar Gen (MU)*	145.01	92.49	134.96	3.21	0.41	376
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	74696	60672	49555	27995	2958	205145
Time Of Maximum Demand Met	19:07	18:44	09:45	00:00	17:57	19:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.070	0.00	0.43	7.56	7.99	67.06	24.95

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13173	0	282.3	168.4	-1.7	645	0.00
	Haryana	11321	0	240.2	192.9	0.1	655	0.00
	Rajasthan	13251	0	296.3	113.2	-5.5	822	0.00
	Delhi	5907	0	123.4	117.5	-0.1	349	0.00
	UP	25515	0	507.7	208.4	-7.2	1227	0.00
	Uttarakhand	2352	0	46.8	23.3	0.1	136	0.00
	HP	1741	0	35.9	7.7	-0.6	51	0.00
	J&K(UT) & Ladakh(UT)	2560	0	51.7	32.2	-0.8	151	0.00
	Chandigarh	323	0	6.5	6.5	0.0	15	0.00
	Railways_NR ISTS	211	0	4.4	3.9	0.5	42	0.00
WR	Chhattisgarh	5190	0	112.9	56.4	-1.5	352	0.00
	Gujarat	18282	0	391.6	167.6	-6.2	1511	0.00
	MP	11316	0	246.7	123.3	0.0	548	0.00
	Maharashtra	23296	0	484.0	172.7	-9.8	700	0.00
	Goa	677	0	14.1	11.8	1.9	40	0.00
	DNHDDPDCL	1228	0	28.6	29.2	-0.6	38	0.00
	AMNSIL	845	0	17.9	10.3	0.6	339	0.00
	BALCO	558	0	13.3	13.4	-0.1	7	0.00
	RIL JAMNAGAR	253	0	5.2	5.2	0.0	0	0.00
	Andhra Pradesh	10299	0	216.9	51.9	-0.2	839	0.00
SR	Telangana	11162	0	213.1	75.7	1.4	546	0.00
	Karnataka	11677	0	212.3	35.1	1.5	739	0.00
	Kerala	4092	0	81.4	52.7	0.1	280	0.00
	Tamil Nadu	14546	0	325.2	109.1	-2.2	687	0.00
	Puducherry	398	0	8.3	7.9	-0.2	100	0.00
	Bihar	7686	0	152.6	140.2	-3.2	286	0.00
ER	DVC	2836	0	56.9	-43.2	-0.6	356	0.00
	Jharkhand	2037	0	42.6	36.5	-2.0	183	0.00
	Odisha	6133	0	121.8	40.1	-3.1	678	0.00
	West Bengal	9843	0	196.6	61.1	-2.8	454	0.00
	Sikkim	51	0	0.8	0.9	-0.2	8	0.00
	Railways_ER ISTS	12	0	0.1	0.1	0.0	0	0.00
NER	Arunachal Pradesh	172	0	3.0	3.2	-0.6	16	0.00
	Assam	1942	0	34.4	27.4	-0.1	96	0.00
	Manipur	230	0	3.1	3.2	-0.2	11	0.00
	Meghalaya	300	0	5.0	2.8	-0.2	26	0.00
	Mizoram	129	0	1.7	0.9	-0.4	9	0.00
	Nagaland	142	0	2.7	2.3	-0.1	18	0.00
	Tripura	283	0	4.9	4.4	-0.3	31	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	55.1	24.4	-23.2	-15.6
Day Peak (MW)	2648.5	1128.3	-983.4	-658.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	404.8	-267.6	-49.7	-84.5	-3.0	0.0
Actual(MU)	413.6	-273.0	-40.9	-104.7	-6.0	-11.0
O/D/U/D(MU)	8.9	-5.4	8.8	-20.2	-3.0	-11.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6301	11816	6378	5720	205	30419	50
State Sector	5424	15709	8353	459	199	30144	50
Total	11725	27525	14731	6179	404	60563	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	714	1252	544	617	10	3137	64
Lignite	25	15	52	0	0	92	2
Hydro	331	105	161	105	33	734	15
Nuclear	37	65	42	0	0	143	3
Gas, Naptha & Diesel	6	17	4	0	22	49	1
RES (Wind, Solar, Biomass & Others)	156	244	373	5	0	779	16
Total	1268	1697	1175	728	66	4934	100

Share of RES in total generation (%)	12.27	14.39	31.75	0.73	0.64	15.78
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	41.24	24.40	48.94	15.19	50.44	33.56

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.052
Based on State Max Demands	1.082

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	197150	9:57	0
Non-Solar hr	205145	19:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 02-Oct-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	5.8	-5.8
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	247	1032	0.0	6.0	-6.0
4	765 kV	SASARAM-FATEHPUR	1	60	558	0.0	4.2	-4.2
5	765 kV	GAYA-BALIA	1	0	904	0.0	14.7	-14.7
6	400 kV	PUSAULI-VARANASI	1	0	97	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	0	86	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	1371	0.0	22.4	-22.4
9	400 kV	PATNA-BALIA	2	0	963	0.0	12.9	-12.9
10	400 kV	NAUBATPUR-BALIA	2	41	234	0.0	4.1	-4.1
11	400 kV	BIHARSHARIFF-BALIA	2	0	448	0.0	5.0	-5.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	741	0.0	11.2	-11.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	24	463	0.0	4.8	-4.8
14	220 kV	SAHUPURI-KARMANASA	1	4	70	0.0	2.4	-2.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	98.4	-97.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	969	664	7.2	0.0	7.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1684	0	27.6	0.0	27.6
3	765 kV	JHARSUGUDA-DURG	2	223	469	0.0	3.8	-3.8
4	400 kV	JHARSUGUDA-RAIGARH	4	284	392	0.0	1.6	-1.6
5	400 kV	RANCHI-SIPAT	2	409	35	6.1	0.0	6.1
6	400 kV	JEYPORE-JACDALPUR	2	222	485	0.0	4.8	-4.8
7	220 kV	BUDHIPADAR-RAIGARH	1	48	132	0.0	1.6	-1.6
8	220 kV	BUDHIPADAR-KORBA	2	142	75	0.2	0.0	0.2
ER-WR						41.1	11.8	29.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	739	0	10.5	0.0	10.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1378	0.0	21.2	-21.2
3	765 kV	ANGUL-SRIKAKULAM	2	65	2663	0.0	40.6	-40.6
4	400 kV	TALCHER I/C	2	355	769	0.0	1.8	-1.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						10.5	61.8	-51.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	183	143	1.0	0.3	0.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	529	0.0	5.7	-5.7
3	220 kV	ALIPURDUAR-SALAKATI	2	6	97	0.0	0.8	-0.8
ER-NER						1.0	6.7	-5.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	503	0.0	12.1	-12.1
NER-NR						0.0	12.1	-12.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5004	0.0	80.6	-80.6
2	HVDC	VINDHYACHAL B/B	-	0	514	0.0	5.9	-5.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1454	0.0	29.2	-29.2
4	765 kV	GWALIOR-AGRA	2	0	2731	0.0	44.8	-44.8
5	765 kV	GWALIOR-PHAGI	2	287	2221	0.2	28.5	-28.4
6	765 kV	JABALPUR-ORAI	2	0	1326	0.0	44.9	-44.9
7	765 kV	GWALIOR-ORAI	1	788	0	11.9	0.0	11.9
8	765 kV	SATNA-ORAI	1	0	1147	0.0	20.3	-20.3
9	765 kV	BANASKANTHA-CHITORGARH	2	967	1104	5.6	4.1	1.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3499	0.0	57.3	-57.3
11	400 kV	ZERDA-KANKROLI	1	267	104	1.8	0.2	1.6
12	400 kV	ZERDA -BHINMAL	1	184	73	1.3	0.2	1.1
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	211	529	0.5	4.8	-4.3
15	400 kV	NEEMUCH-Chittorgarh	2	0	611	0.0	7.8	-7.8
16	220 kV	BHANPURA-RANPUR	1	0	109	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.5	-2.5
18	220 kV	MEHGAON-AURAIYA	1	36	52	0.2	0.3	-0.2
19	220 kV	MALANPUR-AURAIYA	1	21	56	0.0	0.4	-0.4
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						21.4	333.8	-312.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	903	0	17.0	0.0	17.0
2	HVDC	RAIGARH-PUGALUR	2	2876	605	39.4	0.0	39.4
3	765 kV	SOLAPUR-RAICHUR	2	2350	897	13.1	2.9	10.2
4	765 kV	WARDHA-NIZAMABAD	2	887	2131	1.6	21.7	-20.2
5	765 kV	WARORA-WARANGAL(NEW)	2	620	1474	1.1	15.8	-14.7
6	400 kV	KOLHAPUR-KUDGI	2	2395	0	35.8	0.0	35.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	97	1.9	0.0	1.9
WR-SR						109.9	40.4	69.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1677	0	1321	31.70
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	904	838	875	21.00
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	120	2	56	1.35
	NER	132kV GELEPHU-SALAKATI	37	0	17	0.40
	NER	132kV MOTANGA-RANGIA	48	-3	28	0.68
NEPAL	NR	NEPAL IMPORT (FROM UP)	-10	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	61	0	16	0.38
	ER	NEPAL IMPORT (FROM BIHAR)	184	145	163	3.91
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	884	750	840	20.16
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-934	-904	-930	-22.32
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-658	-635	-649	-15.57
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-45	0	-35	-0.84

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 02-Oct-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	22.87	0.19	0.00	0.00	0.00	0.00	0.00	0.00	23.06
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.87	0.19	0.00	0.00	0.00	0.00	0.00	0.00	23.06

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	35.18	0.00	1.63	0.00	0.00	0.00	0.00	0.00	36.81
Nepal	9.11	4.81	0.00	0.00	0.00	8.80	0.00	0.00	22.72
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	44.29	4.81	1.63	0.00	0.00	8.80	0.00	0.00	59.53

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	35.18	0.00	1.63	0.00	0.00	0.00	0.00	0.00	36.81
Nepal	9.11	4.81	0.00	0.00	0.00	8.80	0.00	0.00	22.72
Bangladesh	-22.87	-0.19	0.00	0.00	0.00	0.00	0.00	0.00	-23.06
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	21.42	4.62	1.63	0.00	0.00	8.80	0.00	0.00	36.47

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+H+G+H)	(K)
0:00	50.07	192065	5306	16736	0	30856	1887	134630	1960	175329	191375	2230
0:15	49.97	191117	5294	16620	0	30288	1878	135397	1906	174497	191383	2265
0:30	50.02	189955	5301	16557	0	30243	1891	134471	1989	173398	190452	2257
0:45	49.92	188454	5306	16473	0	30296	1883	133049	1859	171981	188866	2268
1:00	50.02	187323	5310	16300	0	30098	1885	132848	1896	171023	188337	2304
1:15	49.97	185716	5305	15990	0	30015	1884	131717	1888	169726	186799	2340
1:30	49.97	184513	5314	15784	0	29407	1883	131202	1883	168729	185473	2355
1:45	49.95	183420	5319	15680	0	29246	1886	130176	1914	167740	184221	2321
2:00	49.95	182273	5321	15558	0	29269	1884	129275	1851	166715	183158	2320
2:15	49.95	181567	5322	15321	0	29396	1885	128570	1861	166246	182355	2304
2:30	50.00	181269	5321	15294	0	29572	1878	127924	1946	165975	181935	2309
2:45	50.00	180543	5320	15251	0	29675	1886	127466	1722	165292	181320	2308
3:00	50.00	180125	5321	15009	0	29557	1881	127282	1723	165116	180773	2312
3:15	50.00	179966	5314	14904	0	28528	1887	128199	1728	165062	180560	2301
3:30	50.00	179132	5320	14633	0	27717	1880	128461	1722	164499	179733	2294
3:45	49.85	179574	5312	14216	0	27597	1891	129390	1733	165358	180139	2330
4:00	49.95	179297	5324	13774	0	27432	1889	129755	1814	165523	179988	2341
4:15	49.95	180434	5328	13765	0	26974	1887	131420	1747	166669	181121	2332
4:30	50.00	180638	5330	14093	0	26587	1884	131710	1728	166545	181332	2300
4:45	50.00	181635	5320	14223	0	26282	1885	132896	1696	167412	182302	2301
5:00	50.05	182404	5337	14104	580	25745	1884	133957	1704	167720	183311	2270
5:15	50.00	183319	5337	13840	575	25935	1884	134755	1700	168904	184026	2285
5:30	50.00	184536	5333	13636	579	26270	1890	135642	1708	170321	185058	2328
5:45	50.05	186661	5333	13385	583	27737	1885	136498	1720	172693	187141	2309
6:00	50.05	186905	5337	13134	587	28795	1845	136218	1720	173184	187636	2269
6:15	50.05	187250	5342	13080	695	29718	1814	135578	1709	173475	187936	2292
6:30	50.00	189017	5346	13160	1158	30555	1822	135827	1703	174699	189571	2297
6:45	50.05	189840	5336	13035	2310	30213	1827	135969	1693	174495	190383	2238
7:00	50.05	189334	5361	12765	4706	29533	1822	133726	1710	171863	189623	2240
7:15	50.05	190377	5344	12470	8116	28870	1826	132474	1746	169791	190846	2268
7:30	50.05	189755	5347	12419	12349	27400	1827	129219	1824	164987	190385	2177
7:45	50.20	189300	5351	12406	17118	26544	1833	124977	1840	159776	190069	2263
8:00	50.20	187599	5371	12439	21759	25718	1844	119595	1843	153401	188569	2289
8:15	50.15	188575	5349	12958	26528	25747	1849	115377	1840	149089	189648	2312
8:30	50.10	189273	5339	13613	31068	26070	1844	111229	1855	144592	191018	2301
8:45	50.15	189851	5333	14147	34558	25131	1834	108634	1888	141146	191525	2341
9:00	50.15	191081	5340	14663	37761	24094	1842	107144	1880	138657	192724	2324
9:15	50.05	193711	5334	15131	39821	24506	1846	106611	1913	138759	195162	2354
9:30	50.25	195769	5353	15145	43685	23766	1851	105896	1918	136939	197614	2319
9:45	50.25	196823	5360	15436	46622	23201	1846	104183	1899	134765	198547	2333
10:00	50.30	197009	5312	15750	47054	22917	1844	103806	1954	134205	198637	2331
10:15	50.05	196441	5325	16012	46512	23153	1855	102907	1940	133917	197704	2333
10:30	50.05	196268	5325	16194	45508	23386	1868	103031	1938	134566	197250	2354
10:45	50.00	195732	5320	16410	44262	23174	1864	104003	1964	135060	196997	2368
11:00	49.95	196269	5321	16790	44210	23056	1874	104472	1952	135269	197675	2332
11:15	49.95	195567	5311	16970	43896	22871	1878	104284	1930	134701	197140	2254
11:30	49.95	195950	5316	16989	43748	22381	1866	104766	1938	135213	197004	2310
11:45	49.90	195622	5321	16944	43405	22609	1872	104854	1942	135273	196947	2308
12:00	49.95	195857	5346	17045	44401	22477	1870	104230	1945	134411	197314	2297
12:15	49.95	194538	5324	17281	42474	22723	1865	103946	2012	134783	195625	2487
12:30	50.00	194869	5333	17172	43509	23294	1871	102757	1929	134188	195865	2389
12:45	50.00	193958	5323	17197	43002	23516	1866	101884	1976	133759	194764	2264
13:00	50.10	191534	5332	16952	42152	23290	1874	101232	1956	132430	192788	2194
13:15	50.00	188691	5332	16870	39270	23095	1852	101409	1908	132551	189736	2215
13:30	50.15	188289	5342	16860	40503	22720	1834	100070	1913	130926	189242	2234
13:45	50.00	188578	5339	16981	39733	23187	1849	100829	1927	131864	189845	2186
14:00	50.00	188327	5345	16920	38435	23285	1851	101843	1930	132972	189609	2217
14:15	49.95	188820	5333	16839	38149	23475	1851	102505	1943	133832	190095	2242
14:30	49.90	190517	5324	16730	38303	23633	1854	103849	1834	135484	191527	2317
14:45	49.90	191571	5323	16487	38379	23917	1845	104849	1836	136705	192636	2261
15:00	49.90	192432	5342	16435	38077	24473	1841	105744	1831	137920	193743	2234
15:15	49.90	192018	5328	16157	37530	24956	1833	105770	1812	138331	193386	2229
15:30	49.90	193004	5327	16179	36420	25643	1837	106320	1805	140405	193531	2237
15:45	49.85	192959	5339	16008	34974	25785	1859	107189	1878	141977	192937	2273
16:00	49.85	191435	5330	15449	32501	25460	1850	108618	1778	143085	191386	2298
16:15	49.85	190347	5346	15843	29171	24879	1878	111820	1759	145733	190296	2314
16:30	49.95	190187	5350	15217	25453	24784	1881	115871	1745	149517	190301	2301
16:45	50.00	190239	5348	15241	21603	24486	1935	120473	1736	153395	190822	2291
17:00	50.00	190562	5346	15054	17485	24605	1954	124539	1749	158023	190732	2273
17:15	50.05	189980	5368	14792	14252	24780	1979	126916	1723	160936	189810	2283
17:30	50.05	192676	5355	14896	9908	25445	2009	132985	1692	167872	192290	2087
17:45	50.05	194607	5360	14806	6248	26988	2060	137033	1749	173553	194244	2055
18:00	50.10	196943	5343	14851	3457	28780	2115	140220	1751	178635	196517	2133
18:15	50.10	199344	5356	14861	1632	29456	2166	143841	1741	182851	199053	2189
18:30	50.10	203219	5352	14698	994	30340	2252	147328	1808	187527	202772	2241
18:45	50.10	205028	5359	14896	867	30488	2391	148906	1767	189265	204674	2244
19:00	50.10	205145	5366	15241	875	31188	2408	148099	1761	189029	204938	2261
19:15	50.10	204288	5382	15527	875	31353	2409	147090	1770	187886	204406	2243
19:30	50.10	203158	5376	15984	0	31345	2413	145255	1794	187174	202167	2215
19:45	50.05	201383	5381	16061	0	31016	2408	143721	1741	185322	200328	2234
20:00	50.00	199018	5385	16169	0	31692	2372	141147	1746	182849	198511	2216
20:15	49.95	197526	5387	16234	0	32827	2248	138835	1766	181292	197297	2244
20:30	49.95	196514	5381	16406	0	33047	2238	137787	1784	180108	196643	2259
20:45	49.90	195512	5364	16576	0	33363	2172	136283	1752	178936	195510	2250
21:00	49.95	195330	5377	17012	0	32545	2140	136702	1786	178318	195562	2274
21:15	50.00	194628	5377	17389	0	32083	2142	136079	1781	177239	194851	2280
21:30	50.00	194390	5358	17457	0	32277	2136	135129	1778	176933	194135	2347
21:45	50.00	193657	5383	17352	0	31993	2137	134675	1797	176305	193337	2395
22:00	50.00	192775	5385	17380	0	32189	2147	133689	1798	175395	192588	2346
22:15	49.95	193403	5362	17008	0	32478	2145	134127	1766</			