



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 27.07.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 26.07.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 26-जुलाई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 26.07.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 27-Jul-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	80487	55028	44983	27991	3710	212199
Peak Shortage (MW)	213	0	0	340	0	553
Energy Met (MU)	1831	1265	1054	636	75	4861
Hydro Gen (MU)	369	41	132	79	35	655
Wind Gen (MU)	30	245	323	-	-	598
Solar Gen (MU)*	147.79	47.82	93.75	2.24	1.28	293
Energy Shortage (MU)	1.89	0.00	0.00	0.98	0.00	2.87
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	81661	56023	50105	29179	3732	212835
Time Of Maximum Demand Met	22:52	19:26	09:44	00:03	19:27	10:29

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.042	0.00	0.57	3.24	3.81	75.14	21.05

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15449	0	358.3	223.0	-0.8	167	0.00
	Haryana	13177	0	279.7	214.8	-2.1	152	0.73
	Rajasthan	14022	0	300.8	92.8	1.4	657	0.00
	Delhi	6949	0	145.3	128.0	-0.7	192	0.00
	UP	28472	0	588.7	290.3	1.5	582	0.00
	Uttarakhand	2380	0	53.4	29.7	2.1	245	0.92
	HP	1840	0	39.6	1.4	0.8	160	0.00
	J&K(UT) & Ladakh(UT)	2575	0	53.0	27.2	0.9	426	0.24
	Chandigarh	423	0	8.0	7.7	0.3	40	0.00
WR	Railways_NR ISTS	188	0	4.1	3.7	0.4	73	0.00
	Chhattisgarh	4398	0	97.3	49.5	-2.2	153	0.00
	Gujarat	17391	0	389.3	138.2	-5.9	404	0.00
	MP	11326	0	240.3	123.7	-2.7	370	0.00
	Maharashtra	21860	0	465.8	135.6	-10.5	694	0.00
	Goa	620	0	13.3	11.3	2.0	128	0.00
	DNHDDPDCL	1290	0	30.1	30.0	0.1	107	0.00
	AMNSIL	726	0	16.4	5.8	0.9	276	0.00
	BALCO	528	0	12.6	12.7	-0.1	8	0.00
SR	Andhra Pradesh	9899	0	207.5	22.4	-1.2	491	0.00
	Telangana	10895	0	208.9	107.2	0.3	2056	0.00
	Karnataka	9865	0	170.9	-31.0	0.0	924	0.00
	Kerala	3951	0	79.5	44.0	1.1	772	0.00
	Tamil Nadu	17377	0	377.0	162.3	-6.5	1217	0.00
	Puducherry	464	0	10.5	10.3	-0.4	52	0.00
ER	Bihar	7797	97	168.6	164.3	-2.8	326	0.98
	DVC	3473	0	73.4	-39.9	-0.9	395	0.00
	Jharkhand	2121	0	45.5	34.4	-0.9	225	0.00
	Odisha	5414	0	113.4	32.2	-2.0	430	0.00
	West Bengal	10978	0	233.9	99.2	-2.2	221	0.00
	Sikkim	83	0	1.3	1.4	-0.1	25	0.00
	Railways_ER ISTS	12	0	0.1	0.2	0.0	8	0.00
NER	Arunachal Pradesh	174	0	3.0	2.7	-0.2	35	0.00
	Assam	2524	0	51.5	43.7	0.3	163	0.00
	Manipur	185	0	2.8	2.8	0.0	61	0.00
	Meghalaya	312	0	5.5	-0.9	0.1	119	0.00
	Mizoram	119	0	2.0	0.6	0.0	22	0.00
	Nagaland	174	0	3.0	2.7	0.0	40	0.00
	Tripura	349	0	6.8	6.1	0.5	107	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	40.8	14.9	-19.1	-31.9
Day Peak (MW)	2254.0	752.7	-1026.0	-1465.8

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	434.5	-297.3	-85.8	-61.8	10.4	0.0
Actual(MU)	439.1	-300.1	-101.4	-54.1	9.9	-6.6
O/D/U/D(MU)	4.6	-2.8	-15.6	7.8	-0.5	-6.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	1826	15458	6558	4716	652	29209	51
State Sector	6446	11870	8777	1024	131	28247	49
Total	8271	27327	15335	5740	783	57456	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	858	1228	545	679	13	3322	64
Lignite	21	13	45	0	0	79	2
Hydro	369	41	132	79	35	655	13
Nuclear	31	61	76	0	0	169	3
Gas, Naptha & Diesel	26	42	5	0	21	95	2
RES (Wind, Solar, Biomass & Others)	186	294	422	4	1	907	17
Total	1490	1681	1225	761	70	5228	100

Share of RES in total generation (%)	12.47	17.48	34.47	0.50	1.81	17.35
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.30	23.60	51.45	10.84	50.99	33.11

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.036
Based on State Max Demands	1.079

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	212835	10:29	117
Non-Solar hr	212228	19:45	105

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

						Import=(+ve) /Export =(-ve) for NET (MU)		
						Date of Reporting: 27-Jul-2024		
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	701	0.0	17.0	-17.0
2	HVDC	PUSAULI B/B	-	0	95	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	941	493	0.0	0.1	-0.1
4	765 kV	SASARAM-FATEHPUR	1	407	215	0.0	0.5	-0.5
5	765 kV	GAYA-BALIA	1	0	829	0.0	13.2	-13.2
6	400 kV	PUSAULI-VARANASI	1	0	121	0.0	1.8	-1.8
7	400 kV	PUSAULI -ALLAHABAD	1	29	58	0.0	0.4	-0.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	187	586	0.0	7.1	-7.1
9	400 kV	PATNA-BALIA	2	301	612	0.0	6.9	-6.9
10	400 kV	NAUBATPUR-BALIA	2	172	345	0.0	2.6	-2.6
11	400 kV	BIHARSHARIFF-BALIA	2	217	64	1.3	0.0	1.3
12	400 kV	MOTIHARI-GORAKHPUR	2	138	344	0.0	4.0	-4.0
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	76	0.0	1.4	-1.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						2.0	57.5	-55.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	50	1350	0.0	18.8	-18.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2617	0	39.0	0.0	39.0
3	765 kV	JHARSUGUDA-DURG	2	319	541	0.0	2.9	-2.9
4	400 kV	JHARSUGUDA-RAIGARH	4	279	336	0.0	0.8	-0.8
5	400 kV	RANCHI-SIPAT	2	666	37	8.7	0.0	8.7
6	220 kV	BUDHIPADAR-RAIGARH	1	39	94	0.0	0.7	-0.7
7	220 kV	BUDHIPADAR-KORBA	2	55	58	0.0	0.2	-0.2
ER-WR						47.6	23.4	24.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	697	0	14.2	0.0	14.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	891	0.0	18.6	-18.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	2307	0.0	29.5	-29.5
4	400 kV	TALCHER-I/C	2	726	127	9.8	0.0	9.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						14.2	48.1	-33.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	396	0.0	5.9	-5.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	526	0.0	7.5	-7.5
3	220 kV	ALIPURDUAR-SALAKATI	2	0	112	0.0	2.0	-2.0
ER-NER						0.0	15.4	-15.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	310	0.0	7.4	-7.4
NER-NR						0.0	7.4	-7.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	5536	0.0	106.1	-106.1
2	HVDC	VINDHYACHAL B/B	-	0	311	0.0	7.2	-7.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2358	0.0	54.3	-54.3
4	765 kV	GWALIOR-AGRA	2	0	2886	0.0	48.5	-48.5
5	765 kV	GWALIOR-PHAGI	2	997	1460	4.0	16.5	-12.5
6	765 kV	JABALPUR-ORAI	2	0	1462	0.0	44.1	-44.1
7	765 kV	GWALIOR-ORAI	1	656	22	9.0	0.0	9.0
8	765 kV	SATNA-ORAI	1	0	1073	0.0	20.0	-20.0
9	765 kV	BANASKANTHA-CHITORGARH	2	0	1973	0.0	26.2	-26.2
10	765 kV	VINDHYACHAL-VARANASI	2	0	4070	0.0	75.5	-75.5
11	400 kV	ZERDA-KANKROLI	1	24	295	0.0	3.2	-3.2
12	400 kV	ZERDA -BHINMAL	1	17	204	0.0	2.2	-2.2
13	400 kV	VINDHYACHAL -RIHAND	1	971	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	193	638	0.8	5.8	-5.0
15	400 kV	NEEMUCH-Chittorgarh	2	271	687	1.1	6.4	-5.3
16	220 kV	BHANPURA-RANPUR	1	0	104	0.0	1.9	-1.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	73	9	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	46	56	0.1	0.3	-0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						37.6	419.8	-382.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	998	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGALUR	2	1734	0	31.3	0.0	31.3
3	765 kV	SOLAPUR-RAICHUR	2	2072	564	26.0	0.6	25.4
4	765 kV	WARDHA-NIZAMABAD	2	289	2096	0.5	11.3	-10.8
5	765 kV	WARORA-WARANGAL(NEW)	2	378	1945	0.7	10.0	-9.3
6	400 kV	KOLHAPUR-KUDGI	2	2365	0	45.1	0.0	45.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	119	0.8	0.0	0.8
WR-SR						128.4	21.9	106.5
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1018	345	652	15.64		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	901	0	838	20.11		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	154	90	125	3.01		
	NER	132kV GELEPHU-SALAKATI	56	0	38	0.92		
	NER	132kV MOTANGA-RANGIA	70	0	46	1.11		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-11	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	47	1.14		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	685	483	572	13.73		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-920	0	-707	-16.98		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1466	-1198	-1330	-31.92		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-106	0	-87	-2.08		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.06	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.06
Bangladesh	21.98	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.98
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.04

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	37.91	0.00	1.08	0.00	0.00	0.00	0.00	0.00	38.99
Nepal	2.63	0.00	13.15	0.00	0.00	0.00	0.00	0.00	15.78
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	40.54	0.00	14.23	0.00	0.00	0.00	0.00	0.00	54.77

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	37.91	0.00	1.08	0.00	0.00	0.00	0.00	0.00	38.99
Nepal	2.57	0.00	13.15	0.00	0.00	0.00	0.00	0.00	15.72
Bangladesh	-21.98	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.98
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	18.50	0.00	14.23	0.00	0.00	0.00	0.00	0.00	32.73