



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 01.09.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 31.08.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 31-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 31.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 01-Sep-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	59015	57539	44518	29146	3554	193772
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1325	1371	1103	631	69	4500
Hydro Gen (MU)	393	116	189	92	42	832
Wind Gen (MU)	16	143	250	-	-	409
Solar Gen (MU)*	81.95	91.93	125.62	2.91	1.04	303
Energy Shortage (MU)	0.00	0.00	0.00	0.05	0.00	0.05
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67299	59705	51959	29562	3578	199160
Time Of Maximum Demand Met	00:00	19:20	09:23	22:49	18:37	00:00

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.049	0.00	0.00	2.75	2.75	74.59	22.66

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7858	0	159.5	74.7	-1.7	326	0.00
	Haryana	9424	0	181.7	139.9	-2.8	261	0.00
	Rajasthan	10888	0	245.1	101.8	-16.8	1233	0.00
	Delhi	5780	0	117.1	112.0	-0.2	333	0.00
	UP	26852	0	496.3	224.1	-4.6	579	0.00
	Uttarakhand	2091	0	44.4	23.4	-0.3	155	0.00
	HP	1567	0	31.8	3.2	-0.4	149	0.00
	J&K(UT) & Ladakh(UT)	1967	0	39.2	18.3	-1.6	435	0.00
	Chandigarh	267	0	5.4	5.6	-0.2	16	0.00
	Railways_NR ISTS	220	0	4.4	3.8	0.6	52	0.00
WR	Chhattisgarh	5828	0	129.7	77.2	-1.8	444	0.00
	Gujarat	17640	0	409.9	179.1	-5.5	636	0.00
	MP	12118	0	260.0	123.9	-2.9	602	0.00
	Maharashtra	22574	0	493.4	165.3	-2.7	1071	0.00
	Goa	464	0	12.5	10.5	1.6	37	0.00
	DNHDDPDCL	1269	0	28.9	28.9	0.0	37	0.00
	AMNSIL	820	0	18.4	7.7	0.3	283	0.00
	BALCO	537	0	12.8	12.7	0.1	7	0.00
	RIL JAMNAGAR	249	0	5.6	5.6	0	0	0.00
	Andhra Pradesh	10090	0	217.5	37.9	-1.5	614	0.00
SR	Telangana	12399	0	239.5	112.3	4.1	1359	0.00
	Karnataka	11160	0	207.8	19.2	0.3	943	0.00
	Kerala	3786	0	74.2	34.4	0.2	372	0.00
	Tamil Nadu	15774	0	354.5	111.7	1.2	1151	0.00
	Puducherry	451	0	9.8	9.2	0.0	46	0.00
	Bihar	8134	0	168.3	159.4	-2.0	420	0.00
ER	DVC	3305	0	71.1	-30.0	1.0	465	0.05
	Jharkhand	2238	0	45.7	33.2	-0.2	169	0.00
	Odisha	6392	0	131.0	74.6	-0.8	455	0.00
	West Bengal	10755	0	213.6	98.1	-1.6	357	0.00
	Sikkim	63	0	0.8	1.0	-0.1	20	0.00
	Railways_ER ISTS	12	0	0.2	0.1	0.1	10	0.00
NER	Arunachal Pradesh	188	0	3.7	3.8	-0.6	14	0.00
	Assam	2405	0	45.9	38.4	0.8	159	0.00
	Manipur	225	0	3.2	3.2	0.0	22	0.00
	Meghalaya	328	0	5.6	0.7	-0.2	61	0.00
	Mizoram	115	0	1.9	0.8	-0.4	3	0.00
	Nagaland	149	0	3.0	2.6	-0.1	13	0.00
	Tripura	344	0	6.1	5.4	0.2	21	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	50.4	19.6	-24.4	-24.9
Day Peak (MW)	2305.5	967.2	-1029.4	-1168.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	212.2	-204.0	15.6	-23.7	0.0	0.0
Actual(MU)	198.1	-194.2	22.7	-39.3	0.1	-12.7
O/D/U/D(MU)	-14.1	9.8	7.1	-15.6	0.1	-12.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7221	11102	11068	3180	51	32622	49
State Sector	8889	13136	8878	2739	199	33841	51
Total	16110	24237	19946	5919	250	66462	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	641	1225	459	627	10	2961	62
Lignite	23	9	50	0	0	81	2
Hydro	393	116	189	92	42	832	17
Nuclear	41	58	47	0	0	147	3
Gas, Naptha & Diesel	6	10	2	0	22	40	1
RES (Wind, Solar, Biomass & Others)	104	237	401	6	1	749	16
Total	1208	1656	1147	725	74	4810	100

Share of RES in total generation (%)	8.62	14.34	34.94	0.79	1.41	15.57
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	44.57	24.87	55.49	13.50	57.47	35.91

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.064
Based on State Max Demands	1.088

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godha (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	190287	9:40	13
Non-Solar hr	199160	0:00	0

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 01-Sep-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	402	0.0	9.5	-9.5
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	701	650	1.3	0.0	1.3
4	765 kV	SASARAM-FATEHPUR	1	350	240	2.0	0.0	2.0
5	765 kV	GAYA-BALIA	1	0	888	0.0	10.6	-10.6
6	400 kV	PUSAULI-VARANASI	1	0	144	0.0	2.5	-2.5
7	400 kV	PUSAULI-ALLAHABAD	1	50	43	0.2	0.0	0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	124	791	0.0	8.5	-8.5
9	400 kV	PATNA-BALIA	2	0	979	0.0	12.1	-12.1
10	400 kV	NAUBATPUR-BALIA	2	0	429	0.0	3.0	-3.0
11	400 kV	BIHARSHARIFF-BALIA	2	195	311	0.0	1.0	-1.0
12	400 kV	MOTIHARI-GORAKHPUR	2	74	481	0.0	4.9	-4.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	532	307	0.0	0.7	-0.7
14	220 kV	SAHUPURI-KARMANASA	1	0	60	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						4.1	56.2	-52.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1543	0	19.9	0.0	19.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1802	0	32.3	0.0	32.3
3	765 kV	JHARSUGUDA-DURG	2	198	887	0.0	6.3	-6.3
4	400 kV	JHARSUGUDA-RAIGARH	4	458	58	4.5	0.0	4.5
5	400 kV	RANCHI-SIPAT	2	344	118	5.0	0.0	5.0
6	400 kV	JEYPORE-JACDALPUR	2	385	130	3.7	0.0	3.7
7	220 kV	BUDHIPADAR-RAIGARH	1	77	102	0.0	0.7	-0.7
8	220 kV	BUDHIPADAR-KORBA	2	146	157	0.0	0.5	-0.5
ER-WR						65.3	7.6	57.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	207	0.0	4.9	-4.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1195	0.0	22.8	-22.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2521	0.0	35.8	-35.8
4	400 kV	TALCHER/IC	2	314	675	0.0	0.9	-0.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	63.5	-63.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	187	262	1.3	1.2	0.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	104	568	0.0	3.5	-3.5
3	220 kV	ALIPURDUAR-SALAKATI	2	30	115	0.0	0.7	-0.7
ER-NER						1.3	5.5	-4.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	303	0.0	6.3	-6.3
NER-NR						0.0	6.3	-6.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2015	0.0	44.8	-44.8
2	HVDC	VINDHYACHAL B/B	-	0	257	0.0	6.0	-6.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	498	0.0	12.2	-12.2
4	765 kV	GWALIOR-AGRA	2	471	2347	1.0	16.7	-15.6
5	765 kV	GWALIOR-PHAGI	2	839	1325	5.4	12.4	-7.0
6	765 kV	JABALPUR-ORAI	2	116	1332	0.0	23.6	-23.6
7	765 kV	GWALIOR-ORAI	1	872	0	10.8	0.0	10.8
8	765 kV	SATNA-ORAI	1	0	908	0.0	10.7	-10.7
9	765 kV	BANASKANTHA-CHITORGARH	2	1290	523	8.7	2.1	6.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2935	0.0	43.8	-43.8
11	400 kV	ZERDA-KANKROLI	1	250	26	2.3	0.0	2.3
12	400 kV	ZERDA -BHINMAL	1	172	18	1.6	0.0	1.6
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	518	441	4.2	1.8	2.4
15	400 kV	NEEMUCH-Chittorgarh	2	276	668	1.6	3.3	-1.7
16	220 kV	BHANPURA-RANPUR	1	0	146	0.0	2.6	-2.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	92	18	1.3	0.1	1.3
19	220 kV	MALANPUR-AURAIYA	1	65	36	0.2	0.3	0.0
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						37.1	181.9	-144.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	302	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	1250	0	12.4	0.0	12.4
3	765 kV	SOLAPUR-RAICHUR	2	1230	884	13.2	1.5	11.7
4	765 kV	WARDHA-NIZAMABAD	2	0	2485	0.0	26.6	-26.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2434	0.0	25.2	-25.2
6	400 kV	KOLHAPUR-KUDGI	2	1582	0	27.4	0.0	27.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	107	0.0	2.1	-2.1
WR-SR						62.2	53.4	8.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1145	1037	1058	25.38
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	964	820	874	20.99
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	139	63	105	2.53
	NER	132kV GELEPHU-SALAKATI	35	0	18	0.42
	NER	132kV MOTANGA-RANGIA	69	0	45	1.07
NEPAL	NR	NEPAL IMPORT (FROM UP)	-58	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	68	0	45	1.07
	ER	NEPAL IMPORT (FROM BIHAR)	131	79	127	3.05
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	698	304	646	15.50
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-976	-974	-975	-23.39
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1168	-831	-1037	-24.90
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-52	0	-43	-1.02

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 01-Sep-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	24.15	0.10	0.00	0.00	0.00	0.00	0.00	0.00	24.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.15	0.10	0.00	0.00	0.00	0.00	0.00	0.00	24.25

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.41	0.00	1.39	0.00	0.00	0.07	0.00	0.00	50.87
Nepal	8.43	4.71	0.00	0.00	0.00	6.52	0.00	0.00	19.66
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	57.84	4.71	1.39	0.00	0.00	6.59	0.00	0.00	70.53

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.41	0.00	1.39	0.00	0.00	0.07	0.00	0.00	50.87
Nepal	8.43	4.71	0.00	0.00	0.00	6.52	0.00	0.00	19.66
Bangladesh	-24.15	-0.10	0.00	0.00	0.00	0.00	0.00	0.00	-24.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	33.69	4.61	1.39	0.00	0.00	6.59	0.00	0.00	46.28

