



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 19.03.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 18.03.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 18-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 18.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 19-Mar-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55146	70729	54478	26070	2765	209188
Peak Shortage (MW)	0	0	0	177	0	177
Energy Met (MU)	1212	1644	1451	549	48	4904
Hydro Gen (MU)	128	53	101	25	11	317
Wind Gen (MU)	8	100	36	-	-	144
Solar Gen (MU)*	218.16	147.40	144.85	5.76	1.07	517
Energy Shortage (MU)	0.13	0.00	0.00	0.34	0.16	0.63
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	58304	73187	69242	26276	2835	223113
Time Of Maximum Demand Met	10:23	16:30	15:41	19:46	18:25	10:30

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.00	0.58	3.04	3.62	79.06	17.31

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9174	0	173.0	67.4	1.2	681	0.00
	Haryana	7054	0	150.0	97.3	-0.9	214	0.00
	Rajasthan	15001	0	293.7	82.6	-5.9	278	0.00
	Delhi	3811	0	75.3	67.5	-0.2	219	0.00
	UP	19544	0	377.2	73.0	-3.4	557	0.00
	Uttarakhand	2037	0	40.6	30.1	0.8	87	0.00
	HP	1919	0	33.8	23.3	0.0	517	0.00
	J&K(UT) & Ladakh(UT)	2913	0	60.7	54.1	-0.8	585	0.13
	Chandigarh	198	0	3.5	3.6	-0.1	4	0.00
WR	Railways_NR ISTS	195	0	4.0	3.9	0.1	27	0.00
	Chhattisgarh	6350	0	145.8	84.7	-0.1	386	0.00
	Gujarat	22807	0	458.5	185.3	-7.8	526	0.00
	MP	14423	0	283.1	157.0	-4.8	539	0.00
	Maharashtra	29409	0	671.3	250.7	-1.7	635	0.00
	Goa	792	0	17.4	15.8	1.1	48	0.00
	DNHDDPDCL	1356	0	31.1	31.6	-0.5	36	0.00
	AMNSIL	779	0	17.9	10.2	0.6	208	0.00
	BALCO	534	0	12.7	12.7	0.0	51	0.00
SR	RIL JAMNAGAR	252	0	6.0	6.2	-0.2	0	0.00
	Andhra Pradesh	12911	0	250.4	72.9	-0.8	479	0.00
	Telangana	16976	0	339.2	192.6	-0.5	1015	0.00
	Karnataka	17850	0	357.6	143.5	3.2	1298	0.00
	Kerala	4932	0	92.7	79.2	-0.7	372	0.00
	Tamil Nadu	19226	0	399.5	272.4	-0.5	928	0.00
	Puducherry	459	0	11.3	9.8	0.0	49	0.00
	Bihar	5839	0	105.5	100.2	-0.6	278	0.34
	DVC	3466	0	72.4	-48.9	-0.9	308	0.00
ER	Jharkhand	2144	0	41.3	30.8	-1.3	202	0.00
	Odisha	5638	0	120.7	33.3	0.9	476	0.00
	West Bengal	9576	0	207.5	67.1	-2.4	263	0.00
	Sikkim	99	0	1.6	1.6	0.0	19	0.00
	Railways_ER ISTS	24	0	0.2	0.2	0.0	4	0.00
	Arunachal Pradesh	156	0	2.4	3.4	-1.1	0	0.00
	Assam	1661	0	28.3	22.0	-0.1	107	0.00
	Manipur	192	0	2.8	2.7	0.1	30	0.16
	Meghalaya	337	0	5.5	4.7	-0.2	75	0.00
NER	Mizoram	132	0	1.9	1.9	-0.3	30	0.00
	Nagaland	150	0	2.1	2.2	-0.1	25	0.00
	Tripura	287	0	5.4	5.1	0.4	69	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.1	-12.3	-23.8	-28.0
Day Peak (MW)	-239.0	-784.0	-1017.0	-1521.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	63.2	-245.4	303.9	-131.0	9.2	0.0
Actual(MU)	46.8	-240.2	317.2	-138.3	7.4	-7.2
O/D/U/D(MU)	-16.5	5.1	13.2	-7.3	-1.8	-7.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5339	9265	2908	3967	601	22080	50
State Sector	5428	8988	6716	1154	187	22472	50
Total	10767	18252	9624	5120	788	44552	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	828	1642	753	751	10	3984	75
Lignite	24	14	54	0	0	92	2
Hydro	128	53	101	25	11	317	6
Nuclear	18	50	71	0	0	138	3
Gas, Naptha & Diesel	8	17	9	0	24	57	1
RES (Wind, Solar, Biomass & Others)	248	250	226	7	1	732	14
Total	1253	2027	1212	783	46	5320	100
Share of RES in total generation (%)	19.78	12.33	18.64	0.92	2.35	13.76	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.38	17.42	32.78	4.07	26.55	22.32	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.030
Based on State Max Demands	1.077

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	223113	10:30	10
Non-Solar hr	211498	18:58	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 19-Mar-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	567	784	0.0	6.6	-6.6
4	765 kV	SASARAM-FATEHPUR	1	126	477	0.0	6.2	-6.2
5	765 kV	GAYA-BALIA	1	126	436	0.0	5.7	-5.7
6	400 kV	PUSAULI-VARANASI	1	0	120	0.0	0.0	0.0
7	400 kV	PUSAULI -ALLAHABAD	1	31	46	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	604	251	0.0	2.1	-2.1
9	400 kV	PATNA-BALIA	2	15	751	0.0	11.5	-11.5
10	400 kV	NAUBATPUR-BALIA	2	39	336	0.0	0.0	0.0
11	400 kV	BIHARSHARIFF-BALIA	2	392	37	3.2	0.0	3.2
12	400 kV	MOTHARI-GORAKHPUR	2	96	342	0.0	4.2	-4.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	1.5	-1.5
14	220 kV	SAHUPURI-KARAMNASA	1	0	48	0.0	0.0	0.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						3.9	40.5	-36.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1141	303	6.3	0.0	6.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	392	1121	0.0	7.2	-7.2
3	765 kV	JHARSUGUDA-DURG	2	0	786	0.0	14.8	-14.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	810	0.0	13.1	-13.1
5	400 kV	RANCHI-SIPAT	2	50	407	0.0	4.2	-4.2
6	220 kV	BUDHIPADAR-RAIGARH	1	8	138	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-KORBA	2	0	238	0.0	3.0	-3.0
ER-WR						6.3	43.7	-37.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	681	0.0	16.3	-16.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1761	0.0	81.3	-81.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	3317	0.0	63.5	-63.5
4	400 kV	TALCHER-I/C	2	650	262	0.0	37.0	-37.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	161.0	-161.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	234	4	2.8	0.0	2.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	370	0	4.5	0.0	4.5
3	220 kV	ALIPURDUAR-SALAKATI	2	96	0	1.7	0.0	1.7
ER-NER						9.0	0.0	9.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	662	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2521	0.0	34.2	-34.2
2	HVDC	VINDHYACHAL B/B	-	49	0	1.3	0.0	1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1457	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	989	861	4.1	3.6	0.5
5	765 kV	GWALIOR-PHAGI	2	788	1073	3.6	10.4	-6.8
6	765 kV	JABALPUR-ORAI	2	701	437	0.0	1.2	-1.2
7	765 kV	GWALIOR-ORAI	1	695	0	11.1	0.0	11.1
8	765 kV	SATNA-ORAI	1	0	809	0.0	15.1	-15.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2136	0	25.9	0.0	25.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	1853	0.0	24.6	-24.6
11	400 kV	ZERDA-KANKROLI	1	454	0	6.0	0.0	6.0
12	400 kV	ZERDA -BHINMAL	1	313	0	4.2	0.0	4.2
13	400 kV	VINDHYACHAL -RIHAND	1	969	0	21.2	0.0	21.2
14	400 kV	RAPP-SHUJALPUR	2	748	12	7.6	0.0	7.6
15	400 kV	NEEMUCH-Chittorgarh	2	694	62	7.0	0.0	7.0
16	220 kV	BHANPURA-RANPUR	1	0	111	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	128	0	1.8	0.0	1.8
19	220 kV	MALANPUR-AURAIYA	1	95	0	1.1	0.0	1.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						95.0	128.7	-33.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	22.3	-22.3
2	HVDC	RAIGARH-PUGALUR	2	0	6025	0.0	117.3	-117.3
3	765 kV	SOLAPUR-RAICHUR	2	135	1438	0.1	17.1	-17.1
4	765 kV	WARDHA-NIZAMABAD	2	0	3127	0.0	53.2	-53.2
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3275	0.0	56.3	-56.3
6	400 kV	KOLHAPUR-KUDGI	2	1272	0	18.3	0.0	18.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	122	2.3	0.0	2.3
WR-SR						20.6	266.2	-245.6
INTERNATIONAL EXCHANGES								
Import(+ve)/Export(-ve)								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	366	160	273	6.55		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-246	65	-112	-2.70		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-353	-234	-302	-7.25		
	NER	132kV GELEPHU-SALAKATI	9	-2	3	0.07		
	NER	132kV MOTANGA-RANGIA	23	-2	10	0.23		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-74	0	-45	-1.08		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-74	0	-42	-1.02		
	ER	NEPAL IMPORT (FROM BIHAR)	-250	-1	-168	-4.04		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-534	-10	-258	-6.18		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-933	-882	-920	-22.08		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1522	903	-1165	-27.97		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-84	0	-71	-1.70		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 19-Mar-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.39	5.55	0.00	0.00	0.00	0.00	0.00	5.94
Nepal	4.15	0.00	1.68	0.00	0.00	4.64	0.00	0.00	10.47
Bangladesh	23.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.05
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.20	0.39	7.23	0.00	0.00	4.64	0.00	0.00	39.46

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.97
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.97

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.97	-0.39	-5.55	0.00	0.00	0.00	0.00	0.00	-3.97
Nepal	-4.15	0.00	-1.68	0.00	0.00	-4.64	0.00	0.00	-10.47
Bangladesh	-23.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.05
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.23	-0.39	-7.23	0.00	0.00	-4.64	0.00	0.00	-37.49

