



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 06.02.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 05.02.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 5-फ़रवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 05.02.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 06-Feb-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60045	68043	53481	24582	2885	209036
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1252	1594	1298	491	52	4687
Hydro Gen (MU)	111	37	89	24	13	275
Wind Gen (MU)	29	104	92	-	-	225
Solar Gen (MU)*	230.74	164.94	142.43	3.91	1.25	543
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65196	80946	64325	25188	3016	235926
Time Of Maximum Demand Met	09:38	09:56	09:40	18:38	18:02	09:40

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.032	0.00	0.00	5.64	5.64	83.22	11.14

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8658	0	165.8	70.0	-0.7	463	0.00
	Haryana	8358	0	164.4	116.2	-2.4	317	0.00
	Rajasthan	18561	0	337.9	99.0	-4.8	432	0.00
	Delhi	4851	0	85.1	76.8	-0.9	430	0.00
	UP	18816	0	344.3	62.1	0.2	569	0.00
	Uttarakhand	2570	0	45.6	37.9	0.3	86	0.00
	HP	2196	0	38.8	32.5	-0.6	102	0.00
	J&K(UT) & Ladakh(UT)	2985	0	62.3	56.8	-1.0	143	0.00
	Chandigarh	260	0	4.1	4.1	0.0	12	0.00
WR	Railways_NR ISTS	193	0	4.0	3.8	0.2	34	0.00
	Chhattisgarh	6061	0	123.8	65.1	-0.6	235	0.00
	Gujarat	24334	0	449.9	211.2	-0.7	926	0.00
	MP	17292	0	312.3	190.2	0.0	1004	0.00
	Maharashtra	30488	0	623.5	199.4	-2.9	518	0.00
	Goa	751	0	14.9	12.4	2.0	75	0.00
	DNHDDPDCL	1406	0	32.1	31.7	0.4	80	0.00
	AMNSIL	786	0	17.0	13.2	0.7	254	0.00
	BALCO	606	0	14.4	14.5	-0.1	40	0.00
SR	RIL JAMNAGAR	248	0	5.6	5.7	-0.1	0	0.00
	Andhra Pradesh	12676	0	235.8	67.0	-0.3	708	0.00
	Telangana	15838	0	280.4	129.8	-0.7	492	0.00
	Karnataka	17269	0	324.2	125.9	0.9	1012	0.00
	Kerala	4741	0	90.2	70.2	1.3	354	0.00
	Tamil Nadu	17748	0	358.4	220.7	0.8	1340	0.00
	Puducherry	423	0	9.0	8.5	-0.1	45	0.00
ER	Bihar	5675	0	104.9	85.7	-2.4	254	0.00
	DVC	3312	0	70.3	-32.9	0.4	344	0.00
	Jharkhand	2038	0	38.0	31.4	-1.0	261	0.00
	Odisha	5684	0	102.6	18.8	-2.5	342	0.00
	West Bengal	8362	0	173.6	58.5	-1.9	178	0.00
	Sikkim	119	0	1.9	2.0	0.0	10	0.00
	Railways_ER ISTS	26	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	184	0	3.0	3.1	-0.2	17	0.00
	Assam	1679	0	29.4	23.5	-0.1	95	0.00
	Manipur	264	0	3.8	3.8	0.0	28	0.00
	Meghalaya	370	0	6.3	5.7	-0.1	78	0.00
	Mizoram	154	0	2.4	2.0	0.1	24	0.00
	Nagaland	167	0	2.7	2.6	0.0	7	0.00
	Tripura	236	0	4.0	5.0	-0.1	34	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-15.4	-10.4	-24.2	-16.0
Day Peak (MW)	-999.8	-721.3	-1041.6	-764.9

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	151.2	-220.8	200.6	-145.0	14.0	0.0
Actual(MU)	124.0	-197.0	188.9	-142.6	12.7	-14.0
O/D/U/D(MU)	-27.2	23.8	-11.8	2.5	-1.3	-14.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5790	10565	4658	2945	685	24643	45
State Sector	8824	12081	6356	3225	205	30691	55
Total	14614	22646	11014	6170	890	55333	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	742	1525	706	711	8	3692	72
Lignite	27	17	50	0	0	94	2
Hydro	111	37	89	24	13	275	5
Nuclear	42	61	71	0	0	174	3
Gas, Naptha & Diesel	10	20	9	0	22	61	1
RES (Wind, Solar, Biomass & Others)	285	273	268	8	1	835	16
Total	1217	1932	1193	743	45	5130	100

Share of RES in total generation (%)	23.45	14.11	22.48	1.03	2.80	16.28
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.02	19.19	35.88	4.28	32.57	25.02

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.044

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	235926	9:40	0
Non-Solar hr	213026	18:51	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 06-Feb-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	571	1240	0.0	13.6	-13.6
4	765 kV	SASARAM-FATEHPUR	1	221	577	0.0	5.8	-5.8
5	765 kV	GAYA-BALIA	1	15	827	0.0	10.8	-10.8
6	400 kV	PUSAULI-VARANASI	1	7	159	0.0	1.7	-1.7
7	400 kV	PUSAULI -ALLAHABAD	1	67	109	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	612	446	0.5	0.0	0.5
9	400 kV	PATNA-BALIA	2	102	899	0.0	10.8	-10.8
10	400 kV	NAUBATPUR-BALIA	2	213	218	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	464	147	2.9	0.0	2.9
12	400 kV	MOTIHARI-GORAKHPUR	2	158	492	0.0	4.9	-4.9
13	400 kV	BIHARSARIEFF-SAHUPURI	2	201	450	0.0	3.6	-3.6
14	220 kV	SAHUPURI-KARAMNASA	1	24	12	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						4.0	59.5	-55.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1252	0.0	14.0	-14.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	985	1013	2.1	0.0	2.1
3	765 kV	JHARSUGUDA-DURG	2	0	1567	0.0	27.9	-27.9
4	400 kV	JHARSUGUDA-RAIGARH	4	73	455	0.0	4.4	-4.4
5	400 kV	RANCHI-SIPAT	2	191	384	0.0	1.5	-1.5
6	400 kV	JEYPORE-JAGDALPUR	2	281	165	2.4	0.0	2.4
7	220 kV	BUDHIPADAR-RAIGARH	1	0	175	0.0	2.7	-2.7
8	220 kV	BUDHIPADAR-KORBA	2	39	125	0.0	1.0	-1.0
ER-WR						4.5	51.4	-47.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	523	0.0	12.3	-12.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1624	0.0	42.2	-42.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1987	0.0	33.8	-33.8
4	400 kV	TALCHER-I/C	2	291	546	0.5	0.0	0.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	88.3	-88.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	128	177	0.5	1.4	-1.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	346	110	2.6	0.0	2.6
3	220 kV	ALIPURDUAR-SALAKATI	2	40	48	0.0	0.1	-0.1
ER-NER						3.0	1.5	1.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	15.9	0.0	15.9
NER-NR						15.9	0.0	15.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3530	0.0	54.7	-54.7
2	HVDC	VINDHYACHAL B/B	-	94	252	0.6	4.5	-3.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1176	0.0	24.0	-24.0
4	765 kV	GWALIOR-AGRA	2	1318	1773	4.3	15.4	-11.2
5	765 kV	GWALIOR-PHAGI	2	1066	2017	3.2	23.8	-20.6
6	765 kV	JABALPUR-ORAI	2	616	1007	0.0	14.9	-14.9
7	765 kV	GWALIOR-ORAI	1	977	0	14.5	0.0	14.5
8	765 kV	SATNA-ORAI	1	0	1137	0.0	18.1	-18.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2756	0	35.6	0.0	35.6
10	765 kV	VINDHYACHAL-VARANASI	2	81	2015	0.0	25.4	-25.4
11	400 kV	ZERDA-KANKROLI	1	471	0	7.0	0.0	7.0
12	400 kV	ZERDA -BHINMAL	1	324	0	4.8	0.0	4.8
13	400 kV	VINDHYACHAL -RIHAND	1	484	0	10.3	0.0	10.3
14	400 kV	RAPP-SHUJALPUR	2	1040	204	8.0	0.6	7.5
15	400 kV	NEEMUCH-Chittorgarh	2	929	413	5.8	1.7	4.1
16	220 kV	BHANPURA-RANPUR	1	0	125	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	108	18	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	79	27	0.7	0.1	0.6
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						95.8	186.7	-90.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	6027	0.0	82.1	-82.1
3	765 kV	SOLAPUR-RAICHUR	2	1352	1113	8.1	6.8	1.3
4	765 kV	WARDHA-NIZAMABAD	2	0	2939	0.0	36.0	-36.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3195	0.0	42.5	-42.5
6	400 kV	KOLHAPUR-KUDGI	2	1758	0	28.5	0.0	28.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	115	2.1	0.0	2.1
WR-SR						38.7	191.4	-152.7

INTERNATIONAL EXCHANGES						Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-340	11	-264	-6.33	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-413	98	-158	-3.78	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-195	-73	-157	-3.76	
	NER	132kV GELEPHU-SALAKATI	-75	-3	-45	-1.09	
	NER	132kV MOTANGA-RANGIA	-35	2	-18	-0.42	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-32	-0.78	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-49	-1.18	
	ER	NEPAL IMPORT (FROM BIHAR)	-150	-85	-117	-2.80	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-424	-156	-237	-5.69	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-918	-913	-914	-21.95	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-765	-408	-668	-16.02	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-116	0	-95	-2.29	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.36	18.95	0.00	0.00	0.00	0.00	0.00	19.31
Nepal	3.44	1.20	1.46	0.00	0.00	3.40	0.00	0.00	9.50
Bangladesh	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.39	1.56	20.41	0.00	0.00	3.40	0.00	0.00	51.76

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	-0.36	-18.95	0.00	0.00	0.00	0.00	0.00	-18.97
Nepal	-3.44	-1.20	-1.46	0.00	0.00	-3.40	0.00	0.00	-9.50
Bangladesh	-22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.05	-1.56	-20.41	0.00	0.00	-3.40	0.00	0.00	-51.42

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												Date of Reporting: 06-Feb-2026
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(+ve) Import, (-ve) Export
0:00	50.07	161763	6639	15899	0	5981	2233	132563	4281	145864	167596	-2191
0:15	49.98	161734	6639	15845	0	5780	2238	132776	4208	145889	167486	-2168
0:30	49.94	162054	6644	15533	0	6285	2218	132736	4184	146521	167600	-2172
0:45	49.98	161363	6644	15439	0	6473	2238	131952	4178	145924	166924	-2139
1:00	49.99	160194	6631	15249	0	6203	2228	131389	4171	144945	165871	-2166
1:15	50.03	159319	6632	15147	0	5666	2225	131216	4192	144172	165078	-2228
1:30	49.97	158865	6628	14974	0	5808	2240	130572	4120	143891	164342	-2199
1:45	49.99	158627	6634	14947	0	6182	2237	130144	4124	143680	164268	-2198
2:00	50.03	157297	6640	14842	0	6102	2247	128878	4135	142455	162844	-2148
2:15	49.99	156956	6643	14662	0	6183	2181	128641	4082	142294	162392	-2110
2:30	49.99	157244	6659	14412	0	6169	2187	129103	4116	142832	162646	-2118
2:45	49.96	157019	6650	14080	0	6210	2183	129225	4132	142939	162480	-2124
3:00	50.00	156391	6640	13837	0	5881	2180	129236	4130	142554	161904	-2143
3:15	50.01	157029	6623	13853	0	5723	2187	130175	4120	143176	162681	-2182
3:30	50.00	157467	6638	13882	0	6015	2197	130143	4112	143585	162987	-2187
3:45	50.01	157566	6646	13455	0	6391	2296	130535	4107	144111	163430	-2220
4:00	50.03	157557	6644	13447	0	6782	2306	130278	4084	144110	163541	-2255
4:15	49.99	160143	6647	13499	0	7327	2364	132090	4097	146644	166024	-2234
4:30	49.99	161871	6642	13579	0	7339	2360	133660	4087	148292	167667	-2266
4:45	49.98	163872	6648	13265	0	7551	2365	136299	4039	150607	170167	-2255
5:00	50.05	165877	6624	12977	138	7582	2365	138009	4127	152762	171822	-2301
5:15	50.03	169553	6622	12811	134	7766	2392	142051	4065	156608	175841	-2267
5:30	50.01	174364	6633	12494	129	8185	2398	146831	4012	161741	180682	-2293
5:45	49.99	179682	6634	12591	125	8618	2387	151450	4017	166966	185822	-2328
6:00	50.12	183255	6637	12247	143	9680	2389	154348	4045	170865	189489	-2367
6:15	49.99	189891	6635	12046	423	10373	2331	160058	4044	177422	195910	-2361
6:30	50.02	197333	6630	11955	389	12107	2339	165624	4154	184989	203198	-2317
6:45	49.97	204692	6643	11782	447	16086	2397	168611	4088	192463	210054	-1755
7:00	50.04	211081	6623	11709	628	19606	2388	170738	4047	198744	215739	-1250
7:15	49.85	216264	6646	11507	1387	22115	2517	172473	4078	203370	220723	-1250
7:30	49.93	219879	6629	11450	2945	23153	2550	173577	4092	205484	224396	-1237
7:45	50.03	222824	6623	11285	6038	23483	2594	173115	4086	205501	227224	-1246
8:00	50.16	222948	6631	8684	9405	23097	2712	170594	3736	204859	224859	-1262
8:15	50.07	225901	6643	10982	15205	21801	2412	168790	4142	199714	229975	-1318
8:30	50.12	227122	6642	10582	21602	20385	2378	165317	4143	194938	231049	-1341
8:45	50.10	228294	6635	10097	28305	16267	2319	163816	4204	189892	231643	-1343
9:00	50.06	229075	6637	9810	35209	13298	2324	161315	4188	184056	232781	-1876
9:15	49.98	232701	6618	9337	40610	11768	2317	162424	4186	182754	237260	-2409
9:30	49.95	234134	6637	8695	47136	10755	2324	158657	4161	178303	238365	-2466
9:45	50.00	235281	6640	8099	52979	9795	2297	155924	4160	174203	239894	-2490
10:00	50.07	233888	6620	7702	58246	9496	2292	150429	4138	167940	238923	-2505
10:15	49.95	232495	6624	7381	61948	8008	2290	147125	4114	163166	237490	-2581
10:30	49.99	232081	6611	7131	65693	6775	2279	144479	4037	159257	237005	-2580
10:45	49.99	231395	6616	6939	68235	6600	2285	141359	4026	156221	236060	-2571
11:00	50.02	229494	6614	6743	70117	6196	2286	139016	4092	152634	235064	-2610
11:15	49.98	226625	6621	6629	71441	5999	2295	135211	4056	148555	232252	-2638
11:30	49.97	225393	6636	6568	72425	6431	2290	132569	4055	146400	230974	-2649
11:45	49.94	224680	6616	6436	72869	6245	2290	131187	4000	145375	229643	-2618
12:00	50.00	222046	6613	6351	73331	6242	2286	128254	4084	142364	227161	-2616
12:15	49.93	219501	6608	6103	73626	5977	2147	126375	4020	139772	224856	-2596
12:30	49.93	217988	6614	5938	73696	6023	2181	124926	4009	138354	223387	-2590
12:45	49.86	216422	6622	5691	73731	5831	2152	123741	3996	137000	221764	-2578
13:00	50.02	213464	6603	5402	73421	5907	2141	121386	3995	134641	218855	-2619
13:15	49.98	209959	6606	5212	73247	5892	2149	118041	4041	131500	215188	-2567
13:30	50.02	208600	6609	4868	73019	5986	2148	117054	4015	130713	213699	-2566
13:45	49.98	209323	6611	4759	72167	5907	2152	118582	4025	132397	214203	-2593
14:00	50.04	209168	6596	4583	71319	5760	2153	119474	4023	133266	213908	-2471
14:15	49.98	209525	6614	4716	58913	5168	2477	124150	3763	145896	205801	-2482
14:30	50.00	210982	6589	4154	68750	5483	2139	124664	3997	138078	215776	-2461
14:45	49.96	212026	6592	4017	67236	5799	2143	127074	3934	140773	216795	-2456
15:00	49.99	211484	6583	3861	65075	6143	2144	128986	3969	142548	216761	-2430
15:15	49.99	210236	6592	3737	62572	6196	2134	130012	3960	143927	215203	-2428
15:30	49.98	209887	6597	3656	59158	6647	2143	133163	3982	147073	215346	-2447
15:45	50.00	209912	6606	3590	55311	7381	2145	136350	3956	151011	215339	-2418
16:00	50.05	209741	6590	3512	51295	7866	2168	139771	3960	154934	215162	-2411
16:15	49.95	203153	6470	2897	39909	7583	2374	142081	3840	160347	205154	-2358
16:30	50.00	203993	6486	3833	36265	9175	2446	146063	3607	163895	207875	-2310
16:45	49.86	207164	6601	3453	36029	10847	2176	149126	3977	167682	212209	-2342
17:00	50.05	207416	6591	3755	28079	12286	2204	155193	3978	175582	212086	-2301
17:15	50.03	203935	6609	3834	21131	13502	2286	156863	4058	178970	208283	-2063
17:30	50.05	204920	6591	3666	12861	15333	2467	162071	4075	188393	207064	-1450
17:45	50.01	207976	6591	3819	7903	18835	2439	167478	4033	196254	211098	-1445
18:00	50.10	208742	6589	4365	4628	21294	2453	169058	3982	199749	212369	-1336
18:15	50.03	208261	6628	4588	2063	21918	2494	170256	3992	201610	211939	-1284
18:30	50.06	210780	6618	4758	729	22622	2558	173470	4091	205293	214846	-1274
18:45	49.94	212594	6649	3902	436	23266	2573	174406	3966	208256	215198	-1217
19:00	50.01	212351	6659	5334	476	22954	2560	174075	4028	206541	216086	-1240
19:15	50.04	210331	6652	5692	402	21591	2533	173144	4015	204237	214029	-1212
19:30	50.03	207228	6648	5753	0	18499	2470	173358	4012	201475	210740	-1203
19:45	50.03	204800	6646	6153	0	17340	2260	171876	3969	198647	208244	-1205
20:00	50.05	200946	6669	6426	0	16155	2157	169274	4020	194520	204701	-1264
20:15	50.03	197837	6664	6934	0	14270	2171	168463	4064	190903	202566	-1883
20:30	50.02	194834	6660	7227	0	13101	2181	166985	4097	187607	200251	-2269
20:45	49.97	192934	6676	7466	0	12391	2199	165631	4081	185468	198444	-2270
21:00	49.99	189939	6684	7849	0	11546	2166	163054	4134	182090	195433	-2257
21:15	50.00	186834	6677	8108	0	11080	2172	160367	4142	178726	192546	-2280
21:30	50.01	184335	6697	8436	0	10286	2192	158450	4143	175899	190204	-2245
21:45	49.97	181716	6682	8741	0	9100	2196	156307	4170	172975	187196	-2215
22:00	50.06	177570	6686	8923	0	8450	2176	153221	4160	168647	183616	-2255
22:15	49.98	178366	6679	9142	0	8262	2186	153675	4162	169224	184106	-2227
22:30	49.95	176641	6678	9292	0	8016	2191	152209	4118	167349	182504	-2221
22:45	50.03	174746	6682	9386	0	7945	2					