



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 23.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 22.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 22-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 22.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 23-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61780	70302	50837	24354	2908	210181
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1299	1601	1246	497	53	4694
Hydro Gen (MU)	102	43	82	22	15	264
Wind Gen (MU)	38	87	92	-	-	217
Solar Gen (MU)*	151.48	154.28	162.26	3.41	0.82	472
Energy Shortage (MU)	0.09	0.00	0.00	0.00	0.00	0.09
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71061	82859	62420	24660	2955	241522
Time Of Maximum Demand Met	09:36	09:57	09:39	18:52	17:33	09:39

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.041	0.00	0.24	4.20	4.44	79.60	15.96

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9193	0	168.1	82.0	-1.8	672	0.00
	Haryana	8721	0	170.4	112.0	-2.1	272	0.00
	Rajasthan	19094	0	341.2	117.1	-1.6	1693	0.00
	Delhi	4918	0	84.8	77.6	-1.0	438	0.00
	UP	20668	0	379.9	86.9	-1.9	436	0.00
	Uttarakhand	2516	0	47.0	39.6	-0.1	109	0.09
	HP	2228	0	39.2	33.7	-0.8	103	0.00
	J&K(UT) & Ladakh(UT)	3010	0	59.8	58.8	-3.4	168	0.00
	Chandigarh	285	0	4.4	4.4	-0.1	12	0.00
	Railways_NR ISTS	208	0	4.1	3.6	0.5	42	0.00
WR	Chhattisgarh	5739	0	115.0	58.1	-1.2	270	0.00
	Gujarat	24829	0	448.6	201.1	0.7	1133	0.00
	MP	19508	0	351.4	218.0	0.0	514	0.00
	Maharashtra	30036	0	601.6	172.7	-10.8	944	0.00
	Goa	726	0	13.9	11.9	1.9	35	0.00
	DNHDDPDCL	1382	0	31.6	31.5	0.1	39	0.00
	AMNSIL	819	0	18.2	12.3	0.2	293	0.00
	BALCO	602	0	14.3	14.5	-0.2	11	0.00
	RIL JAMNAGAR	262	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	12338	0	227.5	61.7	-1.1	820	0.00
SR	Telangana	15720	0	276.8	124.5	-0.9	815	0.00
	Karnataka	17098	0	309.4	100.8	-2.2	844	0.00
	Kerala	4550	0	83.6	64.9	1.0	413	0.00
	Tamil Nadu	17323	0	340.0	178.7	-2.7	731	0.00
	Puducherry	392	0	8.2	7.9	-0.3	28	0.00
	Bihar	6100	0	109.2	85.5	2.0	174	0.00
ER	DVC	3122	0	68.2	-19.8	-0.3	323	0.00
	Jharkhand	2095	0	38.8	32.2	-1.4	201	0.00
	Odisha	5591	0	110.4	23.6	-1.9	347	0.00
	West Bengal	8166	0	168.3	49.1	-2.6	192	0.00
	Sikkim	112	0	1.8	2.0	-0.2	11	0.00
	Railways_ER ISTS	28	0	0.2	0.2	0.0	8	0.00
NER	Arunachal Pradesh	192	0	3.3	3.2	0.1	28	0.00
	Assam	1633	0	30.1	26.4	0.3	106	0.00
	Manipur	276	0	4.0	4.0	0.0	32	0.00
	Meghalaya	370	0	6.2	5.6	-0.2	80	0.00
	Mizoram	159	0	2.3	2.2	-0.1	35	0.00
	Nagaland	168	0	2.6	2.5	0.0	22	0.00
	Tripura	237	0	4.0	6.3	0.2	88	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-16.7	-10.0	-14.4	-17.9
Day Peak (MW)	-972.4	-703.1	-624.4	-773.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	235.4	-230.3	137.5	-155.1	12.5	0.0
Actual(MU)	238.5	-223.8	119.6	-158.3	11.0	-13.0
O/D/U/D(MU)	3.0	6.6	-17.9	-3.2	-1.5	-13.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6036	10715	5548	3344	469	26111	49
State Sector	7879	9816	5395	3719	205	27014	51
Total	13915	20531	10943	7063	674	53124	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	764	1676	718	715	13	3885	74
Lignite	20	21	41	0	0	82	2
Hydro	102	43	82	22	15	264	5
Nuclear	50	48	65	0	0	163	3
Gas, Naptha & Diesel	12	21	9	0	20	62	1
RES (Wind, Solar, Biomass & Others)	215	244	297	7	1	764	15
Total	1163	2054	1212	744	48	5221	100

Share of RES in total generation (%)	18.48	11.89	24.52	0.92	1.98	14.64
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.58	16.34	36.65	3.90	32.60	22.83

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.010
Based on State Max Demands	1.036

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	241522	9:39	0
Non-Solar hr	214259	18:42	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export=(-ve) for NET (MU)
Date of Reporting: 23-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	316	1548	0.0	20.3	-20.3
4	765 kV	SASARAM-FATEHPUR	1	112	766	0.0	10.0	-10.0
5	765 kV	GAYA-BALIA	1	0	753	0.0	11.9	-11.9
6	400 kV	PUSAULI-VARANASI	1	33	96	0.0	0.8	-0.8
7	400 kV	PUSAULI-ALLAHABAD	1	2	137	0.0	1.5	-1.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	461	609	0.0	4.0	-4.0
9	400 kV	PATNA-BALIA	2	0	987	0.0	14.8	-14.8
10	400 kV	NAUBATPUR-BALIA	2	148	235	0.0	4.6	-4.6
11	400 kV	BIHARSHARIFF-BALIA	2	385	207	0.0	0.0	0.0
12	400 kV	MOTIHARI-GORAKHPUR	2	54	604	0.0	7.7	-7.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	147	512	0.0	6.1	-6.1
14	220 kV	SAHUPURI-KARAMNANA	1	26	16	0.0	2.2	-2.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	7	0.0	0.0	0.0
ER-NR						0.2	86.0	-85.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	44	1366	0.0	15.5	-15.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1173	512	6.2	0.0	6.2
3	765 kV	JHARSUGUDA-DURG	2	0	1079	0.0	18.3	-18.3
4	400 kV	JHARSUGUDA-RAIGARH	4	360	310	0.7	0.0	0.7
5	400 kV	RANCHI-SIPAT	2	299	246	0.2	0.0	0.2
6	400 kV	JEYPORE-JAGDALPUR	2	504	156	5.0	0.0	5.0
7	220 kV	BUDHIPADAR-RAIGARH	1	0	93	0.0	1.3	-1.3
8	220 kV	BUDHIPADAR-KORBA	2	85	132	0.0	0.4	-0.4
ER-WR						12.1	35.5	-23.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	632	0.0	13.9	-13.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1625	0.0	47.0	-47.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	1512	0.0	25.5	-25.5
4	400 kV	TALCHER-I/C	2	0	1201	0.0	14.9	-14.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	2	2	0.0	0.0	0.0
ER-SR						0.0	86.4	-86.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	188	195	0.5	1.6	-1.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	384	117	2.1	0.0	2.1
3	220 kV	ALIPURDUAR-SALAKATI	2	50	39	0.1	0.1	0.0
ER-NER						2.7	1.7	1.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	572	0	14.0	0.0	14.0
NER-NR						14.0	0.0	14.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4065	0.0	79.4	-79.4
2	HVDC	VINDHYACHAL B/B	-	94	0	2.4	0.0	2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1925	0.0	40.1	-40.1
4	765 kV	GWALIOR-AGRA	2	309	1944	0.0	22.4	-22.4
5	765 kV	GWALIOR-PHAGI	2	260	2123	0.0	23.7	-23.7
6	765 kV	JABALPUR-ORAI	2	119	1019	0.0	26.3	-26.3
7	765 kV	GWALIOR-ORAI	1	986	0	14.8	0.0	14.8
8	765 kV	SATNA-ORAI	1	0	1102	0.0	18.8	-18.8
9	765 kV	BANASKANTHA-CHITORGARH	2	2503	438	23.0	0.0	23.0
10	765 kV	VINDHYACHAL VARANASI	2	0	1893	0.0	26.5	-26.5
11	400 kV	ZERDA-KANKROLI	1	399	0	5.3	0.0	5.3
12	400 kV	ZERDA BHINMAL	1	275	0	3.6	0.0	3.6
13	400 kV	VINDHYACHAL -RIHAND	1	470	0	10.0	0.0	10.0
14	400 kV	RAPP-SHUJALPUR	2	878	182	5.8	0.4	5.4
15	400 kV	NEEMUCH-Chittorgarh	2	765	385	1.2	0.0	1.2
16	220 kV	BHANPURA-RANPUR	1	0	126	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	134	6	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	103	22	0.6	0.1	0.5
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						67.7	241.4	-173.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	21.9	-21.9
2	HVDC	RAIGARH-PUGALUR	2	0	4007	0.0	44.0	-44.0
3	765 kV	SOLAPUR-RAICHUR	2	2071	922	15.1	3.7	11.4
4	765 kV	WARDHA-NIZAMABAD	2	620	1959	0.0	19.7	-19.7
5	765 kV	WARORA-WARANGAL(NEW)	2	5	2465	0.0	32.2	-32.2
6	400 kV	KOLHAPUR-KUDGI	2	2028	0	31.2	0.0	31.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	114	2.1	0.0	2.1
WR-SR						48.4	121.6	-73.2

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-296	99	-216	-5.19	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-329	165	-146	-3.51	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-287	-175	-254	-6.09	
	NER	132kV GELEPHU-SALAKATI	-64	-35	-53	-1.27	
	NER	132kV MOTANGA-RANGIA	-56	-6	-29	-0.69	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-20	-0.48	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-45	-1.08	
	ER	NEPAL IMPORT (FROM BIHAR)	-163	-87	-119	-2.85	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-450	-148	-234	-5.61	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-483	-479	-482	-11.56	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-773	-656	-744	-17.85	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-140	0	-118	-2.82	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 23-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	16.88	0.00	0.00	0.38	0.00	0.00	17.57
Nepal	3.00	1.75	1.27	0.00	0.00	3.32	0.00	0.00	9.34
Bangladesh	12.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	12.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	15.15	2.06	18.15	0.00	0.00	3.70	0.00	0.00	39.06

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.39
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.39	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.39

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.39	-0.31	-16.88	0.00	0.00	-0.38	0.00	0.00	-17.18
Nepal	-3.00	-1.75	-1.27	0.00	0.00	-3.32	0.00	0.00	-9.34
Bangladesh	-12.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-12.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-14.76	-2.06	-18.15	0.00	0.00	-3.70	0.00	0.00	-38.67

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+H+G+H)	(K)
0:00	49.94	160843	6085	10526	0	4959	2375	137124	3658	150317	164727	-1769
0:15	50.02	161289	6069	10410	0	5311	2375	137155	3791	150879	165111	-1756
0:30	50.04	160503	6082	10391	0	5794	2388	135911	3749	150112	164315	-1760
0:45	50.00	159491	6068	10455	0	5719	2274	135174	3669	149036	163359	-1728
1:00	50.00	158778	6094	10512	0	5494	2275	134606	3720	148266	162701	-1719
1:15	49.98	157789	6034	10224	0	5172	2280	134243	3667	147565	161620	-1735
1:30	49.98	156701	6011	9901	0	4858	2271	133773	3694	146800	160508	-1736
1:45	50.02	156302	5992	9605	0	4708	2275	133931	3640	146697	160151	-1702
2:00	50.04	154835	5990	9286	0	4621	2284	132948	3650	145549	158779	-1685
2:15	49.98	155035	5993	8922	0	4755	2272	133407	3593	146113	158942	-1707
2:30	49.96	155131	5962	8812	0	4874	2238	133417	3638	146319	158941	-1679
2:45	49.94	154877	5956	8706	0	4855	2259	133394	3589	146171	158759	-1673
3:00	50.01	155058	5960	8650	0	4950	2248	133751	3601	146408	159160	-1697
3:15	49.97	155469	5984	8767	0	4621	2257	134349	3585	146702	159563	-1700
3:30	50.00	156042	5979	8825	0	5115	2255	134236	3621	147217	160031	-1665
3:45	50.04	156404	5996	8782	0	5192	2234	134692	3590	147622	160486	-1684
4:00	50.05	156610	5982	8775	0	5064	2262	134952	3594	147835	160629	-1665
4:15	50.01	158517	5996	8719	0	5453	2280	136568	3665	149798	162681	-1660
4:30	50.04	159815	5996	8580	0	5612	2276	137954	3606	151235	164024	-1685
4:45	50.02	162534	5972	8569	0	5864	2282	140360	3651	153965	166698	-1717
5:00	50.04	164653	5965	8488	166	6141	2291	142194	3694	155999	168939	-1699
5:15	50.08	168882	5941	8443	173	6579	2315	145893	3660	160266	173004	-1717
5:30	49.98	172297	5929	8224	172	6751	2389	149817	3630	163901	176912	-1743
5:45	50.03	178306	5935	8199	172	7516	2544	154636	3747	169935	182749	-1799
6:00	50.09	181917	5953	8014	165	8551	2875	157262	3737	173738	186557	-1789
6:15	50.05	188989	5930	8026	181	9880	3109	162812	3726	180782	193664	-1841
6:30	50.06	195808	5941	7900	177	12771	3621	166403	3796	187731	200609	-1820
6:45	50.07	204104	5937	7846	164	15961	3596	170980	3830	196094	208314	-1264
7:00	50.03	210047	5948	7923	442	18568	3722	173286	3855	201682	213744	-752
7:15	50.05	215403	5946	7964	1155	20435	4034	174014	3769	206284	217317	-718
7:30	50.03	219622	5949	7813	2593	22708	4065	174539	3778	209216	221445	-723
7:45	50.02	222254	5912	7631	5159	22939	3925	174321	3723	209464	223610	-704
8:00	50.07	224780	5902	7336	8664	22775	3492	173995	3747	208780	225911	-749
8:15	50.03	228883	5869	6992	13262	23280	2318	175222	3750	208629	230693	-760
8:30	50.04	230823	5880	6345	17911	23073	2284	174133	3859	206567	233485	-766
8:45	50.07	233572	5886	5886	23053	21275	2522	173705	3840	204633	236167	-815
9:00	50.08	233279	5916	5859	29272	17064	2423	171065	3923	198148	235522	-959
9:15	49.96	237318	5956	5963	35323	14296	2379	171647	3886	196032	239450	-963
9:30	50.05	240542	5975	6018	42687	13042	2393	168598	3833	191837	242546	-1277
9:45	49.99	241440	5988	6196	48413	11063	2348	166091	3869	186831	243968	-1695
10:00	50.02	239540	6011	6271	53213	9486	2349	161321	3791	180056	242442	-1939
10:15	50.00	237578	6001	6208	57258	7876	2333	156939	3746	174112	240361	-2061
10:30	50.02	236337	6052	6206	60565	7621	2337	152690	3739	169566	239210	-2069
10:45	50.02	234099	6057	6178	62678	6857	2320	149457	3741	165243	237288	-2080
11:00	50.01	232761	6070	6323	65478	5974	2332	146452	3707	160960	236336	-1994
11:15	49.99	229974	6075	6271	66634	6001	2315	142111	3706	157069	233113	-2072
11:30	50.02	227575	6093	5980	67981	5808	2323	138931	3670	153614	230786	-2084
11:45	49.99	225636	6090	5959	69030	5845	2306	135970	3736	150647	228936	-2084
12:00	50.05	222870	6106	6135	70084	5883	2309	131678	3683	146651	225878	-2066
12:15	50.01	220270	6134	6261	71436	5813	2286	127647	3660	142573	223237	-2075
12:30	49.99	219160	6153	6406	71460	5936	2291	126392	3719	141294	222357	-2074
12:45	50.03	218223	6159	6687	71927	5766	2259	125148	3670	139609	221616	-2095
13:00	50.18	215824	6147	6769	71326	5787	2267	123474	3742	137729	219512	-2101
13:15	50.18	212683	6163	6744	70446	5401	2247	121170	3703	135493	215874	-2114
13:30	49.95	210030	6172	7188	67494	5528	2291	120925	3685	135348	213283	-2102
13:45	49.95	210230	6177	7352	65704	5398	2304	123111	3718	137174	213764	-2107
14:00	49.88	209874	6154	7433	63351	5581	2272	125367	3664	139090	213822	-2121
14:15	49.93	210983	6150	7694	61150	5566	2286	127713	3718	142139	214277	-2099
14:30	49.91	211823	6141	7704	58826	6131	2293	130463	3722	145293	215280	-2055
14:45	49.94	212267	6126	7697	55699	6183	2306	133865	3749	148871	215625	-2042
15:00	49.92	212495	6104	8001	53042	6067	2305	136944	3696	151452	216159	-2110
15:15	49.93	210448	6138	8088	49098	6275	2310	138713	3632	153262	214254	-2092
15:30	50.03	212418	6139	8061	45535	6814	2300	143260	3699	158822	215808	-2067
15:45	49.86	211617	6148	8139	40404	7413	2323	147166	3642	163074	215235	-2056
16:00	50.02	212112	6137	8365	36137	8020	2312	151059	3630	167610	215660	-2070
16:15	49.95	209920	6124	8514	32966	8254	2295	151820	3633	168440	213660	-2105
16:30	50.06	210988	6089	8729	26305	10005	2300	157514	3588	175954	214530	-2033
16:45	50.05	209872	6085	8848	21144	11425	2293	159225	3615	179880	212635	-1882
17:00	50.07	209292	6037	9036	14794	12979	2370	163048	3687	185462	211951	-1857
17:15	50.10	207893	6057	8892	12959	14144	2388	161944	3722	186042	210106	-1403
17:30	50.13	209544	6032	9047	8266	17451	2542	164458	3718	192231	211514	-968
17:45	50.06	211800	6019	8999	4738	21122	2624	167596	3685	198063	214783	-956
18:00	50.06	212490	6002	8767	1907	22555	2709	169859	3689	201816	215488	-893
18:15	50.02	212056	5980	8189	5461	23460	2619	167872	3703	198406	217284	-989
18:30	49.98	213424	6017	8529	283	24094	2639	171690	3799	204612	217051	-993
18:45	49.99	214129	6021	8785	155	24086	2635	172009	3751	205189	217442	-957
19:00	50.03	212039	6022	9201	167	23327	2580	170182	3752	202671	215231	-974
19:15	49.98	209473	6011	9619	162	20583	2598	170133	3771	199692	212877	-990
19:30	50.00	207236	6009	9256	0	19041	2514	166324	3706	197980	206850	-954
19:45	50.05	203899	6016	9819	0	17507	2406	167494	3781	194080	207023	-1017
20:00	50.04	200652	6027	10138	0	16560	2350	164981	3766	190514	203822	-1085
20:15	49.99	197177	6033	10583	0	15593	2297	162251	3798	186594	200555	-1259
20:30	49.97	194279	6033	10924	0	14474	2304	160178	3795	183355	197708	-1466
20:45	49.94	190108	6023	11002	0	13090	2303	158441	3806	179106	194665	-1543
21:00	49.98	186915	6041	11245	0	12058	2302	155450	3841	175670	190937	-1516
21:15	49.98	184603	6048	11314	0	11425	2308	153745	3765	173289	188605	-1484
21:30	49.96	181793	6074	11334	0	10912	2309	151737	3771	170459	186137	-1589
21:45	50.04	177928	6064	11380	0	9803	2275	148684	3714	166548	181920	-1572
22:00	50.12	173860	6092	9756	0	9209	2285	145302	3687	164104	176331	-1553
22:15	50.02	172949	6084	9531	0	8569	2287	144767	3738	163418	174976	-1701
22:30	50.01	170546	6081	9343	0	8217	2271	142977	3700	161203	17	