



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 21-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 20.05.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 20-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 20-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 21-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	73553	64737	45496	25411	3237	212434
Peak Shortage (MW)	11	0	0	0	0	11
Energy Met (MU)	1756	1575	1022	583	59	4995
Hydro Gen (MU)	349	58	30	26	17	480
Wind Gen (MU)	37	134	56	-	-	227
Solar Gen (MU)*	169.42	95.21	104.48	4.12	0.94	374
Energy Shortage (MU)	0.24	0.00	0.00	0.00	0.00	0.24
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	81783	72548	47558	29233	3308	228719
Time Of Maximum Demand Met	15:00	15:00	11:55	00:00	18:53	15:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.022	0.00	0.00	0.42	0.42	82.12	17.46

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13913	0	268.6	138.8	-1.5	170	0.00
	Haryana	11251	0	237.5	181.2	-1.4	350	0.00
	Rajasthan	16274	0	344.9	126.7	-2.1	271	0.00
	Delhi	7481	0	152.4	132.8	-1.3	618	0.00
	UP	26433	0	591.5	280.4	-0.4	544	0.00
	Uttarakhand	2657	0	56.0	30.7	-1.3	281	0.00
	HP	1764	0	36.6	1.7	-0.3	144	0.00
	J&K(UT) & Ladakh(UT)	2749	11	56.6	30.6	0.3	231	0.24
	Chandigarh	408	0	7.8	7.6	0.2	49	0.00
WR	Railways_NR ISTS	212	0	4.3	3.8	0.5	65	0.00
	Chhattisgarh	5013	0	112.1	54.6	-1.1	387	0.00
	Gujarat	24675	0	495.8	172.8	-10.7	877	0.00
	MP	13574	0	290.1	163.7	-3.8	528	0.00
	Maharashtra	26683	0	598.7	188.9	-4.1	825	0.00
	Goa	780	0	16.3	14.3	1.8	49	0.00
	DNHDDPDCL	1281	0	29.7	29.6	0.1	65	0.00
	AMNSIL	838	0	19.3	8.7	0.6	268	0.00
	BALCO	523	0	12.5	12.5	0.0	7	0.00
SR	Andhra Pradesh	10035	0	209.5	68.0	-0.4	799	0.00
	Telangana	8763	0	181.3	62.2	0.5	717	0.00
	Karnataka	10877	0	214.5	97.0	-0.7	760	0.00
	Kerala	3906	0	81.1	69.1	0.3	443	0.00
	Tamil Nadu	15199	0	325.5	204.4	-12.1	765	0.00
	Puducherry	437	0	9.8	9.8	-0.6	12	0.00
ER	Bihar	6800	0	131.2	120.4	0.6	386	0.00
	DVC	3389	0	75.7	-40.7	0.6	245	0.00
	Jharkhand	2244	0	45.4	34.2	-1.1	265	0.00
	Odisha	5971	0	123.5	49.9	-1.3	505	0.00
	West Bengal	11209	0	205.9	71.8	-3.0	284	0.00
	Sikkim	100	0	1.5	1.5	0.0	52	0.00
	Railways_ER ISTS	12	0	0.2	0.1	0.0	0	0.00
NER	Arunachal Pradesh	161	0	3.1	3.0	0.0	25	0.00
	Assam	2116	0	37.5	30.6	0.2	177	0.00
	Manipur	190	0	3.0	3.1	-0.1	16	0.00
	Meghalaya	314	0	5.2	2.7	-0.1	95	0.00
	Mizoram	128	0	1.9	1.9	-0.4	21	0.00
	Nagaland	157	0	2.8	2.9	-0.1	11	0.00
	Tripura	300	0	5.8	5.1	0.7	55	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	3.1	-8.3	-22.8	-15.0
Day Peak (MW)	293.0	-717.1	-1061.0	-771.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	356.4	-377.1	90.5	-77.6	8.0	0.4
Actual(MU)	354.2	-379.4	89.9	-69.5	10.2	5.4
O/D/U/D(MU)	-2.2	-2.3	-0.7	8.0	2.2	5.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	2181	4436	4302	2661	501	14081	48
State Sector	4533	3626	5688	1544	110	15500	52
Total	6714	8062	9990	4205	611	29581	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	852	1660	663	714	12	3900	72
Lignite	15	19	67	0	0	101	2
Hydro	349	58	30	26	17	480	9
Nuclear	25	64	51	0	0	141	3
Gas, Naptha & Diesel	47	72	11	0	24	155	3
RES (Wind, Solar, Biomass & Others)	214	231	188	5	1	639	12
Total	1503	2104	1009	745	54	5415	100

Share of RES in total generation (%)	14.26	10.96	18.61	0.69	1.77	11.80
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.14	16.79	26.60	4.16	33.67	23.25

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.024
Based on State Max Demands	1.044

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	228719	15:00	0
Non-Solar hr	217332	22:26	60

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 21-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	0	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	271	662	0.0	5.6	-5.6
4	765 kV	SASARAM-FATEHPUR	1	77	412	0.0	5.1	-5.1
5	765 kV	GAYA-BALIA	1	0	703	0.0	7.5	-7.5
6	400 kV	PUSAULI-VARANASI	1	44	46	0.1	0.0	0.1
7	400 kV	PUSAULI -ALLAHABAD	1	48	44	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	10	585	0.0	6.1	-6.1
9	400 kV	PATNA-BALIA	2	0	864	0.0	13.7	-13.7
10	400 kV	NAUBATPUR-BALIA	2	0	268	0.0	4.0	-4.0
11	400 kV	BIHARSHARIFF-BALIA	2	178	141	0.0	0.2	-0.2
12	400 kV	MOTIHARI-GORAKHPUR	2	0	468	0.0	7.6	-7.6
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	31	61	0.0	0.8	-0.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.8	50.7	-49.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	790	670	4.4	0.0	4.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1242	0	20.3	0.0	20.3
3	765 kV	JHARSUGUDA-DURG	2	0	1006	0.0	16.7	-16.7
4	400 kV	JHARSUGUDA-RAIGARH	4	226	154	0.0	0.0	0.0
5	400 kV	RANCHI-SIPAT	2	453	0	6.5	0.0	6.5
6	220 kV	BUDHIPADAR-RAIGARH	1	58	88	0.0	0.4	-0.4
7	220 kV	BUDHIPADAR-KORBA	2	197	34	1.8	0.0	1.8
ER-WR						33.0	17.0	16.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	704	0.0	8.0	-8.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1680	0.0	31.5	-31.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2223	0.0	39.3	-39.3
4	400 kV	TALCHER-I/C	2	654	249	11.2	0.0	11.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	78.8	-78.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	354	177	1.6	0.5	1.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	571	340	2.8	0.0	2.8
3	220 kV	ALIPURDUAR-SALAKATI	2	121	61	0.7	0.0	0.7
ER-NER						5.2	0.5	4.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	654	0	13.1	0.0	13.1
NER-NR						13.1	0.0	13.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	6059	0.0	118.2	-118.2
2	HVDC	VINDHYACHAL B/B	-	492	0	10.3	0.0	10.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1661	0.0	42.4	-42.4
4	765 kV	GWALIOR-AGRA	2	0	2514	0.0	43.2	-43.2
5	765 kV	GWALIOR-PHAGI	2	571	1430	1.6	16.6	-15.0
6	765 kV	JABALPUR-ORAI	2	0	1161	0.0	36.6	-36.6
7	765 kV	GWALIOR-ORAI	1	635	0	10.5	0.0	10.5
8	765 kV	SATNA-ORAI	1	0	1212	0.0	23.8	-23.8
9	765 kV	BANASKANTHA-CHITORGARH	2	359	1036	1.0	6.9	-6.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	3523	0.0	72.1	-72.1
11	400 kV	ZERDA-KANKROLI	1	160	157	1.2	0.6	0.6
12	400 kV	ZERDA -BHINMAL	1	161	156	1.2	0.6	0.6
13	400 kV	VINDHYACHAL -RIHAND	1	976	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	273	464	1.6	3.4	-1.8
15	400 kV	NEEMUCH-Chittorgarh	2	397	413	2.7	2.6	0.1
16	220 kV	BHANPURA-RANPUR	1	0	133	0.0	2.6	-2.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.8	-2.8
18	220 kV	MEHGAON-AURAIYA	1	53	2	0.6	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	33	15	0.2	0.1	0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						52.6	372.3	-319.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	502	318	11.0	0.2	10.8
2	HVDC	RAIGARH-PUGALUR	2	0	2002	0.0	48.2	-48.2
3	765 kV	SOLAPUR-RAICHUR	2	1152	915	7.6	2.8	4.8
4	765 kV	WARDHA-NIZAMABAD	2	5	1664	0.0	20.7	-20.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	1800	0.0	24.2	-24.2
6	400 kV	KOLHAPUR-KUDGI	2	1162	0	17.6	0.0	17.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	76	1.6	0.0	1.6
9	220 kV	XELDEM-AMBEWADI	1	0	132	2.4	0.0	2.4
WR-SR						40.3	96.1	-55.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	254	-137	169	4.05
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	249	-11	63	1.50
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-169	-85	-124	-2.98
	NER	132kV GELEPHU-SALAKATI	22	-33	5	0.11
	NER	132kV MOTANGA-RANGIA	51	-4	17	0.41
NEPAL	NR	NEPAL IMPORT (FROM UP)	-71	0	-35	-0.84
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-71	0	-28	-0.67
	ER	NEPAL IMPORT (FROM BIHAR)	-304	0	-129	-3.09
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-378	-28	-154	-3.69
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-944	-652	-857	-20.56
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-771	-409	-626	-15.02
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-117	0	-95	-2.28

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 21-May-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.88	0.00	0.00	0.00	0.00	0.00	0.88
Nepal	0.35	0.00	4.28	0.00	0.00	0.00	0.00	0.00	4.63
Bangladesh	20.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.63
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.98	0.00	5.16	0.00	0.00	0.00	0.00	0.00	26.14

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.90
Nepal	0.00	0.00	0.00	0.00	0.00	0.33	0.00	0.00	0.33
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	2.90	0.00	0.00	0.00	0.00	0.33	0.00	0.00	3.23

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	2.90	0.00	-0.88	0.00	0.00	0.00	0.00	0.00	2.02	
Nepal	-0.35	0.00	-4.28	0.00	0.00	0.00	0.33	0.00	0.00	-4.30
Bangladesh	-20.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.63
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-18.08	0.00	-5.16	0.00	0.00	0.00	0.33	0.00	0.00	-22.91