



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 25.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 24.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 24-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 24.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 25-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	59205	66770	45975	23208	2797	197955
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1247	1586	1209	473	51	4566
Hydro Gen (MU)	90	42	84	23	10	249
Wind Gen (MU)	22	163	80	-	-	265
Solar Gen (MU)*	183.82	109.63	142.33	2.98	0.54	439
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66133	79254	61891	24373	2895	231215
Time Of Maximum Demand Met	10:13	09:52	09:39	18:19	17:42	09:53

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.00	0.00	2.73	2.73	80.81	16.46

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8617	0	158.0	70.1	0.2	776	0.00
	Haryana	8267	0	157.2	114.0	-0.9	384	0.00
	Rajasthan	17921	0	335.7	104.1	-4.9	626	0.00
	Delhi	4801	0	80.3	79.8	-1.3	376	0.00
	UP	20083	0	358.3	127.7	-2.4	423	0.00
	Uttarakhand	2438	0	43.6	34.5	-0.3	73	0.00
	HP	2160	0	39.3	33.4	-0.4	99	0.00
	J&K(UT) & Ladakh(UT)	3060	0	66.6	64.3	-1.3	984	0.00
	Chandigarh	283	0	4.3	4.3	0.1	21	0.00
WR	Railways_NR ISTS	203	0	3.9	3.8	0.1	35	0.00
	Chhattisgarh	5749	0	119.0	66.2	1.4	425	0.00
	Gujarat	23482	0	430.9	166.3	-2.8	628	0.00
	MP	18491	0	346.7	214.4	-3.3	521	0.00
	Maharashtra	29190	0	611.8	214.7	1.9	654	0.00
	Goa	718	0	14.0	13.9	-0.4	41	0.00
	DNHDDPDCL	1314	0	30.3	30.8	-0.5	47	0.00
	AMNSIL	735	0	16.6	7.1	0.1	250	0.00
	BALCO	533	0	12.7	12.7	0.0	15	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	11182	0	209.6	51.3	-1.0	511	0.00
	Telangana	14846	0	277.2	141.9	-1.3	846	0.00
	Karnataka	17164	0	296.0	90.3	-0.3	852	0.00
	Kerala	4367	0	86.5	69.8	0.4	437	0.00
	Tamil Nadu	16414	0	330.6	171.8	-2.8	600	0.00
	Puducherry	416	0	9.0	8.6	-0.1	63	0.00
ER	Bihar	5480	0	100.7	91.5	-2.8	221	0.00
	DVC	3232	0	69.4	-37.9	-1.5	268	0.00
	Jharkhand	2135	0	40.8	30.6	0.1	188	0.00
	Odisha	5103	0	98.1	27.4	-1.1	443	0.00
	West Bengal	7840	0	161.5	33.6	-1.7	344	0.00
	Sikkim	129	0	2.0	2.0	0.0	38	0.00
	Railways_ER ISTS	21	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	186	0	3.4	3.3	0.1	0	0.00
	Assam	1536	0	28.1	23.1	0.4	45	0.00
	Manipur	250	0	3.9	3.9	0.1	2	0.00
	Meghalaya	370	0	6.9	5.6	-0.1	22	0.00
	Mizoram	153	0	2.5	1.9	0.0	0	0.00
	Nagaland	150	0	2.5	2.4	0.0	0	0.00
	Tripura	235	0	4.1	3.5	-0.1	22	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-5.1	-10.7	-21.8	-12.4
Day Peak (MW)	-440.0	-628.5	-1007.0	-758.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	248.4	-274.5	154.3	-137.6	9.4	0.0
Actual(MU)	223.5	-260.0	148.8	-132.6	9.6	-10.7
O/D/U/D(MU)	-24.9	14.5	-5.5	5.0	0.3	-10.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5084	7999	6008	3856	673	23619	47
State Sector	7298	11176	4736	3119	222	26550	53
Total	12382	19174	10744	6975	894	50169	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	727	1573	639	666	13	3619	73
Lignite	27	13	51	0	0	92	2
Hydro	90	42	84	23	10	249	5
Nuclear	32	51	71	0	0	154	3
Gas, Naptha & Diesel	3	12	5	0	22	42	1
RES (Wind, Solar, Biomass & Others)	232	277	271	6	1	787	16
Total	1112	1968	1121	695	47	4942	100

Share of RES in total generation (%)	20.88	14.06	24.19	0.90	1.16	15.92
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.86	18.80	37.99	4.15	23.36	24.07

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.035

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	231215	9:53	0
Non-Solar hr	204667	18:50	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 25-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.3	-1.3
3	765 kV	GAYA-VARANASI	2	550	961	0.0	9.1	-9.1
4	765 kV	SASARAM-FATEHPUR	1	92	575	0.0	7.1	-7.1
5	765 kV	GAYA-BALIA	1	0	737	0.0	11.1	-11.1
6	400 kV	PUSAULI-VARANASI	1	0	102	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	56	38	0.1	0.0	0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	369	569	0.0	3.2	-3.2
9	400 kV	PATNA-BALIA	2	159	704	0.0	8.1	-8.1
10	400 kV	NAUBATPUR-BALIA	2	77	242	0.0	2.4	-2.4
11	400 kV	BIHARSHARIFF-BALIA	2	317	261	0.0	0.1	-0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	97	445	0.0	4.8	-4.8
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	119	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	48.9	-48.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	720	788	0.9	0.0	0.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	633	663	2.7	0.0	2.7
3	765 kV	JHARSUGUDA-DURG	2	0	1005	0.0	17.8	-17.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	660	0.0	10.1	-10.1
5	400 kV	RANCHI-SIPAT	2	150	256	0.0	0.6	-0.6
6	220 kV	BUDHIPADAR-RAIGARH	1	0	126	0.0	0.8	-0.8
7	220 kV	BUDHIPADAR-KORBA	2	123	68	1.2	0.0	1.2
ER-WR						4.7	29.3	-24.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	362	0.0	9.3	-9.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1246	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2649	0.0	48.2	-48.2
4	400 kV	TALCHER-I/C	2	183	484	1.0	0.0	1.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	87.6	-87.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	130	184	0.5	1.2	-0.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	239	371	0.0	0.5	-0.5
3	220 kV	ALIPURDUAR-SALAKATI	2	52	63	0.1	0.0	0.1
ER-NER						0.6	1.8	-1.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	367	0	9.1	0.0	9.1
NER-NR						9.1	0.0	9.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4037	0.0	74.8	-74.8
2	HVDC	VINDHYACHAL B/B	-	15	0	2.4	0.0	2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	187	2287	0.2	27.0	-26.8
5	765 kV	GWALIOR-PHAGI	2	561	1577	1.7	17.2	-15.5
6	765 kV	JABALPUR-ORAI	2	132	1120	0.0	23.2	-23.2
7	765 kV	GWALIOR-ORAI	1	1011	0	13.7	0.0	13.7
8	765 kV	SATNA-ORAI	1	0	1118	0.0	18.1	-18.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1250	725	6.4	7.3	-0.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	2856	0.0	44.5	-44.5
11	400 kV	ZERDA-KANKROLI	1	270	108	1.8	0.5	1.3
12	400 kV	ZERDA -BHINMAL	1	185	75	1.3	0.3	0.9
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	21.4	0.0	21.4
14	400 kV	RAPP-SHUJALPUR	2	695	258	5.5	1.0	4.5
15	400 kV	NEEMUCH-Chittorgarh	2	630	391	4.7	1.4	3.3
16	220 kV	BHANPURA-RANPUR	1	0	209	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	112	6	1.2	0.0	1.2
19	220 kV	MALANPUR-AURAIYA	1	78	23	0.6	0.1	0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						60.9	249.8	-188.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	209	0.0	3.6	-3.6
2	HVDC	RAIGARH-PUGALUR	2	0	2504	0.0	47.2	-47.2
3	765 kV	SOLAPUR-RAICHUR	2	1307	1443	6.6	8.3	-1.7
4	765 kV	WARDHA-NIZAMABAD	2	99	2533	0.0	34.9	-34.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2455	0.0	36.6	-36.6
6	400 kV	KOLHAPUR-KUDGI	2	1502	0	26.2	0.0	26.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	118	2.2	0.0	2.2
WR-SR						35.1	130.6	-95.5
INTERNATIONAL EXCHANGES								
State	Region		Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN	ER		400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	205	-3	70	1.69	
	ER		400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-291	105	-86	-2.07	
	ER		220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-238	-91	-177	-4.24	
	NER		132kV GELEPHU-SALAKATI	-34	0	-20	-0.48	
	NER		132kV MOTANGA-RANGIA	-12	0	0	0.00	
NEPAL	NR		NEPAL IMPORT (FROM UP)	-65	0	-65	-1.55	
	NR		132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-44	-1.06	
	ER		NEPAL IMPORT (FROM BIHAR)	-174	-36	-81	-1.95	
	ER		400kV DHALKEBAR-MUZAFFARPUR 1&2	-455	8	-255	-6.13	
BANGLADESH	ER		BHERAMARA B/B HVDC (B'DESH)	-936	-738	-855	-20.52	
	ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-758	-398	-516	-12.38	
	NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-71	0	-52	-1.24	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.30	6.56	0.00	0.00	0.05	0.00	0.00	6.91
Nepal	2.08	0.00	5.51	0.00	0.00	0.91	0.00	0.00	8.50
Bangladesh	21.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.33	0.30	12.07	0.00	0.00	0.96	0.00	0.00	36.66

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.35
Nepal	0.00	0.00	0.00	0.00	0.00	0.06	0.00	0.00	0.06
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.35	0.00	0.00	0.00	0.00	0.06	0.00	0.00	1.41

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.35	-0.30	-6.56	0.00	0.00	-0.05	0.00	0.00	-5.56
Nepal	-2.08	0.00	-5.51	0.00	0.00	-0.85	0.00	0.00	-8.44
Bangladesh	-21.25	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.25
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.98	-0.30	-12.07	0.00	0.00	-0.90	0.00	0.00	-35.25

Date of Reporting: 25-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	155758	6282	15420	4	5790	1682	127204	3275	140334	159657	-1648
0:15	50.02	156349	6294	15427	1	5795	1699	127587	3305	140921	160108	-1605
0:30	49.96	155616	6299	15320	3	6116	1696	126697	3276	140293	159407	-1652
0:45	50.01	154784	6274	15282	3	5829	1683	126216	3268	139499	158555	-1620
1:00	50.01	153718	6270	15342	1	5723	1690	125213	3278	138375	157517	-1628
1:15	49.96	152955	6286	15270	1	5424	1680	124729	3306	137684	156696	-1560
1:30	50.01	152019	6267	15189	0	5357	1697	123834	3291	136830	155635	-1494
1:45	50.02	151710	6273	15112	1	5304	1692	123755	3264	136597	155401	-1500
2:00	50.07	150666	6262	15036	0	5242	1683	122699	3295	135630	154217	-1514
2:15	50.01	150329	6298	15006	1	4972	1677	122722	3283	135322	153959	-1508
2:30	49.97	150517	6299	14885	1	5147	1694	122664	3288	135631	153978	-1484
2:45	50.02	150001	6294	14618	0	5150	1685	122415	3269	135383	153431	-1459
3:00	50.01	149838	6288	14380	1	5171	1694	122631	3280	135457	153445	-1496
3:15	50.02	149998	6292	14246	0	5106	1688	122794	3285	135752	153411	-1486
3:30	50.01	149575	6312	14009	1	5170	1671	122676	3314	135565	153153	-1509
3:45	49.96	149959	6296	13856	-2	5182	1684	123262	3271	136105	153549	-1537
4:00	50.06	150503	6295	13730	-3	5114	1692	124011	3311	136776	154150	-1561
4:15	49.96	152114	6296	13436	-2	5365	1680	125611	3328	138680	155714	-1462
4:30	49.96	154237	6293	13264	-3	5371	1683	127799	3283	140976	157690	-1484
4:45	50.01	155648	6287	13092	-2	5607	1694	129370	3269	142558	159317	-1496
5:00	50.01	157378	6286	12845	-2	5673	1696	131222	3296	144535	161016	-1537
5:15	49.91	161911	6306	12628	-2	6381	1691	135100	3282	149285	165386	-1487
5:30	49.96	165920	6314	12405	-2	6742	1675	138744	3310	153517	169188	-1536
5:45	49.86	170324	6308	12231	-3	7684	1678	142381	3313	158096	173592	-1504
6:00	50.06	174679	6120	12313	3	8202	1688	146498	3333	162363	178157	-1536
6:15	50.01	180452	6104	12247	30	9222	1666	151323	3303	168175	183895	-1548
6:30	50.01	187775	6097	12152	127	11298	1694	156317	3305	175496	190990	-1272
6:45	50.01	194508	6114	12156	136	14668	1736	159808	3322	182216	197940	-1235
7:00	49.96	200699	6116	12086	308	18012	1742	162249	3344	188305	203857	-1201
7:15	49.86	205874	6138	11876	944	21037	1820	163591	3353	193054	208759	-953
7:30	49.96	211070	6149	11828	2292	23209	1825	165265	3379	196950	213947	-913
7:45	50.01	214477	6161	11760	4388	23770	1799	165981	3353	198329	217212	-865
8:00	50.06	215481	6150	11441	7907	23197	1804	164255	3357	196133	218111	-894
8:15	50.06	219584	6166	10941	12377	22999	1809	164120	3479	196266	221891	-881
8:30	50.05	222252	6158	10426	17572	21716	1805	163661	3451	194254	224789	-1029
8:45	50.05	223728	6198	9881	23188	18886	1756	162971	3479	190659	226359	-1067
9:00	50.15	224973	5998	9267	28468	16866	1747	161318	3549	187238	227213	-1143
9:15	50.05	228812	6184	8465	33891	15362	1727	162333	3490	186456	231452	-1200
9:30	50.05	230350	6189	7735	38376	14478	1661	161233	3507	184239	233179	-1193
9:45	50.00	230966	6188	7089	42160	13217	1685	160410	3576	181717	234325	-1453
10:00	50.00	230623	6150	6677	45470	12034	1639	158575	3558	178476	234103	-1484
10:15	49.95	230464	6156	6380	48887	10897	1663	156513	3531	175197	234027	-1480
10:30	50.00	229916	6125	6432	51351	10150	1649	154359	3599	172133	233665	-1542
10:45	49.95	227987	6105	6501	53852	9119	1640	151042	3557	167634	231816	-1586
11:00	50.00	226672	6106	6542	55541	8546	1654	148622	3605	164589	230616	-1680
11:15	49.99	224493	6114	6873	57019	7818	1636	145729	3558	160601	228747	-1853
11:30	49.99	223800	6098	6937	58234	7033	1642	144638	3532	158629	228114	-2087
11:45	49.99	222800	6098	6916	59274	6862	1647	142904	3532	156610	227233	-2090
12:00	50.04	220892	6091	6768	59733	6748	1645	140591	3548	154391	225124	-2049
12:15	49.94	219326	6089	6716	60162	6146	1619	139251	3500	152448	223483	-2073
12:30	49.99	218140	6073	6719	60422	5671	1641	138280	3494	150999	222300	-2098
12:45	49.99	216583	6062	6645	60572	5755	1632	136567	3526	149366	220759	-2069
13:00	50.04	213633	6083	6587	60539	5818	1632	133398	3498	146507	217555	-2099
13:15	50.04	208988	6069	6627	60022	5115	1637	130134	3460	142339	213064	-2055
13:30	50.04	207440	6075	6619	59902	4832	1643	128968	3450	140919	211489	-2110
13:45	50.04	206475	6064	6585	59582	4750	1633	128386	3508	140308	210508	-2052
14:00	50.15	205784	6059	6712	58799	4364	1622	128693	3518	140273	209767	-2074
14:15	50.10	205149	6069	6796	57792	4409	1622	129115	3484	140561	209287	-1999
14:30	50.04	205989	6070	7017	56858	4575	1636	130043	3467	142114	209666	-1760
14:45	49.99	205526	6069	7230	54986	5079	1614	130826	3436	143310	209240	-1827
15:00	49.99	205287	6060	7446	52871	5206	1621	131524	3406	144970	208134	-1842
15:15	49.99	204434	6068	7546	50215	5460	1626	132939	3406	146673	207260	-1748
15:30	50.00	203684	6071	7543	47380	5805	1635	134666	3389	148761	206489	-1691
15:45	50.00	203292	6086	7659	44186	6515	1640	136679	3406	151447	206171	-1869
16:00	50.05	202607	6082	7735	40475	6838	1636	139208	3401	154397	205375	-1868
16:15	50.00	201015	6094	7818	36659	7010	1626	140799	3393	156538	203399	-1753
16:30	49.95	201388	6086	7914	31826	8512	1649	144472	3319	161648	203778	-1790
16:45	49.95	200429	6112	8019	26385	9485	1647	147249	3339	166025	202236	-1616
17:00	49.90	200062	6124	8198	20600	11549	1634	150632	3313	171264	202050	-1334
17:15	49.95	197950	6148	8204	14780	14007	1660	151298	3293	174966	199390	-1075
17:30	50.07	198884	6162	8203	9639	17714	1615	153734	3260	181042	200327	-1043
17:45	50.02	198993	6174	8318	5822	20085	1626	155535	3269	184853	200829	-1054
18:00	50.02	200536	6204	8452	6534	20816	1652	157987	3276	185550	204921	-1059
18:15	49.97	202722	6209	8686	927	21618	1738	161261	3279	193109	203718	-1015
18:30	50.02	203542	6187	9072	1067	22176	1760	162036	3259	193403	205557	-990
18:45	50.02	204396	6208	9422	148	22111	1754	162242	3229	194826	205114	-958
19:00	50.07	203724	6203	9967	131	21194	1648	161948	3258	193626	204349	-952
19:15	50.07	202597	6186	10397	63	19988	1658	161729	3268	192137	203289	-1001
19:30	50.02	199547	6181	10875	67	17768	1663	160424	3253	188605	200231	-996
19:45	49.97	195943	6162	11290	66	14997	1644	159279	3259	184587	196697	-985
20:00	50.02	192187	6139	11584	63	13765	1634	156514	3256	180540	192955	-969
20:15	49.92	188340	6129	11730	60	11668	1654	154653	3288	176550	189182	-1038
20:30	49.97	186836	6126	12104	54	11602	1631	152874	3272	174678	187663	-1028
20:45	49.97	184556	6145	12489	53	11029	1641	151057	3219	172014	185633	-1044
21:00	50.02	180695	6147	13037	14	9652	1629	148720	3211	167644	182410	-1098
21:15	50.02	178519	6138	13289	13	9035	1641	147668	3256	165217	181040	-1447
21:30	50.02	176396	6140	13468	18	8630	1641	146016	3204	162910	179117	-1604
21:45	50.02	173740	6152	13488	16	8031	1656	144035	3210	160236	176588	-1652
22:00	50.12	170859	6131	13497	18	7369	1662	141427	3260	157344	173364	-1660
22:15	49.92	171818	6141	13548	19	7510	1653	142184	3216	158251	174271	-1806
22:30	49.97	170563	6154	13375	19	7527	1665	141233				