



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 24.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 23.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 23-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 23.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 24-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57981	66437	50791	23990	2836	202035
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1113	1594	1265	502	53	4527
Hydro Gen (MU)	99	42	84	23	15	263
Wind Gen (MU)	26	95	74	-	-	195
Solar Gen (MU)*	214.76	165.03	162.06	3.19	1.00	546
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	59626	82925	64076	25337	2955	228472
Time Of Maximum Demand Met	18:55	10:11	09:28	09:23	17:51	09:35

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.037	0.00	0.43	5.59	6.02	78.80	15.18

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7159	0	121.3	49.7	-2.5	621	0.00
	Haryana	7663	0	138.3	94.1	-3.6	240	0.00
	Rajasthan	16008	0	298.2	97.0	-11.0	911	0.00
	Delhi	4987	0	88.2	81.1	-1.6	426	0.00
	UP	19183	0	358.2	79.9	-0.5	637	0.00
	Uttarakhand	2678	0	45.9	39.2	-0.7	222	0.00
	HP	1640	0	29.8	24.6	-1.9	80	0.00
	J&K(UT) & Ladakh(UT)	2265	0	24.1	32.4	-10.4	60	0.00
	Chandigarh	260	0	4.2	4.5	-0.3	13	0.00
	Railways_NR ISTS	200	0	4.3	3.8	0.5	43	0.00
WR	Chhattisgarh	5861	0	116.6	60.6	-0.1	341	0.00
	Gujarat	23847	0	441.7	200.3	-6.0	650	0.00
	MP	19708	0	350.0	223.2	0.0	669	0.00
	Maharashtra	29614	0	601.0	178.0	-13.2	1028	0.00
	Goa	723	0	14.1	12.1	1.9	44	0.00
	DNHDDPDCL	1366	0	31.7	31.4	0.3	59	0.00
	AMNSIL	823	0	18.9	12.8	0.3	289	0.00
	BALCO	603	0	14.4	14.5	-0.1	11	0.00
	RIL JAMNAGAR	249	0	5.6	5.7	-0.1	0	0.00
	Andhra Pradesh	12457	0	231.3	77.1	-1.2	670	0.00
SR	Telangana	16048	0	280.2	134.1	-0.7	678	0.00
	Karnataka	17303	0	315.9	103.3	-1.0	730	0.00
	Kerala	4510	0	83.7	65.9	0.7	406	0.00
	Tamil Nadu	17610	0	344.8	189.2	-4.0	1022	0.00
	Puducherry	403	0	8.8	8.3	-0.1	41	0.00
	Bihar	6330	0	113.5	91.1	1.1	459	0.00
ER	DVC	3291	0	72.3	-12.6	1.9	310	0.00
	Jharkhand	2181	0	40.8	30.8	-0.6	262	0.00
	Odisha	5652	0	110.5	21.1	-2.3	683	0.00
	West Bengal	7745	0	163.2	44.1	-3.6	254	0.00
	Sikkim	120	0	1.9	1.9	0.0	15	0.00
	Railways_ER ISTS	22	0	0.2	0.2	0.1	4	0.00
NER	Arunachal Pradesh	187	0	3.3	3.2	0.0	22	0.00
	Assam	1659	0	30.1	25.8	0.3	120	0.00
	Manipur	265	0	4.1	4.1	0.0	28	0.00
	Meghalaya	362	0	6.2	5.5	-0.1	64	0.00
	Mizoram	160	0	2.5	2.2	0.0	22	0.00
	Nagaland	174	0	2.6	2.5	0.0	10	0.00
	Tripura	238	0	4.0	6.1	-0.1	39	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-16.0	-8.9	-14.1	-17.5
Day Peak (MW)	-984.4	-663.0	-620.8	-773.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	105.0	-168.4	190.6	-139.6	12.4	0.0
Actual(MU)	76.8	-159.3	176.1	-119.5	11.4	-14.6
O/D/U/D(MU)	-28.2	9.1	-14.5	20.1	-1.0	-14.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6226	10630	5488	3344	469	26156	47
State Sector	10344	10160	5395	3509	205	29613	53
Total	16570	20790	10883	6853	674	55769	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	687	1482	695	683	11	3558	72
Lignite	20	21	41	0	0	83	2
Hydro	99	42	84	23	15	263	5
Nuclear	53	49	66	0	0	167	3
Gas, Naptha & Diesel	10	20	9	0	20	58	1
RES (Wind, Solar, Biomass & Others)	265	263	279	7	1	815	16
Total	1133	1877	1173	712	47	4943	100

Share of RES in total generation (%)	23.36	14.03	23.76	0.95	2.11	16.48
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.72	18.87	36.49	4.13	34.71	25.17

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.028
Based on State Max Demands	1.057

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	228472	9:35	0
Non-Solar hr	207564	18:51	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 24-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	782	1655	0.0	10.8	-10.8
4	765 kV	SASARAM-FATEHPUR	1	273	406	0.0	2.1	-2.1
5	765 kV	GAYA-BALIA	1	61	831	0.0	9.3	-9.3
6	400 kV	PUSAULI-VARANASI	1	7	150	0.0	1.5	-1.5
7	400 kV	PUSAULI-ALLAHABAD	1	57	166	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	606	694	0.0	1.3	-1.3
9	400 kV	PATNA-BALIA	2	140	1101	0.0	10.1	-10.1
10	400 kV	NAUBATPUR-BALIA	2	221	240	0.0	3.5	-3.5
11	400 kV	BIHARSHARIFF-BALIA	2	489	333	2.7	0.0	2.7
12	400 kV	MOTIHARI-GORAKHPUR	2	169	581	0.0	5.2	-5.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	249	561	0.0	3.3	-3.3
14	220 kV	SAHUPURI-KARAMNANA	1	19	56	0.0	2.0	-2.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	7	0.0	0.0	0.0
ER-NR						2.8	52.7	-49.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	550	1776	0.0	14.0	-14.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1054	802	5.4	0.0	5.4
3	765 kV	JHARSUGUDA-DURG	2	0	1343	0.0	18.9	-18.9
4	400 kV	JHARSUGUDA-RAIGARH	4	208	412	0.0	1.0	-1.0
5	400 kV	RANCHI-SIPAT	2	286	304	0.4	0.0	0.4
6	400 kV	JEYPORE-JAGDALPUR	2	417	262	2.9	0.0	2.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	113	0.0	1.3	-1.3
8	220 kV	BUDHIPADAR-KORBA	2	61	139	0.0	0.7	-0.7
ER-WR						8.7	35.9	-27.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	633	0.0	11.4	-11.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1623	0.0	35.7	-35.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	1878	0.0	30.1	-30.1
4	400 kV	TALCHER-I/C	2	152	1137	0.0	6.5	-6.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	77.2	-77.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOON	2	281	231	0.7	1.8	-1.1
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	501	323	2.0	0.0	2.0
3	220 kV	ALIPURDUAR-SALAKATI	2	70	72	0.0	0.0	0.0
ER-NER						2.7	1.8	0.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	569	0	14.4	0.0	14.4
NER-NR						14.4	0.0	14.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2577	0.0	26.8	-26.8
2	HVDC	VINDHYACHAL B/B	-	94	106	0.4	0.0	0.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1923	0.0	31.1	-31.1
4	765 kV	GWALIOR-AGRA	2	1825	2199	0.0	9.0	-9.0
5	765 kV	GWALIOR-PHAGI	2	778	1382	0.0	12.1	-12.1
6	765 kV	JABALPUR-ORAI	2	672	996	0.0	12.7	-12.7
7	765 kV	GWALIOR-ORAI	1	863	0	13.6	0.0	13.6
8	765 kV	SATNA-ORAI	1	108	1012	0.0	13.4	-13.4
9	765 kV	BANASKANTHA-CHITTOORGARH	2	2201	0	28.5	0.0	28.5
10	765 kV	VINDHYACHAL VARANASI	2	336	1744	0.0	23.2	-23.2
11	400 kV	ZERDA-KANKROLI	1	412	0	6.4	0.0	6.4
12	400 kV	ZERDA BHINMAL	1	284	0	4.4	0.0	4.4
13	400 kV	VINDHYACHAL -RIHAND	1	478	0	9.2	0.0	9.2
14	400 kV	RAAPP-SHUJALPUR	2	1323	287	11.8	0.8	11.0
15	400 kV	NEEMUCH-Chittorgarh	2	1201	524	7.1	0.0	7.1
16	220 kV	BHANPURA-RANPUR	1	0	116	0.0	1.9	-1.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	119	10	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	90	19	0.9	0.0	0.9
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						83.6	132.5	-48.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	19.0	-19.0
2	HVDC	RAIGARH-PUGALUR	2	0	6023	0.0	77.9	-77.9
3	765 kV	SOLAPUR-RAICHUR	2	1833	1487	9.4	7.0	2.4
4	765 kV	WARDHA-NIZAMABAD	2	696	2735	0.0	30.5	-30.5
5	765 kV	WARORA-WARANGAL(NEW)	2	119	3311	0.0	42.2	-42.2
6	400 kV	KOLHAPUR-KUDGI	2	1789	0	27.6	0.0	27.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.2	0.0	2.2
WR-SR						39.2	176.6	-137.4

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-294	42	-190	-4.56	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-319	176	-143	-3.43	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-295	-147	-251	-6.02	
	NER	132kV GELEPHU-SALAKATI	-66	-27	-53	-1.26	
	NER	132kV MOTANGA-RANGIA	-46	-13	-30	-0.71	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-68	0	-23	-0.55	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-43	-1.04	
	ER	NEPAL IMPORT (FROM BIHAR)	-162	-46	-116	-2.79	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-423	32	-187	-4.49	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-487	-483	-484	-11.61	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-774	-514	-728	-17.46	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-134	0	-102	-2.44	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 24-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	16.88	0.00	0.00	0.18	0.00	0.00	17.37
Nepal	3.08	1.75	1.37	0.00	0.00	2.45	0.00	0.00	8.65
Bangladesh	12.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	12.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	15.23	2.06	18.25	0.00	0.00	2.63	0.00	0.00	38.17

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	0.19	0.00	0.00	0.19
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	0.19	0.00	0.00	0.53

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	-0.31	-16.88	0.00	0.00	-0.18	0.00	0.00	-17.03
Nepal	-3.08	-1.75	-1.37	0.00	0.00	-2.26	0.00	0.00	-8.46
Bangladesh	-12.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-12.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-14.89	-2.06	-18.25	0.00	0.00	-2.44	0.00	0.00	-37.64

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K) (+ve) Import, (-ve) Export
0:00	49.98	156854	6073	11529	0	5281	2308	132400	3689	145325	161280	-1671
0:15	49.92	156657	6094	11415	0	4882	2315	132674	3684	145242	161064	-1706
0:30	50.02	156089	6081	9248	0	5263	2322	131655	3733	146841	158302	-1712
0:45	49.95	155414	6096	9373	0	5061	2327	130681	3663	146041	157201	-1691
1:00	49.99	154043	6098	9556	0	5026	2340	129588	3694	144487	156302	-1667
1:15	50.02	153405	6099	9509	0	5027	2339	129087	3792	143896	155853	-1662
1:30	49.97	152785	6103	9622	0	4687	2339	128202	3727	143163	154680	-1675
1:45	49.98	152298	6092	9471	0	4648	2349	127457	3758	142827	153775	-1626
2:00	49.99	150927	6100	11637	0	4231	2339	126956	3823	139290	155086	-1634
2:15	49.99	150817	6105	11596	0	4232	2335	127040	3831	139221	155139	-1633
2:30	50.03	150586	6101	11565	0	4454	2330	126723	3843	139021	155016	-1643
2:45	49.98	150587	6126	9758	0	4346	2371	126644	3866	140829	153111	-1629
3:00	50.00	150217	6114	11543	0	4407	2372	125960	3829	138674	154225	-1594
3:15	50.02	150407	6128	11719	0	4598	2357	125672	3842	138688	154316	-1544
3:30	50.02	150442	6135	10517	0	4850	2368	125267	3880	139925	153017	-1554
3:45	50.02	150621	6146	12350	0	4892	2374	125439	3851	138271	155052	-1526
4:00	50.07	150999	6149	11182	0	4862	2374	125510	3849	139817	153926	-1518
4:15	50.03	153168	6146	12884	0	5307	2339	126920	3889	140284	157485	-1523
4:30	50.01	154608	6143	12995	0	5292	2383	128246	3826	141613	158885	-1551
4:45	49.97	156521	6149	13147	0	5656	2405	129464	3848	143374	160669	-1557
5:00	50.06	158500	6118	11772	162	5627	2388	131213	3887	146566	161167	-1605
5:15	50.03	162114	6115	12779	159	5804	2385	135195	3827	149176	166264	-1690
5:30	50.09	165478	6124	12586	157	6042	2393	138952	3762	152735	170016	-1741
5:45	50.08	170629	6100	11511	152	6717	2396	142592	3834	158966	173302	-1690
6:00	50.12	174086	6106	12377	195	7687	2380	145950	3815	161514	178510	-1645
6:15	50.10	179791	6103	12226	202	9105	2315	150784	3746	167363	184481	-1826
6:30	50.07	185270	6126	12238	206	10674	2261	154586	3855	172826	189946	-1787
6:45	50.02	192096	6129	12247	251	13168	2303	158480	3853	179598	196431	-1289
7:00	50.11	197311	6129	11529	481	15895	2445	159499	3901	185301	199879	-864
7:15	50.07	203901	6107	12044	1189	18591	2616	163183	3951	190668	207681	-876
7:30	49.98	208343	6098	11745	2183	19782	2592	165131	3962	194415	211493	-806
7:45	49.97	211588	6076	11419	4870	20177	2581	165519	3917	195299	214559	-794
8:00	50.00	213434	6059	10983	9062	20292	2645	163781	3917	193389	216739	-816
8:15	50.04	216574	6067	10806	14960	20256	2525	161515	3882	190808	220011	-806
8:30	50.06	219253	6088	10076	22033	19518	2572	158209	3867	187144	222363	-828
8:45	50.10	221928	6097	9329	29513	18273	2471	155212	3845	183086	224740	-881
9:00	50.02	222665	6113	8671	37157	14536	2423	152621	3869	176837	225390	-924
9:15	49.98	225414	6125	8426	43849	14173	2356	149592	3802	173139	228323	-1008
9:30	49.99	228319	6127	8371	49989	13569	2284	147228	3853	169959	231421	-1435
9:45	49.93	227780	6139	8282	54806	12169	2276	144063	3863	164692	231598	-1735
10:00	49.99	226177	6168	8066	59365	11225	2269	139078	3839	158746	230010	-2023
10:15	49.96	227036	6172	7856	64236	9859	2312	136599	3866	154944	230900	-2093
10:30	49.98	227359	6171	7545	67915	9812	2303	133560	3819	151899	231125	-2079
10:45	49.98	224528	6178	7034	69641	8908	2340	130556	3814	147853	228471	-2100
11:00	49.98	221691	6188	6691	71389	8056	2357	127748	3764	143611	226193	-2097
11:15	49.94	220869	6205	6188	72998	7081	2298	125829	3859	141683	224458	-2113
11:30	49.91	218373	6212	5780	72789	7034	2294	124255	3760	139804	222124	-2085
11:45	49.88	216920	6219	5379	73746	6880	2306	122927	3784	137795	221241	-2061
12:00	50.02	214652	6240	4919	75417	7039	2297	119392	3745	134316	219049	-2057
12:15	49.96	212599	6243	4405	74916	6857	2290	118290	3753	133278	216754	-2074
12:30	49.91	212052	6258	3880	74860	6730	2354	118192	3752	133312	216026	-2041
12:45	49.87	210533	6257	1970	74250	6960	2326	118289	3752	134313	213804	-1970
13:00	50.00	208247	6267	3356	73125	6933	2296	116980	3738	131766	212695	-2012
13:15	49.98	204927	6269	3195	71291	6398	2319	115624	3693	130441	208789	-2051
13:30	50.04	203064	6264	3084	72744	6248	2326	112815	3686	127236	207167	-2022
13:45	49.97	202543	6267	2947	72447	6215	2306	112802	3706	127149	206690	-2029
14:00	50.09	201629	6239	2849	72416	6047	2308	112141	3671	126364	205671	-2040
14:15	49.97	201368	6243	2812	72448	5806	2320	112345	3680	126108	205654	-2022
14:30	49.98	202674	6233	2933	71404	5979	2313	114243	3715	128337	206820	-2038
14:45	50.04	203455	6211	3025	69725	6207	2341	116076	3666	130705	207251	-1993
15:00	50.08	202643	6199	3157	67027	6528	2347	117834	3704	132459	206796	-2011
15:15	50.12	202108	6233	3213	64426	6486	2336	119867	3763	134469	206324	-1996
15:30	50.03	202805	6217	3375	61023	6818	2312	123788	3736	138407	207269	-2038
15:45	49.99	202767	5817	3456	57078	7435	2313	127025	3711	142233	206835	-2040
16:00	50.02	203649	5815	3608	52711	7623	2328	131695	3655	147330	207435	-2031
16:15	49.94	201849	5856	3622	47224	8149	2332	134467	3673	151003	205323	-2040
16:30	50.04	202291	5854	3559	42041	9814	2352	138742	3688	156691	206050	-2070
16:45	49.88	202472	6123	3525	35044	11360	2333	143918	3718	163903	206021	-2013
17:00	50.06	202109	6084	3401	27889	14047	2329	148056	3778	170819	205584	-1826
17:15	49.88	199944	6025	3303	20318	15699	2394	151382	3752	176323	202873	-1276
17:30	49.98	201634	6018	3289	13408	18115	2556	158243	3759	184937	205388	-848
17:45	49.98	204413	5985	3347	7739	19106	2572	164633	3780	193327	207162	-888
18:00	50.00	205195	5957	3513	3875	20063	2641	167886	3716	197807	207651	-822
18:15	49.89	204515	5951	3725	1708	20575	2778	168774	3718	199082	207229	-749
18:30	50.06	206588	5963	3910	1139	21050	2665	170893	3695	201539	209315	-769
18:45	50.04	207179	5975	4176	570	21400	2645	170999	3744	202433	209509	-724
19:00	50.03	205865	5994	4604	538	20595	2651	170765	3775	200723	208922	-723
19:15	50.05	203117	5989	4971	185	18898	2684	169315	3779	197961	205821	-750
19:30	49.99	201119	6001	5480	0	17627	2633	168086	3788	195639	203615	-757
19:45	50.03	198515	6007	5896	0	16898	2520	166266	3790	192619	201377	-737
20:00	50.05	194774	6015	6198	0	15741	2442	163310	3746	188576	197452	-765
20:15	50.01	191720	6030	6698	0	14535	2376	161677	3749	185022	195065	-1216
20:30	50.01	190214	6052	7038	0	14451	2360	159154	3749	183176	192804	-1412
20:45	49.96	187653	6057	7154	0	13599	2374	157420	3738	180499	190342	-1482
21:00	49.93	184166	6058	6887	0	12608	2348	155293	3750	177279	186944	-1456
21:15	49.96	181111	6068	6767	0	12233	2279	153298	3719	174344	184364	-1443
21:30	49.98	178458	6079	6739	0	11702	2280	151416	3709	171719	181925	-1421
21:45	50.05	175365	6079	6857	0	10566	2288	149230	3695	168508	178715	-1417
22:00	50.05	172038	6083	6686	0	9807	2280	146940	3704	165352	175500	-1411
22:15	49.97	171169	6078	6843	0	9979	2288	145785	3695	164326	174668	-1545
22:30	50.03	169164	6048	6745	0	9800	2287	144260	3729	162419	17286	