



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 14.08.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 13.08.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 13-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 13.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 14-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	79600	63844	45066	28487	3258	220255
Peak Shortage (MW)	80	0	0	0	0	80
Energy Met (MU)	1769	1554	1045	633	61	5062
Hydro Gen (MU)	424	110	178	101	46	858
Wind Gen (MU)	23	115	230	-	-	368
Solar Gen (MU)*	170.39	93.64	79.75	2.59	0.32	347
Energy Shortage (MU)	0.62	0.00	0.00	0.00	0.00	0.62
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	80497	69720	49078	30836	3355	221879
Time Of Maximum Demand Met	21:21	09:56	09:26	00:01	18:41	19:30

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.00	0.69	7.27	7.96	82.58	9.45

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15368	0	312.7	207.6	0.1	764	0.00
	Haryana	12115	0	257.5	194.3	-0.4	345	0.00
	Rajasthan	17475	0	377.9	166.8	1.8	708	0.00
	Delhi	6760	0	137.4	123.1	-0.9	265	0.00
	UP	27045	0	536.2	236.7	-1.4	373	0.00
	Uttarakhand	2365	0	48.7	26.9	0.7	188	0.62
	HP	1725	0	36.1	-9.6	-0.3	122	0.00
	J&K(UT) & Ladakh(UT)	2584	0	51.4	26.5	0.7	308	0.00
	Chandigarh	345	0	6.5	6.8	-0.3	29	0.00
	Railways NR ISTS	201	0	4.2	3.8	0.4	37	0.00
WR	Chhattisgarh	6338	0	138.1	94.6	-1.7	233	0.00
	Gujarat	23688	0	493.5	204.2	0.2	777	0.00
	MP	12625	0	272.2	138.1	-0.8	513	0.00
	Maharashtra	25617	0	567.4	226.6	-1.8	760	0.00
	Goa	616	0	14.6	11.9	2.3	37	0.00
	DNHDDPDCL	1358	0	31.6	31.6	0.0	56	0.00
	AMNSIL	811	0	18.3	11.8	0.0	272	0.00
	BALCO	532	0	12.7	12.7	0.0	21	0.00
	RIL JAMNAGAR	249	0	5.6	5.7	-0.1	0	0.00
	Andhra Pradesh	9163	0	197.7	18.6	-2.4	413	0.00
SR	Telangana	10596	0	207.5	66.7	-2.0	588	0.00
	Karnataka	10773	0	204.4	24.5	-1.9	358	0.00
	Kerala	4012	0	80.9	40.4	-1.4	206	0.00
	Tamil Nadu	16365	0	344.3	112.2	0.1	1381	0.00
	Puducherry	446	0	9.8	9.1	0.1	69	0.00
	Bihar	7767	0	138.7	131.3	-1.3	374	0.00
ER	DVC	3186	0	69.2	-39.4	-0.9	388	0.00
	Jharkhand	2154	0	45.0	36.2	0.4	323	0.00
	Odisha	6910	0	147.2	53.1	-3.3	576	0.00
	West Bengal	11195	0	231.8	107.4	-3.1	289	0.00
	Sikkim	79	0	1.3	1.3	0.0	15	0.00
	Railways ER ISTS	24	0	0.1	0.2	0.0	4	0.00
NER	Arunachal Pradesh	202	0	3.5	3.5	-0.6	3	0.00
	Assam	2080	0	38.7	33.0	0.0	335	0.00
	Manipur	215	0	3.1	3.2	-0.1	49	0.00
	Meghalaya	342	0	5.9	1.0	-0.2	34	0.00
	Mizoram	179	0	1.8	0.9	-0.6	40	0.00
	Nagaland	157	0	2.2	2.3	-0.6	16	0.00
	Tripura	306	0	5.9	4.5	-0.1	47	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	53.5	18.2	-24.1	-29.5
Day Peak (MW)	2415.0	841.7	-1018.4	-1461.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	404.1	-191.6	-102.2	-99.6	-10.7	0.0
Actual(MU)	393.3	-175.8	-109.0	-107.1	-11.2	-9.9
O/D/U/D(MU)	-10.8	15.8	-6.8	-7.5	-0.6	-9.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	8794	11983	7752	3670	452	32651	54
State Sector	7459	10429	6623	3012	199	27721	46
Total	16253	22411	14375	6682	651	60372	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	763	1436	612	702	12	3526	65
Lignite	24	13	39	0	0	76	1
Hydro	424	110	178	101	46	858	16
Nuclear	40	49	47	0	0	136	3
Gas, Naptha & Diesel	16	38	7	0	20	81	1
RES (Wind, Solar, Biomass & Others)	200	210	336	5	0	751	14
Total	1468	1856	1218	808	79	5429	100

Share of RES in total generation (%)	13.64	11.29	27.60	0.63	0.41	13.84
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	45.28	19.84	46.02	13.13	59.16	32.16

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.052
Based on State Max Demands	1.099

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	220580	15:34	140
Non-Solar hr	221879	19:30	130

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 14-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	751	0.0	17.4	-17.4
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	53	1049	0.0	12.2	-12.2
4	765 kV	SASARAM-FATEHPUR	1	0	567	0.0	7.2	-7.2
5	765 kV	GAYA-BALIA	1	0	1190	0.0	14.3	-14.3
6	400 kV	PUSAULI-VARANASI	1	12	84	0.0	1.0	-1.0
7	400 kV	PUSAULI-ALLAHABAD	1	0	110	0.0	1.4	-1.4
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	948	0.0	15.2	-15.2
9	400 kV	PATNA-BALIA	2	0	937	0.0	12.1	-12.1
10	400 kV	NAUBATPUR-BALIA	2	0	376	0.0	3.8	-3.8
11	400 kV	BIHARSHARIFF-BALIA	2	120	340	0.0	2.6	-2.6
12	400 kV	MOTIHARI-GORAKHPUR	2	13	550	0.0	9.1	-9.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	468	0.0	5.5	-5.5
14	220 kV	SAHUPURI-KARAMNESA	1	5	64	0.0	1.7	-1.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	0.6	-105.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	406	1080	0.0	3.3	-3.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1629	265	24.6	0.0	24.6
3	765 kV	JHARSUGUDA-DURG	2	0	577	0.0	5.9	-5.9
4	400 kV	JHARSUGUDA-RAIGARH	4	315	280	0.0	1.1	-1.1
5	400 kV	RANCHI-SIPAT	2	303	205	3.4	0.0	3.4
6	400 kV	JEYPORE-JAGDALPUR	2	0	697	0.0	9.4	-9.4
7	220 kV	BUDHIPADAR-RAIGARH	1	27	100	0.0	1.1	-1.1
8	220 kV	BUDHIPADAR-KORBA	2	12	139	0.0	1.1	-1.1
						ER-WR	28.0	6.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	652	0	12.5	0.0	12.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1760	0.0	41.7	-41.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	1950	0.0	25.0	-25.0
4	400 kV	TALCHER-I/C	2	672	872	0.0	0.7	-0.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	12.5	-54.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	221	120	2.4	0.0	2.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	181	291	0.3	0.0	0.3
3	220 kV	ALIPURDUAR-SALAKATI	2	42	67	0.0	0.0	0.0
						ER-NER	2.7	0.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	503	0.0	8.6	-8.6
						NER-NR	0.0	-8.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4037	0.0	71.9	-71.9
2	HVDC	VINDHYACHAL-B/B	-	0	401	0.0	4.1	-4.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2003	0.0	37.2	-37.2
4	765 kV	GWALIOR-AGRA	2	0	2843	0.0	36.5	-36.5
5	765 kV	GWALIOR-PHAGI	2	195	2508	0.2	31.1	-31.0
6	765 kV	JABALPUR-ORAI	2	0	1520	0.0	46.1	-46.1
7	765 kV	GWALIOR-ORAI	1	1017	0	15.9	0.0	15.9
8	765 kV	SATNA-ORAI	1	0	1372	0.0	22.0	-22.0
9	765 kV	BANASKANTHA-CHITORGARH	2	1583	557	12.9	0.6	12.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	3450	0.0	52.5	-52.5
11	400 kV	ZERDA-KANKROLI	1	274	117	2.6	0.2	2.4
12	400 kV	ZERDA-BHINMAL	1	189	81	1.8	0.1	1.7
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	345	863	1.2	6.7	-5.6
15	400 kV	NEEMUCH-Chittorgarh	2	207	1004	0.4	9.0	-8.6
16	220 kV	BHANPURA-RANPUR	1	0	146	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.9	-2.9
18	220 kV	MEHGAON-AURAIYA	1	87	38	0.3	0.1	0.3
19	220 kV	MALANPUR-AURAIYA	1	62	52	0.2	0.0	0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	35.5	-288.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	998	0	20.7	0.0	20.7
2	HVDC	RAIGARH-PUGAULUR	2	1442	302	0.0	3.7	-3.7
3	765 kV	SOLAPUR-RAICHUR	2	1317	0	46.3	0.0	46.3
4	765 kV	WARDHAN-NIZAMABAD	2	1489	1051	10.5	4.2	6.3
5	765 kV	WARORA-WARANGAL(NEW)	2	1334	1002	8.4	4.9	3.5
6	400 kV	KOLHAPUR-KUDGI	2	2326	0	44.0	0.0	44.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	114	2.2	0.0	2.2
						WR-SR	131.9	119.1

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1457	1087	1276	30.63	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	889	822	863	20.71	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	121	44	86	2.07	
	NER	132kV GELEPHU-SALAKATI	30	0	7	0.17	
	NER	132kV MOTANGA-RANGIA	-13	11	-5	-0.12	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-18	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	64	0	25	0.59	
	ER	NEPAL IMPORT (FROM BIHAR)	144	73	124	2.97	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	686	582	608	14.60	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-970	-941	-963	-23.10	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1462	-1040	-1230	-29.51	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-50	0	-42	-1.00	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 14-Aug-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.28	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.28
Bangladesh	23.81	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.94
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.09	0.13	0.00	0.00	0.00	0.00	0.00	0.00	24.22

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.37	0.00	1.88	0.00	0.00	0.13	0.00	0.00	55.38
Nepal	8.40	1.30	7.50	0.00	0.00	1.30	0.00	0.00	18.50
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	61.77	1.30	9.38	0.00	0.00	1.43	0.00	0.00	73.88

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.37	0.00	1.88	0.00	0.00	0.13	0.00	0.00	55.38
Nepal	8.12	1.30	7.50	0.00	0.00	1.30	0.00	0.00	18.22
Bangladesh	-23.81	-0.13	0.00	0.00	0.00	0.00	0.00	0.00	-23.94
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	37.68	1.17	9.38	0.00	0.00	1.43	0.00	0.00	49.66

