



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 20.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 19.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 19-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 19.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 20-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58866	64263	44427	21281	2717	191554
Peak Shortage (MW)	168	0	30	0	0	198
Energy Met (MU)	1265	1518	1121	431	48	4383
Hydro Gen (MU)	114	57	99	19	14	301
Wind Gen (MU)	25	79	17	-	-	120
Solar Gen (MU)*	149.39	89.04	101.78	2.42	1.07	344
Energy Shortage (MU)	2.19	0.00	0.12	0.00	0.00	2.31
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67207	76488	54961	21860	2794	219721
Time Of Maximum Demand Met	10:28	09:48	09:24	18:00	18:39	10:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.035	0.00	0.31	4.14	4.46	78.37	17.17

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9222	0	164.4	66.7	-0.5	322	0.00
	Haryana	9192	0	168.3	111.9	-1.9	835	0.00
	Rajasthan	18405	0	338.2	104.4	-1.7	804	0.00
	Delhi	4622	0	80.9	76.9	-0.3	366	0.00
	UP	19431	0	354.9	113.7	-0.8	338	0.00
	Uttarakhand	2471	0	45.6	35.0	0.4	93	0.00
	HP	2201	0	40.5	33.4	-0.3	159	0.00
	J&K(UT) & Ladakh(UT)	3062	0	63.5	57.2	1.4	717	2.19
	Chandigarh	258	0	4.5	4.3	0.2	62	0.00
WR	Railways_NR ISTS	209	0	4.0	3.7	0.3	41	0.00
	Chhattisgarh	5036	0	102.6	40.5	1.1	275	0.00
	Gujarat	22309	0	418.8	198.3	0.4	654	0.00
	MP	18725	0	346.6	214.2	-4.2	306	0.00
	Maharashtra	28273	0	575.8	214.2	0.5	687	0.00
	Goa	612	0	12.4	12.0	-0.1	51	0.00
	DNHDDPDCL	1303	0	30.0	29.7	0.3	185	0.00
	AMNSIL	759	0	16.6	8.6	0.2	279	0.00
	BALCO	530	0	12.6	12.7	-0.1	11	0.00
SR	RIL JAMNAGAR	100	0	2.4	2.3	0.1	0	0.00
	Andhra Pradesh	9853	0	193.0	57.3	0.4	451	0.00
	Telangana	13689	0	261.9	153.7	0.2	1091	0.00
	Karnataka	14958	0	261.7	73.2	2.4	799	0.00
	Kerala	4384	0	84.1	60.8	1.9	421	0.00
	Tamil Nadu	15801	0	311.9	187.9	4.0	1608	0.00
	Puducherry	424	0	8.7	8.6	0.1	45	0.12
ER	Bihar	4923	0	90.9	79.2	-0.5	178	0.00
	DVC	3194	0	68.8	-46.0	0.0	342	0.00
	Jharkhand	2033	0	38.1	28.0	-1.5	108	0.00
	Odisha	4669	0	88.3	15.9	-1.0	471	0.00
	West Bengal	7106	0	142.7	6.5	-2.0	119	0.00
	Sikkim	118	0	2.0	1.8	0.3	62	0.00
	Railways_ER ISTS	16	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	180	0	2.5	2.8	-0.4	46	0.00
	Assam	1565	0	27.0	19.5	0.5	134	0.00
	Manipur	236	0	3.7	3.7	0.0	39	0.00
	Meghalaya	378	0	6.5	5.4	-0.1	160	0.00
	Mizoram	142	0	2.1	1.7	-0.1	15	0.00
	Nagaland	166	0	2.5	2.4	0.0	32	0.00
	Tripura	229	0	4.2	3.4	0.1	34	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.5	-4.6	-21.8	-13.1
Day Peak (MW)	-371.8	-300.0	-982.0	-766.9

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	222.8	-247.7	202.6	-181.5	3.9	0.0
Actual(MU)	214.5	-274.3	228.8	-183.4	2.6	-11.8
O/D/U/D(MU)	-8.4	-26.5	26.2	-1.8	-1.3	-11.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5414	6260	8428	5023	268	25393	47
State Sector	6508	12814	7574	1869	191	28955	53
Total	11922	19074	16002	6892	459	54348	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	750	1574	609	674	11	3619	76
Lignite	32	13	36	0	0	80	2
Hydro	114	57	99	19	14	301	6
Nuclear	32	64	70	0	0	166	3
Gas, Naptha & Diesel	10	35	5	0	25	75	2
RES (Wind, Solar, Biomass & Others)	200	172	147	5	1	526	11
Total	1137	1915	966	699	50	4767	100

Share of RES in total generation (%)	17.61	8.98	15.24	0.78	2.16	11.03
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.39	15.29	32.72	3.46	29.23	20.84

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.050

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	219721	10:00	143
Non-Solar hr	200832	18:22	148

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 20-Dec-2024								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	249	0.0	6.1	-6.1
3	765 kV	GAYA-VARANASI	2	0	908	0.0	14.6	-14.6
4	765 kV	SASARAM-FATEHPUR	1	0	523	0.0	9.0	-9.0
5	765 kV	GAYA-BALIA	1	0	685	0.0	11.1	-11.1
6	400 kV	PUSAULI-VARANASI	1	0	180	0.0	3.6	-3.6
7	400 kV	PUSAULI -ALLAHABAD	1	0	120	0.0	2.3	-2.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	739	0.0	9.2	-9.2
9	400 kV	PATNA-BALIA	2	0	828	0.0	14.6	-14.6
10	400 kV	NAUBATPUR-BALIA	2	0	469	0.0	4.6	-4.6
11	400 kV	BIHARSHARIFF-BALIA	2	0	238	0.0	4.5	-4.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	571	0.0	9.4	-9.4
13	400 kV	BIHARSHARIFF-VARANASI	2	0	366	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	63	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	89.8	-89.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	138	1023	0.0	14.2	-14.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	329	1076	0.0	8.4	-8.4
3	765 kV	JHARSUGUDA-DURG	2	0	755	0.0	14.0	-14.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	747	0.0	10.7	-10.7
5	400 kV	RANCHI-SIPAT	2	0	2	0.0	0.0	0.0
6	220 kV	BUDHIPADAR-RAIGARH	1	0	132	0.0	1.9	-1.9
7	220 kV	BUDHIPADAR-KORBA	2	85	82	0.2	0.0	0.2
ER-WR						0.2	49.2	-49.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	532	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1643	0.0	34.3	-34.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2978	0.0	55.2	-55.2
4	400 kV	TALCHER-I/C	2	586	0	8.8	0.0	8.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	102.1	-102.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	303	0	3.8	0.0	3.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	535	0	7.9	0.0	7.9
3	220 kV	ALIPURDUAR-SALAKATI	2	95	0	1.5	0.0	1.5
ER-NER						13.2	0.0	13.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	666	0	16.4	0.0	16.4
NER-NR						16.4	0.0	16.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2512	0.0	50.0	-50.0
2	HVDC	VINDHYACHAL B/B	-	0	55	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1918	0.0	39.6	-39.6
4	765 kV	GWALIOR-AGRA	2	86	1855	0.0	21.6	-21.6
5	765 kV	GWALIOR-PHAGI	2	0	1541	0.0	20.8	-20.8
6	765 kV	JABALPUR-ORAI	2	0	919	0.0	22.7	-22.7
7	765 kV	GWALIOR-ORAI	1	821	0	14.5	0.0	14.5
8	765 kV	SATNA-ORAI	1	0	1010	0.0	19.5	-19.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1782	647	14.6	2.1	12.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2281	0.0	32.9	-32.9
11	400 kV	ZERDA-KANKROLI	1	343	70	3.2	0.1	3.1
12	400 kV	ZERDA -BHINMAL	1	237	49	2.2	0.1	2.2
13	400 kV	VINDHYACHAL -RIHAND	1	970	0	21.5	0.0	21.5
14	400 kV	RAPP-SHUJALPUR	2	565	213	4.1	0.6	3.6
15	400 kV	NEEMUCH-Chittorgarh	2	583	219	4.2	0.5	3.7
16	220 kV	BHANPURA-RANPUR	1	0	196	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	177	0	1.8	0.0	1.8
19	220 kV	MALANPUR-AURAIYA	1	117	7	0.6	0.0	0.6
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						66.7	216.8	-150.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1003	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	3506	0.0	74.3	-74.3
3	765 kV	SOLAPUR-RAICHUR	2	666	1938	1.3	12.7	-11.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2707	0.0	38.1	-38.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2808	0.0	42.8	-42.8
6	400 kV	KOLHAPUR-KUDGI	2	1292	0	15.4	0.0	15.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	114	2.1	0.0	2.1
WR-SR						18.8	191.9	-173.1
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	196	-131	-20	-0.48		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-186	183	-31	-0.75		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-249	-145	-198	-4.76		
	NER	132kV GELEPHU-SALAKATI	-27	-15	-22	-0.54		
	NER	132kV MOTANGA-RANGIA	8	-6	1	0.03		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-64	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-64	0	-40	-0.96		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-300	-8	-152	-3.66		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-922	-634	-857	-20.57		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-767	-400	-547	-13.13		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-60	0	-51	-1.23		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 20-Dec-2024

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	7.78	0.00	0.00	0.00	0.00	0.00	7.78	
Nepal	0.38	0.00	2.37	0.00	0.00	0.00	1.36	0.00	0.00	4.11
Bangladesh	21.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.71	0.00	10.15	0.00	0.00	0.00	1.36	0.00	0.00	33.22

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.61
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.61	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.61

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.61	0.00	-7.78	0.00	0.00	0.00	0.00	0.00	-7.17
Nepal	-0.38	0.00	-2.37	0.00	0.00	-1.36	0.00	0.00	-4.11
Bangladesh	-21.33	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.33
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.10	0.00	-10.15	0.00	0.00	-1.36	0.00	0.00	-32.61

Date of Reporting: 20-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	148458	6625	8762	11	7024	2126	127630	2838	139685	155016	-1624
0:15	49.97	147973	6639	8667	10	6685	2134	127674	2858	139296	154667	-1599
0:30	49.97	147171	6625	8520	10	6936	2131	126771	2889	138641	153882	-1567
0:45	49.87	145990	5980	8376	9	7089	2102	125766	2873	137605	152195	-1465
1:00	49.92	145489	5951	8266	9	7095	2306	125474	2912	137214	152013	-1401
1:15	49.87	144661	5957	8136	8	6893	2135	124868	2947	136517	150944	-1419
1:30	49.92	143608	5958	7871	7	6968	2156	124312	2934	135730	150206	-1445
1:45	49.92	143327	5953	7622	8	6961	2154	124396	2898	135697	149992	-1448
2:00	50.02	142691	5967	7465	7	6619	2121	123949	2893	135219	149021	-1436
2:15	50.02	142283	5962	7381	7	6284	2133	124105	2957	134895	148829	-1426
2:30	50.03	142117	5969	7375	7	6090	2121	124085	2941	134735	148588	-1398
2:45	50.03	141865	5965	7278	9	6031	2136	124024	2961	134578	148404	-1320
3:00	50.08	141662	6283	7145	8	6003	2128	123732	2932	134509	148231	-1334
3:15	50.03	141556	6418	7006	8	5959	2126	123791	2966	134542	148274	-1310
3:30	50.08	141907	6444	6976	8	6126	2137	123875	2981	134923	148547	-1333
3:45	50.03	142517	6447	6856	9	6419	2141	124479	2864	135652	149215	-1355
4:00	50.08	142733	6460	6794	9	6533	2354	124560	2919	135930	149629	-1355
4:15	50.03	144652	6467	6701	9	6679	2163	126359	2916	137942	151294	-1362
4:30	50.08	146503	6471	6532	7	6992	2183	128330	2904	139964	153419	-1334
4:45	49.98	148287	6483	6425	8	7102	2189	129955	2972	141854	155134	-1376
5:00	50.03	151504	6474	6326	8	7342	2214	133080	2903	145170	158347	-1434
5:15	50.03	155888	6486	6151	9	8465	2304	136313	2897	149728	162625	-1455
5:30	50.03	159661	6484	6128	9	9167	2399	139063	2933	153524	166183	-1314
5:45	50.03	164511	6473	6123	9	10597	2674	141849	2920	158379	170645	-1131
6:00	50.13	168867	6487	6073	-1	12418	3315	143709	2899	162795	174900	-1231
6:15	50.03	174028	6484	6111	233	13986	4128	146807	2921	167684	180670	-1288
6:30	50.08	181452	6469	5928	273	16877	4227	151414	2918	175251	188106	-1273
6:45	49.98	187958	6478	5867	319	19836	4580	154957	2928	181772	194965	-1365
7:00	50.03	193629	6483	5844	607	22651	4573	157263	2990	187178	200411	-1461
7:15	49.93	197866	6489	5709	1308	25172	4338	158600	2932	190849	204548	-1460
7:30	49.88	200756	6487	5624	2511	25744	4608	159205	3058	192621	207237	-1354
7:45	49.98	203327	6478	5586	4719	25816	4399	159226	3062	193022	209286	-1299
8:00	50.08	204130	6508	5734	7621	24426	4645	157997	2971	190775	209902	-1283
8:15	49.98	206954	6501	5675	11432	22368	4530	159104	3012	189847	212622	-1274
8:30	50.03	209282	6497	5372	15647	20419	4478	159376	3125	188263	214914	-1279
8:45	50.03	212236	6541	5140	20452	19321	4464	158241	3122	186644	217281	-1264
9:00	50.18	212948	6538	4930	25123	17287	4429	156408	3095	182895	217810	-1275
9:15	50.03	216749	6531	4616	29394	15727	4476	157969	3108	182739	221821	-1284
9:30	50.03	218277	6514	4217	33426	13976	4206	157632	3109	180634	223080	-1055
9:45	49.98	219376	6509	3830	36685	12095	3611	158057	3110	178861	223897	-1064
10:00	49.98	219721	6521	3521	39950	10842	2699	157483	3131	176250	224147	-1161
10:15	50.03	218584	6452	3275	42642	9608	2321	156122	3056	172667	223476	-1184
10:30	50.04	219024	6505	3005	44828	9476	2176	154850	3100	171191	223940	-1214
10:45	49.99	218349	6537	2934	46517	9478	2216	152355	3153	168898	223190	-1384
11:00	49.99	217466	6544	2881	47972	9489	2191	148646	3052	166613	220775	-1529
11:15	49.99	215529	6528	2915	49079	8549	2187	149207	3080	163535	221545	-1840
11:30	50.04	214270	6533	3007	49937	8212	2182	147356	3082	161326	220309	-1837
11:45	49.99	212932	6531	2997	50080	8091	2182	146712	3071	159855	219664	-1866
12:00	50.04	210752	6535	3088	50556	7419	2210	144553	2978	157108	217339	-1849
12:15	49.99	208939	6544	3177	51140	7016	2184	142340	3070	154622	215471	-1837
12:30	49.99	208630	6535	3252	51663	7193	2186	141119	3019	153715	214967	-1860
12:45	49.94	207119	6515	3365	51036	7250	2187	139997	2990	152718	213340	-1838
13:00	50.04	204604	6509	3389	50690	7710	2174	137420	3019	150525	210911	-1824
13:15	49.99	200712	6516	3372	50007	7013	2180	134942	3008	147333	207038	-1840
13:30	50.04	199552	6514	3437	49836	6813	2178	133898	3010	146279	205686	-1840
13:45	49.99	199210	6515	3453	48483	6517	2181	135518	2977	147274	205644	-1883
14:00	49.99	198928	6514	3464	45603	6898	2184	137619	2990	149861	205272	-1852
14:15	49.94	198944	6534	3426	44706	7012	2168	138753	2947	150812	205546	-1846
14:30	49.99	199907	6524	3402	42652	7517	2188	141201	2961	153853	206445	-1862
14:45	49.94	200463	6540	3374	40204	8256	2203	143532	2938	156885	207047	-1890
15:00	49.99	200269	6539	3404	37616	8530	2269	145459	2941	159249	206758	-1851
15:15	49.94	199581	6529	3474	34618	8436	2475	147558	2907	161489	205997	-1882
15:30	49.94	199257	6540	3402	31190	9228	2933	149645	2916	164665	205854	-1900
15:45	49.99	198488	6530	3434	28063	10076	3466	150561	2824	166991	204954	-1872
16:00	50.04	196571	6511	3482	24181	10920	3512	151834	2802	168908	203242	-1759
16:15	50.04	194623	6527	3588	20477	11936	3660	151664	2800	170558	200652	-1677
16:30	49.99	195570	6538	3802	15846	14629	4156	153599	2786	175922	201356	-1558
16:45	49.99	196888	6533	3946	11527	17991	4232	155162	2797	181415	202188	-1410
17:00	49.99	197461	6525	4161	7977	19998	4382	156817	2776	185323	202636	-1194
17:15	49.99	196958	6537	4198	4869	21761	4797	157115	2778	187891	202055	-1117
17:30	49.99	197631	6522	4323	2510	23709	4888	158390	2807	190798	203149	-1172
17:45	49.89	199127	6540	4556	1152	25462	5049	158979	2762	193419	204500	-1246
18:00	50.04	200018	6529	4929	523	26606	5090	158938	2766	194566	205381	-1126
18:15	50.04	199773	6566	5212	311	26909	5137	158119	2778	194250	205032	-1206
18:30	50.04	200561	6557	5704	268	27460	4830	158331	2786	194589	205936	-1110
18:45	50.04	198688	6551	6187	276	27076	3462	157619	2778	192225	203949	-1142
19:00	50.04	198672	6572	6627	279	26678	3152	157520	2784	191766	203612	-1107
19:15	50.04	197477	6575	7111	282	25250	2986	157035	2784	190084	202023	-1092
19:30	49.99	194138	6583	7451	273	22302	2869	156400	2802	186414	198680	-1052
19:45	49.99	190672	6582	7644	261	20553	2759	154813	2830	182767	195442	-1029
20:00	50.04	186936	6588	7927	256	17504	2658	153667	2920	178753	191520	-1004
20:15	49.94	182969	6589	8175	27	16298	2555	151387	2930	174767	187961	-968
20:30	49.94	180900	6579	8497	25	15354	2551	149813	2956	172378	185775	-974
20:45	49.99	178705	6585	8830	-14	14556	2366	148482	2911	169889	183716	-968
21:00	50.04	175512	6590	9236	-18	13598	2429	146192	2931	166294	180958	-1107
21:15	49.99	172649	6586	9593	-19	12280	2323	144793	2956	163075	178512	-1384
21:30	49.99	169718	6585	9891	-19	12095	2340	141888	2964	159846	175744	-1533
21:45	49.99	167502	6575	10022	-20	11979	2333	140210	2969	157500	174068	-1730
22:00	50.09	164069	6570	10245	-20	11410	2341	136971	2917	153844	170434	-1694
22:15	50.04	164644	6576	10473	-18	11597	2342	137253	2943	154189	171166	-1766
22:30	49.99	163253	6593	10726	-18	11472	2321	135479	2955	15254		