



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 24.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 23.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 23-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 23.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day Date of Reporting: 24-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57212	62887	46172	21845	2715	190831
Peak Shortage (MW)	0	307	0	0	0	307
Energy Met (MU)	1208	1500	1131	440	49	4329
Hydro Gen (MU)	112	63	96	17	13	301
Wind Gen (MU)	21	57	25	-	-	103
Solar Gen (MU)*	93.20	67.06	110.32	2.91	0.95	274
Energy Shortage (MU)	1.78	7.44	0.00	0.19	0.00	9.41
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64311	75474	55646	22066	2818	216168
Time Of Maximum Demand Met	10:55	10:01	09:58	18:11	17:17	10:40

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.060	1.11	0.96	5.89	7.96	74.66	17.38

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7645	0	142.3	49.9	-1.1	538	0.00
	Haryana	7613	0	149.5	97.5	-3.3	614	0.00
	Rajasthan	17672	0	325.7	108.1	-3.7	501	0.00
	Delhi	4641	0	79.7	77.5	-0.4	431	0.00
	UP	19928	0	348.8	65.6	-0.2	668	0.00
	Uttarakhand	2444	0	46.4	35.1	1.4	340	0.00
	HP	2202	0	40.1	34.2	-0.8	189	0.00
	J&K(UT) & Ladakh(UT)	3088	0	66.2	60.3	0.9	850	1.78
	Chandigarh	253	0	4.7	4.8	0.0	46	0.00
	Railways_NR ISTS	187	0	3.9	3.8	0.1	20	0.00
WR	Chhattisgarh	4986	0	102.5	46.9	-0.8	219	0.00
	Gujarat	22313	0	414.4	205.6	-3.8	531	0.00
	MP	17450	396	334.3	206.2	1.8	891	7.44
	Maharashtra	28413	0	572.9	206.0	2.1	837	0.00
	Goa	694	0	13.9	12.9	0.4	58	0.00
	DNHDDPDCL	1329	0	30.1	30.3	-0.2	136	0.00
	AMNSIL	784	0	16.9	8.1	0.1	301	0.00
	BALCO	527	0	12.6	12.7	-0.1	9	0.00
	RIL JAMNAGAR	2359	0	2.4	2.3	0.1	0	0.00
SR	Andhra Pradesh	10328	0	198.6	58.0	-0.1	497	0.00
	Telangana	13768	0	263.9	157.0	0.2	1420	0.00
	Karnataka	14966	0	262.7	89.8	0.0	576	0.00
	Kerala	4195	0	81.4	64.2	0.5	212	0.00
	Tamil Nadu	16056	0	315.7	199.7	-0.9	831	0.00
	Puducherry	416	0	9.1	8.6	-0.1	46	0.00
ER	Bihar	5263	0	94.2	82.1	0.0	423	0.19
	DVC	3290	0	69.3	-44.9	-0.3	317	0.00
	Jharkhand	1993	0	39.6	26.6	2.1	211	0.00
	Odisha	4919	0	94.3	25.1	0.3	648	0.00
	West Bengal	7120	0	140.9	1.9	-1.6	211	0.00
	Sikkim	120	0	1.9	1.9	-0.1	30	0.00
	Railways_ER ISTS	24	0	0.2	0.2	0.1	3	0.00
NER	Arunachal Pradesh	170	0	3.1	2.9	0.1	23	0.00
	Assam	1551	0	25.8	19.5	-0.6	108	0.00
	Manipur	254	0	3.9	3.9	0.1	37	0.00
	Meghalaya	371	0	6.6	5.6	0.0	128	0.00
	Mizoram	126	0	2.7	1.7	0.0	16	0.00
	Nagaland	156	0	2.7	2.5	0.0	27	0.00
	Tripura	227	0	4.2	3.2	0.1	28	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.1	-6.2	-21.9	-16.4
Day Peak (MW)	-503.0	-549.3	-1020.0	-775.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	192.4	-204.1	202.9	-191.7	0.6	0.0
Actual(MU)	180.4	-205.2	209.9	-195.1	-1.2	-11.2
O/D/U/D(MU)	-12.0	-1.1	7.0	-3.4	-1.8	-11.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5354	9331	5978	4088	268	25019	47
State Sector	4388	12477	8934	2259	171	28228	53
Total	9742	21807	14912	6347	438	53247	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	798	1553	622	697	15	3686	78
Lignite	30	14	43	0	0	88	2
Hydro	112	63	96	17	13	301	6
Nuclear	31	54	70	0	0	155	3
Gas, Naptha & Diesel	11	20	14	0	25	71	1
RES (Wind, Solar, Biomass & Others)	140	127	162	6	1	436	9
Total	1123	1833	1007	720	55	4737	100

Share of RES in total generation (%)	12.47	6.95	16.09	0.85	1.73	9.21
Share of Non-fossil fuel (Hydro,Nuclear and RES)	25.20	13.34	32.57	3.17	25.85	18.84

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.063

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	216168	10:40	1439
Non-Solar hr	200065	18:16	717

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 24-Dec-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	249	0.0	6.1	-6.1
3	765 kV	GAYA-VARANASI	2	0	1041	0.0	16.9	-16.9
4	765 kV	SASARAM-FATEHPUR	1	0	515	0.0	7.6	-7.6
5	765 kV	GAYA-BALIA	1	0	678	0.0	11.7	-11.7
6	400 kV	PUSAULI-VARANASI	1	0	196	0.0	4.0	-4.0
7	400 kV	PUSAULI-ALLAHABAD	1	0	103	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	638	0.0	10.0	-10.0
9	400 kV	PATNA-BALIA	2	0	981	0.0	17.9	-17.9
10	400 kV	NAUBATPUR-BALIA	2	0	322	0.0	5.7	-5.7
11	400 kV	BIHARSHARIFF-BALIA	2	0	237	0.0	4.9	-4.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	576	0.0	10.6	-10.6
13	400 kV	BIHARSHARIFF-VARANASI	2	0	356	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	58	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.2	0.0	0.2
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	98.0	-97.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	535	1095	0.0	3.5	-3.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	367	1148	0.0	10.3	-10.3
3	765 kV	JHARSUGUDA-DURG	2	0	735	0.0	13.9	-13.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	869	0.0	13.6	-13.6
5	400 kV	RANCHI-SIPAT	2	0	1	0.0	0.0	0.0
6	220 kV	BUDHIPADAR-RAIGARH	1	12	116	0.0	1.8	-1.8
7	220 kV	BUDHIPADAR-KORBA	2	68	97	0.0	0.4	-0.4
ER-WR						0.0	43.5	-43.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	211	0.0	5.0	-5.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	2000	0.0	48.2	-48.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	3033	0.0	59.9	-59.9
4	400 kV	TALCHER-I/C	2	0	672	0.0	6.6	-6.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	113.1	-113.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	326	0	5.0	0.0	5.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	575	0	9.4	0.0	9.4
3	220 kV	ALIPURDUAR-SALAKATI	2	108	0	1.9	0.0	1.9
ER-NER						16.3	0.0	16.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	665	0	16.0	0.0	16.0
NER-NR						16.0	0.0	16.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1005	0.0	24.3	-24.3
2	HVDC	VINDHYACHAL B/B	-	148	55	1.7	0.6	1.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	979	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	49	1735	0.0	21.7	-21.7
5	765 kV	GWALIOR-PHAGI	2	0	1771	0.0	26.9	-26.9
6	765 kV	JABALPUR-ORAI	2	0	840	0.0	24.5	-24.5
7	765 kV	GWALIOR-ORAI	1	954	0	16.9	0.0	16.9
8	765 kV	SATNA-ORAI	1	0	969	0.0	19.4	-19.4
9	765 kV	BANASKANTHA-CHITORGARH	2	1042	313	10.6	0.5	10.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2087	0.0	23.6	-23.6
11	400 kV	ZERDA-KANKROLI	1	231	18	2.5	0.0	2.5
12	400 kV	ZERDA -BHINMAL	1	160	13	1.7	0.0	1.7
13	400 kV	VINDHYACHAL -RIHAND	1	961	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	343	186	3.0	0.5	2.5
15	400 kV	NEEMUCH-Chittorgarh	2	504	159	4.1	0.2	3.9
16	220 kV	BHANPURA-RANPUR	1	0	194	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.9	-1.9
18	220 kV	MEHGAON-AURAIYA	1	158	0	2.1	0.0	2.1
19	220 kV	MALANPUR-AURAIYA	1	124	4	1.4	0.0	1.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						65.6	171.5	-106.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	21.2	-21.2
2	HVDC	RAIGARH-PUGALUR	2	0	5009	0.0	62.0	-62.0
3	765 kV	SOLAPUR-RAICHUR	2	1730	1667	5.7	12.3	-6.6
4	765 kV	WARDHA-NIZAMABAD	2	0	2581	0.0	36.1	-36.1
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2699	0.0	39.5	-39.5
6	400 kV	KOLHAPUR-KUDGI	2	1505	0	20.4	0.0	20.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	128	2.4	0.0	2.4
WR-SR						28.5	171.1	-142.6

INTERNATIONAL EXCHANGES						Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-135	120	-31	-0.74	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	220	-201	-37	-0.89	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-259	-135	-208	-4.98	
	NER	132kV GELEPHU-SALAKATI	-37	0	-23	-0.56	
	NER	132kV MOTANGA-RANGIA	11	0	2	0.04	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-64	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-64	0	-36	-0.87	
	ER	NEPAL IMPORT (FROM BIHAR)	-109	-50	-70	-1.67	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-440	-138	-150	-3.61	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-930	-642	-868	-20.83	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-775	-405	-682	-16.36	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-90	0	-44	-1.06	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	8.40	0.00	0.00	0.00	0.00	0.00	8.40
Nepal	1.77	0.00	3.20	0.00	0.00	0.00	0.63	0.00	5.60
Bangladesh	21.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.39	0.00	11.60	0.00	0.00	0.63	0.00	0.00	35.62

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.60	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.60

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.60	0.00	-8.40	0.00	0.00	0.00	0.00	0.00	-7.80	
Nepal	-1.77	0.00	-3.20	0.00	0.00	0.00	-0.63	0.00	0.00	-5.60
Bangladesh	-21.62	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.62
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-22.79	0.00	-11.60	0.00	0.00	0.00	-0.63	0.00	0.00	-35.02

Date of Reporting: 24-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	145687	6072	7044	-11	7051	1785	126447	2943	138654	151331	-1653
0:15	50.00	145949	6087	6850	-12	7190	1784	126618	2944	139111	151461	-1633
0:30	50.00	145017	6081	6722	-9	7072	1789	126130	2939	138304	150724	-1670
0:45	50.00	144268	6067	6569	-10	6967	1958	125621	2948	137709	150120	-1570
1:00	50.00	143606	6072	6430	13	6884	1946	125026	2945	137163	149316	-1480
1:15	49.95	142623	6091	6236	16	6904	1791	124104	2995	136371	148137	-1427
1:30	49.95	142046	6075	6117	13	7009	1793	123392	2996	135916	147395	-1427
1:45	49.95	141634	6083	5882	15	6817	1964	123503	2949	135737	147213	-1426
2:00	50.00	140657	6075	5841	12	6878	1958	122873	2903	134804	146540	-1432
2:15	50.00	139845	6072	5614	15	6609	1948	122453	2956	134216	145667	-1376
2:30	49.95	139853	6083	5520	14	6775	1955	122074	2919	134319	145340	-1397
2:45	50.00	139362	6085	5522	12	6641	1788	121732	2982	133828	144762	-1323
3:00	50.00	139008	6076	5418	12	6426	1955	121730	2938	133578	144555	-1325
3:15	49.95	139179	6073	5497	7	6337	1975	122015	2944	133675	144848	-1310
3:30	50.05	139452	6070	5555	12	6240	1782	122325	2954	133885	144938	-1312
3:45	50.00	139436	6084	5614	10	6124	1790	122440	2934	133812	144996	-1312
4:00	50.10	139509	6092	5649	11	5983	1966	122611	2960	133849	145272	-1320
4:15	50.00	141877	6071	5658	12	6113	1779	124943	2890	136207	147466	-1320
4:30	50.05	143286	6092	5494	11	6297	1995	126368	2918	137781	149175	-1339
4:45	50.00	145082	6079	5356	11	6492	1783	128276	2913	139715	150910	-1321
5:00	50.00	147475	6078	5200	10	7047	2006	130417	2898	142265	153656	-1372
5:15	49.90	150813	6085	4994	14	7965	1787	133245	2947	145805	157037	-1411
5:30	50.05	154689	6082	5060	13	9550	2074	135456	2932	149616	161167	-1424
5:45	50.00	158603	6091	5005	14	10890	1906	137916	2956	153584	164778	-1474
6:00	50.05	162065	6066	5100	6	12423	2386	139877	2918	156959	168776	-1541
6:15	50.05	166333	6075	5050	273	13014	2532	142559	2890	161010	172393	-1314
6:30	50.05	172833	6082	4910	276	15685	2755	145805	2968	167647	178481	-1024
6:45	50.00	178790	6090	4728	314	17629	3324	150071	2893	173748	185049	-1116
7:00	49.95	184160	6072	4650	577	19678	3742	153127	2917	178933	190763	-1136
7:15	49.90	190156	6073	4650	1175	21902	3833	156009	2961	184331	196603	-1220
7:30	49.90	194630	6066	4638	2092	23204	3856	158359	3006	187900	201221	-1200
7:45	49.95	198109	6074	4641	3421	23848	3603	159584	3053	190047	204224	-1173
8:00	50.05	199213	6081	4616	5287	23673	3844	158917	3032	189310	205450	-1160
8:15	49.95	202217	6083	4564	7470	23058	3847	159999	3035	190183	208056	-1084
8:30	49.95	204110	6074	4469	10039	21766	3847	160556	3133	189602	209884	-1074
8:45	49.90	206055	6079	4299	13036	20483	3882	161074	3063	188720	211916	-1100
9:00	50.05	208162	6081	4217	15868	20039	3848	160694	3112	188077	213859	-1078
9:15	49.59	210469	6048	4079	18672	18432	3837	161819	3180	187718	216067	-1078
9:30	49.85	213364	6068	4010	21244	18586	3611	161929	3187	188110	218635	-1082
9:45	49.90	214557	6068	3639	24522	17732	3611	161583	3169	186396	220324	-1101
10:00	50.05	215047	6068	3344	27717	16371	3578	160835	3094	183986	221007	-1224
10:15	50.00	215696	6054	3118	30211	15632	3853	160108	3140	182367	222116	-1319
10:30	49.95	215480	6067	3125	31991	14772	3843	160059	3073	180364	222930	-1385
10:45	50.00	216078	6083	3189	34035	13936	3815	159477	3089	178854	223624	-1419
11:00	49.95	214875	6055	3106	36072	12594	3815	158379	3112	175697	223133	-1632
11:15	50.05	214257	6071	3154	38104	11326	3806	156824	3190	172999	222475	-1907
11:30	50.05	212912	6084	3246	39790	10941	3809	153845	3101	169876	220816	-1908
11:45	50.10	211762	6083	3281	41086	10747	3811	151649	3125	167395	219782	-1890
12:00	50.05	209795	6074	3369	41455	9619	2765	149651	3168	164971	216101	-1816
12:15	50.00	207151	6073	3436	41739	9282	2088	147781	3183	161976	213582	-1892
12:30	50.00	206917	6062	3533	41849	9471	1963	147118	3180	161535	213176	-1827
12:45	50.00	205420	6079	3597	42022	9567	1956	145462	3165	159801	211848	-1876
13:00	50.10	202740	6067	3597	42426	9030	1957	143135	3125	156717	209337	-1866
13:15	50.15	200172	6064	3607	42770	8158	1949	141138	3079	153795	206765	-1863
13:30	50.10	199095	6061	3663	41824	8103	1922	141001	3119	153608	205693	-1917
13:45	50.05	199429	6065	3715	41183	8152	1934	141496	3115	154531	205660	-1906
14:00	50.05	198599	6054	3761	39569	8121	1933	141662	3058	155269	204158	-1845
14:15	50.05	198069	6035	3817	37927	8639	1926	143563	3132	156325	205039	-1909
14:30	50.00	198968	6038	3868	36095	8651	1926	146569	3067	159005	206214	-1930
14:45	50.00	199475	6048	3942	33863	8617	1921	149334	3002	161670	206727	-1907
15:00	50.00	199737	6046	3955	31589	9218	2045	151264	2982	164193	207099	-1912
15:15	50.00	198652	6038	3949	28808	9335	2321	152748	2958	165895	206157	-1845
15:30	49.95	198670	6032	3981	25887	10343	2548	154503	2955	168802	206249	-1860
15:45	49.90	197348	6050	4158	22684	10769	3059	154776	3027	170506	204523	-1871
16:00	50.05	196939	6038	4067	19733	11287	3160	156545	2960	173139	203790	-1711
16:15	50.00	194288	6035	4159	16306	11909	3323	156634	2894	173823	201260	-1594
16:30	49.90	194760	6029	4116	13097	13547	3138	158299	2880	177547	201106	-1264
16:45	49.90	195574	6049	4030	10469	16351	3284	158848	2935	181075	201966	-1306
17:00	50.05	196541	6044	4008	7575	18638	3303	160005	2874	184958	202447	-1213
17:15	50.00	196655	6037	4048	4739	20837	3514	160369	2874	187868	202418	-1079
17:30	49.95	196915	6043	4114	2692	22121	3436	161972	2882	190109	203260	-1128
17:45	49.96	197998	6041	4220	1252	23785	3695	162636	2914	192526	204543	-1189
18:00	49.91	199480	6064	4455	670	25139	3493	162327	2892	194355	205040	-1161
18:15	49.91	199952	6046	4698	552	25758	3769	162712	2893	194702	206428	-1165
18:30	50.06	199663	6045	4920	506	25643	3746	162002	2882	194237	205744	-1149
18:45	50.06	197948	6056	5042	505	24960	3765	160783	2913	192401	204024	-1133
19:00	50.11	196565	6063	5341	516	24507	3751	159575	2868	190708	202621	-1087
19:15	50.06	193643	6073	5622	513	22240	2937	159186	2850	187508	199421	-1058
19:30	50.06	190657	6074	5935	509	20645	2150	158116	2880	184213	196309	-1028
19:45	50.01	188104	6055	6360	522	18177	1730	157894	2868	181222	193606	-991
20:00	50.06	183908	6058	7010	515	15674	1741	155610	2822	176383	189430	-1020
20:15	50.06	181011	6067	7364	281	14063	1732	153732	2924	173366	186163	-987
20:30	50.01	178461	6059	7666	270	13414	1740	151522	2917	170525	183588	-967
20:45	50.01	175950	6055	7860	241	12765	1744	149474	2938	167849	181077	-971
21:00	50.06	172834	6068	8089	243	11825	1948	147104	2941	164502	178218	-1048
21:15	50.06	170272	6069	8294	161	11322	1740	145692	2919	161817	176197	-1501
21:30	50.06	167714	6061	8377	160	11247	1750	143562	2953	159177	174110	-1693
21:45	50.06	165156	6066	8513	165	10998	1753	140968	2932	156478	171395	-1691
22:00	50.06	161726	6058	8629	160	10483	1747	137924	2935	152937	167936	-1658
22:15	50.01	160823	6060	8665	163	10331	1750	137161	2933	151995	167063	-1653
22:30	50.01	159903	6058	8715	162	9886						