



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 26.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 25.02.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 25-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 25.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 26-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55738	69702	51237	23103	2701	202481
Peak Shortage (MW)	85	242	0	0	35	362
Energy Met (MU)	1216	1658	1375	479	50	4778
Hydro Gen (MU)	93	41	75	23	9	241
Wind Gen (MU)	15	58	102	-	-	174
Solar Gen (MU)*	126.29	116.12	135.52	4.01	1.21	383
Energy Shortage (MU)	0.35	0.29	0.00	0.00	0.30	0.94
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	62314	78106	68939	23536	2790	231406
Time Of Maximum Demand Met	09:41	10:17	10:26	18:32	18:14	09:41

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.057	0.05	0.52	6.96	7.52	74.22	18.26

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7745	0	139.8	47.6	-0.6	384	0.00
	Haryana	7803	0	154.6	107.6	-0.8	201	0.00
	Rajasthan	18159	0	347.5	115.9	-0.4	798	0.00
	Delhi	3988	0	72.8	64.4	0.5	384	0.00
	UP	18271	0	350.8	82.6	-0.5	435	0.00
	Uttarakhand	2226	0	42.3	33.0	-0.4	77	0.00
	HP	2097	0	39.5	32.9	0.0	369	0.00
	J&K(UT) & Ladakh(UT)	2879	50	61.5	58.3	-0.4	843	0.35
	Chandigarh	231	0	3.7	3.7	0.0	24	0.00
WR	Railways_NR ISTS	183	0	3.8	3.9	-0.1	23	0.00
	Chhattisgarh	6133	0	135.7	67.8	0.3	484	0.29
	Gujarat	22852	0	453.5	199.2	-5.3	757	0.00
	MP	16741	0	338.0	209.6	-3.8	519	0.00
	Maharashtra	29250	0	650.2	232.4	-2.4	625	0.00
	Goa	745	0	15.5	15.0	0.1	59	0.00
	DNHDDPDCL	1311	0	30.8	31.2	-0.4	37	0.00
	AMNSIL	762	0	17.1	10.4	-0.3	173	0.00
	BALCO	534	0	12.7	12.7	0.0	10	0.00
SR	RIL JAMNAGAR	196	0	4.7	4.7	0.0	0	0.00
	Andhra Pradesh	12577	0	242.2	59.0	0.1	557	0.00
	Telangana	16506	0	315.6	175.4	-0.6	641	0.00
	Karnataka	17766	0	326.3	122.5	-1.4	639	0.00
	Kerala	4779	0	94.2	76.2	-0.2	409	0.00
	Tamil Nadu	18461	0	387.0	228.8	1.7	834	0.00
	Puducherry	433	0	9.7	9.2	-0.1	40	0.00
ER	Bihar	4974	0	96.3	88.0	1.8	265	0.00
	DVC	3310	0	69.3	-43.9	-0.8	302	0.00
	Jharkhand	2011	0	38.3	29.3	0.4	303	0.00
	Odisha	5196	0	108.6	28.2	0.5	589	0.00
	West Bengal	8030	0	165.1	27.6	-2.1	189	0.00
	Sikkim	107	0	1.5	2.1	-0.6	13	0.00
	Railways_ER ISTS	16	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	179	0	3.2	3.1	0.0	14	0.00
	Assam	1594	0	29.1	22.7	0.2	118	0.00
	Manipur	180	33	3.0	2.7	0.4	46	0.30
	Meghalaya	328	0	5.5	4.3	-0.1	101	0.00
	Mizoram	141	0	2.1	1.8	-0.1	29	0.00
	Nagaland	161	0	2.6	2.5	0.0	34	0.00
	Tripura	235	0	4.0	3.7	0.1	31	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.6	-13.4	-23.9	-17.5
Day Peak (MW)	-578.0	-735.9	-1028.0	-764.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	208.4	-235.0	190.8	-175.2	11.0	0.0
Actual(MU)	211.9	-229.0	179.3	-183.2	9.8	-11.1
O/D/U/D(MU)	3.6	6.0	-11.5	-8.0	-1.2	-11.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6079	7756	2448	2956	1068	20307	45
State Sector	8636	8755	4652	2259	181	24483	55
Total	14715	16511	7100	5215	1249	44789	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	768	1713	779	729	10	3999	77
Lignite	30	16	56	0	0	102	2
Hydro	93	41	75	23	9	241	5
Nuclear	21	63	71	0	0	155	3
Gas, Naptha & Diesel	12	23	4	0	24	63	1
RES (Wind, Solar, Biomass & Others)	167	177	277	7	1	629	12
Total	1091	2033	1262	759	44	5189	100

Share of RES in total generation (%)	15.30	8.69	21.98	0.93	2.80	12.13
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	25.78	13.83	33.49	3.98	23.11	19.77

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.033

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	231406	9:41	25
Non-Solar hr	206805	18:58	95

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 26-Feb-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	0	1052	0.0	19.1	-19.1
4	765 kV	SASARAM-FATEHPUR	1	0	666	0.0	13.1	-13.1
5	765 kV	GAYA-BALIA	1	0	630	0.0	9.2	-9.2
6	400 kV	PUSAULI-VARANASI	1	0	68	0.0	1.2	-1.2
7	400 kV	PUSAULI -ALLAHABAD	1	0	75	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	105	502	0.0	5.4	-5.4
9	400 kV	PATNA-BALIA	2	0	912	0.0	16.6	-16.6
10	400 kV	NAUBATPUR-BALIA	2	0	350	0.0	6.0	-6.0
11	400 kV	BIHARSHARIFF-BALIA	2	116	239	0.0	2.4	-2.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	475	0.0	8.4	-8.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	53	420	0.0	6.6	-6.6
14	220 kV	SAHUPURI-KARAMNASA	1	0	61	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	92.6	-91.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1023	70	12.4	0.0	12.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	521	1013	0.0	8.7	-8.7
3	765 kV	JHARSUGUDA-DURG	2	0	952	0.0	17.7	-17.7
4	400 kV	JHARSUGUDA-RAIGARH	4	0	848	0.0	14.3	-14.3
5	400 kV	RANCHI-SIPAT	2	69	314	0.0	3.5	-3.5
6	220 kV	BUDHIPADAR-RAIGARH	1	0	106	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-KORBA	2	93	76	0.5	0.0	0.5
ER-WR						12.9	45.6	-32.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	367	0.0	9.7	-9.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1635	0.0	48.2	-48.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2847	0.0	50.9	-50.9
4	400 kV	TALCHER-I/C	2	0	142	0.0	4.0	-4.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	108.8	-108.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	189	141	0.9	0.5	0.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	354	133	2.2	0.0	2.2
3	220 kV	ALIPURDUAR-SALAKATI	2	75	11	0.7	0.0	0.7
ER-NER						3.8	0.5	3.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	665	0	13.5	0.0	13.5
NER-NR						13.5	0.0	13.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2010	0.0	48.2	-48.2
2	HVDC	VINDHYACHAL B/B	-	198	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	980	0.0	13.5	-13.5
4	765 kV	GWALIOR-AGRA	2	0	1810	0.0	22.1	-22.1
5	765 kV	GWALIOR-PHAGI	2	240	1819	0.0	29.8	-29.8
6	765 kV	JABALPUR-ORAI	2	0	993	0.0	25.7	-25.7
7	765 kV	GWALIOR-ORAI	1	831	0	15.8	0.0	15.8
8	765 kV	SATNA-ORAI	1	0	1117	0.0	22.3	-22.3
9	765 kV	BANASKANTHA-CHITORGARH	2	1158	0	15.3	0.0	15.3
10	765 kV	VINDHYACHAL-VARANASI	2	0	2066	0.0	26.0	-26.0
11	400 kV	ZERDA-KANKROLI	1	171	20	2.1	0.0	2.1
12	400 kV	ZERDA -BHINMAL	1	118	14	1.4	0.0	1.4
13	400 kV	VINDHYACHAL -RIHAND	1	485	0	8.3	0.0	8.3
14	400 kV	RAPP-SHUJALPUR	2	138	322	0.8	1.3	-0.5
15	400 kV	NEEMUCH-Chittorgarh	2	286	303	1.6	1.1	0.5
16	220 kV	BHANPURA-RANPUR	1	0	179	0.0	3.0	-3.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.4	-2.4
18	220 kV	MEHGAON-AURAIYA	1	140	0	1.8	0.0	1.8
19	220 kV	MALANPUR-AURAIYA	1	104	0	1.1	0.0	1.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						53.1	195.2	-142.1
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1013	0.0	21.8	-21.8
2	HVDC	RAIGARH-PUGALUR	2	0	2502	0.0	40.4	-40.4
3	765 kV	SOLAPUR-RAICHUR	2	1036	1384	4.7	9.4	-4.6
4	765 kV	WARDHA-NIZAMABAD	2	0	2605	0.0	38.0	-38.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2715	0.0	42.7	-42.7
6	400 kV	KOLHAPUR-KUDGI	2	1515	0	25.9	0.0	25.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	38	0.0	0.3	-0.3
9	220 kV	XELDEM-AMBEWADI	1	0	119	2.4	0.0	2.4
WR-SR						33.0	152.7	-119.7

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	275	-106	31	0.75	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-248	109	-94	-2.27	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-303	-109	-202	-4.85	
	NER	132kV GELEPHU-SALAKATI	-25	5	-14	-0.33	
	NER	132kV MOTANGA-RANGIA	12	2	4	0.10	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	-48	-1.16	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-45	-1.07	
	ER	NEPAL IMPORT (FROM BIHAR)	-220	-15	-167	-4.01	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-516	15	-298	-7.15	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-946	-890	-933	-22.39	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-764	-595	-729	-17.50	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-82	0	-63	-1.52	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.35	7.65	0.00	0.00	0.00	0.00	0.00	8.00	
Nepal	4.00	0.00	5.34	0.00	0.00	0.00	2.26	0.00	0.00	11.60
Bangladesh	23.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.21
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.21	0.35	12.99	0.00	0.00	0.00	2.26	0.00	0.00	42.81

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.95
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.95

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.95	-0.35	-7.65	0.00	0.00	0.00	0.00	0.00	-7.05
Nepal	-4.00	0.00	-5.34	0.00	0.00	-2.26	0.00	0.00	-11.60
Bangladesh	-23.21	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.21
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.26	-0.35	-12.99	0.00	0.00	-2.26	0.00	0.00	-41.86

Date of Reporting: 26-Feb-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K) (+ve) Import, (-ve) Export
0:00	50.07	175422	6009	8830	131	6684	2379	153618	3101	166461	180752	-1994
0:15	49.91	175254	6014	8789	136	5761	2374	154167	3078	166329	180319	-1903
0:30	50.02	175006	6026	8817	133	6013	2371	153844	3011	166056	180215	-1918
0:45	49.97	174734	6022	8919	126	5801	2360	153606	3046	165689	179880	-1910
1:00	49.97	173624	6030	8758	122	5261	2374	153233	3025	164744	178803	-1886
1:15	49.97	172634	6029	8659	124	5119	2366	152088	2992	163851	177377	-1896
1:30	50.02	172186	6024	8641	125	4895	2372	151723	3000	163420	176780	-1915
1:45	50.02	171550	6052	8580	130	4600	2374	151325	2992	162840	176053	-1883
2:00	50.02	170178	6050	8500	130	4227	2364	150524	2986	161548	174781	-1858
2:15	49.97	169286	6059	8392	129	4183	2345	149671	3002	160765	173781	-1886
2:30	49.97	169137	6048	8224	130	4271	2347	149667	3003	160783	173690	-1862
2:45	50.02	168969	6045	8179	131	4273	2345	149434	3002	160659	173409	-1862
3:00	50.02	168284	6045	8177	128	4223	2301	148815	2990	159979	172679	-1865
3:15	49.97	168151	6038	8074	121	4269	2362	148754	3006	159956	172624	-1871
3:30	50.02	167954	6043	8068	118	4442	2380	148479	3024	159768	172554	-1900
3:45	50.02	168057	6056	8177	117	4437	2382	148548	3026	159763	172743	-1956
4:00	50.02	168677	6054	8249	117	4410	2390	149047	3010	160311	173277	-1954
4:15	49.97	169910	6065	8384	119	4578	2386	149988	2987	161407	174507	-1990
4:30	50.02	171222	6052	8313	117	5043	2393	151041	3024	162792	175983	-2015
4:45	50.02	172359	6051	8354	115	5228	2388	152259	2870	163890	177265	-2027
5:00	50.02	174527	6059	8283	116	5535	2394	154108	2849	166128	179344	-1983
5:15	49.92	177605	6064	8293	118	6204	2465	156339	2834	169194	182317	-1936
5:30	50.02	180916	6074	8440	119	6592	2540	158896	2782	172357	185443	-1810
5:45	49.97	184143	6079	8382	113	7139	2507	161564	2842	175648	188626	-1845
6:00	50.07	187292	6075	8424	121	7869	2493	163848	2903	178747	191733	-1822
6:15	49.97	191226	6068	8460	286	9081	2552	166308	2890	182480	195645	-1624
6:30	50.07	198051	6065	8690	421	12840	2700	168434	2947	188940	202097	-1371
6:45	50.02	202985	6062	8638	520	15979	3042	170277	2956	193827	207474	-1357
7:00	50.02	207163	6093	8526	1075	18069	3387	170902	3001	197562	211053	-1017
7:15	49.97	210769	6084	8240	2436	19446	3838	171370	3014	200093	214428	-1026
7:30	50.07	213148	6097	7967	4943	19794	3848	170838	3025	200238	216512	-899
7:45	50.07	215734	6095	7725	8391	20704	3852	168849	3011	199618	218627	-990
8:00	50.22	215288	6104	7450	12655	18594	3671	167130	2976	195183	218580	-1008
8:15	50.07	218403	6090	6871	17310	17394	3679	166930	3044	194222	221318	-1049
8:30	50.02	219544	6092	6666	21397	15497	3678	166381	3112	191481	222823	-1373
8:45	50.02	221329	6091	6618	25772	13824	3652	165793	3136	188939	224886	-1391
9:00	50.07	222699	6097	6720	31353	12605	3654	162929	3129	184626	226487	-1482
9:15	50.03	227688	6091	6759	35719	11327	3880	164642	3152	185210	231570	-1574
9:30	50.03	229094	6079	6616	38750	10527	3664	163970	3130	183728	232736	-1608
9:45	49.98	230601	6079	6539	41232	10155	3655	163402	3223	182830	234285	-1629
10:00	49.93	229581	6054	6294	42281	9470	3354	162565	3189	181006	233207	-1624
10:15	50.03	230432	6050	6306	44231	9342	3898	161072	3166	179895	234065	-1622
10:30	49.93	229086	6068	6233	45667	8617	3947	159028	3154	177186	232714	-1626
10:45	49.98	228556	6074	6240	47386	8632	3951	157479	3125	174930	232887	-1626
11:00	49.88	226762	6083	6267	47189	7949	3963	156703	3150	173306	231304	-1641
11:15	49.88	226720	6061	6260	47697	7943	3907	155659	3140	172763	230667	-1964
11:30	50.03	227167	6067	6239	48883	8291	3866	155088	3138	172045	231572	-2150
11:45	50.03	226018	6046	6286	49603	7879	3664	153831	3181	170129	230490	-2151
12:00	50.13	223921	6067	6149	50444	6898	3127	152372	3168	167328	228225	-2079
12:15	50.03	222184	6071	6099	51026	6200	2335	151290	3155	165059	226176	-2076
12:30	50.13	221333	6050	6024	51853	6198	2193	150207	3119	163456	225644	-2127
12:45	50.18	220733	6058	6123	53019	5413	2207	149007	3109	161591	224936	-2113
13:00	50.23	217873	6040	6162	51782	5611	2197	146903	3184	159929	221879	-2112
13:15	50.08	213560	6037	5990	51253	4833	2208	143966	3175	156317	217462	-2137
13:30	49.98	211472	6042	5796	50525	5169	2213	142822	3085	155151	215652	-2153
13:45	49.93	211932	6043	5654	49182	5620	2183	144037	3090	157096	215809	-2167
14:00	50.03	212172	6020	5627	48338	6042	2197	144567	3095	158207	215886	-2151
14:15	49.98	212854	6013	5476	47343	5842	2209	146819	3043	160035	216745	-2131
14:30	49.98	213969	6033	5452	45539	6142	2265	149352	3063	162978	217846	-2131
14:45	49.92	214154	6033	5504	43076	6375	2292	150042	3020	165574	216342	-2154
15:00	50.03	214712	6042	5565	40837	6909	2333	153959	3042	168310	218687	-2131
15:15	49.92	213639	6047	5585	38691	6569	2342	155639	2987	169363	217860	-2142
15:30	49.87	214726	6038	5545	35926	7426	2380	158661	2962	173255	218938	-2157
15:45	49.97	214920	6038	5443	32713	7935	2402	161616	2970	176764	219117	-2129
16:00	49.87	213799	6046	5449	28635	8278	2474	164062	2917	179715	217861	-2142
16:15	49.82	210853	6030	5616	24871	7793	2412	165244	2884	180366	214850	-1909
16:30	49.87	211716	6018	5623	22204	9039	2509	166961	2924	183889	215278	-1577
16:45	49.87	211309	6020	5654	18883	10384	2568	168121	2946	186772	214576	-1367
17:00	49.92	209331	6027	5880	15386	11301	2559	168286	2993	188065	212432	-1331
17:15	49.97	206299	6004	5880	11394	12690	2552	168071	2954	189025	209545	-1058
17:30	50.07	205376	5996	5792	8184	15669	2556	167404	3002	191400	208603	-1050
17:45	50.02	205160	5996	5738	5503	17099	2503	168443	2877	193919	208159	-1043
18:00	50.07	202581	6000	5593	3365	18853	2481	167436	2915	193623	206643	-1070
18:15	50.02	202070	6014	5317	1756	18735	2525	168119	2907	194997	205373	-1003
18:30	49.97	204824	5998	5292	797	20546	2554	170119	2901	198735	208207	-1012
18:45	49.97	206676	6004	5391	426	21566	2636	171149	2987	200859	210159	-956
19:00	50.07	206515	6018	5653	210	21464	2624	170931	2864	200652	209764	-978
19:15	50.02	205473	6015	5903	221	20634	2614	170658	2858	199349	208903	-950
19:30	50.03	203992	6013	6096	102	19569	2501	170174	2897	197794	207352	-959
19:45	50.08	201141	6033	6235	99	18769	2423	168104	2841	194807	204504	-939
20:00	50.03	197779	6027	6291	138	16309	2445	167222	2852	191350	201284	-997
20:15	49.98	194272	6022	6422	153	13610	2335	166278	2896	187697	197716	-1042
20:30	50.03	192131	6038	6665	133	12548	2317	165129	2839	185333	195669	-897
20:45	49.98	192028	6023	6942	126	10865	2323	164913	2847	183140	194039	-1042
21:00	50.08	188066	6042	7234	124	10626	2200	162826	2873	180708	191925	-1253
21:15	50.03	186500	6041	7703	132	10046	2074	161952	2861	178665	190809	-1755
21:30	50.03	185309	6023	8009	135	9725	2053	160966	2860	177165	189771	-1938
21:45	50.03	184028	6041	8227	136	9629	1978	159827	2826	175665	188664	-1920
22:00	50.08	181632	6031	8219	119	8709	2010	158238	2865	173294	186191	-1931
22:15	49.98	183219	6043	8513	104	9115	2014	159188	2852	174602	187829	-2002
22:30	50.03	183226	6025	8627	104							