



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 05.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 04.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 4-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 04.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 05-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60004	63404	44045	22253	2701	192407
Peak Shortage (MW)	4	0	0	766	0	770
Energy Met (MU)	1240	1470	1147	452	49	4358
Hydro Gen (MU)	96	36	95	18	12	257
Wind Gen (MU)	9	52	58	-	-	119
Solar Gen (MU)*	143.75	102.69	143.47	3.07	1.11	394
Energy Shortage (MU)	0.08	0.00	0.00	1.51	0.00	1.59
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64701	73377	57703	23810	2796	219312
Time Of Maximum Demand Met	09:55	09:58	09:17	19:25	17:33	09:49

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.053	0.02	2.82	6.89	9.73	72.89	17.38

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8479	0	156.1	78.0	-1.3	300	0.00
	Haryana	7963	0	150.7	108.1	-1.9	369	0.00
	Rajasthan	17584	0	318.2	111.9	0.6	396	0.00
	Delhi	5065	0	84.2	82.6	-1.0	405	0.00
	UP	20821	4	372.0	112.6	-1.8	285	0.08
	Uttarakhand	2371	0	44.7	36.4	0.4	169	0.00
	HP	2125	0	37.5	31.0	-0.9	258	0.00
	J&K(UT) & Ladakh(UT)	3143	0	68.2	65.9	-1.8	809	0.00
	Chandigarh	287	0	4.7	4.6	0.1	40	0.00
WR	Railways_NR ISTS	192	0	3.8	3.6	0.2	46	0.00
	Chhattisgarh	5330	0	107.8	56.9	0.2	305	0.00
	Gujarat	22372	0	419.9	200.6	0.5	656	0.00
	MP	15489	0	287.6	169.1	-3.0	529	0.00
	Maharashtra	27920	0	578.6	188.8	0.4	734	0.00
	Goa	693	0	14.0	13.4	0.0	43	0.00
	DNHDDPDCL	1333	0	30.5	30.4	0.1	39	0.00
	AMNSIL	791	0	16.3	5.5	1.1	318	0.00
	BALCO	526	0	12.6	12.7	-0.1	2	0.00
SR	RIL JAMNAGAR	101	0	2.4	2.3	0.1	0	0.00
	Andhra Pradesh	10685	0	200.0	54.3	-2.3	372	0.00
	Telangana	14471	0	267.6	162.7	-1.9	882	0.00
	Karnataka	15625	0	273.6	83.9	0.1	499	0.00
	Kerala	4135	0	80.3	64.0	1.1	291	0.00
	Tamil Nadu	15906	0	316.6	175.7	-2.7	787	0.00
ER	Puducherry	392	0	8.6	8.3	-0.3	41	0.00
	Bihar	5550	428	99.0	91.2	-4.2	461	1.51
	DVC	3270	0	71.0	-38.8	-0.2	339	0.00
	Jharkhand	2023	0	36.5	26.9	0.0	184	0.00
	Odisha	5235	0	97.9	33.4	-2.1	406	0.00
	West Bengal	7203	0	146.1	6.8	-1.2	179	0.00
	Sikkim	105	0	1.6	1.8	-0.2	13	0.00
	Railways_ER ISTS	14	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	159	0	2.8	3.0	-0.3	13	0.00
	Assam	1536	0	27.5	20.2	0.8	107	0.00
	Manipur	258	0	3.8	3.9	-0.1	20	0.00
	Meghalaya	407	0	6.4	5.3	0.0	89	0.00
	Mizoram	175	0	2.2	1.8	-0.1	15	0.00
	Nagaland	156	0	2.4	2.4	0.0	14	0.00
	Tripura	231	0	4.1	3.2	0.1	41	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.1	-5.7	-19.9	-13.6
Day Peak (MW)	-573.0	-387.0	-999.0	-765.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	252.6	-246.8	145.2	-157.4	6.4	0.0
Actual(MU)	249.2	-245.5	136.8	-158.4	5.6	-12.3
O/D/U/D(MU)	-3.5	1.3	-8.4	-1.0	-0.8	-12.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4481	8046	5388	6303	568	24786	45
State Sector	7568	12450	7964	2249	191	30421	55
Total	12049	20495	13352	8552	759	55207	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	749	1559	628	672	10	3617	76
Lignite	23	16	52	0	0	91	2
Hydro	96	36	95	18	12	257	5
Nuclear	32	54	66	0	0	151	3
Gas, Naptha & Diesel	3	13	5	0	25	45	1
RES (Wind, Solar, Biomass & Others)	179	159	237	6	1	582	12
Total	1081	1837	1083	696	48	4745	100

Share of RES in total generation (%)	16.55	8.65	21.91	0.87	2.34	12.27
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.34	13.59	36.71	3.46	28.19	20.89

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.014
Based on State Max Demands	1.049

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	219312	9:49	0
Non-Solar hr	200685	18:35	460

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 05-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	1	0	0.0	6.0	-6.0
3	765 kV	GAYA-VARANASI	2	0	1083	0.0	16.3	-16.3
4	765 kV	SASARAM-FATEHPUR	1	62	447	0.0	6.5	-6.5
5	765 kV	GAYA-BALIA	1	0	950	0.0	11.4	-11.4
6	400 kV	PUSAULI-VARANASI	1	0	209	0.0	3.8	-3.8
7	400 kV	PUSAULI -ALLAHABAD	1	0	127	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	825	0.0	9.3	-9.3
9	400 kV	PATNA-BALIA	2	0	960	0.0	14.4	-14.4
10	400 kV	NAUBATPUR-BALIA	2	0	633	0.0	4.5	-4.5
11	400 kV	BIHARSHARIFF-BALIA	2	0	416	0.0	6.9	-6.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	774	0.0	8.3	-8.3
13	400 kV	BIHARSHARIFF-VARANASI	2	47	343	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	2.8	-2.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	92.2	-91.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	676	607	0.8	0.0	0.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	873	544	3.2	0.0	3.2
3	765 kV	JHARSUGUDA-DURG	2	0	1000	0.0	18.2	-18.2
4	400 kV	JHARSUGUDA-RAIGARH	4	0	742	0.0	11.6	-11.6
5	400 kV	RANCHI-SIPAT	2	180	298	0.0	0.7	-0.7
6	220 kV	BUDHIPADAR-RAIGARH	1	0	107	0.0	1.5	-1.5
7	220 kV	BUDHIPADAR-KORBA	2	69	95	0.0	0.1	-0.1
ER-WR						4.0	32.1	-28.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1646	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	2861	0.0	50.4	-50.4
4	400 kV	TALCHER-I/C	2	246	0	4.4	0.0	4.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	95.3	-95.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	358	6	3.0	0.0	3.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	581	0	5.6	0.0	5.6
3	220 kV	ALIPURDUAR-SALAKATI	2	110	0	1.3	0.0	1.3
ER-NER						9.9	0.0	9.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3020	0.0	45.1	-45.1
2	HVDC	VINDHYACHAL B/B	-	228	103	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1916	0.0	40.2	-40.2
4	765 kV	GWALIOR-AGRA	2	0	2817	0.0	33.7	-33.7
5	765 kV	GWALIOR-PHAGI	2	279	1822	0.3	25.3	-25.0
6	765 kV	JABALPUR-ORAI	2	0	1474	0.0	36.8	-36.8
7	765 kV	GWALIOR-ORAI	1	965	0	15.6	0.0	15.6
8	765 kV	SATNA-ORAI	1	0	1110	0.0	18.7	-18.7
9	765 kV	BANASKANTHA-CHITORGARH	2	1356	644	11.7	1.0	10.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	2902	0.0	34.1	-34.1
11	400 kV	ZERDA-KANKROLI	1	273	91	2.7	0.1	2.5
12	400 kV	ZERDA -BHINMAL	1	188	63	1.8	0.1	1.7
13	400 kV	VINDHYACHAL -RIHAND	1	973	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	437	480	2.0	2.1	-0.1
15	400 kV	NEEMUCH-Chittorgarh	2	412	507	1.8	2.2	-0.4
16	220 kV	BHANPURA-RANPUR	1	0	156	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	97	3	0.8	0.0	0.8
19	220 kV	MALANPUR-AURAIYA	1	63	24	0.4	0.1	0.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						58.8	244.7	-185.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	19.2	-19.2
2	HVDC	RAIGARH-PUGALUR	2	0	2503	0.0	40.9	-40.9
3	765 kV	SOLAPUR-RAICHUR	2	1790	793	8.1	4.5	3.6
4	765 kV	WARDHA-NIZAMABAD	2	0	2069	0.0	29.4	-29.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2410	0.0	32.0	-32.0
6	400 kV	KOLHAPUR-KUDGI	2	1695	0	28.5	0.0	28.5
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	112	2.1	0.0	2.1
WR-SR						38.7	126.0	-87.3
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	243	-144	82	1.98		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-243	61	-110	-2.63		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-256	-159	-209	-5.03		
	NER	132kV GELEPHU-SALAKATI	-28	0	-18	-0.44		
	NER	132kV MOTANGA-RANGIA	-9	8	0	-0.01		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-45	-1.09		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-36	-0.86		
	ER	NEPAL IMPORT (FROM BIHAR)	-167	-68	-74	-1.78		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-220	21	-84	-2.01		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-938	-554	-778	-18.67		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-765	-403	-568	-13.64		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-61	0	-49	-1.18		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 05-Jan-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	6.16	0.00	0.00	0.00	0.90	0.00	0.00	7.06
Nepal	1.89	0.00	1.41	0.00	0.00	0.00	0.62	0.00	0.00	3.92
Bangladesh	19.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	19.43
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.32	0.00	7.57	0.00	0.00	0.00	1.52	0.00	0.00	30.41

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.88
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.88	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.88

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.88	0.00	-6.16	0.00	0.00	-0.90	0.00	0.00	-6.18
Nepal	-1.89	0.00	-1.41	0.00	0.00	-0.62	0.00	0.00	-3.92
Bangladesh	-19.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-19.43
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.44	0.00	-7.57	0.00	0.00	-1.52	0.00	0.00	-29.53

Date of Reporting: 05-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.11	150076	5838	7658	134	6939	1611	128973	3141	142284	154294	-1445
0:15	50.00	149332	5814	7525	136	6122	1605	129277	3195	141671	153674	-1528
0:30	50.00	148342	5814	7449	129	6204	1621	128004	3205	140764	152426	-1430
0:45	50.00	147201	5819	7299	131	6123	1631	126979	3229	139771	151211	-1357
1:00	50.00	145867	5818	7132	129	6138	1667	125614	3199	138606	149697	-1228
1:15	49.95	145263	5838	6917	129	6044	1668	125325	3241	138217	149162	-1492
1:30	49.95	144911	5826	6697	126	6286	1669	124769	3213	138088	148586	-1420
1:45	49.95	143662	5825	6496	122	6317	1674	123947	3220	137044	147601	-1320
2:00	50.00	143021	5835	6289	126	6240	1669	123294	3283	136606	146736	-1331
2:15	50.00	142448	5832	6063	125	6254	1681	122966	3248	136260	146169	-1308
2:30	50.00	141791	5835	5837	126	6208	1682	122458	3269	135828	145415	-1284
2:45	50.00	141119	5840	5664	130	6254	1675	122021	3207	135325	144791	-1169
3:00	50.00	141126	5831	5455	129	6205	1682	122076	3211	135542	144589	-1121
3:15	49.95	141177	5817	5208	129	6368	1683	122340	3291	135840	144836	-1123
3:30	50.00	141135	5802	4992	126	6405	1686	122817	3269	136017	145097	-1238
3:45	50.00	141168	5817	4862	124	6371	1688	123044	3231	136182	145137	-1135
4:00	50.05	141531	5818	4812	123	6472	1709	123502	3203	136596	145639	-1123
4:15	50.00	143201	5811	4710	121	6612	1695	125301	3222	138370	147472	-1157
4:30	50.05	144878	5822	4586	121	6793	1689	126755	3291	140171	149057	-1184
4:45	50.00	146803	5818	4531	121	6718	1687	128943	3237	142151	151055	-1184
5:00	50.05	148990	5805	4502	121	6470	1689	131309	3270	144367	153166	-1177
5:15	49.95	152589	5812	4443	128	6719	1674	134717	3220	148018	156713	-1174
5:30	50.05	156907	5810	4370	126	6859	1678	139246	3226	152411	161315	-1191
5:45	50.00	161354	5803	4237	127	7782	1687	142980	3231	156990	165847	-1311
6:00	50.05	164778	5812	4141	145	8777	1666	145835	3266	160492	169642	-1474
6:15	49.95	169095	5808	4036	138	9503	1678	149424	3248	164921	173835	-1532
6:30	50.05	175117	5822	3927	205	11609	1705	153205	3263	170985	179736	-1431
6:45	49.95	181157	5822	3878	237	14102	1665	157221	3289	177042	186214	-1371
7:00	49.90	186620	5824	3915	508	17187	1685	158914	3252	182197	191285	-1142
7:15	49.85	191308	5849	4006	1274	19500	1684	160389	3289	186028	195991	-1118
7:30	49.70	195811	5871	3995	2700	21235	1689	161164	3360	189116	200014	-1045
7:45	50.00	198543	5883	3993	4958	21360	1682	161092	3362	189592	202330	-1057
8:00	50.05	200327	5905	4133	8215	20963	1689	159925	3382	187979	204212	-1066
8:15	50.05	203351	5902	4178	12240	20165	1675	159303	3401	186933	206864	-946
8:30	50.05	206100	5902	4128	16890	18828	1705	158353	3435	185082	209241	-800
8:45	50.05	208753	5909	4015	21930	16391	1673	158434	3417	182808	211769	-789
9:00	50.10	211215	5917	3901	26974	13753	1670	158118	3498	180340	213831	-782
9:15	50.05	214743	5890	3878	31286	12625	1665	158591	3548	179579	217483	-923
9:30	50.05	216918	5867	3675	34491	11808	1667	157840	3545	178752	218893	-881
9:45	49.95	218180	5858	3369	37127	10766	1680	157914	3522	177684	220236	-957
10:00	50.00	218697	5844	3864	42520	9317	1673	154451	3533	172313	221202	-944
10:15	49.90	217621	5826	3915	45298	8023	1676	152271	3537	168408	220546	-1089
10:30	49.95	217629	5830	3940	47725	7601	1662	150295	3553	165964	220606	-1154
10:45	50.00	216770	5828	4021	49717	6973	1672	148342	3481	163032	220034	-1228
11:00	49.95	215706	5812	4144	51350	6343	1648	146341	3459	160212	219097	-1315
11:15	49.95	214100	5817	4261	52640	5598	1671	143883	3538	157199	217408	-1354
11:30	50.00	213439	5808	4321	53929	5744	1654	142266	3552	155189	217274	-1405
11:45	50.00	212899	5809	4364	54958	5859	1656	140584	3513	153577	216743	-1540
12:00	50.10	211550	5779	4353	55725	5963	1650	138453	3535	151472	215458	-1716
12:15	50.05	209999	5773	4332	56195	5381	1652	136874	3496	149472	213703	-1672
12:30	50.10	208559	5786	4239	56228	5940	1646	135021	3465	148092	212325	-1761
12:45	50.00	207118	5781	4348	56148	6112	1653	133176	3490	146622	210708	-1748
13:00	50.05	204388	5788	4209	55984	6058	1644	130877	3448	144195	208008	-1776
13:15	50.05	200058	5795	3974	55747	5755	1649	127369	3393	140337	203682	-1773
13:30	50.05	198656	5788	3870	55143	5941	1655	126428	3432	139643	202257	-1759
13:45	50.00	198355	5786	3720	54502	5783	1665	127085	3420	140133	201961	-1763
14:00	50.00	197270	5803	3484	53176	5841	1650	127521	3377	140610	200852	-1757
14:15	50.00	196688	5801	3376	51790	5615	1663	128515	3403	141522	200163	-1744
14:30	49.95	197204	5788	3243	49820	5534	1647	130897	3377	144141	200306	-1715
14:45	49.95	197445	5777	3252	47884	5635	1655	133122	3367	146309	200692	-1761
15:00	49.95	197547	5775	3151	45485	5905	1634	135152	3361	148911	200463	-1774
15:15	49.95	196551	5772	3053	42607	5887	1645	137202	3396	150891	199562	-1666
15:30	50.00	196306	5781	3020	39515	6588	1643	139613	3357	153771	199517	-1678
15:45	50.00	196351	5793	3018	35961	7368	1654	142203	3365	157372	199362	-1646
16:00	50.05	196211	5797	2945	31831	7941	1647	146104	3305	161435	199570	-1488
16:15	50.00	194713	5784	2960	27529	7362	1656	149996	3323	164224	198610	-1376
16:30	49.96	195762	5801	2920	22804	8942	1666	154330	3268	170038	199731	-1229
16:45	50.01	196290	5814	2971	17950	10730	1643	157649	3289	175369	200046	-1154
17:00	49.85	195778	5830	3036	13098	13092	1677	159433	3305	179644	199471	-1033
17:15	49.95	194890	5856	3145	8650	16377	1667	159280	3171	183095	198146	-967
17:30	49.90	195814	5850	3248	5143	19784	1649	160220	3195	187423	199089	-828
17:45	49.75	197637	5898	3375	2877	22528	1687	160884	3250	191385	200499	-799
18:00	49.91	198314	5849	3450	1509	23702	1679	161702	3459	193355	201350	-785
18:15	49.81	199249	5870	3638	1007	24391	1757	161715	3494	194604	201872	-716
18:30	49.91	200341	5872	3917	864	24915	1768	162119	3463	195560	202918	-714
18:45	50.01	200397	5888	4154	826	24921	1775	161853	3498	195417	202915	-760
19:00	50.01	198958	5881	4450	691	23242	1686	162040	3571	193817	201561	-712
19:15	49.96	197725	5866	4743	697	21591	1673	162240	3415	192285	200225	-729
19:30	49.90	195810	5853	5110	698	19947	1668	161524	3379	190002	198179	-732
19:45	49.85	193203	5850	5146	697	18450	1666	160158	3305	187360	195272	-679
20:00	50.05	189957	5848	5278	695	15969	1673	159946	3259	183984	192668	-800
20:15	50.00	186378	5845	5455	121	14281	1682	158371	3191	180802	188946	-1014
20:30	50.00	183738	5836	5593	123	12383	1650	157385	3247	178022	186217	-1015
20:45	49.85	181393	5862	5651	153	11406	1678	155745	3181	175589	183676	-981
21:00	49.95	178711	5912	5823	114	11145	1676	153343	3190	172774	181203	-1152
21:15	50.04	176228	5927	5821	88	11208	1678	150791	3198	170319	178711	-1245
21:30	50.04	172967	5957	5983	85	10685	1672	147915	3256	166899	175553	-1393
21:45	50.04	169617	5931	6200	90	9700	1659	145615	3210	163327	172405	-1537
22:00	50.09	166362	5944	6409	93	8399	1686	143687	3254	159860	169472	-1448
22:15	49.99	165454	5943	6401	95	7955	1845	143028	3226	158958	168493	-1506
22:30	49.99	163858	5932	6472	94	7824	1683	14				