



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 27.12.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 26.12.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 26-दिसंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 26.12.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 27-Dec-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57314	63844	43391	21839	2668	189056
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1228	1512	1088	440	49	4317
Hydro Gen (MU)	104	55	93	14	13	279
Wind Gen (MU)	35	113	32	-	-	180
Solar Gen (MU)*	94.45	60.58	68.32	2.29	1.04	227
Energy Shortage (MU)	0.00	0.15	0.00	0.05	0.00	0.20
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65805	76583	54300	22699	2799	218593
Time Of Maximum Demand Met	10:15	10:32	10:33	18:01	17:36	09:58

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	0.52	1.39	7.09	9.00	76.45	14.55

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8205	0	152.1	61.9	-1.3	295	0.00
	Haryana	8345	0	157.2	99.9	-1.9	631	0.00
	Rajasthan	17930	0	333.8	111.4	-2.5	752	0.00
	Delhi	4619	0	79.3	78.3	-1.5	371	0.00
	UP	19901	0	344.1	96.8	-2.0	443	0.00
	Uttarakhand	2411	0	44.6	34.4	-0.3	134	0.00
	HP	2187	0	40.3	33.2	-1.2	327	0.00
	J&K(UT) & Ladakh(UT)	3102	0	68.4	63.4	2.9	974	0.00
	Chandigarh	262	0	4.4	4.5	-0.1	24	0.00
WR	Railways_NR ISTS	203	0	4.1	3.7	0.3	36	0.00
	Chhattisgarh	5049	0	106.4	53.8	1.4	372	0.00
	Gujarat	22453	0	417.1	182.0	1.8	1770	0.00
	MP	17926	61	336.9	208.7	-3.0	435	0.15
	Maharashtra	28604	0	577.6	207.5	0.4	428	0.00
	Goa	713	0	13.6	13.5	-0.5	80	0.00
	DNHDDPDCL	1336	0	30.6	30.8	-0.2	14	0.00
	AMNSIL	752	0	17.0	8.1	0.2	319	0.00
	BALCO	530	0	12.6	12.7	-0.1	15	0.00
SR	RIL JAMNAGAR	2365	0	0.0	2.3	-2.3	0	0.00
	Andhra Pradesh	9003	0	181.4	49.7	-1.3	451	0.00
	Telangana	13109	0	245.0	151.3	-1.5	969	0.00
	Karnataka	14422	0	256.2	87.4	-0.7	740	0.00
	Kerala	4113	0	81.2	64.9	0.8	313	0.00
	Tamil Nadu	15768	0	315.5	211.4	-0.3	626	0.00
	Puducherry	395	0	8.9	8.6	-0.3	16	0.00
	Bihar	5401	0	93.4	83.5	-2.0	0	0.05
	DVC	3398	0	69.0	-43.7	-0.4	0	0.00
ER	Jharkhand	1985	0	38.0	28.0	-0.9	0	0.00
	Odisha	4841	0	93.6	26.7	-0.9	0	0.00
	West Bengal	7613	0	144.3	2.0	-1.6	0	0.00
	Sikkim	125	0	1.9	2.1	-0.1	0	0.00
	Railways_ER ISTS	16	0	0.2	0.2	-0.1	0	0.00
	Arunachal Pradesh	176	0	3.0	2.8	0.0	34	0.00
	Assam	1566	0	27.2	19.9	0.4	136	0.00
NER	Manipur	251	0	3.8	3.9	-0.1	49	0.00
	Meghalaya	361	0	6.4	5.6	-0.2	299	0.00
	Mizoram	110	0	2.3	1.7	0.0	16	0.00
	Nagaland	154	0	2.5	2.4	0.0	29	0.00
	Tripura	230	0	4.0	3.3	-0.1	44	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-8.2	-3.9	-22.3	-14.0
Day Peak (MW)	-541.0	-421.7	-1003.0	-763.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	228.5	-237.1	190.4	-187.4	5.7	0.0
Actual(MU)	221.1	-227.2	186.3	-194.1	4.8	-9.2
O/D/U/D(MU)	-7.4	9.9	-4.1	-6.7	-0.9	-9.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4975	10131	5368	4058	518	25050	48
State Sector	5863	11417	7674	1909	161	27023	52
Total	10838	21547	13042	5967	679	52073	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	770	1559	632	702	10	3673	78
Lignite	28	13	51	0	0	93	2
Hydro	104	55	93	14	13	279	6
Nuclear	31	54	70	0	0	155	3
Gas, Naptha & Diesel	8	17	5	0	25	55	1
RES (Wind, Solar, Biomass & Others)	155	177	127	5	1	466	10
Total	1096	1875	979	721	49	4720	100

Share of RES in total generation (%)	14.18	9.46	12.95	0.66	2.15	9.86
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	26.52	15.29	29.60	2.64	28.22	19.07

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.051

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	218593	9:58	61
Non-Solar hr	200490	18:27	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES							Import=(+ve) /Export =(-ve) for NET (MU)	
							Date of Reporting: 27-Dec-2024	
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	249	0.0	5.9	-5.9
3	765 kV	GAYA-VARANASI	2	0	1036	0.0	15.9	-15.9
4	765 kV	SASARAM-FATEHPUR	1	0	590	0.0	9.2	-9.2
5	765 kV	GAYA-BALIA	1	0	776	0.0	13.6	-13.6
6	400 kV	PUSAULI-VARANASI	1	0	202	0.0	3.7	-3.7
7	400 kV	PUSAULI -ALLAHABAD	1	0	110	0.0	2.1	-2.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	698	0.0	9.6	-9.6
9	400 kV	PATNA-BALIA	2	0	990	0.0	17.8	-17.8
10	400 kV	NAUBATPUR-BALIA	2	0	329	0.0	5.8	-5.8
11	400 kV	BIHARSHARIFF-BALIA	2	0	324	0.0	7.3	-7.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	522	0.0	8.7	-8.7
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	69	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	100.5	-100.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	729	583	0.0	2.8	-2.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	365	846	0.0	6.7	-6.7
3	765 kV	JHARSUGUDA-DURG	2	0	750	0.0	13.9	-13.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	885	0.0	13.4	-13.4
5	400 kV	RANCHI-SIPAT	2	41	351	0.0	3.6	-3.6
6	220 kV	BUDHIPADAR-RAIGARH	1	0	138	0.0	2.0	-2.0
7	220 kV	BUDHIPADAR-KORBA	2	44	123	0.0	1.3	-1.3
ER-WR						0.0	43.8	-43.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	210	0.0	5.0	-5.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1646	0.0	39.7	-39.7
3	765 kV	ANGUL-SRIKAKULAM	2	0	3030	0.0	56.7	-56.7
4	400 kV	TALCHER-I/C	2	121	360	0.0	1.5	-1.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	101.5	-101.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	343	70	3.3	0.0	3.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	611	9	6.4	0.0	6.4
3	220 kV	ALIPURDUAR-SALAKATI	2	101	0	1.5	0.0	1.5
ER-NER						11.2	0.0	11.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	662	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2020	0.0	29.4	-29.4
2	HVDC	VINDHYACHAL B/B	-	0	55	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	739	0.0	18.2	-18.2
4	765 kV	GWALIOR-AGRA	2	0	1997	0.0	26.1	-26.1
5	765 kV	GWALIOR-PHAGI	2	0	1676	0.0	25.2	-25.2
6	765 kV	JABALPUR-ORAI	2	0	971	0.0	26.0	-26.0
7	765 kV	GWALIOR-ORAI	1	855	0	14.9	0.0	14.9
8	765 kV	SATNA-ORAI	1	0	1052	0.0	18.0	-18.0
9	765 kV	BANASKANTHA-CHITORGARH	2	682	902	2.7	8.6	-5.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	2329	0.0	33.8	-33.8
11	400 kV	ZERDA-KANKROLI	1	155	109	0.8	0.7	0.2
12	400 kV	ZERDA -BHINMAL	1	107	76	0.6	0.5	0.1
13	400 kV	VINDHYACHAL -RIHAND	1	964	0	22.3	0.0	22.3
14	400 kV	RAPP-SHUJALPUR	2	362	279	2.6	0.9	1.7
15	400 kV	NEEMUCH-Chittorgarh	2	439	205	4.0	0.4	3.6
16	220 kV	BHANPURA-RANPUR	1	0	196	0.0	3.2	-3.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.0	-2.0
18	220 kV	MEHGAON-AURAIYA	1	145	0	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	107	8	1.0	0.0	1.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						50.4	194.1	-143.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	2504	0.0	48.2	-48.2
3	765 kV	SOLAPUR-RAICHUR	2	803	1506	1.8	9.2	-7.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2507	0.0	34.5	-34.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2590	0.0	38.4	-38.4
6	400 kV	KOLHAPUR-KUDGI	2	1448	0	23.9	0.0	23.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	108	1.9	0.0	1.9
WR-SR						27.6	154.4	-126.7
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-178	143	-57	-1.37		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-239	193	-58	-1.39		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-257	-114	-194	-4.65		
	NER	132kV GELEPHU-SALAKATI	-36	0	-27	-0.64		
	NER	132kV MOTANGA-RANGIA	-11	2	-7	-0.17		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-59	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-59	0	-33	-0.79		
	ER	NEPAL IMPORT (FROM BIHAR)	-164	0	-79	-1.90		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-258	-49	-52	-1.24		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-652	-878	-21.08		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-763	-400	-582	-13.98		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-62	0	-49	-1.18		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	9.18	0.00	0.00	0.00	0.00	0.00	9.18	
Nepal	2.01	0.00	1.93	0.00	0.00	0.00	0.08	0.00	0.00	4.02
Bangladesh	21.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.90
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.91	0.00	11.11	0.00	0.00	0.00	0.08	0.00	0.00	35.10

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.59
Nepal	0.00	0.00	0.00	0.00	0.00	0.44	0.00	0.00	0.44
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.59	0.00	0.00	0.00	0.00	0.44	0.00	0.00	1.03

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.59	0.00	-9.18	0.00	0.00	0.00	0.00	0.00	-8.59
Nepal	-2.01	0.00	-1.93	0.00	0.00	0.36	0.00	0.00	-3.58
Bangladesh	-21.90	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.90
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.32	0.00	-11.11	0.00	0.00	0.36	0.00	0.00	-34.07

Date of Reporting: 27-Dec-2024												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.06	149004	6079	12454	72	6947	1632	125181	3039	136478	155404	-1615
0:15	49.91	148081	6077	12448	71	6928	1637	124435	3052	135562	154648	-1617
0:30	49.96	147198	6088	12457	78	7095	1623	123358	3070	134663	153769	-1580
0:45	49.96	146542	6082	12422	76	7013	1652	122841	3035	134044	153121	-1497
1:00	49.96	145789	6083	12327	76	6851	1637	122081	3036	133386	152091	-1404
1:15	50.01	144641	6083	12142	83	6795	1629	121306	3064	132416	151102	-1405
1:30	50.01	144045	6089	11931	79	6631	1633	121130	3021	132035	150514	-1352
1:45	50.01	143137	6097	11717	82	6655	1627	120459	3020	131338	149657	-1387
2:00	50.01	142507	6071	11469	79	6630	1643	119986	3079	130959	148957	-1385
2:15	49.96	142072	6081	11184	82	6611	1634	120112	3041	130806	148745	-1394
2:30	49.96	141822	6086	10994	82	6608	1634	120067	3039	130746	148510	-1398
2:45	50.01	141592	6078	10746	81	6559	1622	120019	3032	130765	148137	-1277
3:00	50.01	141082	6088	10535	81	6572	1629	119713	3025	130466	147643	-1287
3:15	49.96	141530	6081	10330	76	6643	1854	120288	3010	131124	148282	-1328
3:30	49.96	141853	6079	10191	81	6740	1859	120541	2998	131581	148489	-1298
3:45	50.01	141831	6076	10064	77	7238	1851	120336	3008	131690	148650	-1293
4:00	50.01	142376	6083	9902	77	7388	1864	120895	3086	132397	149295	-1320
4:15	50.01	144856	6084	9842	77	8015	1873	122801	3041	134937	151733	-1263
4:30	50.06	146017	6079	9733	73	7961	1864	124385	3026	136211	153121	-1334
4:45	50.01	148228	6090	9730	79	8146	1865	126230	3011	138419	155151	-1306
5:00	50.01	150283	6074	9683	82	7965	1868	128793	3043	140518	157508	-1383
5:15	50.01	154414	6080	9626	81	8318	1867	132531	2996	144707	161499	-1394
5:30	50.06	158342	6083	9499	81	8771	1926	135556	3007	148762	164923	-1254
5:45	50.01	161848	6085	9400	79	9129	2021	138694	3082	152369	168490	-1226
6:00	50.11	165475	6075	9250	72	9784	2338	140863	3061	156153	171443	-893
6:15	50.06	169734	6095	9027	145	10943	2613	143768	3033	160562	175624	-1012
6:30	50.06	176146	6084	8806	151	13398	2904	147785	3053	167189	182181	-980
6:45	50.06	181155	6095	8585	174	15031	3062	151481	3003	172396	187431	-1091
7:00	50.06	186643	6092	8510	340	16947	3236	155056	3050	177793	193231	-1173
7:15	50.05	191015	6107	8419	751	17217	3451	158320	3062	181845	197327	-1245
7:30	50.01	196611	6092	8362	1474	19801	3472	160701	3010	186775	202912	-1238
7:45	50.01	200411	6079	8338	2520	21279	3453	161637	3065	189553	206371	-1199
8:00	50.06	202443	6092	8201	4165	21721	3636	161604	3058	190077	208477	-1177
8:15	49.95	205827	6083	8077	6291	21425	3619	163044	3149	191459	211688	-1085
8:30	50.00	208219	6089	7896	8526	20785	3643	163572	3129	191797	213640	-1065
8:45	49.95	210405	6079	7732	10644	20365	3661	164095	3186	192029	215762	-1096
9:00	50.00	212040	6083	7319	13039	19179	3678	164833	3172	191682	217303	-1086
9:15	49.70	214044	6083	6714	15636	18622	3687	165269	3191	191694	219202	-1087
9:30	49.85	215989	6066	6132	18417	18834	3657	165026	3203	191440	221335	-1145
9:45	49.85	218163	6067	5494	21304	18809	3673	164813	3241	191365	223401	-1156
10:00	50.00	218309	6078	4995	23468	17912	3649	164032	3206	189846	223340	-1174
10:15	49.95	218508	6054	4706	25613	16686	3645	163602	3185	188189	223491	-1232
10:30	50.00	217985	6061	4475	27703	14882	3651	163494	3131	185807	223397	-1474
10:45	50.02	217212	6066	4146	29906	14156	3646	161974	3175	183160	223069	-1640
11:00	49.97	215857	6069	3993	31489	12556	2856	162010	3164	180375	222137	-1798
11:15	49.97	213863	6079	3816	32862	11017	2943	160901	3176	177185	220794	-1879
11:30	49.97	212551	6093	3785	34176	10030	2922	158856	3217	174590	219079	-1850
11:45	50.02	211121	6074	3757	35651	9275	2914	157121	3207	171713	217999	-1863
12:00	50.07	208324	6064	3809	36700	8925	2137	154482	3189	167815	215306	-1849
12:15	50.02	206768	6068	3977	36722	8355	1980	153201	3228	166069	213531	-1893
12:30	50.07	206225	6066	4075	37838	8254	1957	151415	3214	164312	212819	-1880
12:45	50.02	203747	6079	4224	37245	7996	1971	149722	3235	162278	210472	-1891
13:00	50.07	200694	6079	4357	35938	7908	1955	147895	3217	160399	207349	-1909
13:15	50.02	196768	6061	4606	35989	7715	1934	143654	3229	156173	203188	-1886
13:30	50.07	195643	6054	4712	35658	7777	1968	142886	3223	155273	202278	-1937
13:45	49.97	194929	6066	4908	34000	7721	1947	143614	3218	156021	201474	-1912
14:00	49.97	194240	6056	5066	32036	7908	1944	144423	3188	157138	200621	-1970
14:15	49.97	193614	6053	5233	29763	8038	1913	146014	3148	158618	200162	-1927
14:30	49.82	193353	6040	5489	27850	8185	1916	147456	3130	160014	200066	-1918
14:45	49.82	193243	6035	5626	25150	8418	1917	149863	3138	162467	200147	-1975
15:00	49.72	193280	6040	5721	22463	9169	1935	151648	3095	165096	200071	-1939
15:15	49.87	192997	6054	5851	20479	9268	1963	153323	3109	166667	200047	-1919
15:30	49.82	193369	6039	5806	18358	10011	1964	155083	3099	169205	200360	-1941
15:45	49.92	193703	6053	5917	16693	10505	1995	156420	3158	171093	200741	-1916
16:00	49.97	192700	6043	5990	13728	11037	2009	157521	3162	172982	199490	-1850
16:15	49.97	191292	6038	6035	11570	10815	2037	158143	3098	173687	197736	-1595
16:30	49.97	191440	6049	6175	9319	10773	1809	160159	3121	175946	197405	-1454
16:45	49.92	191695	6063	6165	7091	11807	2017	161111	3061	178439	197315	-1134
17:00	50.02	192774	6057	6204	5187	14532	2020	161327	3030	181383	198357	-1128
17:15	50.02	192909	6042	6262	3354	16543	1779	160972	3036	183293	197988	-1098
17:30	50.02	195219	6053	6327	1933	19057	2036	162082	3063	186959	200551	-1096
17:45	50.02	197412	6055	6353	919	21769	2040	162594	3129	190140	202859	-1137
18:00	50.07	197416	6050	6495	429	23414	2032	161390	3031	190492	202841	-1119
18:15	49.92	198836	6048	6757	238	24083	2048	161633	3075	191841	203882	-1028
18:30	50.02	200335	6068	7182	163	24548	1823	162476	3001	192990	205261	-1050
18:45	50.02	199181	6047	7669	170	23730	2069	161679	3047	191342	204411	-1055
19:00	50.07	197227	6062	8089	151	22516	1806	160579	3018	188987	202221	-1059
19:15	50.07	194259	6056	8560	153	19666	1811	160057	2986	185546	199289	-1055
19:30	50.02	191694	6054	8860	150	17726	1988	159035	2983	182684	196796	-1058
19:45	50.07	187554	6061	9173	144	15647	1791	156753	2978	178237	192547	-1043
20:00	50.02	183446	6054	9583	85	13500	1780	154440	2985	173778	188427	-1015
20:15	50.02	180473	6076	9906	94	12386	1781	152520	3051	170473	185814	-1078
20:30	50.02	177562	6054	10164	93	12237	1883	149702	3010	167305	183143	-1030
20:45	49.92	175984	6069	10366	52	11530	1906	148256	3007	165566	181186	-1003
21:00	50.07	172837	6073	10550	49	10956	1783	146000	3011	162238	178422	-1163
21:15	49.97	169833	6077	10624	47	10278	1890	144031	3008	159162	175955	-1383
21:30	50.02	166498	6064	10621	49	10250	1805	142283	3016	155828	174088	-1630
21:45	49.97	165629	6074	10777	49	9474	1782	140892	3074	154803	172122	-1570
22:00	50.07	162065	6089	10751	47	8865	1745	138090	3007	151267	168594	-1666
22:15	49.92	161694	6065	10756	53	9122	1796	137172	3007	150885	167971	-1623
22:30	49.97	159997	6075	10735	54	9439</						