



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 31.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 30.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 30-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 30.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 31-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	58979	66863	47916	23708	2753	200219
Peak Shortage (MW)	0	1172	0	0	0	1172
Energy Met (MU)	1288	1620	1259	482	52	4700
Hydro Gen (MU)	95	52	94	23	10	275
Wind Gen (MU)	21	50	49	-	-	120
Solar Gen (MU)*	154.87	115.60	124.97	3.23	0.61	399
Energy Shortage (MU)	0.00	3.14	0.00	0.00	0.00	3.14
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	67960	79688	62950	23972	2916	234525
Time Of Maximum Demand Met	10:46	10:39	09:56	18:23	17:47	09:55

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.069	0.58	2.49	11.90	14.96	69.37	15.67

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9560	0	169.9	69.5	0.3	546	0.00
	Haryana	8847	0	165.9	110.9	-1.2	684	0.00
	Rajasthan	18499	0	352.8	113.2	-1.9	482	0.00
	Delhi	4498	0	77.8	70.8	-1.8	373	0.00
	UP	19713	0	365.0	111.5	-1.1	391	0.00
	Uttarakhand	2479	0	44.9	35.5	-0.1	163	0.00
	HP	2127	0	37.9	32.4	-1.0	206	0.00
	J&K(UT) & Ladakh(UT)	3035	0	65.1	64.0	-2.8	666	0.00
	Chandigarh	263	0	4.1	4.3	-0.2	26	0.00
WR	Railways_NR ISTS	194	0	4.2	3.9	0.2	27	0.00
	Chhattisgarh	5890	0	123.8	74.5	1.6	777	1.20
	Gujarat	23267	0	441.5	188.8	0.0	911	0.00
	MP	18462	0	346.5	212.9	-1.4	755	1.94
	Maharashtra	29826	0	628.9	238.6	3.5	909	0.00
	Goa	718	0	14.5	13.3	0.9	87	0.00
	DNHDDPDCL	1328	0	30.7	30.9	-0.2	37	0.00
	AMNSIL	775	0	16.7	7.5	0.1	319	0.00
	BALCO	533	0	12.7	12.7	0.0	32	0.00
SR	RIL JAMNAGAR	185	0	4.4	4.5	-0.1	0	0.00
	Andhra Pradesh	12027	0	221.7	49.1	-0.2	652	0.00
	Telangana	14896	0	282.8	135.6	-1.8	1318	0.00
	Karnataka	17390	0	311.0	100.9	-0.8	713	0.00
	Kerala	4465	0	86.9	67.9	1.3	252	0.00
	Tamil Nadu	17089	0	347.3	201.4	1.1	997	0.00
	Puducherry	414	0	8.9	8.5	-0.1	38	0.00
	Bihar	5335	0	99.0	86.6	-0.2	215	0.00
	DVC	3296	0	68.4	-45.9	-3.1	290	0.00
ER	Jharkhand	2093	0	38.9	27.3	-0.6	152	0.00
	Odisha	5551	0	111.1	39.1	-1.5	357	0.00
	West Bengal	7797	0	162.2	33.0	-1.6	127	0.00
	Sikkim	119	0	2.1	2.1	-0.1	30	0.00
	Railways_ER ISTS	30	0	0.3	0.2	0.1	0	0.00
	Arunachal Pradesh	184	0	3.5	3.1	0.3	46	0.00
	Assam	1584	0	28.0	24.0	0.3	97	0.00
NER	Manipur	256	0	3.7	3.6	0.1	42	0.00
	Meghalaya	382	0	7.3	5.5	0.0	126	0.00
	Mizoram	159	0	2.4	1.9	0.1	37	0.00
	Nagaland	157	0	2.4	2.3	0.0	51	0.00
	Tripura	233	0	4.5	2.6	0.9	126	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.0	-9.3	-21.9	-14.8
Day Peak (MW)	-426.5	-531.0	-1020.0	-770.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	219.5	-190.7	145.7	-187.3	12.8	0.0
Actual(MU)	209.0	-176.1	138.5	-195.4	15.0	-9.0
O/D/U/D(MU)	-10.4	14.6	-7.2	-8.1	2.2	-9.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4742	8736	4758	3356	1018	22610	45
State Sector	5893	12901	5009	3199	170	27172	55
Total	10635	21637	9767	6555	1188	49782	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	791	1613	727	741	16	3888	77
Lignite	29	13	58	0	0	101	2
Hydro	95	52	94	23	10	275	5
Nuclear	32	55	71	0	0	158	3
Gas, Naptha & Diesel	10	19	10	0	14	54	1
RES (Wind, Solar, Biomass & Others)	202	168	225	7	1	603	12
Total	1160	1921	1186	771	41	5079	100

Share of RES in total generation (%)	17.44	8.77	18.98	0.87	1.49	11.87
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	28.41	14.33	32.94	3.90	26.77	20.41

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.038

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	234525	9:55	91
Non-Solar hr	206930	17:00	100

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES							Import=(+ve) /Export =(-ve) for NET (MU)	
							Date of Reporting: 31-Jan-2025	
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	49	0.0	1.1	-1.1
3	765 kV	GAYA-VARANASI	2	0	1242	0.0	22.0	-22.0
4	765 kV	SASARAM-FATEHPUR	1	0	614	0.0	11.6	-11.6
5	765 kV	GAYA-BALIA	1	0	768	0.0	13.0	-13.0
6	400 kV	PUSAULI-VARANASI	1	0	70	0.0	0.9	-0.9
7	400 kV	PUSAULI -ALLAHABAD	1	40	30	0.0	0.0	0.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	592	0.0	7.5	-7.5
9	400 kV	PATNA-BALIA	2	0	871	0.0	16.0	-16.0
10	400 kV	NAUBATPUR-BALIA	2	0	381	0.0	4.9	-4.9
11	400 kV	BIHARSHARIFF-BALIA	2	14	347	0.0	4.1	-4.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	621	0.0	10.1	-10.1
13	400 kV	BIHARSHARIFF-VARANASI	2	0	419	0.0	0.0	0.0
14	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	7.2	-7.2
15	220 kV	SAHUPURI-KARAMNESA	1	0	63	0.0	1.1	-1.1
16	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
17	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
18	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
19	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	99.5	-98.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	519	523	1.0	0.0	1.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	357	734	0.0	4.2	-4.2
3	765 kV	JHARSUGUDA-DURG	2	0	995	0.0	20.4	-20.4
4	400 kV	JHARSUGUDA-RAIGARH	4	0	846	0.0	14.3	-14.3
5	400 kV	RANCHI-SIPAT	2	33	326	0.0	3.5	-3.5
6	220 kV	BUDHIPADAR-RAIGARH	1	0	92	0.0	1.2	-1.2
7	220 kV	BUDHIPADAR-KORBA	2	59	123	0.0	0.5	-0.5
ER-WR						1.0	44.1	-43.2
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	362	0.0	8.6	-8.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1249	0.0	30.2	-30.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2659	0.0	49.0	-49.0
4	400 kV	TALCHER-I/C	2	186	0	2.2	0.0	2.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	87.8	-87.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	153	245	0.5	1.0	-0.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	311	299	0.8	0.0	0.8
3	220 kV	ALIPURDUAR-SALAKATI	2	71	22	0.5	0.0	0.5
ER-NER						1.8	1.0	0.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	16.2	0.0	16.2
NER-NR						16.2	0.0	16.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2011	0.0	48.1	-48.1
2	HVDC	VINDHYACHAL B/B	-	157	133	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1170	0.0	29.0	-29.0
4	765 kV	GWALIOR-AGRA	2	173	1867	0.1	21.1	-21.0
5	765 kV	GWALIOR-PHAGI	2	0	1718	0.0	22.9	-22.9
6	765 kV	JABALPUR-ORAI	2	0	1110	0.0	26.1	-26.1
7	765 kV	GWALIOR-ORAI	1	807	0	14.8	0.0	14.8
8	765 kV	SATNA-ORAI	1	0	906	0.0	17.1	-17.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1230	507	11.2	0.0	11.2
10	765 kV	VINDHYACHAL-VARANASI	2	149	1711	0.0	18.4	-18.4
11	400 kV	ZERDA-KANKROLI	1	239	35	2.6	0.0	2.5
12	400 kV	ZERDA -BHINMAL	1	165	24	1.8	0.0	1.8
13	400 kV	VINDHYACHAL -RIHAND	1	977	0	21.7	0.0	21.7
14	400 kV	RAPP-SHUJALPUR	2	525	355	3.8	1.0	2.8
15	400 kV	NEEMUCH-Chittorgarh	2	351	401	2.5	1.3	1.2
16	220 kV	BHANPURA-RANPUR	1	0	209	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	117	0	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	89	17	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						60.6	192.9	-132.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1007	0.0	12.3	-12.3
2	HVDC	RAIGARH-PUGALUR	2	0	2503	0.0	42.9	-42.9
3	765 kV	SOLAPUR-RAICHUR	2	1428	777	7.6	4.1	3.5
4	765 kV	WARDHA-NIZAMABAD	2	160	2015	0.1	27.8	-27.7
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2295	0.0	33.8	-33.8
6	400 kV	KOLHAPUR-KUDGI	2	1611	0	25.7	0.0	25.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	90	0.0	1.5	-1.5
9	220 kV	XELDEM-AMBEWADI	1	0	117	2.2	0.0	2.2
WR-SR						35.5	122.3	-86.8
INTERNATIONAL EXCHANGES								
State		Region	Line Name		Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)			172	-9	55	1.31
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)			-282	84	-134	-3.21
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)			-253	-116	-205	-4.92
	NER	132kV GELEPHU-SALAKATI			-20	-7	-13	-0.32
	NER	132kV MOTANGA-RANGIA			11	0	5	0.13
NEPAL	NR	NEPAL IMPORT (FROM UP)			-66	0	-34	-0.82
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)			-66	0	-35	-0.85
	ER	NEPAL IMPORT (FROM BIHAR)			-170	0	-143	-3.44
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2			-367	-4	-173	-4.15
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)			-948	-660	-861	-20.65
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C			-770	-402	-616	-14.78
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2			-72	0	-52	-1.25

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.33	7.86	0.00	0.00	0.00	0.00	0.00	8.19	
Nepal	3.24	0.00	3.67	0.00	0.00	0.00	0.95	0.00	0.00	7.86
Bangladesh	21.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.32
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.56	0.33	11.53	0.00	0.00	0.00	0.95	0.00	0.00	37.37

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.79	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.79

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.79	-0.33	-7.86	0.00	0.00	0.00	0.00	0.00	-7.40
Nepal	-3.24	0.00	-3.67	0.00	0.00	-0.95	0.00	0.00	-7.86
Bangladesh	-21.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.32
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.77	-0.33	-11.53	0.00	0.00	-0.95	0.00	0.00	-36.58

