



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 12.08.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 11.08.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 11-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 11.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 12-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	77811	65300	46672	30026	3656	223465
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1708	1531	1062	638	69	5007
Hydro Gen (MU)	437	105	179	110	40	871
Wind Gen (MU)	45	149	158	-	-	352
Solar Gen (MU)*	207.73	136.10	108.60	3.11	0.49	456
Energy Shortage (MU)	0.00	0.00	0.00	0.26	0.00	0.26
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	77453	68674	49078	30880	3665	224830
Time Of Maximum Demand Met	22:19	15:54	09:47	23:11	19:55	19:35

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.027	0.00	0.00	1.81	1.81	83.45	14.74

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15465	0	321.2	213.7	0.4	1081	0.00
	Haryana	11767	0	249.4	195.8	-3.4	185	0.00
	Rajasthan	15976	0	351.7	138.7	-4.1	523	0.00
	Delhi	6397	0	131.9	119.5	-1.3	197	0.00
	UP	26433	0	507.2	217.6	0.9	459	0.00
	Uttarakhand	2187	0	45.9	21.2	0.3	221	0.00
	HP	1760	0	35.2	-9.6	-0.4	120	0.00
	J&K(UT) & Ladakh(UT)	2615	0	55.1	29.4	1.9	267	0.00
	Chandigarh	327	0	6.7	6.7	0.0	21	0.00
	Railways NR ISTS	207	0	4.2	3.8	0.3	38	0.00
WR	Chhattisgarh	6428	0	145.2	86.7	0.4	416	0.00
	Gujarat	24265	0	493.0	195.1	-3.0	933	0.00
	MP	12061	0	265.4	132.9	-0.7	484	0.00
	Maharashtra	24929	0	544.9	218.5	-1.9	630	0.00
	Goa	566	0	14.1	11.7	2.0	42	0.00
	DNHDDPDCL	1327	0	30.4	30.6	-0.2	41	0.00
	AMNSIL	861	0	19.2	12.4	0.1	303	0.00
	BALCO	532	0	12.7	12.7	0.0	8	0.00
	RIL JAMNAGAR	250	0	5.6	5.7	-0.1	0	0.00
	Andhra Pradesh	9618	0	211.4	37.6	-1.6	440	0.00
SR	Telangana	11528	0	224.0	77.5	-0.9	388	0.00
	Karnataka	10601	0	201.4	27.4	-0.6	1307	0.00
	Kerala	4132	0	81.4	41.7	-3.5	188	0.00
	Tamil Nadu	16395	0	334.5	144.2	-2.2	1048	0.00
	Puducherry	431	0	8.9	8.7	-0.2	23	0.00
	Bihar	7844	0	155.6	150.2	-5.5	413	0.26
ER	DVC	3131	0	65.0	-37.8	-1.4	313	0.00
	Jharkhand	2253	0	45.6	35.2	1.2	312	0.00
	Odisha	6891	0	138.7	49.7	-1.1	502	0.00
	West Bengal	11254	0	231.7	102.2	-1.9	261	0.00
	Sikkim	77	0	1.2	1.2	0.0	16	0.00
	Railways ER ISTS	12	0	0.1	0.1	0.0	0	0.00
NER	Arunachal Pradesh	188	0	3.5	3.4	-0.4	14	0.00
	Assam	2392	0	44.5	37.9	1.2	161	0.00
	Manipur	215	0	3.3	3.2	0.1	42	0.00
	Meghalaya	350	0	6.1	1.5	-0.1	48	0.00
	Mizoram	119	0	2.0	0.8	-0.5	0	0.00
	Nagaland	180	0	3.2	2.9	-0.1	18	0.00
	Tripura	344	0	6.5	4.9	0.2	50	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	56.6	19.7	-24.2	-28.3
Day Peak (MW)	2775.5	915.4	-1017.8	-1460.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	323.4	-238.4	-10.4	-76.1	1.5	0.0
Actual(MU)	304.5	-223.4	-19.8	-70.3	2.0	-6.9
OD/UD(MU)	-18.9	15.0	-9.4	5.9	0.5	-6.9

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4852	12643	7618	4270	452	29835	51
State Sector	7644	11146	6752	3049	199	28790	49
Total	12496	23789	14370	7319	651	58625	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	721	1386	605	657	12	3381	63
Lignite	22	11	35	0	0	68	1
Hydro	437	105	179	110	40	871	16
Nuclear	37	46	47	0	0	130	2
Gas, Naptha & Diesel	14	21	3	0	19	58	1
RES (Wind, Solar, Biomass & Others)	259	288	292	6	0	846	16
Total	1490	1859	1161	773	71	5354	100

Share of RES in total generation (%)	17.38	15.50	25.19	0.77	0.69	15.80
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	49.19	23.67	44.64	15.02	56.29	34.50

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.077

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	219753	14:48	0
Non-Solar hr	224830	19:35	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 12-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	752	0.0	18.5	-18.5
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	633	715	0.0	3.2	-3.2
4	765 kV	SASARAM-FATEHPUR	1	229	371	0.0	1.6	-1.6
5	765 kV	GAYA-BALIA	1	23	898	0.0	10.6	-10.6
6	400 kV	PUSAULI-VARANASI	1	0	118	0.0	1.8	-1.8
7	400 kV	PUSAULI-ALLAHABAD	1	28	51	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	737	0.0	10.0	-10.0
9	400 kV	PATNA-BALIA	2	249	968	0.0	9.8	-9.8
10	400 kV	NAUBATPUR-BALIA	2	137	304	0.0	2.3	-2.3
11	400 kV	BIHARSHARIFF-BALIA	2	387	290	0.3	0.0	0.3
12	400 kV	MOTIHARI-GORAKHPUR	2	13	467	0.0	5.5	-5.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	227	288	0.0	1.8	-1.8
14	220 kV	SAHUPURI-KARAMNESA	1	10	86	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	1.1	68.8
								-67.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1093	250	11.8	0.0	11.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1676	216	26.5	0.0	26.5
3	765 kV	JHARSUGUDA-DURG	2	112	551	0.0	4.6	-4.6
4	400 kV	JHARSUGUDA-RAIGARH	4	234	371	0.0	0.9	-0.9
5	400 kV	RANCHI-SIPAT	2	350	195	4.3	0.0	4.3
6	400 kV	JEYPORE-JAGDALPUR	2	305	226	0.0	0.6	-0.6
7	220 kV	BUDHIPADAR-RAIGARH	1	0	145	0.0	2.3	-2.3
8	220 kV	BUDHIPADAR-KORBA	2	5	157	0.0	1.7	-1.7
						ER-WR	42.5	10.1
								32.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	117	0.0	2.7	-2.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1511	0.0	37.5	-37.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2586	0.0	26.0	-26.0
4	400 kV	TALCHER-I/C	2	872	631	2.2	0.0	2.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	0.0	66.2
								-66.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	74	253	0.3	2.2	-1.9
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	489	0.0	6.8	-6.8
3	220 kV	ALIPURDUAR-SALAKATI	2	0	114	0.0	1.5	-1.5
						ER-NER	0.3	10.5
								-10.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.6	-8.6
						NER-NR	0.0	8.6
								-8.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3554	0.0	75.4	-75.4
2	HVDC	VINDHYACHAL-B/B	-	0	156	0.0	3.6	-3.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1916	0.0	36.5	-36.5
4	765 kV	GWALIOR-AGRA	2	228	2287	0.2	27.1	-27.0
5	765 kV	GWALIOR-PHAGI	2	987	1715	4.2	21.4	-17.1
6	765 kV	JABALPUR-ORAI	2	80	1324	0.0	29.2	-29.2
7	765 kV	GWALIOR-ORAI	1	892	0	13.0	0.0	13.0
8	765 kV	SATNA-ORAI	1	0	1013	0.0	16.4	-16.4
9	765 kV	BANASKANTHA-CHITORGARH	2	1749	560	12.3	0.8	11.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3218	0.0	51.4	-51.4
11	400 kV	ZERDA-KANKROLI	1	357	3	3.5	0.0	3.5
12	400 kV	ZERDA-BHINMAL	1	246	2	2.4	0.0	2.4
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	521	467	3.7	3.8	-0.1
15	400 kV	NEEMUCH-Chittorgarh	2	348	612	2.1	5.9	-3.9
16	220 kV	BHANPURA-RANPUR	1	0	136	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.5	-2.5
18	220 kV	MEHGAON-AURAIYA	1	89	10	0.7	0.0	0.7
19	220 kV	MALANPUR-AURAIYA	1	64	26	0.2	0.1	0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	42.2	276.6
								-234.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	309	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGAULUR	2	0	606	0.0	14.7	-14.7
3	765 kV	SOLAPUR-RAICHUR	2	2953	646	35.2	1.1	34.2
4	765 kV	WARDHAN-NIZAMABAD	2	1509	2047	8.1	10.2	-2.1
5	765 kV	WARORA-WARANGAL(NEW)	2	1279	2028	6.2	10.9	-4.7
6	400 kV	KOLHAPUR-KUDGI	2	1914	0	36.1	0.0	36.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.1	0.0	2.1
						WR-SR	87.8	44.1
								43.7

INTERNATIONAL EXCHANGES				Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1589	1213	1400	33.60
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	930	801	847	20.33
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	197	34	83	1.98
	NER	132kV GELEPHU-SALAKATI	66	4	26	0.63
	NER	132kV MOTANGA-RANGIA	9	0	3	0.07
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	65	0	52	1.24
	ER	NEPAL IMPORT (FROM BIHAR)	156	111	134	3.21
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	708	610	637	15.29
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-970	-964	-968	-23.22
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1460	-951	-1181	-28.34
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-51	0	-43	-1.02

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 12-Aug-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.86	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.99
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.86	0.13	0.00	0.00	0.00	0.00	0.00	0.00	23.99

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.84	0.00	1.61	0.00	0.00	0.16	0.00	0.00	55.61
Nepal	8.40	0.13	5.39	0.00	0.00	5.61	0.00	0.00	19.53
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	62.24	0.13	7.00	0.00	0.00	5.77	0.00	0.00	75.14

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.84	0.00	1.61	0.00	0.00	0.16	0.00	0.00	55.61
Nepal	8.40	0.13	5.39	0.00	0.00	5.61	0.00	0.00	19.53
Bangladesh	-23.86	-0.13	0.00	0.00	0.00	0.00	0.00	0.00	-23.99
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	38.38	0.00	7.00	0.00	0.00	5.77	0.00	0.00	51.15

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.02	201860	5029	13931	0	35471	2134	144421	1789	187929	202775	1867
0:15	50.02	200156	5024	13977	0	35749	2131	142765	1739	186179	201385	1945
0:30	49.97	198809	5019	13961	0	35571	2128	141290	1739	184848	199708	1921
0:45	49.97	197288	5017	13831	0	35367	2139	140079	1747	183457	198180	1927
1:00	49.97	196173	5041	13548	0	35247	2132	139755	1712	182625	197435	1937
1:15	49.97	194320	5044	13488	0	34982	2151	138186	1742	180832	195593	2121
1:30	49.92	193376	5042	13425	0	35217	2178	137011	1767	179951	194640	2101
1:45	49.97	192023	5047	13439	0	34930	2160	136144	1752	178584	193472	2085
2:00	49.97	191158	5064	13344	0	34519	2188	135542	1787	177814	192444	2122
2:15	49.92	190220	5069	13269	0	34751	2149	134561	1718	176951	191517	2125
2:30	49.92	189379	5070	13210	0	34873	2147	133539	1672	176169	190511	2116
2:45	49.92	188774	5072	13079	0	34821	2187	133137	1693	175695	189989	2088
3:00	49.92	187845	5093	13079	0	34308	2188	132659	1662	174766	188989	2099
3:15	49.97	187897	5088	12724	0	34030	2198	133262	1693	175173	188995	2126
3:30	49.97	187047	5083	12606	0	33910	2141	132754	1704	174441	188198	2097
3:45	49.97	186585	5082	12323	0	33654	2122	132735	1685	174262	187601	2086
4:00	49.97	186371	5118	12066	0	33796	2185	132639	1736	174305	187540	2074
4:15	49.87	186000	5095	11867	0	33952	2144	132977	1645	174133	187680	2109
4:30	49.92	187186	5092	11570	0	33935	2192	133854	1646	175616	188289	2072
4:45	49.97	187679	5101	11560	0	34076	2166	134274	1674	176119	188851	2070
5:00	50.02	187736	5118	11479	-10	34163	2179	134317	1658	176267	188904	2078
5:15	49.97	188247	5112	11118	-9	34323	2185	135133	1662	177138	189524	2075
5:30	49.97	189189	5102	10680	-11	34305	2185	136372	1736	178520	190369	2106
5:45	49.97	190043	5107	10389	3	34104	2146	137764	1658	179651	191171	2119
6:00	50.02	190980	5128	10231	15	33857	2113	139093	1698	180734	192135	2107
6:15	49.97	193603	5125	9984	339	34529	2105	141195	1686	183280	194963	2084
6:30	49.97	197045	5121	9927	1048	34713	2078	143680	1721	186070	198288	2068
6:45	49.97	198757	5119	9854	2459	34582	2087	144034	1722	186444	199857	2102
7:00	49.97	198916	5123	9635	4943	34107	2117	142556	1686	184338	200167	2146
7:15	49.97	200929	5124	9522	7926	34314	2053	141138	1763	183481	201840	2224
7:30	50.02	201229	5091	9409	11826	34413	2074	137640	1827	179994	202280	2251
7:45	50.07	201104	5112	9039	16142	33886	2056	134052	1818	175923	202105	2249
8:00	50.07	200374	5114	8849	19715	33388	2048	130703	1817	171810	201634	2206
8:15	50.02	201853	5099	8914	23600	33203	2062	128506	1841	169339	203225	2196
8:30	50.07	202764	5086	9608	28001	33203	2120	124893	1845	165155	204756	2220
8:45	50.07	204262	5091	9901	32279	32855	2052	122128	1847	162082	206153	2224
9:00	50.07	205658	5090	10108	36002	32323	2100	120067	1858	159548	207548	2194
9:15	49.97	209985	5107	10553	39264	31868	2026	121187	1839	160168	211844	2188
9:30	49.97	211437	5085	10966	42402	31272	2102	119480	1859	158069	213166	2218
9:45	49.97	213142	5088	11795	45149	30815	2121	117953	1887	156198	214808	2269
10:00	50.02	213684	5089	12018	47636	30362	2113	116275	1865	154030	215358	2204
10:15	49.97	214785	5059	12452	49014	29879	2108	116041	1930	153319	216483	2213
10:30	49.97	215245	5073	13186	50362	29993	2128	114283	1920	151697	216945	2248
10:45	49.97	216142	5084	13269	51568	30108	2105	113629	1911	151305	217674	2290
11:00	49.97	215576	5087	13319	52379	30071	2109	112553	1897	149878	217415	2256
11:15	49.97	215478	5089	13410	54444	30128	2105	110336	1834	147624	217346	2241
11:30	50.02	216228	5080	13837	55171	30097	2117	109832	1845	147220	217979	2235
11:45	50.02	216437	5083	14082	55404	29995	2134	109912	1902	146951	218512	2269
12:00	49.97	215547	5085	14003	53960	30180	2084	110376	1867	147584	217555	2255
12:15	50.02	215122	5101	14114	53250	29941	2062	110531	1857	147758	216856	2267
12:30	50.02	215301	5085	14163	55387	29490	2122	108739	1899	145751	216885	2256
12:45	50.02	214920	5081	14231	55870	29418	2253	107974	1898	144819	216725	2283
13:00	50.12	213259	5072	14448	55028	29169	2148	106902	1906	143783	214673	2280
13:15	50.17	211633	5094	14794	55237	28149	2128	106140	1892	141602	213434	2223
13:30	50.07	212226	5095	15097	55046	28965	2246	105693	1876	142083	214018	2218
13:45	50.02	213357	5103	15043	54396	29520	2146	106943	1894	143918	215045	2254
14:00	50.02	213561	5096	15032	53359	29650	2240	107959	1889	145170	215225	2502
14:15	49.92	215448	5100	15055	52534	29714	2181	110764	1886	147859	217234	2458
14:30	49.97	218198	5107	15270	52077	30207	2230	113223	1880	150851	219994	2266
14:45	49.97	219575	5105	15507	51086	30735	2246	114985	1853	152982	221517	2014
15:00	50.02	219670	5089	16167	50171	30851	2234	115350	1827	153332	221689	1943
15:15	50.02	219204	5107	16002	45678	31137	2227	116368	1803	157524	218322	1931
15:30	50.02	218614	5113	17213	44257	31448	2244	118531	1784	157144	220590	1955
15:45	50.02	218655	5102	17084	42739	31191	2240	120419	1771	158832	220546	1962
16:00	50.02	217776	5111	17252	40106	31137	2235	122048	1739	160418	219628	1934
16:15	50.02	216481	5105	17641	36853	30797	2288	124006	1775	161987	218465	1973
16:30	50.02	216345	5115	17847	34944	30740	2349	125751	1723	163554	218469	1951
16:45	49.97	215521	5108	18121	31331	30764	2357	127757	1697	166069	217135	2007
17:00	50.07	214693	5125	18341	27081	31540	2442	129120	1730	169271	215379	1960
17:15	49.97	212728	5128	18335	23185	31900	2564	130695	1665	171208	213472	1965
17:30	49.97	212286	5140	18816	18697	32408	2610	133909	1669	174773	213249	1966
17:45	49.97	211665	5148	19052	14724	32941	2624	136360	1667	177889	212516	1948
18:00	50.02	211616	5148	19119	11934	33274	2726	138348	1598	180563	212147	1890
18:15	49.97	211153	5159	18983	7782	33530	2897	141815	1662	184388	211828	1879
18:30	50.02	214458	5151	19159	4793	34395	2997	147279	1651	190506	215425	1825
18:45	49.97	218136	5176	18933	2792	35035	3219	152050	1747	196411	218952	1761
19:00	49.92	220557	5178	18613	1512	36096	3273	155487	1785	200432	221944	1819
19:15	49.97	222668	5185	18495	686	37316	3262	157353	1762	203487	224059	1787
19:30	49.97	224529	5203	18138	339	38054	3273	158317	1789	206052	225113	1832
19:45	50.02	224324	5216	18058	308	37944	3284	158373	1787	205958	224970	1803
20:00	50.07	223273	5209	18007	319	37959	3301	157352	1773	204947	223920	1805
20:15	50.07	222088	5234	17916	0	37438	3247	156856	1750	204172	222441	1855
20:30	50.02	221688	5233	17757	0	37258	3298	156462	1779	203931	221787	1999
20:45	50.07	221207	5253	17489	0	37599	3289	155878	1754	203718	221262	1998
21:00	50.07	220796	5233	17313	0	37184	3239	156298	1749	203483	221016	1985
21:15	50.02	219793	5233	17468	0	36756	3249	155424	1741	202325	219871	1992
21:30	50.02	219447	5226	17556	0	36785	3278	154844	1864	201891	219553	2001
21:45	50.02	219159	5226	17580	0	36631	3213	154668	1875	201579	219193	1975
22:00	50.07	217775	5229	17594	0	36097	3248	153974	1890	200181	218032	2008
22:15	50.02	219025	5224	17730	0	35389	3251	15				