National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, क़ुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report दिनांक: 07.12.2025

To,

1. कार्यकारी निदेशक, पू .क्षे .भा .प्रे .के.,14 , गोल्फ क्लब रोड , कोलकाता - 700033
   Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
2. कार्यकारी निदेशक, ऊ. क्षे. भा. प्रे. के., 18/ ए , शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
   Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016
3. कार्यकारी निदेशक, प .क्षे .भा .प्रे .के., एफ3-, एम आई डी सी क्षेत्र , अंधेरी, मुंबई –400093
   Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
4. कार्यकारी निदेशक, ऊ. पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह , लापलंग, शिलोंग – 793006
   Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
5. कार्यकारी निदेशक , द .क्षे .भा .प्रे .के.,29 , रेस कोर्स क्रॉस रोड, बंगलुरु –560009
   Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 06.12.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 6-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उप्लब्ध है |

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 06.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

Report for previous day

Date of Reporting: 07-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	56836	63673	47214	22269	2761	192753
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1244	1508	1090	454	51	4347
Hydro Gen (MU)	120	49	106	23	13	312
Wind Gen (MU)	13	120	80	-	-	214
Solar Gen (MU)*	136.07	137.88	119.48	2.95	1.08	397
Energy Shortage (MU)	0.36	0.00	0.00	0.00	0.00	0.36
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66787	73300	53042	22488	2910	213934
Time Of Maximum Demand Met	10:25	09:49	09:36	17:44	17:01	09:45

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.085	2.09	2.60	10.62	15.32	72.42	12.26

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9153	0	162.2	76.1	-3.2	769	0.00
	Haryana	9062	0	168.0	126.9	-1.6	410	0.00
	Rajasthan	17784	0	332.2	105.0	-0.9	1219	0.00
	Delhi	4293	0	75.0	70.5	-1.2	313	0.00
	UP	19971	0	351.3	93.3	-0.7	849	0.00
	Uttarakhand	2370	0	43.7	33.8	0.3	127	0.27
	HP	2181	0	38.5	29.2	-1.5	71	0.00
	J&K(UT) & Ladakh(UT)	3113	0	64.9	60.5	-1.6	121	0.09
	Chandigarh	224	0	3.9	3.8	0.1	19	0.00
	Railways_NR ISTS	192	0	4.1	3.8	0.3	36	0.00
WR	Chhattisgarh	4574	0	89.0	29.3	-1.2	275	0.00
	Gujarat	22156	0	431.1	169.3	-6.2	1550	0.00
	MP	18297	0	337.6	213.3	0.0	771	0.00
	Maharashtra	27060	0	567.0	189.2	-5.6	458	0.00
	Goa	741	0	15.1	12.6	2.0	39	0.00
	DNHDDPDCL	1353	0	30.7	30.5	0.2	59	0.00
	AMNSIL	845	0	18.2	11.3	-0.2	273	0.00
	BALCO	567	0	13.5	13.6	-0.1	58	0.00
	RIL JAMNAGAR	250	0	5.6	5.7	-0.1	0	0.00
SR	Andhra Pradesh	9474	0	195.4	54.8	-1.3	838	0.00
	Telangana	12053	0	214.2	93.8	-1.7	548	0.00
	Karnataka	15265	0	275.5	91.0	-0.3	1090	0.00
	Kerala	4397	0	84.9	63.4	-1.0	161	0.00
	Tamil Nadu	16011	0	311.7	194.6	-3.6	591	0.00
	Puducherry	408	0	8.7	8.3	-0.3	23	0.00
ER	Bihar	5138	0	92.8	78.7	-1.4	231	0.00
	DVC	3248	0	68.1	-46.6	-0.1	311	0.00
	Jharkhand	2200	0	41.2	29.1	-2.0	232	0.00
	Odisha	5208	0	98.9	20.9	-3.7	860	0.00
	West Bengal	7438	0	151.2	18.1	-2.9	130	0.00
	Sikkim	96	0	1.5	1.5	0.0	24	0.00
	Railways_ER ISTS	15	0	0.1	0.2	0.0	4	0.00
NER	Arunachal Pradesh	184	0	3.1	2.9	0.0	51	0.00
	Assam	1629	0	28.8	22.3	0.2	166	0.00
	Manipur	254	0	3.8	3.7	0.0	42	0.00
	Meghalaya	352	0	6.1	5.1	-0.2	41	0.00
	Mizoram	155	0	2.2	1.7	-0.3	24	0.00
	Nagaland	165	0	2.8	2.7	0.0	8	0.00
	Tripura	235	0	3.9	4.6	0.0	35	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-6.7	10.2	-18.9	-24.2
Day Peak (MW)	-635.2	709.5	-971.3	-1456.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	256.9	-222.8	139.1	-184.9	11.7	0.0
Actual(MU)	272.8	-220.5	128.5	-188.8	10.3	2.4
O/D/U/D(MU)	15.9	2.3	-10.6	-3.9	-1.3	2.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6217	13395	7288	6630	665	34195	50
State Sector	10959	12310	8724	1687	205	33884	50
Total	17176	25704	16012	8317	870	68079	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	709	1451	622	691	9	3482	73
Lignite	28	14	47	0	0	89	2
Hydro	120	49	106	23	13	312	7
Nuclear	37	53	46	0	0	136	3
Gas, Naptha & Diesel	7	20	4	0	23	54	1
RES (Wind, Solar, Biomass & Others)	172	261	227	7	1	668	14
Total	1074	1847	1052	721	46	4741	100

Share of RES in total generation (%)	16.01	14.13	21.59	0.92	2.33	14.09
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.72	19.62	36.05	4.17	30.53	23.54

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.066

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	213934	9:45	0
Non-Solar hr	200186	18:37	130

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 07-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.2	-2.2
3	765 kV	GAYA-VARANASI	2	0	1359	0.0	20.7	-20.7
4	765 kV	SASARAM-FATEHPUR	1	0	685	0.0	9.6	-9.6
5	765 kV	GAYA-BALIA	1	0	690	0.0	12.4	-12.4
6	400 kV	PUSAULI-VARANASI	1	18	100	0.0	0.5	-0.5
7	400 kV	PUSAULI -ALLAHABAD	1	0	123	0.0	1.8	-1.8
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	741	0.0	9.2	-9.2
9	400 kV	PATNA-BALIA	2	0	878	0.0	12.4	-12.4
10	400 kV	NAUBATPUR-BALIA	2	88	241	0.0	4.1	-4.1
11	400 kV	BIHARSHARIFF-BALIA	2	67	337	0.0	4.0	-4.0
12	400 kV	MOTIHARI-GORAKHPUR	2	0	541	0.0	7.7	-7.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	522	0.0	7.9	-7.9
14	220 kV	SAHUPURI-KARAMNASA	1	28	7	0.0	1.8	-1.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
					ER-NR	0.6	94.3	-93.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	229	638	0.0	7.4	-7.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	432	1035	0.0	8.1	-8.1
3	765 kV	JHARSUGUDA-DURG	2	0	1218	0.0	22.0	-22.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	706	0.0	9.6	-9.6
5	400 kV	RANCHI-SIPAT	2	87	361	0.0	3.2	-3.2
6	400 kV	JEYPORE-JAGDALPUR	2	393	238	4.4	0.0	4.4
7	220 kV	BUDHIPADAR-RAIGARH	1	0	157	0.0	2.0	-2.0
8	220 kV	BUDHIPADAR-KORBA	2	96	58	1.1	0.0	1.1
					ER-WR	5.6	52.2	-46.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	210	0.0	9.9	-9.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1621	0.0	40.0	-40.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2655	0.0	51.2	-51.2
4	400 kV	TALCHER-I/C	2	520	358	4.7	0.0	4.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	3	14	0.0	0.0	0.0
					ER-SR	0.0	101.2	-101.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	173	118	0.8	0.5	0.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	349	60	3.0	0.0	3.0
3	220 kV	ALIPURDUAR-SALAKATI	2	79	0	1.0	0.0	1.0
					ER-NER	4.8	0.5	4.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	662	0	16.3	0.0	16.3
					NER-NR	16.3	0.0	16.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4040	0.0	71.3	-71.3
2	HVDC	VINDHYACHAL B/B	-	0	105	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1457	0.0	28.7	-28.7
4	765 kV	GWALIOR-AGRA	2	0	1912	0.0	30.8	-30.8
5	765 kV	GWALIOR-PHAGI	2	0	1948	0.0	24.3	-24.3
6	765 kV	JABALPUR-ORAI	2	0	1048	0.0	34.5	-34.5
7	765 kV	GWALIOR-ORAI	1	955	0	16.1	0.0	16.1
8	765 kV	SATNA-ORAI	1	0	1071	0.0	20.4	-20.4
9	765 kV	BANASKANTHA-CHITORGARH	2	2087	610	16.9	0.6	16.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	1983	0.0	30.4	-30.4
11	400 kV	ZERDA-KANKROLI	1	341	35	3.3	0.0	3.3
12	400 kV	ZERDA -BHINMAL	1	235	25	1.7	0.0	1.7
13	400 kV	VINDHYACHAL -RIHAND	1	967	0	21.0	0.0	21.0
14	400 kV	RAPP-SHUJALPUR	2	375	269	0.0	0.1	-0.1
15	400 kV	NEEMUCH-Chittorgarh	2	380	325	1.1	1.9	-0.8
16	220 kV	BHANPURA-RANPUR	1	0	136	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	96	12	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	64	23	0.4	0.0	0.4
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
					WR-NR	61.5	248.9	-187.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	19.5	-19.5
2	HVDC	RAIGARH-PUGALUR	2	0	1501	0.0	15.9	-15.9
3	765 kV	SOLAPUR-RAICHUR	2	1037	1053	3.0	11.3	-8.3
4	765 kV	WARDHA-NIZAMABAD	2	0	1943	0.0	28.0	-28.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2256	0.0	36.2	-36.2
6	400 kV	KOLHAPUR-KUDGI	2	1531	0	26.0	0.0	26.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	116	2.2	0.0	2.2
					WR-SR	31.2	110.9	-79.7

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-176	91	-48	-1.14
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	335	-157	111	2.66
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-326	-239	-280	-6.72
	NER	132kV GELEPHU-SALAKATI	-62	-44	-55	-1.31
	NER	132kV MOTANGA-RANGIA	-17	-4	-9	-0.21
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	50	0	35	0.83
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	642	161	389	9.34
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-859	-480	-695	-16.68
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1456	-816	-1006	-24.15
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-123	0	-94	-2.26

CROSS BORDER EXCHANGE SCHEDULE **Date of Reporting: 07-Dec-2025**

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	6.56	0.00	0.00	0.34	0.00	0.00	7.21
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	17.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	17.35	0.31	6.56	0.00	0.00	0.34	0.00	0.00	24.56

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	1.15	0.00	0.00	8.78	0.00	0.00	9.93
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	1.15	0.00	0.00	8.78	0.00	0.00	9.93

Net from India(in MU) **-ve : Export / +ve : Import**

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-6.56	0.00	0.00	-0.34	0.00	0.00	-7.21
Nepal	0.00	0.00	1.15	0.00	0.00	8.78	0.00	0.00	9.93
Bangladesh	-17.35	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-17.35
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-17.35	-0.31	-5.41	0.00	0.00	8.44	0.00	0.00	-14.63

Date of Reporting: 07-Dec-2025

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)

TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	148647	5060	12980	0	6605	2108	120685	3055	135667	150493	-534
0:15	50.00	148057	5051	13037	0	6661	2133	120274	3091	135020	150247	-819
0:30	49.95	147573	5069	13150	0	6632	2141	119521	3155	134423	149668	-838
0:45	49.95	147415	5077	13036	0	6565	2144	119932	3103	134379	149857	-812
1:00	50.00	146598	5063	12748	0	6646	2144	119630	3103	133850	149334	-796
1:15	50.00	145658	5068	12486	0	6757	2139	119309	3048	133172	148807	-988
1:30	50.00	145251	5073	12313	0	6817	2133	118782	3085	132938	148203	-961
1:45	49.95	145337	5073	12212	0	6968	2129	118694	3084	133125	148160	-966
2:00	50.00	143468	5077	12088	0	6979	2137	116936	3108	131380	146325	-975
2:15	50.00	143359	5082	12085	0	6853	2164	116625	3041	131274	145850	-881
2:30	49.95	143402	5078	12068	0	6830	2170	116643	3090	131334	145879	-737
2:45	49.95	143391	5077	11593	0	6961	2184	116885	3067	131798	145767	-655
3:00	49.95	142650	5083	11315	0	6928	2148	116510	3089	131335	145073	-651
3:15	49.95	143628	5088	10982	0	6711	2164	117894	3066	132646	145905	-702
3:30	50.00	143721	5087	10741	0	6788	2161	117995	3127	132980	145899	-691
3:45	50.00	144043	5090	10829	0	6783	2160	118250	3063	133214	146175	-704
4:00	50.05	144394	5082	10678	0	6690	2158	118894	3119	133716	146621	-708
4:15	50.00	146076	5087	10781	0	7002	2219	120445	3054	135295	148588	-711
4:30	50.00	147666	5082	10937	0	7306	2184	121552	3063	136729	150124	-739
4:45	50.00	149322	5095	10911	0	7460	2194	123213	3059	138411	151932	-793
5:00	50.05	151525	5104	11109	61	7648	2206	125061	3146	140355	154335	-821
5:15	50.00	156380	5106	11206	97	8620	2180	128963	3096	145077	159268	-810
5:30	50.05	159916	5081	11286	72	9478	2162	131881	3106	148558	163066	-678
5:45	50.05	163493	5108	11274	110	10487	2171	134729	3145	152109	167024	-681
6:00	50.10	166915	5106	11209	141	12023	2118	137244	3226	155565	171067	-295
6:15	49.95	172153	5071	11096	2139	13606	2144	141583	3142	158918	178781	-254
6:30	50.05	178669	5086	11091	2153	16751	2172	144476	3215	165425	184944	-262
6:45	50.00	183982	5095	11258	2345	19800	2224	146886	3158	170379	190766	-359
7:00	50.05	188040	5099	11230	2989	21112	2250	149292	3190	173821	195162	-488
7:15	50.00	192257	5095	11148	4165	21407	2309	152384	3126	176944	199634	-508
7:30	50.05	195355	5095	11148	6237	21568	2327	153168	3191	177970	202734	-465
7:45	50.10	197633	5101	11287	9354	21459	2308	152090	3149	176992	204748	-459
8:00	50.10	197826	5092	11180	12890	18642	2306	150858	3188	173756	204156	-394
8:15	50.00	199955	5100	10617	18127	17198	2265	149566	3150	171211	206023	-451
8:30	50.00	202104	5094	10343	24140	14417	2212	148319	3159	167621	207684	-444
8:45	49.95	204416	5083	10150	30084	12886	2117	146295	3100	164182	209715	-436
9:00	49.95	206089	5106	9534	35002	11751	2107	144558	3098	161553	211156	-415
9:15	49.70	207871	5076	8764	38296	12186	2116	143385	3104	160811	212927	-403
9:30	49.75	210914	5077	8254	42469	12037	2147	143085	3108	160191	216177	-371
9:45	50.05	213934	5090	7734	48106	11000	2175	141886	3103	158094	219094	-370
10:00	50.05	212659	5083	7201	50544	9778	2156	139473	3057	154914	217292	-443
10:15	49.90	212458	5079	6841	52317	9038	2127	139071	3115	153300	217588	-375
10:30	50.00	213319	5087	6688	54410	8817	2105	137309	3086	152221	217502	-385
10:45	49.95	211145	5058	6640	55227	8580	2105	134970	3031	149278	215611	-378
11:00	50.00	210706	5091	6292	57373	7791	2115	133363	3091	147041	215116	-404
11:15	49.95	209560	5083	6112	59516	7143	2077	131760	3086	143932	214777	-849
11:30	50.00	209000	5073	5924	61393	7025	2070	129232	3077	141683	213794	-872
11:45	49.90	208614	5072	5672	61887	7392	2083	128059	3050	141055	213215	-1060
12:00	50.05	207083	5054	5430	62524	7222	2062	126283	3106	139129	211681	-1132
12:15	49.90	204573	5064	5262	62652	6744	2072	124179	3076	136659	209049	-1174
12:30	50.00	203562	5053	5196	61919	6943	2062	123612	3021	136447	207806	-1203
12:45	49.90	201729	5061	5236	60065	6848	2080	124393	3104	136428	206787	-1194
13:00	50.00	198610	5049	5189	59179	6908	2089	121952	3202	134242	203568	-1268
13:15	49.85	193810	5041	4950	56774	6879	2082	120462	3068	132086	199256	-1234
13:30	49.95	193984	5061	4907	57095	7120	2067	119704	3133	131982	199087	-1233
13:45	49.90	194169	5063	4809	55179	7205	2079	122113	3144	134181	199592	-1228
14:00	49.90	194467	5043	4733	53569	7420	2088	123971	3087	136165	199911	-1282
14:15	50.00	194955	5059	4706	51412	7495	2092	126828	3069	138837	200661	-1223
14:30	49.90	195419	5038	4823	47265	7575	2074	131815	3125	143331	201715	-1142
14:45	49.95	196413	5045	4697	44955	8207	2081	134429	3064	146761	202478	-788
15:00	49.90	196159	5046	4615	40228	8852	2076	139314	3152	151316	203283	-828
15:15	50.00	196312	5043	4700	38361	9051	2080	141142	3072	153251	203449	-573
15:30	49.91	197040	5041	4708	34520	9529	2078	144699	3171	157812	203746	-527
15:45	49.80	197000	5042	4648	30593	10289	2114	148416	3097	161759	204199	-620
16:00	49.90	196596	5032	4407	26909	11814	1966	151127	3191	165280	204446	-635
16:15	49.96	193978	5057	4265	22057	12263	2017	152627	3142	167656	201428	-642
16:30	49.76	194519	5021	4439	17036	15402	2184	155269	3153	173044	202504	-650
16:45	49.91	194964	5049	4175	14300	17667	2066	156382	3200	176489	202839	-543
17:00	49.96	195970	5028	4220	10433	21175	2058	157789	3282	181317	203985	-489
17:15	49.96	195143	5064	4283	7529	23615	2239	157484	3216	183331	203430	-311
17:30	49.86	197744	5051	4386	5271	27545	2109	158528	3244	188087	206134	-347
17:45	49.51	198874	5054	4778	3503	29535	2118	159059	3281	190593	207328	-366
18:00	49.82	199543	5052	5054	2721	30296	2293	159357	3265	191768	208038	-326
18:15	49.97	199998	5051	5433	2530	30592	2108	159112	3245	192035	208071	-393
18:30	50.02	199908	5060	5903	2428	30331	2236	158418	3178	191577	207554	-420
18:45	50.02	199328	5064	6390	2305	30063	2312	157749	3181	190633	207064	-423
19:00	50.07	196741	5070	6656	2295	28879	2308	156317	3136	187790	204661	-434
19:15	50.05	192894	5061	7217	2254	26721	2390	154342	3209	183423	201194	-407
19:30	50.00	190284	5061	7593	0	23879	2111	154341	3144	182691	196129	-736
19:45	50.05	186637	5068	7945	0	21112	2249	153162	3151	178692	192687	-384
20:00	50.00	183583	5066	8138	0	18853	2090	151838	3146	175445	189131	-392
20:15	50.05	179880	5066	8446	0	16412	2034	150098	3173	171434	185229	-453
20:30	50.05	177584	5069	8968	0	14066	1976	148978	3194	168616	182251	-408
20:45	49.99	174870	5061	9374	0	12738	1974	147206	3186	165496	179539	-413
21:00	50.04	172362	5060	9727	0	11912	2055	144870	3229	162635	176853	-401
21:15	50.04	169328	5065	9719	0	11546	2055	141707	3187	159609	173279	-318
21:30	49.99	166632	5080	10096	0	10748	2099	139525	3257	156536	170805	-292
21:45	50.04	164248	5075	10116	0	9722	2087	137957	3284	154132	168241	-342
22:00	50.10	160891	5066	9948	0	9171	2082	135190	3250	150943	164707	-339
22:15	49.99	160209	5056	9919	0	8551	2064	135213	3221	150290	164024	-285
22:30	49.94	158550	5081	10004	0	8537	2074	134098	3216	148546	163010	-587
22:45	49.99	157058	5071	9849	0	8505	2069	132808	3275	147209	161577	-588
23:00	50.04	154686	5074	9844	0	8479	2092	130580	3297	144842	159366	-613
23:15	50.04	152997	5075	9929	0	8165	2094	128949	3247	143068	157459	-609
23:30	49.99	151242	5058	9848	0	7988	2075	127459	3231	141394	155659	-596
23:45	50.04	149784	5091	9790	0	7690	2081	126296	3172	139994	154120	-571

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).
** Hydro generation is excluding Bhutan hydro.
***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:
1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.