



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 13.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 12.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 12-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 12.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 13-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	66602	67482	48869	23791	2866	209610
Peak Shortage (MW)	149	47	0	247	0	443
Energy Met (MU)	1361	1572	1181	489	52	4655
Hydro Gen (MU)	104	44	84	23	13	268
Wind Gen (MU)	9	130	90	-	-	229
Solar Gen (MU)*	194.61	164.87	119.36	3.60	1.08	482
Energy Shortage (MU)	0.93	0.47	0.00	0.22	0.00	1.62
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	74489	80948	62460	24436	3011	240682
Time Of Maximum Demand Met	11:01	09:42	09:38	18:00	17:38	10:17

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.051	0.27	0.96	2.14	3.37	73.24	23.39

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	10113	0	179.6	86.0	-0.7	1224	0.00
	Haryana	9599	0	175.1	113.5	-0.9	305	0.00
	Rajasthan	18876	0	342.0	125.2	1.2	1160	0.00
	Delhi	5586	0	95.9	86.8	-0.1	616	0.00
	UP	22540	0	402.9	65.5	0.3	485	0.00
	Uttarakhand	2728	0	49.3	40.7	0.7	173	0.14
	HP	2192	0	40.0	33.7	-0.8	129	0.00
	J&K(UT) & Ladakh(UT)	3282	100	67.2	62.2	0.8	325	0.79
	Chandigarh	323	0	5.4	5.3	0.1	32	0.00
	Railways_NR ISTS	206	0	4.1	3.7	0.4	67	0.00
WR	Chhattisgarh	5517	0	110.3	51.7	0.5	295	0.00
	Gujarat	24323	0	439.4	168.7	-7.4	820	0.00
	MP	19367	0	348.9	219.0	0.0	625	0.47
	Maharashtra	29576	0	592.9	165.6	-3.9	1322	0.00
	Goa	745	0	14.3	11.8	2.0	77	0.00
	DNHDDPDCL	1355	0	30.4	30.3	0.1	88	0.00
	AMNSIL	943	0	19.3	11.8	0.5	289	0.00
	BALCO	602	0	14.3	14.5	-0.2	9	0.00
	RIL JAMNAGAR	129	0	2.0	2.0	0	0	0.00
	Andhra Pradesh	11750	0	212.2	56.6	-1.9	609	0.00
SR	Telangana	15316	0	261.2	107.9	-1.2	923	0.00
	Karnataka	16715	0	293.5	101.5	-2.2	1242	0.00
	Kerala	4591	0	84.2	62.0	1.7	486	0.00
	Tamil Nadu	16106	0	321.2	205.2	-6.4	554	0.00
	Puducherry	386	0	8.2	8.0	-0.3	31	0.00
	Bihar	6397	0	112.6	94.6	-3.7	336	0.22
ER	DVC	3203	0	66.1	-24.8	0.3	641	0.00
	Jharkhand	2092	0	42.3	35.9	0.4	312	0.00
	Odisha	5538	0	103.3	14.9	-2.6	462	0.00
	West Bengal	8084	0	163.0	40.9	-2.1	216	0.00
	Sikkim	112	0	1.9	1.9	0.0	16	0.00
	Railways_ER ISTS	17	0	0.2	0.1	0.0	1	0.00
NER	Arunachal Pradesh	192	0	3.3	3.3	-0.1	35	0.00
	Assam	1664	0	29.2	22.9	0.2	69	0.00
	Manipur	273	0	3.9	4.0	-0.1	50	0.00
	Meghalaya	367	0	6.4	6.0	-0.2	31	0.00
	Mizoram	157	0	2.3	2.2	-0.2	20	0.00
	Nagaland	167	0	2.6	2.7	-0.2	28	0.00
	Tripura	237	0	4.2	4.9	0.2	80	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-14.6	-8.8	-19.4	-30.8
Day Peak (MW)	-1011.7	-712.2	-1020.6	-1487.2

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	217.5	-233.3	144.5	-137.3	8.6	0.0
Actual(MU)	225.1	-237.7	134.2	-142.3	6.5	-14.2
O/D/U/D(MU)	7.5	-4.4	-10.3	-5.0	-2.0	-14.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6220	12984	5808	6187	245	31443	52
State Sector	5974	11340	7300	4169	205	28988	48
Total	12194	24324	13108	10356	450	60431	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	823	1509	683	693	14	3722	73
Lignite	28	16	58	0	0	102	2
Hydro	104	44	84	23	13	268	5
Nuclear	53	53	47	0	0	152	3
Gas, Naptha & Diesel	11	22	10	0	22	65	1
RES (Wind, Solar, Biomass & Others)	228	298	251	8	1	786	15
Total	1247	1941	1133	723	51	5096	100

Share of RES in total generation (%)	18.27	15.37	22.06	1.08	2.11	15.40
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.89	20.32	33.57	4.20	28.44	23.64

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.044

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	240682	10:17	0
Non-Solar hr	214221	17:50	54

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)

Date of Reporting: 13-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	510	913	0.0	9.3	-9.3
4	765 kV	SASARAM-FATEHPUR	1	221	380	0.0	3.7	-3.7
5	765 kV	GAYA-BALIA	1	0	782	0.0	12.3	-12.3
6	400 kV	PUSAULI-VARANASI	1	0	149	0.0	1.8	-1.8
7	400 kV	PUSAULI-ALLAHABAD	1	55	78	0.0	0.5	-0.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	515	554	0.0	2.6	-2.6
9	400 kV	PATNA-BALIA	2	0	937	0.0	15.0	-15.0
10	400 kV	NAUBATPUR-BALIA	2	105	225	0.0	4.9	-4.9
11	400 kV	BIHARSHARIFF-BALIA	2	340	274	0.0	0.4	-0.4
12	400 kV	MOTIHARI-GORAKHPUR	2	76	497	0.0	6.2	-6.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	226	315	0.0	2.2	-2.2
14	220 kV	SAHUPURI-KARAMNANA	1	34	8	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	38	0.0	0.8	-0.8
ER-NR						0.0	63.0	-63.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1850	0.0	30.0	-30.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1038	363	6.7	0.0	6.7
3	765 kV	JHARSUGUDA-DURG	2	0	1388	0.0	22.9	-22.9
4	400 kV	JHARSUGUDA-RAIGARH	4	149	345	0.0	1.1	-1.1
5	400 kV	RANCHI-SIPAT	2	217	161	0.0	0.3	-0.3
6	400 kV	JEYPORE-JAGDALPUR	2	503	1	5.7	0.0	5.7
7	220 kV	BUDHIPADAR-RAIGARH	1	6	100	0.0	1.2	-1.2
8	220 kV	BUDHIPADAR-KORBA	2	72	99	0.0	0.2	-0.2
ER-WR						12.4	55.8	-43.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	741	0.0	14.4	-14.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1378	0.0	36.2	-36.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1696	0.0	25.3	-25.3
4	400 kV	TALCHER-I/C	2	0	302	0.0	3.0	-3.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	75.9	-75.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	42	200	0.6	2.9	-2.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	865	238	5.7	0.0	5.7
3	220 kV	ALIPURDUAR-SALAKATI	2	16	85	0.0	0.9	-0.9
ER-NER						6.3	3.7	2.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	567	0	10.9	0.0	10.9
NER-NR						10.9	0.0	10.9
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3275	0.0	58.0	-58.0
2	HVDC	VINDHYACHAL B/B	-	0	253	0.0	3.2	-3.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1460	0.0	31.5	-31.5
4	765 kV	GWALIOR-AGRA	2	426	2194	0.6	25.6	-25.0
5	765 kV	GWALIOR-PHAGI	2	563	2057	0.9	26.0	-25.1
6	765 kV	JABALPUR-ORAI	2	233	1143	0.0	27.4	-27.4
7	765 kV	GWALIOR-ORAI	1	993	0	15.6	0.0	15.6
8	765 kV	SATNA-ORAI	1	0	1162	0.0	20.6	-20.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1688	727	8.6	3.2	5.4
10	765 kV	VINDHYACHAL VARANASI	1	0	2816	0.0	41.9	-41.9
11	400 kV	ZERDA-KANKROLI	1	284	81	2.5	0.2	2.3
12	400 kV	ZERDA BHINMAL	1	196	56	1.6	0.1	1.5
13	400 kV	VINDHYACHAL -RIHAND	1	956	0	21.0	0.0	21.0
14	400 kV	RAPP-SHUJALPUR	2	861	272	6.3	0.9	5.3
15	400 kV	NEEMUCH-Chittorgarh	2	779	497	4.4	2.3	2.1
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	115	14	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	82	26	0.6	0.1	0.6
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						63.1	244.3	-181.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	20.9	-20.9
2	HVDC	RAIGARH-PUGALUR	2	0	3509	0.0	66.1	-66.1
3	765 kV	SOLAPUR-RAICHUR	2	1937	1129	12.3	6.1	6.1
4	765 kV	WARDHA-NIZAMABAD	2	1116	2270	3.5	23.0	-19.5
5	765 kV	WARORA-WARANGAL(NEW)	2	671	2893	1.0	30.8	-29.8
6	400 kV	KOLHAPUR-KUDGI	2	1896	0	28.4	0.0	28.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	113	2.1	0.0	2.1
WR-SR						47.3	146.9	-99.6

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-297	84	-193	-4.62
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-314	187	-117	-2.81
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-281	-160	-229	-5.49
	NER	132kV GELEPHU-SALAKATI	-64	-33	-51	-1.22
	NER	132kV MOTANGA-RANGIA	-32	-6	-20	-0.49
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-0.54
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-1.14
	ER	NEPAL IMPORT (FROM BIHAR)	-157	-93	-123	-2.95
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-392	-50	-175	-4.20
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-895	-234	-707	-16.96
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1487	-1015	-1284	-30.81
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-122	0	-102	-2.44

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 13-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.28	15.31	0.00	0.00	0.33	0.00	0.00	15.92
Nepal	2.98	1.75	0.77	0.00	0.00	1.97	0.00	0.00	7.47
Bangladesh	17.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.73
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.71	2.03	16.08	0.00	0.00	2.30	0.00	0.00	41.12

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.43
Nepal	0.00	0.00	0.00	0.00	0.00	0.12	0.00	0.00	0.12
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.43	0.00	0.00	0.00	0.00	0.12	0.00	0.00	0.55

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.43	-0.28	-15.31	0.00	0.00	-0.33	0.00	0.00	-15.49
Nepal	-2.98	-1.75	-0.77	0.00	0.00	-1.85	0.00	0.00	-7.35
Bangladesh	-17.73	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-17.73
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.28	-2.03	-16.08	0.00	0.00	-2.18	0.00	0.00	-40.57

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.08	150737	5685	14070	0	5399	1957	124768	3704	136667	155583	-1940
0:15	50.03	150390	5689	14284	0	5197	1972	124536	3756	136106	155434	-2012
0:30	50.03	149147	5686	14242	0	5340	1970	123150	3725	134905	154113	-1945
0:45	49.98	148581	5695	14186	0	5176	1903	122705	3652	134395	153317	-1858
1:00	50.03	147273	5700	13929	0	5119	1892	121668	3666	133344	151974	-1831
1:15	50.03	146450	5692	13977	0	4896	1964	121173	3677	132473	151379	-1855
1:30	50.03	145505	5684	13877	0	4597	1908	120670	3717	131628	150453	-1840
1:45	50.03	144726	5699	13772	0	4574	1888	120036	3777	130954	149746	-1842
2:00	50.03	143969	5719	13708	0	4513	1958	119378	3719	130261	148995	-1728
2:15	49.98	143924	5710	13818	0	4388	2011	119271	3725	130106	148923	-1628
2:30	49.98	143891	5720	13812	0	4453	1895	118987	3737	130079	148604	-1532
2:45	50.03	143879	5715	13582	0	4338	1903	119136	3685	130297	148359	-1445
3:00	50.03	143651	5721	13424	0	4308	1896	119110	3715	130227	148174	-1331
3:15	49.98	143904	5721	13343	0	4299	1903	119463	3689	130561	148418	-1336
3:30	49.98	143943	5718	13230	0	4647	1993	119547	3694	130713	148829	-1342
3:45	49.98	144498	5717	13221	0	4607	1909	120209	3728	131277	149391	-1328
4:00	50.03	145354	5729	13075	0	4613	1899	120925	3709	132279	149950	-1326
4:15	50.03	147531	5701	13055	0	5021	2016	122811	3685	134476	152289	-1354
4:30	50.03	149731	5718	12894	0	5033	2032	124947	3717	136837	154341	-1361
4:45	50.03	151483	5700	12746	0	5145	1892	126614	3749	138737	155846	-1333
5:00	50.08	154122	5711	12587	48	5466	1915	129329	3721	141487	158777	-1349
5:15	50.08	158227	5691	12430	42	5702	2026	133709	3769	145755	163369	-1345
5:30	50.03	162815	5703	12204	41	5777	2046	138090	3748	150570	167609	-1376
5:45	50.03	167600	5720	12153	42	6241	2051	142773	3731	155405	172711	-1468
6:00	50.08	172022	5707	12055	85	6735	2096	146938	3745	159882	177361	-1568
6:15	49.98	178421	5682	12141	131	7433	2120	151944	3774	166149	183225	-1122
6:30	50.03	185202	5690	11786	132	9018	2076	157445	3730	173284	189877	-784
6:45	50.03	191849	5693	11660	160	11822	2226	161576	3797	180029	196934	-923
7:00	50.08	199167	5690	11563	341	16437	2102	163994	3798	187263	203925	-928
7:15	50.03	205583	5692	11795	958	20782	2250	165041	3832	192830	210250	-909
7:30	49.93	210571	5695	11574	2142	22503	2308	167191	3805	196855	215218	-827
7:45	50.03	213414	5697	11162	4468	23369	2400	166958	3863	197784	217917	-808
8:00	50.08	215525	5704	10317	8354	23323	2419	165720	3858	196854	219695	-856
8:15	50.03	221886	5696	10317	13549	23618	2430	166864	3810	198020	226284	-954
8:30	50.13	224637	5696	9858	19425	21973	2366	165670	3824	195354	228812	-969
8:45	50.18	228162	5698	9393	26047	20239	2235	164261	3824	192722	231697	-981
9:00	50.33	230805	5697	9237	32322	16991	2188	163892	3877	189246	234164	-1019
9:15	50.13	234855	5687	8924	39633	15076	2174	163176	3838	186298	238508	-1115
9:30	50.13	237992	5671	8238	45842	14420	2109	161604	3841	183912	241725	-1289
9:45	50.03	239052	5659	7494	50219	13182	2075	160457	3724	181339	242810	-1423
10:00	50.03	239424	5658	7019	53687	12375	2094	158629	3728	178718	243190	-1442
10:15	49.88	240405	5639	6517	56634	11022	2070	158761	3675	177254	244318	-1471
10:30	49.83	239235	5640	5815	58839	10469	2068	156183	3675	174581	242689	-1443
10:45	49.83	237608	5626	5710	60898	9260	2060	154022	3679	171000	241255	-1983
11:00	49.88	238185	5642	5541	63237	8419	2042	153261	3669	169407	241811	-2376
11:15	49.88	235459	5632	5345	64768	7384	2038	150477	3643	165346	239287	-2349
11:30	49.88	233929	5626	5184	65616	7083	2031	148266	3691	163129	237497	-2416
11:45	49.98	233420	5636	5112	66238	6915	2041	146972	3625	162070	236539	-2373
12:00	50.03	230228	5656	5162	66219	6519	2204	144316	3595	158847	233671	-2348
12:15	50.03	227685	5628	4970	66616	6165	2226	142172	3606	156099	231383	-2347
12:30	50.03	226248	5629	4774	66392	6183	2198	141054	3606	155082	229836	-2440
12:45	49.98	224196	5635	4549	65715	6210	2207	140000	3634	153932	227950	-2445
13:00	50.08	220602	5636	4355	65371	6597	2237	136269	3690	150876	224155	-2490
13:15	49.98	217061	5628	4311	65010	5485	2211	133784	3702	147740	220131	-2438
13:30	50.03	216051	5620	4202	64968	5142	2203	133667	3585	146881	219387	-2489
13:45	50.03	215578	5630	4204	64078	5162	2215	134293	3697	147296	219279	-2493
14:00	50.03	214728	5617	4080	62312	5183	2203	135535	3643	148336	218573	-2491
14:15	50.08	214680	5609	3974	61146	5065	2209	136962	3673	149560	218638	-2459
14:30	50.03	215537	5608	3897	59272	5553	2175	139114	3705	152368	219324	-2421
14:45	49.98	216744	5556	3899	57406	5567	2245	142401	3658	155439	220732	-2469
15:00	49.98	216980	5561	3824	54481	6057	2223	144998	3673	158675	220817	-2491
15:15	50.03	213972	5578	3837	52098	6071	2257	143872	3694	158037	217407	-2488
15:30	49.98	214393	5624	3783	49111	6691	2284	146826	3669	161499	217988	-2480
15:45	49.93	214809	5620	3905	45846	7577	2342	149412	3690	165058	218392	-2613
16:00	50.03	215056	5602	3908	41552	8552	2361	153201	3647	169596	218823	-2539
16:15	50.03	211959	5626	4072	36993	9187	2400	153810	3671	170894	215759	-2555
16:30	50.03	211960	5621	4078	31481	11236	2591	157289	3709	176401	216005	-2483
16:45	49.98	211475	5608	4348	25285	12596	2966	160609	3727	181842	215139	-2482
17:00	50.03	210771	5625	4464	18952	14038	3428	163032	3720	187355	213259	-1876
17:15	50.08	208994	5624	4687	12959	16267	3762	164796	3657	191348	211752	-1369
17:30	50.08	211379	5622	4987	7917	21127	3591	166761	3687	198475	213692	-1364
17:45	49.93	213854	5632	5335	4069	24155	4078	169598	3717	204450	216584	-1373
18:00	49.98	213353	5616	5729	1588	24403	3557	171209	3651	206036	215753	-928
18:15	49.93	212231	5619	6069	568	24540	3577	171241	3599	205594	215213	-898
18:30	49.98	213631	5615	6435	323	25301	4009	171338	3642	206873	216663	-891
18:45	50.03	213259	5621	6535	328	24544	4005	170584	3623	206396	216150	-862
19:00	50.03	212756	5623	7118	186	24579	3866	170393	3601	205452	215366	-904
19:15	50.03	210459	5628	7723	191	21925	3197	170908	3566	202545	213138	-889
19:30	50.03	208902	5620	8343	0	20409	2934	170433	3573	200559	211312	-915
19:45	50.03	207068	5622	8960	0	19349	2906	169256	3632	198108	209725	-893
20:00	50.09	203615	5618	9357	0	18164	2724	166949	3600	194258	206412	-949
20:15	50.04	200334	5638	9630	0	16107	2672	166211	3650	190704	203908	-1329
20:30	49.98	197461	5628	9921	0	14345	2641	165162	3658	187540	201355	-1326
20:45	49.98	194813	5631	10266	0	13220	2597	163449	3648	184547	198811	-1302
21:00	50.04	191471	5631	10365	0	12387	2304	161244	3704	181106	195635	-1331
21:15	50.04	188857	5619	10713	0	11553	2296	159333	3668	178144	193182	-1658
21:30	50.04	184791	5630	10881	0	10240	2275	156996	3696	173910	189718	-2042
21:45	50.04	182729	5644	11240	0	8757	2279	155629	3729	171489	187278	-2014
22:00	50.09	178014	5638	11137	0	7448	2281	152723	3633	166877	182860	-2105
22:15	49.99	176747	5626	11203	0	6672	2248	152238	3599	165544	181586	-2134
22:30	49.99	17472										