



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 15.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 14.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 14-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 14.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 15-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53953	61777	43367	21429	2624	183150
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1217	1490	1070	441	49	4266
Hydro Gen (MU)	125	30	96	18	11	278
Wind Gen (MU)	3	71	70	-	-	145
Solar Gen (MU)*	142.01	161.94	156.98	3.38	1.12	465
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	64290	74352	54780	21634	2720	214183
Time Of Maximum Demand Met	10:39	10:01	09:29	17:42	17:24	10:26

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.038	0.00	0.50	4.52	5.02	74.23	20.75

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8524	0	150.8	70.4	-2.9	210	0.00
	Haryana	8085	0	150.2	104.3	-1.2	331	0.00
	Rajasthan	17932	0	334.4	121.0	-2.9	1269	0.00
	Delhi	4372	0	75.1	69.3	0.4	386	0.00
	UP	19555	0	358.9	91.5	0.4	646	0.00
	Uttarakhand	2287	0	40.6	29.6	0.1	86	0.00
	HP	1931	0	34.8	27.0	-0.4	88	0.00
	J&K(UT) & Ladakh(UT)	3108	0	64.5	63.0	-0.9	172	0.00
	Chandigarh	217	0	3.7	3.6	0.0	20	0.00
	Railways_NR ISTS	195	0	4.0	4.0	0.1	26	0.00
WR	Chhattisgarh	4971	0	98.9	32.6	-0.1	288	0.00
	Gujarat	22004	0	419.7	174.9	-6.1	930	0.00
	MP	18416	0	343.2	217.8	0.0	538	0.00
	Maharashtra	26147	0	547.6	179.7	-6.4	583	0.00
	Goa	612	0	11.9	9.7	1.7	35	0.00
	DNHDDPDCL	1233	0	28.6	28.6	0.0	57	0.00
	AMNSIL	921	0	21.0	13.4	0.7	277	0.00
	BALCO	576	0	13.7	13.6	0.1	57	0.00
	RIL JAMNAGAR	214	0	5.0	5.1	-0.1	0	0.00
	Andhra Pradesh	10756	0	200.8	57.3	-0.5	593	0.00
SR	Telangana	12577	0	220.2	105.2	0.9	750	0.00
	Karnataka	14802	0	268.3	84.6	-0.7	875	0.00
	Kerala	3910	0	73.9	53.0	0.0	230	0.00
	Tamil Nadu	14254	0	298.9	163.9	-2.1	602	0.00
	Puducherry	353	0	7.7	7.3	-0.2	24	0.00
	Bihar	5362	0	97.7	86.3	-1.2	303	0.00
ER	DVC	3113	0	66.9	-38.4	0.8	331	0.00
	Jharkhand	2164	0	40.2	30.3	-1.0	271	0.00
	Odisha	4939	0	93.8	14.3	-4.0	371	0.00
	West Bengal	6831	0	141.2	21.3	-2.4	241	0.00
	Sikkim	93	0	1.5	1.6	-0.1	19	0.00
	Railways_ER ISTS	16	0	0.1	0.2	0.0	4	0.00
NER	Arunachal Pradesh	175	0	3.2	3.0	0.1	28	0.00
	Assam	1504	0	27.0	20.7	0.1	98	0.00
	Manipur	260	0	3.9	3.9	0.1	30	0.00
	Meghalaya	328	0	6.0	5.4	0.0	46	0.00
	Mizoram	131	0	2.1	1.7	-0.2	23	0.00
	Nagaland	156	0	2.7	2.6	-0.1	19	0.00
	Tripura	229	0	3.8	4.5	0.0	35	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-10.3	3.8	-22.0	-28.4
Day Peak (MW)	-863.8	437.5	-1014.9	-1461.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	229.6	-209.3	121.0	-150.3	9.0	0.0
Actual(MU)	232.8	-203.8	112.9	-162.0	7.6	-12.6
O/D/U/D(MU)	3.2	5.5	-8.1	-11.7	-1.5	-12.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6262	11398	7788	5970	55	31473	50
State Sector	9589	10696	8234	2497	205	31220	50
Total	15851	22093	16022	8467	260	62693	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	721	1462	594	660	12	3449	74
Lignite	20	18	44	0	0	82	2
Hydro	125	30	96	18	11	278	6
Nuclear	37	53	47	0	0	136	3
Gas, Naptha & Diesel	6	22	4	0	23	55	1
RES (Wind, Solar, Biomass & Others)	172	236	254	7	1	670	14
Total	1080	1820	1039	685	47	4671	100

Share of RES in total generation (%)	15.88	12.96	24.47	1.09	2.39	14.35
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.87	17.48	38.15	3.66	25.24	23.23

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.042

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	214183	10:26	0
Non-Solar hr	194641	17:57	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 15-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	149	1095	0.0	15.0	-15.0
4	765 kV	SASARAM-FATEHPUR	1	41	557	0.0	7.4	-7.4
5	765 kV	GAYA-BALIA	1	0	642	0.0	11.1	-11.1
6	400 kV	PUSAULI-VARANASI	1	41	49	0.0	0.2	-0.2
7	400 kV	PUSAULI-ALLAHABAD	1	0	138	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	322	600	0.0	4.7	-4.7
9	400 kV	PATNA-BALIA	2	0	850	0.0	11.2	-11.2
10	400 kV	NAUBATPUR-BALIA	2	104	381	0.0	3.7	-3.7
11	400 kV	BIHARSHARIFF-BALIA	2	329	253	0.1	0.0	0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	506	0.0	6.5	-6.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	67	425	0.0	5.4	-5.4
14	220 kV	SAHUPURI-KARMANASA	1	23	21	0.0	0.9	-0.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.1	-0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	24	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	68.3	-67.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	433	517	0.0	4.2	-4.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1092	830	0.0	1.8	-1.8
3	765 kV	JHARSUGUDA-DURG	2	0	1300	0.0	23.9	-23.9
4	400 kV	JHARSUGUDA-RAIGARH	4	57	599	0.0	6.0	-6.0
5	400 kV	RANCHI-SIPAT	2	240	290	0.0	0.5	-0.5
6	400 kV	JEYPORE-JACDALPUR	2	272	259	0.0	0.0	2.0
7	220 kV	BUDHIPADAR-RAIGARH	1	0	133	0.0	2.0	-2.0
8	220 kV	BUDHIPADAR-KORBA	2	51	49	0.1	0.0	0.1
ER-WR						2.1	38.4	-36.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	254	0.0	6.0	-6.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1616	0.0	38.0	-38.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2737	0.0	49.0	-49.0
4	400 kV	TALCHER I/C	2	694	368	4.7	0.0	4.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	93.0	-93.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	126	356	0.3	4.7	-4.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	266	448	0.0	4.3	-4.3
3	220 kV	ALIPURDUAR-SALAKATI	2	66	65	0.0	0.4	-0.4
ER-NER						0.3	9.4	-9.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	0	0.0	0.0	0.0
NER-NR						0.0	0.0	0.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3024	0.0	42.9	-42.9
2	HVDC	VINDHYACHAL B/B	-	0	256	0.0	3.7	-3.7
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1458	0.0	27.4	-27.4
4	765 kV	GWALIOR-AGRA	2	352	1893	0.1	27.4	-27.2
5	765 kV	GWALIOR-PHAGI	2	170	2202	0.0	30.5	-30.5
6	765 kV	JABALPUR-ORAI	2	0	979	0.0	32.9	-32.9
7	765 kV	GWALIOR-ORAI	1	932	0	15.6	0.0	15.6
8	765 kV	SATNA-ORAI	1	0	1100	0.0	22.4	-22.4
9	765 kV	BANASKANTHA-CHITORGARH	2	2993	839	22.7	1.3	21.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	2557	0.0	40.9	-40.9
11	400 kV	ZERDA-KANKROLI	1	0	0	0.0	0.0	0.0
12	400 kV	ZERDA -BHINMAL	1	0	0	0.0	0.0	0.0
13	400 kV	VINDHYACHAL -RIHAND	1	968	0	21.0	0.0	21.0
14	400 kV	RAPP-SHUJALPUR	2	432	247	2.1	1.4	0.7
15	400 kV	NEEMUCH-Chittorgarh	2	439	311	2.0	2.1	-0.2
16	220 kV	BHANPURA-RANPUR	1	0	141	0.0	2.4	-2.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.2	-1.2
18	220 kV	MEHGAON-AURAIYA	1	111	6	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	76	21	0.5	0.1	0.5
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						65.0	236.5	-171.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	999	0.0	9.9	-9.9
2	HVDC	RAIGARH-PUGALUR	2	0	1002	0.0	21.2	-21.2
3	765 kV	SOLAPUR-RAICHUR	2	1470	1202	6.0	8.3	-2.4
4	765 kV	WARDHA-NIZAMABAD	2	0	2116	0.0	26.9	-26.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2430	0.0	34.9	-34.9
6	400 kV	KOLHAPUR-KUDGI	2	1696	0	25.1	0.0	25.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	106	0.0	0.0	0.0
WR-SR						32.9	101.2	-68.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-256	64	-111	-2.67
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	339	-197	39	0.95
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-340	-247	-296	-7.10
	NER	132kV GELEPHU-SALAKATI	-56	-35	-47	-1.13
	NER	132kV MOTANGA-RANGIA	-19	-5	-13	-0.32
NEPAL	NR	NEPAL IMPORT (FROM UP)	-6	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	46	0	20	0.47
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	272	0	141	3.38
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-892	-608	-823	-19.76
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1461	-818	-1183	-28.38
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-122	0	-94	-2.26

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 15-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	9.27	0.00	0.00	1.04	0.00	0.00	10.62
Nepal	0.00	0.00	0.00	0.00	0.00	0.50	0.00	0.00	0.50
Bangladesh	20.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.50
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.50	0.31	9.27	0.00	0.00	1.54	0.00	0.00	31.62

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	4.58	0.00	0.00	4.58
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	4.58	0.00	0.00	4.58

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-9.27	0.00	0.00	-1.04	0.00	0.00	-10.62
Nepal	0.00	0.00	0.00	0.00	0.00	4.08	0.00	0.00	4.08
Bangladesh	-20.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.50
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.50	-0.31	-9.27	0.00	0.00	3.04	0.00	0.00	-27.04

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	150886	5076	7040	0	7454	2106	130716	3273	143846	155665	-1076
0:15	50.05	150142	5080	7138	0	6963	1913	130792	3229	143004	155115	-1226
0:30	50.00	149010	5070	7137	0	7175	2128	129254	3256	141873	154020	-1102
0:45	50.00	149020	5074	7051	0	7399	2126	128752	3300	141969	153702	-1047
1:00	50.05	148274	5071	7232	0	7259	2113	127949	3322	141042	152946	-1025
1:15	50.05	147252	5083	7013	0	7021	2107	127439	3333	140239	151996	-1122
1:30	50.05	146698	5084	7366	0	7009	2124	126810	3298	139332	151691	-1124
1:45	50.00	146458	5078	7325	0	6907	2121	126575	3279	139133	151285	-1107
2:00	50.00	145526	5080	7264	0	6852	2257	125840	3262	138262	150555	-1213
2:15	50.00	145674	5073	7221	0	6991	2108	125957	3266	138453	150616	-1223
2:30	50.00	145162	5081	7115	0	6870	2104	125660	3317	138047	150147	-1216
2:45	49.95	145645	5077	7052	0	6816	2103	126282	3296	138593	150626	-1208
3:00	50.00	145218	5083	7046	0	6828	2113	126037	3306	138172	150413	-1148
3:15	49.95	145254	5074	7164	0	6470	2116	126177	3303	138090	150304	-1194
3:30	50.00	145345	5082	7203	0	6750	2097	126019	3279	138142	150430	-1217
3:45	50.00	145655	5077	7244	0	6741	2061	126374	3305	138411	150802	-1185
4:00	50.05	145981	5065	7287	0	6717	2080	126513	3360	138694	151022	-1169
4:15	50.00	146765	5077	7394	0	7094	2064	127213	3255	139371	152097	-1149
4:30	50.00	148062	5088	7094	0	7184	2054	128326	3287	140968	153033	-1186
4:45	49.95	149944	5093	7152	0	7455	2078	130321	3257	142792	155356	-1184
5:00	50.05	151739	5078	7284	-44	8034	2052	131588	3243	144499	157235	-1232
5:15	50.00	155861	5071	7278	-82	8324	2255	135677	3269	148665	161792	-1294
5:30	50.05	159456	5080	7155	-87	8645	2100	139117	3301	152388	165311	-1295
5:45	50.05	162688	5082	7104	-93	9277	2117	141471	3351	155677	168309	-1147
6:00	50.05	165322	5077	7124	-50	9754	2108	142915	3312	158248	170240	-532
6:15	50.05	169274	5075	6980	331	11196	2147	145651	3291	161963	174671	-502
6:30	50.10	175485	5089	6817	381	16031	2144	146898	3391	168287	180751	-537
6:45	50.05	179236	5088	6658	586	17695	2143	148948	3308	171992	184527	-629
7:00	50.00	183131	5088	6587	1222	19404	2139	150488	3240	175322	188168	-624
7:15	50.00	187709	5087	6611	2464	20474	2133	152490	3329	178634	192528	-662
7:30	50.00	191260	5078	6596	4711	20647	2156	153546	3252	179953	195986	-645
7:45	50.05	193426	5085	6510	8688	20013	2000	152340	3263	178228	197899	-745
8:00	50.05	194515	5100	6464	14273	17108	2146	150658	3240	173778	198989	-872
8:15	50.00	197287	5088	6361	19372	15750	1991	149547	3258	171554	201367	-844
8:30	50.05	200210	5075	6195	26172	13455	2042	148041	3314	167843	204294	-829
8:45	50.00	202132	5088	6075	31966	11386	2019	146239	3282	164091	206055	-850
9:00	50.00	204105	5086	5838	37435	10616	2011	142698	3273	160832	206957	-854
9:15	49.85	209305	5063	5720	42617	10949	2061	142073	3373	160968	211856	-902
9:30	50.05	211095	5077	5626	48585	10566	2107	138757	3242	156884	213960	-903
9:45	50.05	211980	5072	5492	52482	10061	2082	136626	3282	154006	215097	-942
10:00	50.10	212067	5076	5304	54909	8796	2101	134834	3234	151854	214254	-985
10:15	50.00	212930	5073	5207	56686	8379	2102	134531	3293	151037	215271	-1408
10:30	50.20	213212	5078	4935	60528	7246	2052	132782	3247	147749	215868	-1703
10:45	50.10	212895	5067	5092	63108	6758	2087	130646	3350	144695	216108	-1776
11:00	50.10	211290	5083	4909	62547	6495	2095	129569	3249	143834	213947	-1772
11:15	49.95	209418	5072	4552	62562	5899	2097	128494	3185	142304	211861	-1748
11:30	50.01	209805	5054	4466	63668	6103	2092	127264	3145	141671	211792	-1740
11:45	50.05	209712	5071	4120	68045	6023	2085	124405	3151	137547	212900	-1724
12:00	50.06	208064	5055	3756	66307	6330	2146	123929	3195	138001	210718	-1711
12:15	49.95	206448	5111	3448	66744	6575	2174	122417	3219	136256	209688	-1887
12:30	50.01	205159	5087	3258	66097	6794	2189	121990	3221	135804	208636	-1925
12:45	49.90	202853	5088	2913	64741	6969	2154	121215	3211	135199	206291	-1888
13:00	50.00	201443	5050	2696	64794	7094	2138	119826	3271	133953	204869	-1895
13:15	50.05	198323	5048	2539	64028	6536	2154	118547	3147	131756	201999	-1956
13:30	50.00	197690	5034	2430	63175	6810	2175	118605	3163	132085	201392	-1991
13:45	50.10	196344	5054	2307	63767	6792	2157	116803	3237	130270	200117	-2002
14:00	50.05	193721	5047	2229	60231	6713	2227	118006	3156	131261	197609	-2021
14:15	50.10	194612	5059	2199	58775	7120	2151	119420	3238	133638	197962	-2031
14:30	50.05	194665	5043	2138	56271	7051	2176	121403	3206	136256	197288	-1995
14:45	49.95	193214	5054	2064	54025	7353	2167	122402	3185	137125	196250	-1920
15:00	50.00	193327	5044	1989	51737	7761	2168	124493	3260	139601	196452	-1919
15:15	49.95	191634	5041	2002	47079	7679	2161	128042	3225	142553	195229	-1944
15:30	49.95	192102	5036	2008	44448	8283	2159	130578	3206	145646	195718	-1485
15:45	49.85	191335	5051	2063	39481	9347	2182	133151	3245	149791	194520	-1020
16:00	49.95	190876	5040	2033	35798	9658	2184	135987	3213	153045	193913	-1023
16:15	49.85	188721	5024	2116	29630	10777	2169	139299	3208	156975	192223	-1054
16:30	50.00	189737	5045	2011	24840	12470	2182	143562	3302	162886	193412	-926
16:45	49.95	189670	5049	2041	18120	13445	2155	149496	3170	169509	193476	-894
17:00	50.05	190125	5048	2159	12971	16349	2157	152150	3185	174995	194019	-885
17:15	50.00	188144	5046	2402	8247	17279	2178	153916	3200	177495	192268	-912
17:30	50.05	190625	5035	2616	4255	20568	2159	156505	3195	183754	194333	-787
17:45	50.05	193404	5034	3075	1659	23185	2173	158431	3189	188670	196746	-797
18:00	50.05	194415	5042	3653	818	24060	2177	158829	3172	189944	197751	-717
18:15	50.00	193982	5046	4288	582	24686	2173	157579	3169	189112	197523	-680
18:30	50.05	193416	5052	4808	569	24791	2169	156247	3224	188039	196860	-663
18:45	50.05	190868	5040	5329	503	23760	2193	154295	3190	185036	194310	-630
19:00	50.05	188342	5041	5845	460	23138	2166	152037	3196	182037	191883	-702
19:15	50.00	185300	5055	6304	461	22239	2179	149866	3199	178535	189303	-763
19:30	50.00	182911	5056	6706	0	19776	2163	149149	3202	176205	186052	-733
19:45	50.00	180213	5045	7052	0	18255	2188	147692	3198	173161	183430	-773
20:00	50.00	177100	5052	7208	0	17937	2345	144791	3200	169892	180533	-734
20:15	50.00	174954	5053	7370	0	16268	2172	143944	3259	167584	178066	-769
20:30	50.05	172334	5058	7761	0	14534	2165	143111	3192	164573	175821	-729
20:45	50.05	170620	5048	8164	0	13366	2189	142027	3243	162456	174037	-730
21:00	50.10	167897	5070	8359	0	12672	2168	139748	3218	159538	171235	-749
21:15	50.10	164861	5061	8449	0	11542	2175	137683	3184	156412	168094	-675
21:30	50.00	162227	5068	8480	0	11259	2160	135308	3237	153747	165512	-803
21:45	50.00	159903	5048	8635	0	11162	2177	133265	3288	151268	163575	-1117
22:00	50.05	156470	5052	8805	0	10173	2169	130794	3209	147665	160202	-1176
22:15	50.05	155772	5063	8738	0	9897	2179	130402	3208	147034	159487	-1160
22:30	50.00	153482	5060	8877	0	9451	2175	128626				