



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 04th April 2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 03.04.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 03-अप्रैल-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 03rd April 2024, is available at the NLDC website.

धन्यवाद,

Report for previous day

Date of Reporting: 04-Apr-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	54769	64359	53970	27483	2850	203431
Peak Shortage (MW)	0	0	0	206	0	206
Energy Met (MU)	1184	1572	1406	588	51	4801
Hydro Gen (MU)	134	38	72	24	13	280
Wind Gen (MU)	17	98	37	-	-	153
Solar Gen (MU)*	147.74	82.47	129.58	3.03	1.34	364
Energy Shortage (MU)	0.23	0.00	0.00	2.49	0.00	2.72
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	56505	69479	66523	27488	2934	212896
Time Of Maximum Demand Met	19:23	15:43	14:56	19:43	18:18	10:49

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.047	0.13	1.18	8.82	10.13	78.36	11.51

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7117	0	149.4	36.3	1.2	237	0.00
	Haryana	7077	0	146.0	98.4	-0.5	304	0.00
	Rajasthan	13049	0	272.4	70.0	-0.5	312	0.00
	Delhi	4089	0	85.4	76.5	0.4	219	0.00
	UP	20841	0	396.7	127.5	-1.1	537	0.00
	Uttarakhand	2003	0	41.4	24.7	-0.7	159	0.07
	HP	1689	0	31.0	18.6	0.3	124	0.16
	J&K(UT) & Ladakh(UT)	2642	0	53.7	43.7	-0.6	292	0.00
	Chandigarh	215	0	4.0	3.9	0.1	36	0.00
WR	Railways_NR ISTS	197	0	3.9	3.6	0.2	29	0.00
	Chhattisgarh	6166	0	140.0	83.2	-0.4	327	0.00
	Gujarat	20487	0	444.8	146.0	0.1	567	0.00
	MP	12904	0	273.1	139.6	-2.8	463	0.00
	Maharashtra	28228	0	637.1	198.5	-0.7	727	0.00
	Goa	754	0	15.9	13.1	2.6	28	0.00
	DNHDDPDCL	1256	0	28.5	28.4	0.1	94	0.00
	AMNSIL	894	0	20.0	7.4	0.3	287	0.00
	BALCO	523	0	12.5	12.6	-0.1	519	0.00
SR	Andhra Pradesh	12660	0	244.3	72.1	-1.0	508	0.00
	Telangana	13698	0	281.7	154.1	-0.4	528	0.00
	Karnataka	16981	0	334.3	153.4	3.4	913	0.00
	Kerala	5359	0	107.9	82.8	0.5	287	0.00
	Tamil Nadu	19413	0	427.3	271.0	0.6	855	0.00
	Puducherry	457	0	10.3	9.8	-0.1	66	0.00
	Bihar	6014	0	112.7	104.9	-2.8	194	0.10
ER	DVC	3404	0	74.0	-39.6	0.6	444	0.00
	Jharkhand	1862	258	38.3	28.7	-1.4	339	2.39
	Odisha	6225	0	131.7	52.0	0.2	461	0.00
	West Bengal	10467	0	229.3	102.3	-1.0	268	0.00
	Sikkim	103	0	1.8	1.6	0.2	32	0.00
	Railways_ER ISTS	10	0	0.1	0.2	0.0	5	0.00
NER	Arunachal Pradesh	162	0	2.3	2.8	-0.7	24	0.00
	Assam	1721	0	31.5	24.1	0.4	116	0.00
	Manipur	207	0	2.9	2.9	0.0	23	0.00
	Meghalaya	298	0	5.4	4.7	-0.2	63	0.00
	Mizoram	126	0	2.0	1.8	0.0	10	0.00
	Nagaland	146	0	2.3	2.3	0.0	19	0.00
	Tripura	312	0	4.6	5.8	-0.1	58	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-2.4	-10.1	-24.1	-24.4
Day Peak (MW)	-334.8	-412.9	-1087.2	-1039.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	82.2	-337.4	300.4	-49.1	4.3	0.4
Actual(MU)	82.3	-347.4	313.6	-56.7	2.2	-6.0
O/D/U/D(MU)	0.1	-10.0	13.2	-7.6	-2.1	-6.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5143	8326	4878	4036	176	22559	53
State Sector	6351	5933	2838	4652	186	19958	47
Total	11493	14259	7716	8688	361	42517	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	805	1692	785	699	17	3997	77
Lignite	21	20	68	0	0	108	2
Hydro	134	38	72	24	13	280	5
Nuclear	26	58	51	0	0	135	3
Gas, Naptha & Diesel	19	59	6	0	25	109	2
RES (Wind, Solar, Biomass & Others)	185	184	201	5	1	576	11
Total	1190	2050	1183	727	55	5205	100

Share of RES in total generation (%)	15.51	8.98	16.98	0.65	2.42	11.06
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.00	13.64	27.48	4.05	25.68	19.08

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.047
Based on State Max Demands	1.079

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	212896	10:49	0
Non-Solar hr	207352	19:24	206

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 04-Apr-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	49	0.0	1.1	-1.1
3	765 kV	GAYA-VARANASI	2	449	324	0.0	1.3	-1.3
4	765 kV	SASARAM-FATEHPUR	1	55	294	0.0	4.2	-4.2
5	765 kV	GAYA-BALIA	1	0	486	0.0	6.8	-6.8
6	400 kV	PUSAULI-VARANASI	1	0	117	0.0	1.8	-1.8
7	400 kV	PUSAULI -ALLAHABAD	1	68	5	0.7	0.0	0.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	626	234	2.7	0.0	2.7
9	400 kV	PATNA-BALIA	2	163	241	0.0	3.7	-3.7
10	400 kV	NAUBATPUR-BALIA	2	122	107	0.0	0.5	-0.5
11	400 kV	BIHARSHARIFF-BALIA	2	444	0	4.7	0.0	4.7
12	400 kV	MOTIHARI-GORAKHPUR	2	229	221	0.0	1.1	-1.1
13	400 kV	BIHARSHARIFF-VARANASI	2	187	0	1.7	0.0	1.7
14	220 kV	SAHUPURI-KARAMNASA	1	39	84	0.0	3.0	-3.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						9.7	23.5	-13.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1373	0	23.0	0.0	23.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	948	435	4.0	0.0	4.0
3	765 kV	JHARSUGUDA-DURG	2	0	759	0.0	13.8	-13.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	463	0.0	6.9	-6.9
5	400 kV	RANCHI-SIPAT	2	146	191	0.0	1.0	-1.0
6	220 kV	BUDHIPADAR-RAIGARH	1	82	49	0.2	0.0	0.2
7	220 kV	BUDHIPADAR-KORBA	2	131	62	0.2	0.0	0.2
ER-WR						27.4	21.8	5.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	641	0.0	12.5	-12.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1494	0.0	36.1	-36.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2581	0.0	54.4	-54.4
4	400 kV	TALCHER-I/C	2	430	0	8.6	0.0	8.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	103.0	-103.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	277	144	2.8	0.3	2.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	515	78	6.3	0.0	6.3
3	220 kV	ALIPURDUAR-SALAKATI	2	48	13	0.5	0.0	0.5
ER-NER						9.6	0.3	9.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	655	0	11.4	0.0	11.4
NER-NR						11.4	0.0	11.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2006	0.0	45.7	-45.7
2	HVDC	VINDHYACHAL B/B	-	256	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1452	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	688	1397	1.0	10.9	-9.9
5	765 kV	GWALIOR-PHAGI	2	1019	836	4.3	9.8	-5.5
6	765 kV	JABALPUR-ORAI	2	324	544	0.0	4.0	-4.0
7	765 kV	GWALIOR-ORAI	1	617	0	8.9	0.0	8.9
8	765 kV	SATNA-ORAI	1	0	922	0.0	17.5	-17.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1637	290	16.9	0.5	16.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	2657	0.0	39.5	-39.5
11	400 kV	ZERDA-KANKROLI	1	340	30	3.7	0.0	3.7
12	400 kV	ZERDA -BHINMAL	1	333	29	3.7	0.0	3.7
13	400 kV	VINDHYACHAL -RIHAND	1	974	0	21.8	0.0	21.8
14	400 kV	RAPP-SHUJALPUR	2	800	98	7.3	0.1	7.2
15	400 kV	NEEMUCH-Chittorgarh	2	497	0	2.4	0.0	2.4
16	220 kV	BHANPURA-RANPUR	1	0	142	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	105	0	1.3	0.0	1.3
19	220 kV	MALANPUR-AURAIYA	1	80	0	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						78.1	161.3	-83.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	23.9	-23.9
2	HVDC	RAIGARH-PUGALUR	2	0	6020	0.0	115.4	-115.4
3	765 kV	SOLAPUR-RAICHUR	2	0	1960	0.0	30.5	-30.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2580	0.0	50.8	-50.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2907	0.0	58.0	-58.0
6	400 kV	KOLHAPUR-KUDGI	2	1036	0	17.4	0.0	17.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	132	2.5	0.0	2.5
WR-SR						19.9	278.4	-258.5

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	164	-116	30	0.72
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-233	110	-11	-0.27
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-222	-105	-144	-3.46
	NER	132kV GELEPHU-SALAKATI	-17	0	-7	-0.16
	NER	132kV MOTANGA-RANGIA	40	22	31	0.75
NEPAL	NR	NEPAL IMPORT (FROM UP)	-69	0	-50	-1.21
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-69	0	-41	-0.99
	ER	NEPAL IMPORT (FROM BIHAR)	155	0	-54	-1.31
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-568	-14	-275	-6.59
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-939	-651	-871	-20.91
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1040	-992	-1016	-24.38
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-148	0	-131	-3.15

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	4.51	0.00	0.00	0.00	0.00	0.00	4.51	
Nepal	0.23	0.00	5.92	0.00	0.00	0.00	0.06	0.00	0.00	6.21
Bangladesh	21.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.09
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.32	0.00	10.43	0.00	0.00	0.00	0.06	0.00	0.00	31.81

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.58	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.58
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	3.58	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.58

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.58	0.00	-4.51	0.00	0.00	0.00	0.00	0.00	-0.93
Nepal	-0.23	0.00	-5.92	0.00	0.00	-0.06	0.00	0.00	-6.21
Bangladesh	-21.09	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.09
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-17.74	0.00	-10.43	0.00	0.00	-0.06	0.00	0.00	-28.23