



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 08.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 07.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 7-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 07.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 08-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	66639	67326	49247	24721	2882	210815
Peak Shortage (MW)	0	0	0	16	0	16
Energy Met (MU)	1377	1572	1208	497	53	4707
Hydro Gen (MU)	113	44	80	19	14	270
Wind Gen (MU)	27	153	119	-	-	298
Solar Gen (MU)*	145.53	164.21	141.27	3.21	0.81	455
Energy Shortage (MU)	0.13	0.00	0.00	0.34	0.00	0.47
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	74169	79839	61393	25084	3048	238321
Time Of Maximum Demand Met	11:05	09:46	09:29	17:47	17:32	10:15

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.037	0.00	0.00	5.13	5.13	77.39	17.49

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9830	0	178.0	85.1	1.1	907	0.00
	Haryana	9699	0	179.9	136.7	-0.6	320	0.00
	Rajasthan	18598	0	335.7	113.2	-0.8	1166	0.00
	Delhi	5792	0	95.6	87.0	-0.1	582	0.00
	UP	22914	0	421.0	96.1	-1.2	335	0.00
	Uttarakhand	2614	0	49.5	39.4	0.7	146	0.13
	HP	2278	0	41.4	34.8	-0.5	60	0.00
	J&K(UT) & Ladakh(UT)	3362	0	67.3	63.1	-1.1	187	0.00
	Chandigarh	300	0	5.1	5.1	0.0	17	0.00
	Railways_NR ISTS	190	0	3.8	3.5	0.3	52	0.00
WR	Chhattisgarh	5462	0	108.5	52.6	-1.2	285	0.00
	Gujarat	23547	0	434.2	166.0	-9.0	940	0.00
	MP	19539	0	352.7	211.2	0.0	667	0.00
	Maharashtra	28967	0	593.7	170.7	-8.5	1277	0.00
	Goa	730	0	14.0	11.9	1.6	47	0.00
	DNHDDPDCL	1366	0	31.3	31.2	0.1	47	0.00
	AMNSIL	832	0	17.9	10.4	0.5	242	0.00
	BALCO	599	0	14.3	14.5	-0.2	6	0.00
	RIL JAMNAGAR	226	0	5.1	5.2	-0.1	0	0.00
	Andhra Pradesh	11530	0	213.8	49.6	-0.9	573	0.00
SR	Telangana	15019	0	264.4	99.0	-1.6	629	0.00
	Karnataka	16104	0	288.4	106.6	-4.5	481	0.00
	Kerala	4520	0	83.2	64.4	0.2	344	0.00
	Tamil Nadu	17425	0	348.5	214.6	-8.1	590	0.00
	Puducherry	411	0	8.7	8.3	-0.2	27	0.00
	Bihar	6695	0	119.9	109.2	-0.9	442	0.34
ER	DVC	3227	0	68.0	-41.8	-0.1	403	0.00
	Jharkhand	2266	0	43.6	31.0	0.4	218	0.00
	Odisha	5344	0	98.7	10.2	0.3	530	0.00
	West Bengal	8011	0	165.0	35.4	-1.5	214	0.00
	Sikkim	117	0	1.9	1.9	0.0	12	0.00
	Railways_ER ISTS	15	0	0.1	0.1	0.0	4	0.00
NER	Arunachal Pradesh	193	0	3.3	3.2	0.1	212	0.00
	Assam	1673	0	29.8	23.7	0.2	79	0.00
	Manipur	276	0	4.0	3.9	0.0	60	0.00
	Meghalaya	377	0	6.7	5.7	0.0	66	0.00
	Mizoram	166	0	2.6	2.3	0.0	34	0.00
	Nagaland	173	0	2.9	2.7	0.0	28	0.00
	Tripura	237	0	4.2	5.2	0.1	58	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-12.7	-6.5	-11.9	-27.5
Day Peak (MW)	-922.3	-661.6	-548.9	-1463.3

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	284.7	-258.5	144.8	-180.8	9.8	0.0
Actual(MU)	293.5	-265.0	125.0	-169.7	8.6	-7.7
O/D/U/D(MU)	8.8	-6.6	-19.8	11.0	-1.2	-7.7

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5990	11919	6718	4822	295	29744	53
State Sector	6344	10508	6830	2879	205	26765	47
Total	12334	22426	13548	7701	500	56509	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	806	1501	672	720	14	3714	73
Lignite	23	16	49	0	0	88	2
Hydro	113	44	80	19	14	270	5
Nuclear	53	52	47	0	0	152	3
Gas, Naptha & Diesel	11	20	10	0	22	62	1
RES (Wind, Solar, Biomass & Others)	197	321	309	7	1	835	16
Total	1202	1955	1167	747	51	5121	100

Share of RES in total generation (%)	16.38	16.41	26.51	0.94	1.59	16.30
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.18	21.36	37.38	3.54	28.63	24.55

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.051

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	238321	10:15	0
Non-Solar hr	216277	18:36	421

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export=(-ve) for NET (MU)
Date of Reporting: 08-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	88	1159	0.0	18.4	-18.4
4	765 kV	SASARAM-FATEHPUR	1	115	485	0.0	6.5	-6.5
5	765 kV	GAYA-BALIA	1	0	826	0.0	13.4	-13.4
6	400 kV	PUSAULI-VARANASI	1	5	93	0.0	1.0	-1.0
7	400 kV	PUSAULI-ALLAHABAD	1	0	102	0.0	1.3	-1.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	230	607	0.0	5.2	-5.2
9	400 kV	PATNA-BALIA	2	86	869	0.0	10.7	-10.7
10	400 kV	NAUBATPUR-BALIA	2	0	403	0.0	2.7	-2.7
11	400 kV	BIHARSHARIFF-BALIA	2	231	229	0.4	0.0	0.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	539	0.0	7.3	-7.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	55	388	0.0	4.9	-4.9
14	220 kV	SAHUPURI-KARAMNANA	1	0	38	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAUJI	1	0	34	0.0	0.0	0.0
ER-NR						0.5	74.3	-73.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1912	0.0	24.3	-24.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1100	1053	0.0	1.7	-1.7
3	765 kV	JHARSUGUDA-DURG	2	0	1211	0.0	21.9	-21.9
4	400 kV	JHARSUGUDA-RAIGARH	4	243	622	0.0	4.9	-4.9
5	400 kV	RANCHI-SIPAT	2	280	296	0.0	1.0	-1.0
6	400 kV	JEYPORE-JAGDALPUR	2	429	104	3.9	0.0	3.9
7	220 kV	BUDHIPADAR-RAIGARH	1	0	156	0.0	2.3	-2.3
8	220 kV	BUDHIPADAR-KORBA	2	93	78	0.3	0.0	0.3
ER-WR						4.2	56.0	-51.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	734	0.0	12.7	-12.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1617	0.0	41.2	-41.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2669	0.0	37.7	-37.7
4	400 kV	TALCHER-I/C	2	698	447	2.4	0.0	2.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	91.6	-91.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	131	139	0.5	0.9	-0.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	491	202	3.2	0.0	3.2
3	220 kV	ALIPURDUAR-SALAKATI	2	0	205	0.0	2.3	-2.3
ER-NER						3.7	3.2	0.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	463	0	10.4	0.0	10.4
NER-NR						10.4	0.0	10.4
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3526	0.0	67.2	-67.2
2	HVDC	VINDHYACHAL B/B	-	243	0	3.2	0.0	3.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1926	0.0	34.5	-34.5
4	765 kV	GWALIOR-AGRA	2	0	2517	0.0	36.0	-36.0
5	765 kV	GWALIOR-PHAGI	2	611	2124	0.4	30.5	-30.2
6	765 kV	JABALPUR-ORAI	2	0	1239	0.0	36.5	-36.5
7	765 kV	GWALIOR-ORAI	1	1027	0	15.8	0.0	15.8
8	765 kV	SATNA-ORAI	1	0	1272	0.0	24.4	-24.4
9	765 kV	BANASKANTHA-CHITORGARH	2	1636	1074	5.1	10.6	-5.5
10	765 kV	VINDHYACHAL VARANASI	2	0	2654	0.0	37.4	-37.4
11	400 kV	ZERDA-KANKROLI	1	291	168	1.5	0.6	0.9
12	400 kV	ZERDA BHINMAL	1	201	116	1.0	0.4	0.6
13	400 kV	VINDHYACHAL-RIHAND	1	971	0	20.5	0.0	20.5
14	400 kV	RAPP-SHUJALPUR	2	674	345	4.1	1.0	3.1
15	400 kV	NEEMUCH-Chittorgarh	2	592	566	2.9	2.3	0.6
16	220 kV	BHANPURA-RANPUR	1	0	128	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	95	43	0.6	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	64	52	0.1	0.0	0.1
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						55.0	285.0	-230.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1010	0.0	20.5	-20.5
2	HVDC	RAIGARH-PUGALUR	2	0	5014	0.0	76.7	-76.7
3	765 kV	SOLAPUR-RAICHUR	2	1914	1382	16.1	7.1	9.0
4	765 kV	WARDHA-NIZAMABAD	2	1025	2031	4.3	16.6	-12.4
5	765 kV	WARORA-WARANGAL(NEW)	2	516	2222	1.1	21.7	-20.5
6	400 kV	KOLHAPUR-KUDGI	2	1950	0	32.4	0.0	32.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	107	0.0	2.0	2.0
WR-SR						55.8	142.5	-86.7

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-314	17	-180	-4.32	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-256	198	-90	-2.16	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-277	-115	-213	-5.11	
	NER	132kV GELEPHU-SALAKATI	-56	-13	-37	-0.89	
	NER	132kV MOTANGA-RANGIA	-24	7	-8	-0.18	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-64	0	-32	-0.76	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-64	0	-46	-1.10	
	ER	NEPAL IMPORT (FROM BIHAR)	-137	0	-76	-1.83	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-365	70	-116	-2.78	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-419	-186	-393	-9.43	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1463	-815	-1146	-27.51	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-128	0	-103	-2.46	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 08-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.31	15.70	0.00	0.00	0.00	0.00	0.00	16.01	
Nepal	2.07	0.00	1.11	0.00	0.00	0.00	2.55	0.00	0.00	5.73
Bangladesh	9.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	9.49
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	11.56	0.31	16.81	0.00	0.00	0.00	2.55	0.00	0.00	31.23

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	1.23	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.23	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.09	0.00	0.00	0.09
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.23	0.00	0.00	0.00	0.00	0.00	0.09	0.00	0.00	1.32

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.23	-0.31	-15.70	0.00	0.00	0.00	0.00	0.00	-14.78
Nepal	-2.07	0.00	-1.11	0.00	0.00	-2.47	0.00	0.00	-5.65
Bangladesh	-9.49	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-9.49
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-10.33	-0.31	-16.81	0.00	0.00	-2.47	0.00	0.00	-29.92

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+G+H)	(K)
0:00	50.05	159325	5682	14361	0	5516	2055	130746	3642	144964	162002	-1392
0:15	49.94	159176	5672	14152	0	5094	2009	131735	3672	145024	162334	-1550
0:30	49.99	157923	5692	14173	0	5766	2005	129735	3689	143750	161606	-1525
0:45	49.94	157216	5672	13959	0	5674	2020	129396	3701	143257	160422	-1554
1:00	49.99	156080	5674	14005	0	5488	2078	128391	3671	142075	159307	-1510
1:15	49.99	154741	5673	13914	0	5300	1998	127347	3731	140827	157963	-1523
1:30	49.99	154284	5676	14111	0	5103	2083	126846	3742	140173	157561	-1516
1:45	49.99	153215	5674	14038	0	4876	2089	126424	3714	139177	156815	-1491
2:00	50.04	152521	5684	14103	0	4808	2085	125294	3770	138418	155744	-1466
2:15	49.99	152756	5676	14329	0	4796	2082	125318	3741	138427	155942	-1360
2:30	49.99	151988	5696	14427	0	4789	2080	124414	3770	137571	155176	-1314
2:45	49.99	151806	5683	14219	0	5320	2067	123968	3675	137587	154932	-1292
3:00	50.04	151909	5697	14018	0	5350	2084	124181	3657	137891	154987	-1257
3:15	49.99	151868	5693	13845	0	5110	2084	124436	3669	138023	154837	-1236
3:30	50.05	152247	5687	13930	0	5336	2082	124650	3712	138317	155397	-1221
3:45	50.05	152706	5689	13671	0	5460	2090	124676	3695	139035	155281	-1166
4:00	50.05	152554	5700	13514	0	5439	2095	125389	3620	139040	155757	-1189
4:15	50.00	154874	5697	13480	0	5946	2110	127119	3705	141394	158057	-1181
4:30	50.00	155767	5696	13505	0	5628	2106	128168	3681	142262	158784	-1192
4:45	50.00	158073	5693	13128	0	5785	2111	130804	3680	144945	161201	-1233
5:00	50.00	160331	5693	13039	88	5867	2123	133227	3684	147204	163721	-1213
5:15	49.94	165233	5687	12671	90	6213	2116	138179	3663	152472	168619	-1268
5:30	50.04	168577	5686	12705	91	6865	2127	141181	3648	155781	172303	-1327
5:45	49.99	172202	5680	12604	86	7747	2119	143995	3692	159512	175923	-1342
6:00	50.04	175798	5683	12214	76	8668	2111	147152	3657	163508	179561	-1177
6:15	50.00	180573	5668	12189	89	9196	2033	151602	3666	168295	184443	-1255
6:30	50.05	187940	5690	11984	95	10825	2092	156435	3673	175861	190794	-466
6:45	49.94	195677	5674	12074	121	14030	2147	160829	3674	183482	198549	-521
7:00	49.99	202323	5694	11729	287	18294	2216	163459	3671	190307	205350	-563
7:15	49.99	208172	5676	11495	1031	22555	2250	164731	3608	195646	211346	-584
7:30	49.99	211893	5694	11415	2136	24261	2280	165581	3700	198342	215067	-630
7:45	49.94	216705	5684	11392	3805	24776	2308	167931	3669	201508	219565	-611
8:00	49.99	219377	5704	11253	6559	24361	2335	168010	3623	201565	221845	-619
8:15	50.00	223493	5703	11129	10377	23826	2342	168478	3620	201987	225475	-611
8:30	50.05	224521	5692	10760	14769	22463	2326	166875	3687	198992	226572	-660
8:45	50.10	227296	5694	10361	19618	21341	2261	166606	3687	197317	229022	-661
9:00	50.09	228896	5690	9689	24833	17698	2227	167302	3622	194374	231061	-662
9:15	50.04	232793	5678	9263	29586	16908	2218	167295	3678	193944	234626	-676
9:30	50.04	235422	5676	8594	34808	15375	2158	166829	3603	192020	237083	-725
9:45	49.99	236214	5656	8200	38980	13502	2067	166177	3629	189034	238211	-870
10:00	49.94	237184	5663	7985	42377	11570	2009	165835	3643	186822	239082	-921
10:15	50.05	238321	5660	8015	45591	10590	2057	165126	3572	184715	240611	-1337
10:30	50.04	236730	5670	8116	48398	9766	2055	161780	3616	180216	239401	-1820
10:45	50.04	236853	5671	7866	51110	8009	2065	160208	3683	177877	238612	-1863
11:00	49.99	235696	5685	8839	54517	7176	2064	156068	3607	172340	237956	-1776
11:15	49.99	233821	5673	8979	56667	6705	2032	151913	3662	168175	235631	-1950
11:30	49.99	233565	5671	9401	59864	6246	2010	149509	3678	164300	236379	-1965
11:45	50.04	232406	5662	9784	60781	6134	2037	147239	3654	161841	235291	-1919
12:00	50.09	231018	5671	8953	62516	6172	2058	143501	3620	159549	234291	-1903
12:15	49.99	229080	5868	10167	63632	5848	2036	140588	3621	155281	231760	-1908
12:30	50.05	228313	5666	10233	64796	5715	2042	138853	3656	153284	230961	-1892
12:45	50.00	226881	5659	10405	65459	5833	2033	136545	3619	151017	229553	-1769
13:00	50.15	222896	5666	10225	65495	5755	2029	132857	3619	147176	225646	-1784
13:15	50.10	218081	5680	10127	66222	5512	2051	127564	3625	141732	220781	-1773
13:30	50.05	215629	5655	9849	65991	5454	2026	125690	3617	139789	218282	-1771
13:45	50.00	215307	5667	9710	65859	5389	2016	125464	3600	139738	217705	-1701
14:00	49.95	214917	5655	9533	65944	5506	2019	124794	3564	139440	217015	-1685
14:15	49.94	213670	5846	9243	64921	5146	2014	125247	3541	139506	215958	-1693
14:30	49.89	214567	5638	9140	63410	5413	2007	128115	3568	142017	217291	-1678
14:45	49.89	215528	5656	8959	61165	5809	2034	131183	3565	145404	218371	-1596
15:00	49.89	215867	5636	8940	58555	6070	2028	133984	3554	148372	218767	-1649
15:15	49.94	214760	5652	8902	55682	6766	2014	134848	3580	150176	217444	-1640
15:30	50.05	215158	5657	8865	52664	7311	2014	137761	3573	153629	217845	-1674
15:45	49.99	214845	5659	8781	49386	7965	2074	140689	3500	156678	218054	-1652
16:00	50.00	214377	5649	9007	44660	8647	2079	144011	3534	160710	217587	-1659
16:15	49.89	211761	5658	8881	39194	8561	2066	147182	3562	163686	215104	-1669
16:30	50.05	211719	5651	8993	33046	9942	2084	151794	3560	169680	215070	-1549
16:45	49.94	210473	5646	9227	26040	11277	2149	155653	3564	175206	213556	-1519
17:00	50.02	210555	5655	9470	18756	13430	2289	160383	3588	182329	213571	-1468
17:15	49.97	209651	5662	9546	12585	15722	2519	162834	3614	187520	212482	-1040
17:30	50.08	213797	5664	9621	7241	20707	2813	166595	3588	196935	216229	-856
17:45	50.04	214083	5664	9621	7241	20707	2813	166595	3588	214083	217229	-743
18:00	50.03	215303	5658	9780	1642	24391	2796	169965	3572	203881	217804	-716
18:15	49.88	214367	5656	10328	518	24677	2862	169263	3646	203521	216950	-809
18:30	49.98	215857	5655	10623	411	24535	2757	170339	3666	204823	217986	-679
18:45	50.03	215957	5665	11497	209	25176	2716	169363	3655	204251	218281	-677
19:00	50.03	214138	5671	12233	211	24351	2708	167648	3715	201694	216537	-684
19:15	50.03	212312	5679	12873	230	21535	2723	167764	3808	199209	214612	-669
19:30	50.03	209934	5672	13453	0	19955	2724	166565	3743	196481	212112	-673
19:45	50.03	206905	5671	13929	0	17436	2703	165484	3798	192976	209021	-656
20:00	50.08	204027	5677	14443	0	16358	2507	163405	3826	189584	206216	-679
20:15	49.98	199991	5665	14978	0	13874	2152	162145	3816	185013	202630	-742
20:30	49.98	196856	5679	15590	0	12933	2093	159527	3895	181266	199717	-680
20:45	49.98	194211	5691	16060	0	12627	2110	157127	3831	178151	197446	-744
21:00	49.99	191444	5674	16431	0	11280	2115	155513	3822	175013	194835	-726
21:15	49.99	187872	5671	16492	0	9775	2118	153757	3861	171380	191674	-1277
21:30	49.99	184355	5689	16666	0	8658	2117	151272	3833	167689	188235	-1582
21:45	50.04	181041	5693	16920	0	7445	2106	149231	3710	164121	185105	-1579
22:00	50.05	176571	5686	16886	0	6792	2107	145108	3795	159685	180374	-1564
22:15	49.89	175256	5658	16932	0	6704	2126	144083	3764	158324	179267	-1530
22:30	49.94	173560	5665	16956	0	6718	2126	142282	3			