



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 22.03.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 21.03.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 21-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 21.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 22-Mar-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	56914	69014	54134	22954	2752	205768
Peak Shortage (MW)	0	69	0	0	0	69
Energy Met (MU)	1231	1616	1457	499	53	4857
Hydro Gen (MU)	122	54	102	21	9	308
Wind Gen (MU)	18	86	36	-	-	140
Solar Gen (MU)*	207.33	141.23	138.46	2.44	0.68	490
Energy Shortage (MU)	0.00	0.07	0.00	0.13	0.18	0.38
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	60832	72545	69942	23561	2886	226152
Time Of Maximum Demand Met	09:52	10:40	11:42	18:44	17:59	09:42

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.027	0.00	0.15	4.19	4.34	82.66	13.00

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9636	0	174.9	67.4	-0.4	491	0.00
	Haryana	7590	0	157.6	103.8	-1.3	339	0.00
	Rajasthan	15296	0	287.0	76.9	-5.7	282	0.00
	Delhi	4002	0	79.8	72.3	-0.4	224	0.00
	UP	19746	0	385.7	83.6	1.3	588	0.00
	Uttarakhand	2122	0	42.5	33.1	0.7	203	0.00
	HP	1933	0	35.4	25.7	-0.3	725	0.00
	J&K(UT) & Ladakh(UT)	2873	0	60.5	54.5	-0.6	566	0.00
	Chandigarh	200	0	3.6	3.6	0.0	14	0.00
WR	Railways_NR ISTS	196	0	4.0	3.8	0.1	29	0.00
	Chhattisgarh	6405	0	142.0	76.7	-0.2	223	0.00
	Gujarat	23125	0	464.9	180.3	-0.3	558	0.00
	MP	13660	0	267.5	143.2	-2.6	441	0.00
	Maharashtra	28597	0	659.0	261.2	-2.4	733	0.07
	Goa	782	0	16.6	16.1	0.1	66	0.00
	DNHDDPDCL	1333	0	30.8	30.8	0.0	58	0.00
	AMNSIL	760	0	16.4	9.0	0.7	219	0.00
	BALCO	533	0	12.7	12.7	0.0	46	0.00
SR	RIL JAMNAGAR	254	0	6.0	6.2	-0.2	0	0.00
	Andhra Pradesh	12896	0	250.2	78.7	-0.1	449	0.00
	Telangana	16425	0	327.4	182.0	-1.1	1315	0.00
	Karnataka	17981	0	357.9	149.1	0.6	829	0.00
	Kerala	5002	0	101.3	81.8	0.4	241	0.00
	Tamil Nadu	19322	0	410.1	275.1	-0.2	669	0.00
	Puducherry	469	0	10.5	10.1	-0.1	46	0.00
ER	Bihar	5211	0	99.9	94.0	0.7	279	0.13
	DVC	3213	0	66.1	-49.5	-2.9	354	0.00
	Jharkhand	1576	0	32.4	26.1	-3.4	183	0.00
	Odisha	5782	0	118.7	40.0	-1.1	352	0.00
	West Bengal	8540	0	180.5	37.5	-3.1	428	0.00
	Sikkim	104	0	1.8	1.8	0.0	22	0.00
	Railways_ER ISTS	13	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	173	0	3.0	2.9	0.0	44	0.00
	Assam	1690	0	31.9	25.5	0.7	156	0.00
	Manipur	203	0	2.6	2.6	0.0	74	0.18
	Meghalaya	320	0	5.7	4.3	0.1	64	0.00
	Mizoram	130	0	2.4	1.9	-0.1	17	0.00
	Nagaland	158	0	2.4	2.4	0.0	22	0.00
	Tripura	290	0	4.9	4.7	0.1	35	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.9	-12.8	-23.5	-21.7
Day Peak (MW)	-373.0	-926.4	-1006.0	-1264.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	90.5	-243.6	312.7	-173.6	13.9	0.0
Actual(MU)	86.0	-251.6	326.4	-181.2	14.1	-6.3
O/D/U/D(MU)	-4.5	-8.0	13.8	-7.6	0.2	-6.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4733	9765	3538	2741	601	21378	51
State Sector	6659	6994	5726	672	155	20205	49
Total	11392	16758	9264	3413	756	41583	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	824	1603	754	761	10	3952	75
Lignite	31	12	55	0	0	97	2
Hydro	122	54	102	21	9	308	6
Nuclear	16	65	76	0	0	156	3
Gas, Naptha & Diesel	8	27	8	0	24	66	1
RES (Wind, Solar, Biomass & Others)	248	230	214	5	1	697	13
Total	1247	1990	1209	786	44	5275	100

Share of RES in total generation (%)	19.87	11.54	17.71	0.58	1.55	13.20
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.86	17.49	32.43	3.21	23.12	21.99

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.054

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226152	9:42	32
Non-Solar hr	207222	19:15	69

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 22-Mar-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	609	1163	0.0	11.0	-11.0
4	765 kV	SASARAM-FATEHPUR	1	200	671	0.0	8.3	-8.3
5	765 kV	GAYA-BALIA	1	0	654	0.0	7.0	-7.0
6	400 kV	PUSAULI-VARANASI	1	0	182	0.0	2.0	-2.0
7	400 kV	PUSAULI -ALLAHABAD	1	93	92	0.0	0.2	-0.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	616	581	0.0	0.3	-0.3
9	400 kV	PATNA-BALIA	2	105	972	0.0	12.3	-12.3
10	400 kV	NAUBATPUR-BALIA	2	58	325	0.0	4.0	-4.0
11	400 kV	BIHARSHARIFF-BALIA	2	487	243	1.6	0.0	1.6
12	400 kV	MOTIHARI-GORAKHPUR	2	132	506	0.0	5.5	-5.5
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	4.2	-4.2
14	220 kV	SAHUPURI-KARAMNASA	1	0	64	0.0	1.0	-1.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.3	0.0	0.3
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						2.0	58.2	-56.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	532	1178	0.0	4.7	-4.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	0	1422	0.0	12.5	-12.5
3	765 kV	JHARSUGUDA-DURG	2	0	860	0.0	17.0	-17.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	769	0.0	13.1	-13.1
5	400 kV	RANCHI-SIPAT	2	32	479	0.0	6.6	-6.6
6	220 kV	BUDHIPADAR-RAIGARH	1	0	155	0.0	2.3	-2.3
7	220 kV	BUDHIPADAR-KORBA	2	48	137	0.0	1.5	-1.5
ER-WR						0.0	57.7	-57.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	737	0.0	13.2	-13.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1764	0.0	48.1	-48.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	3187	0.0	61.0	-61.0
4	400 kV	TALCHER-I/C	2	0	383	0.0	4.4	-4.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	122.3	-122.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	357	64	2.9	0.3	2.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	634	133	4.6	0.0	4.6
3	220 kV	ALIPURDUAR-SALAKATI	2	148	0	1.8	0.0	1.8
ER-NER						9.3	0.3	9.0
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	952	0	23.1	0.0	23.1
NER-NR						23.1	0.0	23.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3036	0.0	51.9	-51.9
2	HVDC	VINDHYACHAL B/B	-	49	0	1.3	0.0	1.3
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1458	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	926	1267	4.9	5.7	-0.8
5	765 kV	GWALIOR-PHAGI	2	1138	1392	4.8	12.1	-7.3
6	765 kV	JABALPUR-ORAI	2	605	649	1.3	0.0	1.3
7	765 kV	GWALIOR-ORAI	1	679	0	11.3	0.0	11.3
8	765 kV	SATNA-ORAI	1	0	984	0.0	15.7	-15.7
9	765 kV	BANASKANTHA-CHITORGARH	2	2053	0	28.4	0.0	28.4
10	765 kV	VINDHYACHAL-VARANASI	2	87	1882	0.0	18.4	-18.4
11	400 kV	ZERDA-KANKROLI	1	465	0	6.5	0.0	6.5
12	400 kV	ZERDA -BHINMAL	1	321	0	3.9	0.0	3.9
13	400 kV	VINDHYACHAL -RIHAND	1	972	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	780	113	8.6	0.2	8.4
15	400 kV	NEEMUCH-Chittorgarh	2	741	154	7.6	0.2	7.4
16	220 kV	BHANPURA-RANPUR	1	0	140	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	152	0	1.6	0.0	1.6
19	220 kV	MALANPUR-AURAIYA	1	97	0	1.0	0.0	1.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						102.7	144.5	-41.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1011	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	6529	0.0	132.8	-132.8
3	765 kV	SOLAPUR-RAICHUR	2	838	1670	1.0	14.5	-13.5
4	765 kV	WARDHA-NIZAMABAD	2	0	3367	0.0	51.4	-51.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	3249	0.0	50.1	-50.1
6	400 kV	KOLHAPUR-KUDGI	2	1320	0	18.3	0.0	18.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	120	2.5	0.0	2.5
WR-SR						21.7	272.7	-251.0

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	512	119	256	6.15	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-324	11	-150	-3.60	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-365	-240	-313	-7.52	
	NER	132kV GELEPHU-SALAKATI	7	-4	2	0.05	
	NER	132kV MOTANGA-RANGIA	9	-5	1	0.02	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	-50	-1.19	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-39	-0.93	
	ER	NEPAL IMPORT (FROM BIHAR)	-339	0	-168	-4.04	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-587	0	-278	-6.68	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-930	-875	-915	-21.97	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1264	-813	-905	-21.73	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-76	0	-64	-1.54	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.39	4.39	0.00	0.00	1.12	0.00	0.00	5.90
Nepal	4.13	0.00	4.46	0.00	0.00	2.36	0.00	0.00	10.95
Bangladesh	22.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.84
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.97	0.39	8.85	0.00	0.00	3.48	0.00	0.00	39.69

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.63
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.63	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.63

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.63	-0.39	-4.39	0.00	0.00	-1.12	0.00	0.00	-5.27
Nepal	-4.13	0.00	-4.46	0.00	0.00	-2.36	0.00	0.00	-10.95
Bangladesh	-22.84	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.84
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.34	-0.39	-8.85	0.00	0.00	-3.48	0.00	0.00	-39.06

