



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 20.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 19.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 19-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 19.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 20-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60904	66242	48384	23486	2847	201863
Peak Shortage (MW)	0	245	0	0	0	245
Energy Met (MU)	1291	1554	1184	482	52	4564
Hydro Gen (MU)	132	48	99	21	11	311
Wind Gen (MU)	2	50	74	-	-	126
Solar Gen (MU)*	173.16	165.13	152.07	2.35	1.06	494
Energy Shortage (MU)	0.26	1.12	0.00	0.15	0.00	1.53
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	68822	76936	59845	24145	2962	230406
Time Of Maximum Demand Met	10:45	09:40	09:30	17:40	17:15	09:40

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.054	0.49	1.84	8.00	10.32	75.89	13.78

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8217	0	155.6	65.7	-0.9	384	0.00
	Haryana	8979	0	169.5	119.1	-2.1	258	0.00
	Rajasthan	17923	0	329.3	119.1	-0.9	676	0.00
	Delhi	5210	0	86.3	79.3	1.7	503	0.00
	UP	20637	0	389.2	92.3	-0.6	389	0.00
	Uttarakhand	2473	0	46.5	35.7	0.5	188	0.26
	HP	2206	0	39.2	31.5	-0.8	146	0.00
	J&K(UT) & Ladakh(UT)	3191	0	66.7	61.7	-0.5	104	0.00
	Chandigarh	266	0	4.4	4.2	0.1	21	0.00
	Railways_NR ISTS	184	0	4.0	3.7	0.2	48	0.00
WR	Chhattisgarh	5232	0	101.6	38.1	-1.7	536	0.52
	Gujarat	23498	0	448.9	184.8	1.8	574	0.00
	MP	19034	0	349.3	252.4	0.0	762	0.60
	Maharashtra	27148	0	573.6	174.2	-6.1	599	0.00
	Goa	599	0	13.3	9.7	3.1	66	0.00
	DNHDDPDCL	1295	0	30.0	30.0	0.0	41	0.00
	AMNSIL	844	0	17.5	10.2	0.2	279	0.00
	BALCO	585	0	14.0	14.0	0.0	19	0.00
	RIL JAMNAGAR	265	0	6.1	6.1	0.0	0	0.00
	Andhra Pradesh	10979	0	210.6	49.8	0.9	507	0.00
SR	Telangana	14181	0	249.0	116.6	-0.9	779	0.00
	Karnataka	16749	0	296.1	123.2	1.6	1179	0.00
	Kerala	4238	0	80.0	54.3	0.5	664	0.00
	Tamil Nadu	16766	0	339.3	186.1	-1.6	820	0.00
	Puducherry	414	0	8.9	8.4	-0.1	34	0.00
	Bihar	5794	0	105.4	100.9	-1.2	335	0.15
ER	DVC	3270	0	69.7	-36.2	-2.0	231	0.00
	Jharkhand	2262	0	41.5	28.9	-1.0	266	0.00
	Odisha	5580	0	109.4	20.1	-1.9	548	0.00
	West Bengal	7805	0	154.4	13.1	-1.9	223	0.00
	Sikkim	109	0	1.8	1.9	0.0	18	0.00
	Railways_ER ISTS	22	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	188	0	3.3	3.0	0.1	19	0.00
	Assam	1665	0	29.2	26.2	0.1	123	0.00
	Manipur	241	0	3.9	3.7	0.2	28	0.00
	Meghalaya	344	0	6.2	5.3	-0.2	154	0.00
	Mizoram	164	0	2.6	2.0	0.1	15	0.00
	Nagaland	172	0	2.9	2.7	0.0	12	0.00
	Tripura	241	0	4.2	4.8	0.1	27	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-10.2	1.1	-19.8	-23.2
Day Peak (MW)	-855.7	347.5	-1037.0	-1335.8

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	218.0	-206.7	179.6	-205.5	14.7	0.0
Actual(MU)	219.8	-205.6	171.5	-211.1	12.8	-8.6
O/D/U/D(MU)	1.8	1.1	-8.1	-5.6	-2.1	-8.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	7164	11885	8078	4710	144	31981	48
State Sector	10009	11638	9364	2837	205	34052	52
Total	17173	23522	17442	7547	349	66033	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	780	1525	581	760	14	3661	74
Lignite	24	18	49	0	0	90	2
Hydro	132	48	99	21	11	311	6
Nuclear	32	52	42	0	0	127	3
Gas, Naptha & Diesel	14	27	4	0	19	63	1
RES (Wind, Solar, Biomass & Others)	199	219	256	7	1	682	14
Total	1181	1889	1031	788	44	4933	100

Share of RES in total generation (%)	16.89	11.60	24.82	0.83	2.39	13.83
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.80	16.90	38.54	3.52	26.18	22.70

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.009
Based on State Max Demands	1.037

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	230406	9:40	0
Non-Solar hr	208394	18:25	668

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 20-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	0.5	-0.5
3	765 kV	GAYA-VARANASI	2	70	1152	0.0	18.1	-18.1
4	765 kV	SASARAM-FATEHPUR	1	65	680	0.0	9.8	-9.8
5	765 kV	GAYA-BALIA	1	0	716	0.0	9.8	-9.8
6	400 kV	PUSAULI-VARANASI	1	48	59	0.0	0.0	0.0
7	400 kV	PUSAULI-ALLAHABAD	1	34	146	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	209	663	0.0	5.9	-5.9
9	400 kV	PATNA-BALIA	2	0	1068	0.0	18.6	-18.6
10	400 kV	NAUBATPUR-BALIA	2	0	488	0.0	5.5	-5.5
11	400 kV	BIHARSHARIFE-BALIA	2	289	312	0.0	1.5	-1.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	571	0.0	9.3	-9.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	81	455	0.0	6.3	-6.3
14	220 kV	SAHUPURI-KARAMNASA	1	0	49	0.0	1.2	-1.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	28	0.0	0.8	-0.8
ER-NR						0.7	87.8	-87.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	525	764	0.0	3.7	-3.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	761	1180	0.0	7.9	-7.9
3	765 kV	JHARSUGUDA-DURG	2	0	1376	0.0	23.8	-23.8
4	400 kV	JHARSUGUDA-RAIGARH	4	468	16	5.0	0.0	5.0
5	400 kV	RANCHI-SIPAT	2	208	383	0.0	2.9	-2.9
6	400 kV	JEYPORE-JAGDALPUR	2	588	0	9.3	0.0	9.3
7	220 kV	BUDHIPADAR-RAIGARH	1	10	111	0.0	1.1	-1.1
8	220 kV	BUDHIPADAR-KORBA	2	48	68	0.0	0.2	-0.2
ER-WR						14.2	39.7	-25.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	727	0.0	17.2	-17.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1335	0.0	34.2	-34.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2677	0.0	44.7	-44.7
4	400 kV	TALCHER-I/C	2	0	1106	0.0	24.4	-24.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	96.0	-96.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	128	468	0.2	6.7	-6.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	275	599	0.0	7.1	-7.1
3	220 kV	ALIPURDUAR-SALAKATI	2	69	88	0.0	0.8	-0.8
ER-NER						0.2	14.5	-14.3
Import/Export of <null> (With <null>)								
No Records Found								
NER-NR						0.0	0.0	0.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3028	0.0	55.3	-55.3
2	HVDC	VINDHYACHAL B/B	-	871	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	985	0.0	24.3	-24.3
4	765 kV	GWALIOR-AGRA	2	503	1440	0.0	15.6	-15.6
5	765 kV	GWALIOR-PHAGI	2	273	2118	0.0	30.0	-30.0
6	765 kV	JABALPUR-ORAI	2	0	918	0.0	28.9	-28.9
7	765 kV	GWALIOR-ORAI	1	1194	0	21.0	0.0	21.0
8	765 kV	SATNA-ORAI	1	0	1309	0.0	25.3	-25.3
9	765 kV	BANASKANTHA-CHITORGARH	2	2579	202	30.2	0.0	30.2
10	765 kV	VINDHYACHAL-VARANASI	2	0	2862	0.0	42.3	-42.3
11	400 kV	ZERDA-KANKROLI	1	274	0	0.2	0.0	0.2
12	400 kV	ZERDA-BHINMAL	1	176	0	0.1	0.0	0.1
13	400 kV	VINDHYACHAL -RIHAND	1	974	0	21.9	0.0	21.9
14	400 kV	RAPP-SHUJALPUR	2	557	216	3.5	1.2	2.4
15	400 kV	NEEMUCH-Chittorgarh	2	649	293	2.4	0.0	2.4
16	220 kV	BHANPURA-RANPUR	1	0	131	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	171	0	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	134	9	0.9	0.0	0.9
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						87.8	226.5	-138.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	20.0	-20.0
2	HVDC	RAIGARH-PUGALUR	2	0	2004	0.0	40.2	-40.2
3	765 kV	SOLAPUR-RAICHUR	2	1540	1492	6.0	8.2	-2.3
4	765 kV	WARDHA-NIZAMABAD	2	0	2247	0.0	24.8	-24.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2551	0.0	31.9	-31.9
6	400 kV	KOLHAPUR-KUDGI	2	1764	0	25.4	0.0	25.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	105	2.0	0.0	2.0
WR-SR						33.4	125.2	-91.8
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 L.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	-214	-6	-123	-2.95		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) L.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	386	-213	45	1.08		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) L.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-333	-243	-286	-6.86		
	NER	132kV GELEPHU-SALAKATI	-55	-33	-44	-1.06		
	NER	132kV MOTANGA-RANGIA	-23	0	-17	-0.40		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-70	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-70	0	-3	-0.08		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	263	-223	48	1.15		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-916	-539	-736	-17.66		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1336	-822	-967	-23.20		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-106	0	-91	-2.18		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 20-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	12.71	0.00	0.00	0.00	0.00	0.00	13.02
Nepal	0.38	0.00	0.00	0.00	0.00	1.07	0.00	0.00	1.45
Bangladesh	18.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	18.53
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	18.91	0.31	12.71	0.00	0.00	1.07	0.00	0.00	33.00

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	3.15	0.00	0.00	3.15
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.00	0.00	0.00	0.00	3.15	0.00	0.00	3.15

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	-0.31	-12.71	0.00	0.00	0.00	0.00	0.00	-13.02
Nepal	-0.38	0.00	0.00	0.00	0.00	2.06	0.00	0.00	1.68
Bangladesh	-18.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-18.53
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-18.91	-0.31	-12.71	0.00	0.00	2.06	0.00	0.00	-29.87

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	49.99	154073	4870	6983	0	6928	2047	135322	3208	147090	159358	-1323
0:15	49.99	153335	4867	6805	0	7254	2067	134823	3293	146530	159109	-1585
0:30	49.94	152172	4801	6527	0	7488	2043	133873	3244	145645	157976	-1516
0:45	49.89	151988	4800	6406	0	7882	1981	133211	3249	145582	157529	-1532
1:00	49.84	151614	4787	6244	0	8396	2046	132464	3296	145370	157233	-1520
1:15	49.89	151068	4791	6155	0	7943	1949	132234	3283	144913	156355	-1421
1:30	50.00	150379	4801	5976	0	7188	2037	132576	3327	144403	155905	-1422
1:45	50.00	149262	4880	5953	0	6980	1947	131833	3221	143309	154814	-1422
2:00	50.00	148534	4878	5930	0	7025	1935	130878	3250	142604	153896	-1419
2:15	49.94	148527	4822	5942	0	7196	2033	130609	3228	142585	153830	-1412
2:30	49.99	148467	4804	5996	0	7428	1972	130278	3293	142471	153771	-1343
2:45	49.99	148248	4816	5984	0	7263	2023	130053	3315	142264	153454	-1287
3:00	50.04	148215	4809	6126	0	7295	1962	129977	3266	142089	153435	-1275
3:15	49.99	148537	4822	6190	0	6785	2037	130574	3300	142347	153708	-1214
3:30	49.99	148981	4801	6234	0	7000	1966	130901	3235	142747	154137	-1196
3:45	49.94	149758	4872	6193	0	6834	2038	131777	3240	143565	154954	-1127
4:00	50.04	150146	4810	6126	0	6912	1953	132261	3315	144020	155377	-1129
4:15	49.99	152484	4802	6029	0	7100	2040	134357	3250	146455	157578	-1113
4:30	49.94	154380	4813	5931	0	7333	2030	136194	3299	148449	159600	-1117
4:45	49.99	156308	4796	5980	0	8072	2052	137246	3263	150328	161409	-1241
5:00	50.05	158025	4808	5943	85	9322	2104	138216	3237	151997	163715	-1323
5:15	50.05	162798	4800	6027	53	10442	2256	141522	3341	156718	168441	-1303
5:30	50.05	167993	4875	6153	94	11770	2586	144801	3308	161746	173587	-1234
5:45	50.05	172780	4875	6325	88	12277	2814	148230	3332	166367	177941	-877
6:00	50.10	177217	4813	6446	76	13306	3174	150799	3335	170695	181949	-504
6:15	50.00	183067	4814	6510	160	15257	3240	154460	3326	176397	187767	-359
6:30	50.05	190813	4796	6527	161	19097	3291	158633	3342	184125	195847	-369
6:45	50.00	196884	4800	6557	269	21138	3969	161500	3375	190058	201608	-349
7:00	50.00	201552	4798	6530	693	23828	4171	163050	3343	194329	206413	-431
7:15	49.69	205627	4874	6498	1756	24671	4262	165029	3349	197373	210439	-532
7:30	49.80	208988	4852	6363	3625	25942	4218	165591	3314	199000	213905	-571
7:45	50.00	211700	4809	6286	6971	25381	4237	165386	3324	198443	216394	-552
8:00	50.05	213375	4808	6198	11928	23015	4188	164484	3416	195249	218037	-572
8:15	50.05	216974	4805	6093	18079	21508	3234	164279	3405	192802	221403	-586
8:30	50.05	217991	4811	6114	24472	18842	2158	162634	3317	187405	222348	-573
8:45	50.05	219980	4806	5942	31419	16078	1917	160112	3319	182619	223593	-497
9:00	50.15	221678	4875	5628	38462	15185	1974	155669	3306	177588	225099	-493
9:15	50.05	226860	4856	5290	44014	13812	1893	156698	3195	177556	229758	-741
9:30	50.10	229106	4792	5252	49466	13109	2003	154756	3237	174388	232615	-1239
9:45	50.00	230401	4784	5239	53063	11898	1885	153593	3297	172099	233759	-1747
10:00	50.05	229329	4783	5360	56151	10608	1989	150801	3254	167818	232946	-1759
10:15	49.84	228119	4788	5460	58667	9721	1959	148628	3218	163992	232441	-1693
10:30	49.99	228441	4849	5454	61693	8080	1932	146399	3230	161294	231637	-1630
10:45	49.99	227692	4837	5576	64391	7193	1940	143695	3268	157725	230900	-1854
11:00	50.05	226018	4847	5649	65821	7514	1946	140200	3243	154548	229220	-2036
11:15	49.94	225272	4847	5851	66840	6497	1939	139024	3233	152581	228231	-2073
11:30	49.94	225118	4840	5790	67816	6231	1819	138292	3242	151512	228030	-2063
11:45	49.94	224970	4842	5596	68679	6808	1935	137053	3189	150695	228102	-2058
12:00	49.94	223205	4830	5681	69736	6655	1964	134547	3191	147788	226604	-2085
12:15	49.94	220432	4836	5456	70037	6041	1656	133064	3225	144939	224315	-1921
12:30	49.94	219867	4835	5266	70056	6115	1543	131789	3243	144545	222847	-1936
12:45	49.94	218622	4829	4948	70025	6473	1845	130249	3268	143649	221637	-1853
13:00	49.99	216046	4844	4823	69718	6809	1960	127838	3284	141505	219276	-1842
13:15	49.99	211805	4841	4706	69055	6568	1851	124963	3326	138044	215310	-1823
13:30	49.99	210415	4845	4583	68333	6629	1981	124474	3343	137499	214188	-1783
13:45	50.04	210788	4846	4450	67407	6857	1843	125586	3305	138931	214294	-1717
14:00	50.04	211155	4838	4349	65796	6858	1966	127377	3279	141010	214463	-1756
14:15	50.09	210877	4789	4259	64208	6417	1945	129166	3331	142410	214115	-1701
14:30	50.04	211363	4786	3913	62007	6779	1810	131218	3328	145443	213841	-1732
14:45	50.04	211211	4784	3890	60035	6884	1988	133182	3260	147286	214023	-1476
15:00	49.99	211294	4829	3782	56848	7591	1977	136062	3274	150664	214363	-1517
15:15	49.99	209292	4818	3650	53576	8139	2014	136957	3261	152066	212415	-1521
15:30	49.99	209762	4826	3520	49770	9055	2147	140170	3281	156472	212769	-1470
15:45	49.94	210584	4813	3409	45635	9671	2610	144255	3386	161540	213779	-1410
16:00	49.99	210133	4818	3318	40232	10920	2833	147962	3340	166583	213423	-1426
16:15	49.94	207768	4829	3222	34596	12194	2951	150190	3300	169950	211282	-1228
16:30	49.99	208473	4810	3156	27489	14779	3188	155176	3299	177828	211897	-910
16:45	49.94	208612	4828	3035	20227	16844	3602	160060	3384	185350	211980	-902
17:00	49.99	209555	4828	3011	14184	21132	3659	162773	3353	192360	212940	-757
17:15	49.99	206231	4816	3005	8689	23643	4417	162479	3227	194537	210276	-800
17:30	49.99	206427	4817	2967	5085	26305	4694	163340	3241	198375	210449	-805
17:45	49.79	207569	4824	3097	2356	28499	4834	164620	3478	202116	211708	-758
18:00	49.94	206288	4828	3245	955	28182	4981	165151	3448	202088	210790	-833
18:15	49.89	207944	4832	3492	700	29606	5083	164588	3516	203752	211817	-879
18:30	49.94	207085	4820	3655	605	28556	5111	164703	3484	202825	210934	-839
18:45	50.04	208010	4851	3786	471	29185	4985	164815	3512	203753	211605	-813
19:00	50.04	206498	4847	3857	230	28796	3916	164850	3508	202411	210004	-800
19:15	49.99	203669	4844	3986	243	27925	3127	164036	3453	199440	207614	-839
19:30	49.99	201204	4833	4135	0	25545	2784	164320	3471	197069	205088	-829
19:45	50.04	198647	4855	4126	0	23015	2605	164472	3452	194521	202525	-776
20:00	49.99	194988	4850	4132	0	20681	2333	163590	3542	190856	199128	-747
20:15	50.04	191671	4865	4161	0	17688	2140	163577	3546	187510	195977	-780
20:30	50.07	188392	4862	4120	0	16561	2119	161533	3454	184272	192649	-821
20:45	50.07	186645	4861	4073	0	14694	2378	161063	3538	182572	190607	-775
21:00	50.07	184205	4865	3996	0	14111	2685	159141	3523	180209	188321	-799
21:15	50.02	180351	4873	3775	0	12554	2621	157039	3491	176576	184353	-722
21:30	49.97	177160	4854	3631	0	10980	2538	156196	3559	173529	181758	-1336
21:45	49.97	174555	4857	3548	0	10458	2391	154289	3522	171007	179065	-1280
22:00	50.07	170275	4862	3498	0	9421	2189	151628	3507	166777	175105	-1288
22:15	49.97	169936	4871	3506	0	9517	2063	151123	3513	166430	174593	-1308
22:30	49.97	168430	4856	3496	0	9017	1986	150294	3546	164934	173195	-1287
22:45	49.97	166156	4866									