National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report दिनांक: 31.08.2025

To,

1. कार्यकारी निदेशक, पू .क्षे .भा .प्रे .के.,14 , गोल्फ क्लब रोड , कोलकाता - 700033
   Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
2. कार्यकारी निदेशक, ऊ. क्षे. भा. प्रे. के., 18/ ए , शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली – 110016
   Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi – 110016
3. कार्यकारी निदेशक, प .क्षे .भा .प्रे .के., एफ3-, एम आई डी सी क्षेत्र , अंधेरी, मुंबई –400093
   Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
4. कार्यकारी निदेशक, ऊ. पू. क्षे. भा. प्रे. के., डोंगतिएह, लोअर नोंग्रह , लापलंग, शिलोंग – 793006
   Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
5. कार्यकारी निदेशक , द .क्षे .भा .प्रे .के.,29 , रेस कोर्स क्रॉस रोड, बंगलुरु –560009
   Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 30.08.2025.

महोदय/Sir,

आई०ई०जी०सी०-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 30-अगस्त-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रा०भा०प्रे०के० की वेबसाइट पर उप्लब्ध है |

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 30.08.2025, is available at the NLDC website.

धन्यवाद,
Thanks

ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड
राष्ट्रीय भार प्रेषण केंद्र, नई दिल्ली

Report for previous day

Date of Reporting: 31-Aug-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71229	61834	47847	28940	3486	213336
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1501	1434	1151	635	70	4791
Hydro Gen (MU)	376	121	194	103	41	834
Wind Gen (MU)	12	78	246	-	-	335
Solar Gen (MU)*	98.40	102.17	144.54	3.64	0.57	349
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	71209	63480	52721	29161	3596	215970
Time Of Maximum Demand Met	20:49	19:18	09:51	21:17	18:30	19:19

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.053	0.00	0.87	5.14	6.01	75.42	18.57

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9098	0	204.9	110.6	-0.1	436	0.00
	Haryana	10344	0	211.4	163.2	-0.3	258	0.00
	Rajasthan	12215	0	272.2	122.7	-6.9	947	0.00
	Delhi	5983	0	125.9	120.4	-0.3	306	0.00
	UP	28204	0	548.2	249.2	0.0	1226	0.00
	Uttarakhand	2426	0	49.9	25.3	-0.2	177	0.00
	HP	1767	0	37.4	8.9	-0.4	75	0.00
	J&K(UT) & Ladakh(UT)	2170	0	40.3	19.0	-0.6	278	0.00
	Chandigarh	310	0	6.3	6.0	0.3	34	0.00
	Railways_NR ISTS	211	0	4.3	3.9	0.4	39	0.00
WR	Chhattisgarh	5889	0	132.8	75.3	-0.6	357	0.00
	Gujarat	19886	0	439.5	194.1	0.1	865	0.00
	MP	12307	0	272.7	127.1	-1.4	655	0.00
	Maharashtra	24219	0	507.8	168.6	-3.3	657	0.00
	Goa	528	0	13.4	11.0	2.1	43	0.00
	DNHDDPDCL	1308	0	30.6	30.6	0.0	57	0.00
	AMNSIL	834	0	18.4	7.7	0.3	295	0.00
	BALCO	537	0	12.8	12.7	0.1	14	0.00
	RIL JAMNAGAR	249	0	5.6	5.6	0.0	0	0.00
SR	Andhra Pradesh	9950	0	216.4	27.8	-1.6	516	0.00
	Telangana	11611	0	230.1	89.2	-0.4	621	0.00
	Karnataka	11607	0	221.7	20.6	-1.0	522	0.00
	Kerala	4019	0	81.0	40.1	-0.9	379	0.00
	Tamil Nadu	18445	0	391.1	140.0	-1.5	991	0.00
	Puducherry	473	0	10.7	9.9	0.2	65	0.00
ER	Bihar	8284	0	171.8	161.4	-1.1	416	0.00
	DVC	3292	0	71.5	-25.7	-0.7	336	0.00
	Jharkhand	2206	0	45.6	33.4	0.2	230	0.00
	Odisha	6092	0	128.7	63.1	-1.1	676	0.00
	West Bengal	10142	0	216.5	87.6	-1.6	267	0.00
	Sikkim	79	0	1.2	1.4	-0.2	59	0.00
	Railways_ER ISTS	25	0	0.2	0.1	0.1	9	0.00
NER	Arunachal Pradesh	197	0	3.4	3.4	-0.5	11	0.00
	Assam	2302	0	45.8	39.7	0.0	124	0.00
	Manipur	229	0	3.0	3.3	-0.3	25	0.00
	Meghalaya	363	0	6.0	1.8	0.1	32	0.00
	Mizoram	128	0	2.6	1.1	-0.2	0	0.00
	Nagaland	164	0	3.0	2.9	-0.3	21	0.00
	Tripura	325	0	6.2	5.5	0.1	72	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	53.7	19.4	-24.1	-23.8
Day Peak (MW)	2367.6	964.3	-1020.2	-1162.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	336.8	-230.9	-35.3	-71.4	0.8	0.0
Actual(MU)	320.9	-215.5	-29.3	-83.2	-2.0	-9.1
O/D/U/D(MU)	-15.9	15.4	6.0	-11.8	-2.9	-9.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5977	9987	10968	3180	226	30338	48
State Sector	8239	12693	8528	2799	199	32458	52
Total	14216	22680	19496	5979	425	62796	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	699	1344	532	673	12	3259	64
Lignite	22	9	51	0	0	82	2
Hydro	376	121	194	103	41	834	16
Nuclear	41	58	47	0	0	145	3
Gas, Naptha & Diesel	6	34	7	0	21	68	1
RES (Wind, Solar, Biomass & Others)	117	183	416	6	1	722	14
Total	1261	1749	1246	781	74	5111	100

Share of RES in total generation (%)	9.28	10.44	33.38	0.72	0.80	14.12
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	42.36	20.64	52.68	13.86	55.48	33.28

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.019
Based on State Max Demands	1.057

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	203425	15:55	0
Non-Solar hr	215970	19:19	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 31-Aug-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	402	0.0	10.1	-10.1
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	543	781	0.0	7.2	-7.2
4	765 kV	SASARAM-FATEHPUR	1	243	278	0.0	2.0	-2.0
5	765 kV	GAYA-BALIA	1	0	993	0.0	14.9	-14.9
6	400 kV	PUSAULI-VARANASI	1	0	97	0.0	1.3	-1.3
7	400 kV	PUSAULI -ALLAHABAD	1	0	75	0.0	1.0	-1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	862	0.0	12.8	-12.8
9	400 kV	PATNA-BALIA	2	0	1053	0.0	15.5	-15.5
10	400 kV	NAUBATPUR-BALIA	2	0	446	0.0	4.2	-4.2
11	400 kV	BIHARSHARIFF-BALIA	2	95	370	0.0	2.6	-2.6
12	400 kV	MOTIHARI-GORAKHPUR	2	30	514	0.0	6.9	-6.9
13	400 kV	BIHARSARIFF-SAHUPURI	2	398	390	0.0	3.7	-3.7
14	220 kV	SAHUPURI-KARAMNASA	1	0	66	0.0	1.5	-1.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
					ER-NR	**0.7**	**86.3**	**-85.6**
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1172	78	10.7	0.0	10.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2129	0	33.8	0.0	33.8
3	765 kV	JHARSUGUDA-DURG	2	296	915	0.0	9.7	-9.7
4	400 kV	JHARSUGUDA-RAIGARH	4	422	207	1.8	0.0	1.8
5	400 kV	RANCHI-SIPAT	2	452	164	5.0	0.0	5.0
6	400 kV	JEYPORE-JAGDALPUR	2	424	211	3.8	0.0	3.8
7	220 kV	BUDHIPADAR-RAIGARH	1	30	118	0.0	1.3	-1.3
8	220 kV	BUDHIPADAR-KORBA	2	115	131	0.0	0.9	-0.9
					ER-WR	**55.1**	**11.9**	**43.2**
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	518	0.0	8.4	-8.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1761	0.0	27.6	-27.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	2485	0.0	32.7	-32.7
4	400 kV	TALCHER-I/C	2	605	727	3.3	0.0	3.3
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
					ER-SR	**0.0**	**68.6**	**-68.6**
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	173	216	0.6	0.7	-0.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	502	0.0	3.6	-3.6
3	220 kV	ALIPURDUAR-SALAKATI	2	2	108	0.0	1.2	-1.2
					ER-NER	**0.6**	**5.4**	**-4.8**
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	303	0.0	7.1	-7.1
					NER-NR	**0.0**	**7.1**	**-7.1**
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2017	0.0	47.1	-47.1
2	HVDC	VINDHYACHAL B/B	-	0	257	0.0	6.0	-6.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	498	0.0	12.2	-12.2
4	765 kV	GWALIOR-AGRA	2	0	2458	0.0	36.2	-36.2
5	765 kV	GWALIOR-PHAGI	2	328	1457	0.7	22.3	-21.6
6	765 kV	JABALPUR-ORAI	2	0	1410	0.0	43.4	-43.4
7	765 kV	GWALIOR-ORAI	1	675	0	12.6	0.0	12.6
8	765 kV	SATNA-ORAI	1	0	965	0.0	17.6	-17.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1307	1128	9.6	3.4	6.2
10	765 kV	VINDHYACHAL-VARANASI	2	0	3021	0.0	54.4	-54.4
11	400 kV	ZERDA-KANKROLI	1	243	145	1.7	0.4	1.4
12	400 kV	ZERDA -BHINMAL	1	168	103	1.2	0.3	0.9
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	292	485	0.8	4.1	-3.3
15	400 kV	NEEMUCH-Chittorgarh	2	91	700	0.1	8.5	-8.5
16	220 kV	BHANPURA-RANPUR	1	0	148	0.0	3.4	-3.4
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	87	28	0.6	0.1	0.5
19	220 kV	MALANPUR-AURAIYA	1	59	45	0.2	0.4	-0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
					WR-NR	**27.4**	**261.7**	**-234.4**
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	302	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	1931	0	36.5	0.0	36.5
3	765 kV	SOLAPUR-RAICHUR	2	2127	1038	22.0	2.5	19.5
4	765 kV	WARDHA-NIZAMABAD	2	431	2168	0.6	16.8	-16.2
5	765 kV	WARORA-WARANGAL(NEW)	2	561	2230	1.2	17.1	-15.9
6	400 kV	KOLHAPUR-KUDGI	2	2046	0	28.9	0.0	28.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	110	2.0	0.0	2.0
					WR-SR	**98.4**	**36.4**	**62.1**

INTERNATIONAL EXCHANGES

Import(+ve)/Export(-ve)

State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1377	1037	1251	30.03
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	895	832	863	20.71
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	125	62	93	2.23
	NER	132kV GELEPHU-SALAKATI	29	0	4	0.10
	NER	132kV MOTANGA-RANGIA	67	0	28	0.66
NEPAL	NR	NEPAL IMPORT (FROM UP)	-45	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	66	0	44	1.05
	ER	NEPAL IMPORT (FROM BIHAR)	178	94	135	3.24
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	633	508	631	15.14
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-985	-741	-962	-23.09
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1162	-820	-990	-23.75
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-46	0	-40	-0.96

CROSS BORDER EXCHANGE SCHEDULE **Date of Reporting: 31-Aug-2025**

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.87	0.10	0.00	0.00	0.00	0.00	0.00	0.00	23.97
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.87	0.10	0.00	0.00	0.00	0.00	0.00	0.00	23.97

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.02	0.00	1.59	0.00	0.00	0.14	0.00	0.00	54.75
Nepal	8.43	4.71	0.00	0.00	0.00	5.61	0.00	0.00	18.75
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	61.45	4.71	1.59	0.00	0.00	5.75	0.00	0.00	73.50

Net from India(in MU) **-ve : Export / +ve : Import**

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.02	0.00	1.59	0.00	0.00	0.14	0.00	0.00	54.75
Nepal	8.43	4.71	0.00	0.00	0.00	5.61	0.00	0.00	18.75
Bangladesh	-23.87	-0.10	0.00	0.00	0.00	0.00	0.00	0.00	-23.97
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	37.58	4.61	1.59	0.00	0.00	5.75	0.00	0.00	49.53

Date of Reporting: 31-Aug-2025

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)

TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	199161	5448	13132	0	33611	2683	142817	1870	186029	199561	1895
0:15	49.95	198293	5470	12887	0	34879	2611	141874	1861	185406	199582	1906
0:30	50.00	197270	5462	12687	0	34838	2559	141018	1893	184583	198457	1896
0:45	49.95	195847	5459	12688	0	34906	2452	139828	1840	183159	197173	1924
1:00	50.00	194481	5458	12490	0	34928	2427	138702	1892	181991	195897	1881
1:15	50.00	193028	5462	12473	0	34197	2404	137828	1888	180555	194252	1900
1:30	50.00	191593	5455	12164	0	33859	2328	137186	1863	179429	192855	1933
1:45	50.00	190199	5464	11973	0	33679	2301	136116	1794	178226	191327	1955
2:00	50.00	189306	5466	11978	0	33194	2291	135668	1905	177328	190502	1949
2:15	49.96	188151	5468	11801	0	33032	2283	134794	1906	176350	189284	1921
2:30	49.96	186970	5463	11566	0	32746	2296	134424	1823	175404	188318	1941
2:45	49.96	186569	5463	11513	0	32742	2272	133951	1855	175056	187796	1918
3:00	50.01	185928	5463	11353	0	32401	2290	133891	1856	174575	187254	1924
3:15	49.96	185510	5461	11225	0	32037	2289	134007	1902	174285	186921	2005
3:30	50.01	184839	5444	11092	0	32152	2287	133293	1869	173747	186137	2003
3:45	49.96	184388	5468	10849	0	31757	2293	133440	1831	173539	185638	2016
4:00	49.96	183744	5464	10660	0	31903	2288	132931	1813	173084	185059	1974
4:15	50.01	183999	5464	10665	0	31828	2293	132851	1868	173334	184969	2018
4:30	50.01	183951	5464	10681	0	32383	2278	132472	1889	173270	185167	2038
4:45	50.01	184417	5474	10700	0	32467	2283	132704	1875	173717	185503	2038
5:00	50.06	184738	5461	10573	494	32326	2323	133367	1920	173671	186464	2013
5:15	50.06	184611	5473	10442	488	32071	2338	133680	1879	173681	186371	2042
5:30	50.06	184757	5463	10072	488	31969	2320	134396	1843	174197	186551	2048
5:45	50.06	185607	5473	9861	497	31402	2319	135929	1840	175249	187321	2058
6:00	50.06	186394	5468	9633	504	31672	2351	136669	1872	176257	188169	2092
6:15	49.96	188412	5465	9459	611	32072	2319	138625	1895	178342	190446	2119
6:30	50.01	190503	5473	9363	1118	32040	2307	140517	1887	180022	192705	2090
6:45	49.96	192263	5462	9339	2207	32020	2304	141042	1893	180717	194267	2092
7:00	50.01	192765	5467	9083	3907	31543	2310	140477	1853	179775	194640	2112
7:15	49.96	194092	5458	8772	6036	31499	2319	139929	1844	179284	195857	2102
7:30	49.96	194015	5471	8610	8697	31053	2300	137645	1878	176708	195654	2095
7:45	50.01	192707	5463	8535	12007	30009	2304	134210	1872	172165	194400	2135
8:00	50.06	191480	5454	8818	15090	29961	2310	129434	1970	167572	193037	2123
8:15	50.01	192885	5462	9253	18298	29677	2324	127103	1964	165334	194081	2182
8:30	49.96	194604	5460	9858	20996	30081	2346	125024	1994	163750	195759	2223
8:45	50.01	195581	5465	10431	23771	30587	2354	122621	1947	161379	197176	2145
9:00	50.01	196232	5465	11012	26336	30467	2400	120666	2036	158884	198382	2111
9:15	49.96	198314	5453	11700	28209	30498	2422	119832	2062	158405	200176	2108
9:30	49.90	199756	5454	12683	30186	30629	2419	118575	1982	156887	201928	2079
9:45	49.85	201131	5446	13489	30414	30231	2453	119283	2007	157228	203323	2081
10:00	49.95	201340	5423	13730	31336	29284	2416	119408	2083	156274	203680	2132
10:15	50.06	202481	5436	13778	34013	28570	2417	118532	1997	154690	204743	2149
10:30	50.11	203179	5448	13903	36617	28198	2448	116101	2014	152659	204729	2161
10:45	50.11	203050	5437	14226	37465	27596	2414	115493	2043	151359	204674	2084
11:00	50.06	201886	5442	14386	37975	27331	2433	113994	2034	149525	203595	2088
11:15	49.95	201587	5441	14558	38092	27350	2406	113578	2096	148937	203521	1926
11:30	50.01	201900	5457	14563	38608	27919	2449	112979	1965	148729	203940	2037
11:45	50.01	202689	5443	14392	38632	27877	2458	113841	2012	149665	204655	1750
12:00	50.01	201935	5440	13823	40479	27744	2449	111871	2064	147633	203870	1779
12:15	49.96	200188	5434	14076	39598	27855	2453	110996	2034	146514	202446	1818
12:30	49.96	201274	5428	14515	42290	27528	2450	109417	2057	144469	203685	1875
12:45	50.01	201807	5434	14635	43336	27789	2475	108221	2013	143836	203903	1908
13:00	50.21	200478	5443	14835	44262	27408	2367	106188	2060	141381	202563	1783
13:15	50.26	198139	5441	15038	43723	26906	2365	104547	1973	139378	199993	1797
13:30	50.26	197541	5441	15245	43944	26842	2388	103523	2002	138352	199385	1773
13:45	50.06	197675	5454	15673	43585	27792	2397	102715	2048	138417	199664	1801
14:00	50.06	198322	5442	15863	42723	28470	2443	103372	2000	139736	200313	1794
14:15	50.06	199551	5452	16021	43311	28072	2445	103956	2008	140219	201265	1785
14:30	50.01	200570	5444	16371	43120	28983	2395	104362	1968	141079	202643	1843
14:45	50.01	201954	5466	16931	41411	29150	2428	106278	1912	143612	203576	2187
15:00	50.06	202242	5452	17092	40036	29209	2422	108073	1915	145114	204199	2060
15:15	50.06	202245	5447	16805	38480	29136	2445	110099	1872	146960	204284	2045
15:30	50.01	202372	5445	16802	36861	29558	2427	111295	1849	148709	204237	2068
15:45	50.01	202921	5446	16752	35035	29970	2421	113194	1863	151134	204681	2056
16:00	50.01	203085	5431	18043	32308	30423	2442	114129	1883	152734	204659	2072
16:15	50.01	201051	5450	18113	29480	30517	2483	113947	1809	153458	201799	2062
16:30	49.96	201164	5455	18425	26622	30838	2527	116503	1783	156117	202153	1856
16:45	49.91	200500	5456	18634	23105	30850	2513	119306	1827	158761	201691	1776
17:00	49.81	197794	5424	18456	17649	31255	2533	122025	1786	161689	199128	1767
17:15	49.91	197717	5449	18169	13850	30978	2522	126379	1734	165698	199081	1778
17:30	49.91	198003	5458	17910	10632	31403	2564	129714	1802	169461	199483	2041
17:45	49.86	199104	5471	17913	7625	31756	2641	133738	1739	173566	200883	1859
18:00	49.91	199352	5465	18019	5346	31841	2662	135879	1736	175987	200948	1822
18:15	50.01	200388	5467	17853	3439	32023	2739	138966	1734	179096	202221	1760
18:30	50.01	205770	5463	18081	2194	32370	2930	143781	1895	185495	206714	1739
18:45	50.01	207741	5470	18002	1031	33460	3080	146068	1930	188708	209041	1653
19:00	50.01	211798	5456	18040	359	35439	3115	148518	1941	193399	212868	1774
19:15	49.96	215663	5477	18073	281	36802	3149	150820	1944	197309	216546	1809
19:30	50.06	215270	5483	18107	278	36891	3183	150217	1955	196885	216114	1783
19:45	50.11	213146	5472	16641	296	36430	3131	150167	1998	196209	214135	1790
20:00	50.01	212057	5471	16695	286	36692	3158	148702	1982	195076	212986	1834
20:15	50.01	211467	5471	16550	0	36542	3130	148409	1974	194917	212076	1795
20:30	50.06	210608	5484	16743	0	35930	3056	148086	1980	193865	211279	1832
20:45	50.01	210467	5494	16851	0	35978	3026	147822	1987	193616	211158	1844
21:00	50.06	210057	5479	16990	0	35758	2960	147755	1962	193067	210904	1847
21:15	50.01	209965	5489	17493	0	35232	3019	147658	1993	192472	210884	1780
21:30	50.01	209116	5504	17634	0	35044	3009	146914	1819	191482	209924	1840
21:45	50.01	209570	5488	18262	0	34901	2999	147089	1862	191308	210601	1864
22:00	50.01	209173	5485	17896	0	34882	2993	147026	1796	191277	210078	1849
22:15	50.01	209367	5485	17618	0	35024	3014	147127	1868	191749	210136	1859
22:30	49.96	208685	5491	17079	0	34884	2991	147124	1899	191606	209468	1836
22:45	50.01	208048	5492	16632	0	35578	3047	146374	1880	191416	209003	1840
23:00	50.01	206608	5486	16390	0	35407	3091	145533	1865	190218	207772	1867
23:15	50.06	205190	5500	15957	0	35011	3061	144867	1801	189233	206197	1872
23:30	50.01	203184	5501	15868	0	34701	2934	143464	1830	187316	204298	1899
23:45	50.01	201315	5503	15893	0	34269	2832	141894	1854	185422	202245	1898

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).
** Hydro generation is excluding Bhutan hydro.
***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:
1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.