



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 27.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 26.02.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 26-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 26.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 27-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	53386	66798	49301	22635	2701	194821
Peak Shortage (MW)	0	0	0	0	35	35
Energy Met (MU)	1213	1634	1367	478	50	4742
Hydro Gen (MU)	98	39	69	21	8	235
Wind Gen (MU)	20	52	117	-	-	188
Solar Gen (MU)*	141.54	124.81	139.70	3.79	1.33	411
Energy Shortage (MU)	0.00	0.00	0.00	0.09	0.30	0.39
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65208	77125	68567	23073	2794	233736
Time Of Maximum Demand Met	09:41	10:27	09:44	18:15	17:56	09:42

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.045	0.00	0.24	3.02	3.26	70.55	26.19

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8663	0	137.3	50.9	-0.9	408	0.00
	Haryana	7410	0	151.0	111.1	-2.1	190	0.00
	Rajasthan	18240	0	345.9	114.5	-3.4	608	0.00
	Delhi	4270	0	71.7	64.3	-0.5	270	0.00
	UP	19820	0	363.7	105.0	0.0	598	0.00
	Uttarakhand	2355	0	41.3	32.5	-0.8	89	0.00
	HP	2041	0	36.2	30.1	-1.2	355	0.00
	J&K(UT) & Ladakh(UT)	2897	0	58.4	59.2	-4.5	790	0.00
	Chandigarh	225	0	3.5	3.5	0.0	18	0.00
WR	Railways_NR ISTS	176	0	3.8	3.9	-0.1	13	0.00
	Chhattisgarh	5976	0	134.2	67.2	0.4	287	0.00
	Gujarat	21800	0	436.5	187.5	-1.5	641	0.00
	MP	17498	0	338.1	211.0	-3.7	429	0.00
	Maharashtra	29784	0	646.6	228.3	0.9	670	0.00
	Goa	737	0	15.5	14.6	0.4	62	0.00
	DNHDDPDCL	1288	0	28.7	28.9	-0.2	79	0.00
	AMNSIL	743	0	17.2	10.4	-0.1	204	0.00
	BALCO	534	0	12.7	12.7	0.0	8	0.00
SR	RIL JAMNAGAR	196	0	4.7	4.7	0.0	0	0.00
	Andhra Pradesh	12448	0	237.7	58.6	-0.6	654	0.00
	Telangana	16601	0	315.8	189.6	-0.4	678	0.00
	Karnataka	18320	0	326.7	122.2	-1.9	855	0.00
	Kerala	4648	0	94.2	78.6	0.6	459	0.00
	Tamil Nadu	18537	0	382.8	226.6	-4.0	733	0.00
	Puducherry	431	0	9.6	9.2	-0.2	22	0.00
ER	Bihar	4868	0	97.8	89.2	2.1	402	0.09
	DVC	3267	0	69.7	-43.8	-0.6	268	0.00
	Jharkhand	1979	0	38.8	26.8	-0.7	168	0.00
	Odisha	4928	0	103.5	36.0	-1.2	450	0.00
	West Bengal	7959	0	166.4	24.7	-2.4	235	0.00
	Sikkim	111	0	1.8	2.1	-0.2	25	0.00
	Railways_ER ISTS	21	0	0.3	0.2	0.1	2	0.00
NER	Arunachal Pradesh	176	0	3.2	3.1	0.0	14	0.00
	Assam	1618	0	29.2	22.2	0.2	90	0.00
	Manipur	186	33	2.9	2.7	0.3	52	0.30
	Meghalaya	324	0	5.4	4.2	-0.2	97	0.00
	Mizoram	140	0	2.1	1.8	-0.1	26	0.00
	Nagaland	162	0	2.5	2.5	0.0	27	0.00
	Tripura	240	0	4.3	3.7	0.2	37	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.0	-10.6	-23.8	-8.2
Day Peak (MW)	-551.0	-567.4	-1027.0	-760.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	214.9	-237.1	201.3	-190.2	11.1	0.0
Actual(MU)	207.9	-220.1	196.6	-198.3	11.2	-2.6
O/D/U/D(MU)	-7.0	17.0	-4.7	-8.2	0.2	-2.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5959	6946	2458	2956	1068	19387	44
State Sector	9296	8347	4712	2259	181	24795	56
Total	15255	15293	7170	5215	1249	44181	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	743	1687	752	745	9	3936	77
Lignite	32	16	53	0	0	102	2
Hydro	98	39	69	21	8	235	5
Nuclear	18	63	70	0	0	152	3
Gas, Naptha & Diesel	10	10	4	0	24	49	1
RES (Wind, Solar, Biomass & Others)	188	179	287	7	1	662	13
Total	1089	1996	1235	773	43	5135	100

Share of RES in total generation (%)	17.24	8.99	23.21	0.87	3.09	12.89
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	27.94	14.14	34.46	3.58	22.69	20.44

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.033

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	233736	9:42	25
Non-Solar hr	201231	18:57	42

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 27-Feb-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	110	1188	0.0	19.2	-19.2
4	765 kV	SASARAM-FATEHPUR	1	0	662	0.0	12.2	-12.2
5	765 kV	GAYA-BALIA	1	0	646	0.0	10.2	-10.2
6	400 kV	PUSAULI-VARANASI	1	0	108	0.0	1.4	-1.4
7	400 kV	PUSAULI -ALLAHABAD	1	13	77	0.0	0.9	-0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	191	516	0.0	5.5	-5.5
9	400 kV	PATNA-BALIA	2	0	953	0.0	18.4	-18.4
10	400 kV	NAUBATPUR-BALIA	2	0	321	0.0	5.8	-5.8
11	400 kV	BIHARSHARIFF-BALIA	2	235	260	0.0	2.0	-2.0
12	400 kV	MOTIHARI-GORAKHPUR	2	60	475	0.0	6.7	-6.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	279	457	0.0	6.6	-6.6
14	220 kV	SAHUPURI-KARAMNASA	1	0	62	0.0	1.1	-1.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.7	92.6	-91.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	781	249	5.7	0.0	5.7
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	566	1146	0.0	10.6	-10.6
3	765 kV	JHARSUGUDA-DURG	2	0	1015	0.0	18.8	-18.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	817	0.0	14.0	-14.0
5	400 kV	RANCHI-SIPAT	2	141	367	0.0	3.9	-3.9
6	220 kV	BUDHIPADAR-RAIGARH	1	0	111	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	97	83	0.2	0.0	0.2
ER-WR						5.9	48.8	-43.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	367	0.0	7.1	-7.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1635	0.0	48.2	-48.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	2755	0.0	55.5	-55.5
4	400 kV	TALCHER-I/C	2	0	142	0.0	3.7	-3.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	110.7	-110.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	103	161	0.4	1.2	-0.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	226	178	0.2	0.0	0.2
3	220 kV	ALIPURDUAR-SALAKATI	2	61	15	0.5	0.0	0.5
ER-NER						1.0	1.2	-0.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	461	0	11.5	0.0	11.5
NER-NR						11.5	0.0	11.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2010	0.0	50.7	-50.7
2	HVDC	VINDHYACHAL B/B	-	198	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	981	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	0	1889	0.0	19.1	-19.1
5	765 kV	GWALIOR-PHAGI	2	0	1630	0.0	24.8	-24.8
6	765 kV	JABALPUR-ORAI	2	0	919	0.0	25.7	-25.7
7	765 kV	GWALIOR-ORAI	1	791	0	14.9	0.0	14.9
8	765 kV	SATNA-ORAI	1	0	1083	0.0	20.4	-20.4
9	765 kV	BANASKANTHA-CHITORGARH	2	1254	335	13.2	0.2	13.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	2036	0.0	26.0	-26.0
11	400 kV	ZERDA-KANKROLI	1	204	75	2.2	0.1	2.2
12	400 kV	ZERDA -BHINMAL	1	141	52	1.5	0.0	1.5
13	400 kV	VINDHYACHAL -RIHAND	1	490	0	8.3	0.0	8.3
14	400 kV	RAPP-SHUJALPUR	2	399	319	1.9	1.3	0.6
15	400 kV	NEEMUCH-Chittorgarh	2	424	284	2.2	0.9	1.3
16	220 kV	BHANPURA-RANPUR	1	0	180	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.4	-2.4
18	220 kV	MEHGAON-AURAIYA	1	121	0	1.9	0.0	1.9
19	220 kV	MALANPUR-AURAIYA	1	84	2	1.2	0.0	1.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						52.2	198.7	-146.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1013	0.0	21.8	-21.8
2	HVDC	RAIGARH-PUGALUR	2	0	3006	0.0	40.4	-40.4
3	765 kV	SOLAPUR-RAICHUR	2	848	1081	4.6	7.6	-2.9
4	765 kV	WARDHA-NIZAMABAD	2	0	2378	0.0	37.5	-37.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2620	0.0	42.6	-42.6
6	400 kV	KOLHAPUR-KUDGI	2	1682	0	27.6	0.0	27.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	27	0.0	0.2	-0.2
9	220 kV	XELDEM-AMBEWADI	1	0	116	2.2	0.0	2.2
WR-SR						34.5	150.1	-115.6

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	168	-51	40	0.96	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-278	95	-115	-2.75	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-268	-124	-206	-4.93	
	NER	132kV GELEPHU-SALAKATI	-22	-4	-13	-0.30	
	NER	132kV MOTANGA-RANGIA	-32	14	0	-0.01	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-1.10	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.00	
	ER	NEPAL IMPORT (FROM BIHAR)	-190	0	-158	-3.79	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-377	18	-237	-5.69	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-945	-897	-936	-22.46	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-761	-64	-341	-8.19	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-82	0	-57	-1.36	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.35	7.22	0.00	0.00	0.82	0.00	0.00	8.39
Nepal	4.03	0.00	5.35	0.00	0.00	1.42	0.00	0.00	10.80
Bangladesh	23.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.32
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.35	0.35	12.57	0.00	0.00	2.24	0.00	0.00	42.51

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.75	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.75
Nepal	0.00	0.00	0.00	0.00	0.00	0.42	0.00	0.00	0.42
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.75	0.00	0.00	0.00	0.00	0.42	0.00	0.00	1.17

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.75	-0.35	-7.22	0.00	0.00	-0.82	0.00	0.00	-7.64
Nepal	-4.03	0.00	-5.35	0.00	0.00	-1.00	0.00	0.00	-10.38
Bangladesh	-23.32	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.32
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.60	-0.35	-12.57	0.00	0.00	-1.82	0.00	0.00	-41.34

