



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 12.11.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 11.11.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 11-नवंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 11.11.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 12-Nov-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	55343	61730	46508	22736	2740	189057
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1229	1472	1112	467	51	4330
Hydro Gen (MU)	133	45	99	35	19	331
Wind Gen (MU)	5	42	37	-	-	84
Solar Gen (MU)*	151.46	91.30	125.72	3.49	1.14	373
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	58967	68222	53101	23700	2987	201924
Time Of Maximum Demand Met	09:55	10:23	11:58	17:33	17:16	10:22

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.050	0.00	1.31	11.35	12.66	72.98	14.36

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7238	0	144.4	63.9	0.9	374	0.00
	Haryana	7755	0	153.3	109.2	-0.9	234	0.00
	Rajasthan	16763	0	326.7	123.9	0.0	723	0.00
	Delhi	4152	0	82.6	74.3	-0.5	265	0.00
	UP	18677	0	386.4	148.1	-2.0	692	0.00
	Uttarakhand	2076	0	41.1	31.2	0.4	100	0.00
	HP	1894	0	33.7	23.4	-0.9	158	0.00
	J&K(UT) & Ladakh(UT)	2590	0	52.7	45.8	-0.5	250	0.00
	Chandigarh	206	0	3.9	3.9	0.0	61	0.00
WR	Railways_NR ISTS	191	0	3.9	3.8	0.2	30	0.00
	Chhattisgarh	4450	0	96.3	38.4	1.4	321	0.00
	Gujarat	20790	0	413.6	217.0	-3.5	497	0.00
	MP	15813	0	315.3	191.8	-2.8	416	0.00
	Maharashtra	26518	0	569.9	226.8	-0.1	849	0.00
	Goa	715	0	14.9	14.3	0.0	48	0.00
	DNHDDPDCL	1324	0	29.9	29.6	0.3	80	0.00
	AMNSIL	880	0	19.6	8.9	0.4	298	0.00
	BALCO	529	0	12.6	12.5	0.1	50	0.00
SR	Andhra Pradesh	11023	0	219.0	61.1	-0.7	642	0.00
	Telangana	10093	0	201.0	89.5	0.0	614	0.00
	Karnataka	13704	0	251.6	98.8	1.7	693	0.00
	Kerala	4347	0	85.2	62.3	1.2	271	0.00
	Tamil Nadu	16872	0	345.1	197.2	0.3	705	0.00
	Puducherry	442	0	9.7	9.3	-0.1	36	0.00
ER	Bihar	5182	0	101.0	89.9	0.1	329	0.00
	DVC	3153	0	64.6	-39.4	-0.2	317	0.00
	Jharkhand	1939	0	37.4	27.1	-0.6	92	0.00
	Odisha	5289	0	100.4	34.8	-2.5	466	0.00
	West Bengal	8263	0	162.0	34.7	-3.3	190	0.00
	Sikkim	102	0	1.4	1.5	-0.1	10	0.00
	Railways_ER ISTS	11	0	0.1	0.1	0.0	3	0.00
NER	Arunachal Pradesh	160	0	2.8	2.5	0.1	27	0.00
	Assam	1754	0	30.2	21.6	1.0	158	0.00
	Manipur	215	0	2.5	2.5	0.0	44	0.00
	Meghalaya	399	0	6.4	5.0	0.0	125	0.00
	Mizoram	132	0	1.8	1.6	-0.7	13	0.00
	Nagaland	162	0	2.4	2.2	0.0	23	0.00
	Tripura	276	0	4.8	5.5	0.3	66	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.2	9.7	-23.5	-12.2
Day Peak (MW)	368.0	521.1	-1008.0	-515.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	274.4	-191.8	113.6	-196.2	-0.1	0.0
Actual(MU)	273.1	-194.9	111.5	-201.5	-1.3	-13.1
O/D/U/D(MU)	-1.3	-3.2	-2.1	-5.3	-1.2	-13.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5672	9319	5848	3126	409	24373	47
State Sector	9713	9384	6161	2359	230	27846	53
Total	15385	18702	12009	5485	638	52220	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	664	1533	649	707	16	3569	76
Lignite	24	16	50	0	0	90	2
Hydro	133	45	99	35	19	331	7
Nuclear	36	52	76	0	0	164	3
Gas, Naptha & Diesel	12	19	6	0	21	57	1
RES (Wind, Solar, Biomass & Others)	175	135	190	5	1	505	11
Total	1043	1800	1069	747	57	4717	100

Share of RES in total generation (%)	16.75	7.48	17.74	0.67	1.99	10.71
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.87	12.91	34.12	5.33	35.48	21.21

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.025
Based on State Max Demands	1.070

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	201924	10:22	0
Non-Solar hr	198206	18:18	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 12-Nov-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	301	0.0	7.4	-7.4
2	HVDC	PUSAULI B/B	-	0	299	0.0	7.3	-7.3
3	765 kV	GAYA-VARANASI	2	47	1050	0.0	18.2	-18.2
4	765 kV	SASARAM-FATEHPUR	1	50	502	0.0	8.2	-8.2
5	765 kV	GAYA-BALIA	1	0	655	0.0	12.6	-12.6
6	400 kV	PUSAULI-VARANASI	1	0	272	0.0	5.2	-5.2
7	400 kV	PUSAULI -ALLAHABAD	1	0	117	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	42	587	0.0	9.3	-9.3
9	400 kV	PATNA-BALIA	2	0	808	0.0	15.6	-15.6
10	400 kV	NAUBATPUR-BALIA	2	0	261	0.0	4.9	-4.9
11	400 kV	BIHARSHARIFF-BALIA	2	122	168	0.0	2.6	-2.6
12	400 kV	MOTIHARI-GORAKHPUR	2	42	443	0.0	7.0	-7.0
13	400 kV	BIHARSHARIFF-VARANASI	2	8	363	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	101	0.0	0.6	-0.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	100.8	-100.4
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	205	495	0.0	1.2	-1.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	842	434	3.8	0.0	3.8
3	765 kV	JHARSUGUDA-DURG	2	0	950	0.0	17.8	-17.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	758	0.0	11.7	-11.7
5	400 kV	RANCHI-SIPAT	2	166	228	0.0	1.4	-1.4
6	220 kV	BUDHIPADAR-RAIGARH	1	0	112	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	119	72	0.4	0.0	0.4
ER-WR						4.2	33.8	-29.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	530	0.0	12.6	-12.6
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1493	0.0	36.1	-36.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	2471	0.0	49.2	-49.2
4	400 kV	TALCHER-I/C	2	377	0	7.4	0.0	7.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	98.0	-98.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	575	0.0	7.8	-7.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	795	0.0	9.5	-9.5
3	220 kV	ALIPURDUAR-SALAKATI	2	2	100	0.0	1.1	-1.1
ER-NER						0.0	18.5	-18.5
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	1005	0.0	20.2	-20.2
NER-NR						0.0	20.2	-20.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1013	0.0	24.7	-24.7
2	HVDC	VINDHYACHAL B/B	-	373	80	0.0	0.0	0.0
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1448	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	1636	0.0	24.0	-24.0
5	765 kV	GWALIOR-PHAGI	2	364	2026	0.4	30.4	-29.9
6	765 kV	JABALPUR-ORAI	2	0	940	0.0	34.6	-34.6
7	765 kV	GWALIOR-ORAI	1	917	0	14.3	0.0	14.3
8	765 kV	SATNA-ORAI	1	0	1018	0.0	19.7	-19.7
9	765 kV	BANASKANTHA-CHITORGARH	2	1261	0	15.8	0.0	15.8
10	765 kV	VINDHYACHAL-VARANASI	2	0	1855	0.0	31.0	-31.0
11	400 kV	ZERDA-KANKROLI	1	307	0	3.9	0.0	3.9
12	400 kV	ZERDA -BHINMAL	1	216	0	2.8	0.0	2.8
13	400 kV	VINDHYACHAL -RIHAND	1	953	47	0.5	0.0	0.5
14	400 kV	RAPP-SHUJALPUR	2	568	261	2.5	2.0	0.6
15	400 kV	NEEMUCH-Chittorgarh	2	582	293	2.9	1.8	1.1
16	220 kV	BHANPURA-RANPUR	1	0	192	0.0	3.3	-3.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.2	-2.2
18	220 kV	MEHGAON-AURAIYA	1	115	0	1.4	0.0	1.4
19	220 kV	MALANPUR-AURAIYA	1	81	3	0.8	0.0	0.8
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						45.4	209.9	-164.5
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	408	0.0	9.6	-9.6
2	HVDC	RAIGARH-PUGALUR	2	0	1501	0.0	30.8	-30.8
3	765 kV	SOLAPUR-RAICHUR	2	1254	653	7.0	2.8	4.2
4	765 kV	WARDHA-NIZAMABAD	2	0	1454	0.0	22.9	-22.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	1727	0.0	28.8	-28.8
6	400 kV	KOLHAPUR-KUDGI	2	1553	0	25.8	0.0	25.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	124	2.3	0.0	2.3
WR-SR						35.1	94.9	-59.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	179	77	118	2.84	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	245	149	190	4.55	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-190	-131	-162	-3.88	
	NER	132kV GELEPHU-SALAKATI	18	0	7	0.17	
	NER	132kV MOTANGA-RANGIA	32	13	23	0.55	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	65	0	57	1.36	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	456	205	348	8.34	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-930	-908	-917	-22.00	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-515	-497	-508	-12.19	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-78	0	-63	-1.50	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.01
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.01

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.81
Nepal	0.00	0.00	0.43	0.00	0.00	8.78	0.00	0.00	9.21
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	3.81	0.00	0.43	0.00	0.00	8.78	0.00	0.00	13.02

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.81	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.81
Nepal	0.00	0.00	0.43	0.00	0.00	8.78	0.00	0.00	9.21
Bangladesh	-23.01	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.01
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-19.20	0.00	0.43	0.00	0.00	8.78	0.00	0.00	-9.99

Date of Reporting:											12-Nov-2024	
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G +H)	(K)
0:00	50.03	158050	6477	4560	44	9801	1900	136970	1406	153446	161158	-108
0:15	49.98	157743	6480	4601	43	9258	1900	137094	1422	153099	160798	-146
0:30	50.03	156762	6448	4667	44	9402	1899	136126	1397	152051	159983	-159
0:45	50.03	155467	6471	4793	42	9774	1891	134198	1404	150632	158573	-193
1:00	49.98	154700	6458	4739	42	9317	1883	133988	1412	149919	157839	-172
1:15	49.93	153365	6466	4683	42	9258	1887	132620	1418	148640	156374	-178
1:30	49.93	152367	6468	4615	40	9333	1907	131888	1397	147712	155648	-199
1:45	49.93	151803	6470	4691	42	8850	1901	131804	1402	147070	155160	-168
2:00	50.03	151116	6480	4625	40	8785	1903	131307	1377	146451	154517	-159
2:15	50.03	150377	6499	4621	55	8137	1911	131009	1378	145701	153610	-191
2:30	49.98	150020	6487	4644	39	8100	1916	130931	1425	145337	153542	-181
2:45	49.98	149570	6487	4536	38	8127	1904	130490	1402	144996	152984	-187
3:00	50.03	148955	6499	4348	39	8198	1895	130132	1393	144568	152504	-187
3:15	49.98	149045	6486	4162	37	8180	1899	130104	1383	144846	152251	-162
3:30	49.98	148911	6493	3960	38	8322	1908	130379	1391	144913	152491	-195
3:45	50.03	148781	6496	3833	38	8302	1894	130569	1449	144910	152581	-197
4:00	50.03	148756	6498	3742	38	8305	1895	130516	1410	144976	152404	-214
4:15	49.98	150802	6480	3681	39	8761	1889	131603	1377	147082	153830	-231
4:30	50.03	151747	6479	3650	37	8899	1912	131969	1377	148060	154323	-234
4:45	50.03	153982	6495	3676	39	9520	1903	132907	1391	150267	155931	-213
5:00	50.03	155391	6490	3622	39	10062	1910	133894	1407	151730	157424	-229
5:15	49.98	159244	6483	3567	38	10504	1919	136195	1392	155639	160098	-245
5:30	50.03	162217	6505	3508	39	11275	1958	137566	1375	158670	162226	-250
5:45	49.98	164605	6502	3493	37	12149	1969	138481	1381	161075	164012	-246
6:00	50.03	167317	6491	3497	41	13932	2074	138782	1375	163779	166192	-276
6:15	49.82	172009	6488	3431	54	16505	2055	139445	1364	168524	169342	-274
6:30	49.77	177054	6483	3445	73	17857	2073	141291	1375	173536	172597	-303
6:45	49.87	180684	6493	3467	161	18289	2070	143203	1373	177056	175056	-275
7:00	50.02	181985	6511	3463	459	18597	2073	143655	1379	178063	176137	-324
7:15	49.82	184616	6501	3482	1212	18789	1973	144412	1402	179922	177771	-353
7:30	49.92	187190	6502	3514	2728	17990	2076	145004	1401	180948	179215	-337
7:45	50.07	187892	6495	3528	5126	15271	2005	144450	1471	179238	178346	-355
8:00	50.12	187281	6516	3616	8067	12991	1945	142545	1520	175598	177200	-329
8:15	50.07	189753	6514	3545	11327	12063	2004	141835	1513	174881	178801	-362
8:30	50.07	190814	6497	3368	14670	11547	1932	139957	1533	172776	179504	-350
8:45	50.02	192185	6500	3189	17689	11194	1869	138265	1593	171307	180299	-343
9:00	50.02	192773	6492	2966	20484	10541	2065	136834	1588	169323	180970	-394
9:15	50.03	197966	6489	2746	22898	9943	1934	138022	1650	172322	183682	-372
9:30	50.08	199741	6492	2534	25035	8875	1936	136984	1681	172172	183537	-342
9:45	50.03	200917	6499	2559	40795	9734	1973	139160	1696	157563	202416	-353
10:00	50.03	201500	6496	2585	42580	9583	1989	138279	1695	156335	203207	-343
10:15	50.03	201290	6494	3147	46477	8291	1987	135152	1694	151666	203242	-333
10:30	49.98	201476	6420	3320	48269	8097	2002	133543	1712	149887	203363	-327
10:45	49.98	201561	6483	3429	49821	7938	2006	132373	1666	148311	203716	-482
11:00	49.98	200819	6499	3370	50046	8072	2112	130484	1709	147403	202292	-399
11:15	49.92	199879	6487	3540	51345	7942	1987	128927	1701	144994	201929	-415
11:30	49.87	200115	6480	3458	52072	7948	1991	127975	1740	144585	201664	-333
11:45	49.82	200334	6468	3253	52663	8434	1971	127410	1722	144418	201921	-344
12:00	49.87	199415	6481	3063	52909	8541	1975	126205	1763	143443	200937	-355
12:15	49.97	198178	6498	2958	52994	7391	2014	125853	1733	142226	199441	-383
12:30	49.90	197765	6475	2821	52595	7759	2042	125843	1716	142349	199251	-375
12:45	49.95	197695	6473	2814	52572	7913	2058	125687	1710	142309	199227	-364
13:00	49.97	195108	6486	2690	52168	7475	2096	124643	1692	140250	197250	-369
13:15	49.97	192017	6478	2639	51155	7210	2044	122805	1688	138223	194019	-360
13:30	49.97	191922	6477	2526	50179	7699	2108	123365	1679	139217	194033	-359
13:45	50.06	193030	6484	2420	49306	7693	2055	125529	1717	141304	195204	-343
14:00	49.91	193568	6471	2304	48086	7838	2079	127576	1668	143178	196022	-384
14:15	50.01	194030	6469	2236	46226	7655	2057	130086	1640	145568	196369	-394
14:30	49.91	195855	6479	2145	44173	7840	2057	133595	1645	149537	197934	-377
14:45	49.91	197387	6471	2045	41787	8912	2071	136507	1653	153555	199446	-380
15:00	49.96	198246	6463	1949	39218	9787	2042	139094	1617	157079	200170	-385
15:15	49.96	197478	6463	1895	36091	10577	2066	140771	1641	159492	199504	-492
15:30	49.81	197690	6470	2021	32418	11311	2350	143177	1599	163251	199346	-438
15:45	49.96	196319	6483	1973	28438	11766	2607	145356	1600	165908	198223	-475
16:00	49.96	195591	6460	2034	24638	12705	3087	146870	1634	168919	197428	-428
16:15	49.91	193563	6466	1949	20854	13068	2951	148371	1568	170760	195227	-388
16:30	49.91	194571	6469	2000	16942	15053	3356	151364	1565	175629	196749	-434
16:45	49.86	194818	6471	2105	12731	17329	3474	153285	1539	179982	196934	-461
17:00	49.91	194568	6462	2157	8807	19440	3794	154963	1476	183604	197099	-506
17:15	49.91	193240	6466	2195	5809	20897	3952	155196	1460	185236	195975	-603
17:30	49.86	194714	6437	2353	3414	23574	3992	156502	1463	188947	197735	-693
17:45	49.86	196660	6455	2445	942	26510	4022	157996	1471	193273	199841	-669
18:00	50.06	197739	6452	2565	453	27778	4079	158174	1452	194721	200953	-611
18:15	49.96	197735	6481	2684	317	28169	4095	157470	1474	194734	200690	-619
18:30	50.01	197851	6483	2965	320	28302	4094	157249	1520	194566	200933	-615
18:45	50.06	197344	6488	3121	144	27594	4224	157403	1500	194079	200474	-611
19:00	50.11	194514	6484	3209	91	26549	4109	155733	1471	191214	197646	-576
19:15	50.06	192346	6494	3204	90	25509	2454	156117	1449	189052	195317	-587
19:30	50.06	189855	6490	3185	90	24315	2294	155213	1441	186580	193028	-570
19:45	50.06	186826	6491	3191	91	21889	2268	154629	1454	183544	190013	-551
20:00	50.06	183977	6525	3195	88	20325	2245	153551	1474	180694	187403	-546
20:15	50.01	181711	6496	3213	74	19081	2199	152410	1483	178424	184956	-536
20:30	50.06	179266	6493	3223	72	17766	2182	151530	1506	175971	182772	-498
20:45	50.01	177879	6506	3239	34	17256	2117	150734	1423	174606	181309	-441
21:00	50.06	176240	6492	3255	31	16873	2086	149668	1397	172954	179802	-418
21:15	50.01	175245	6497	3175	29	16036	2087	149337	1449	172041	178610	-368
21:30	50.06	173998	6517	3132	29	15472	2092	148821	1398	170837	177461	-329
21:45	50.06	172647	6515	3089	29	14710	2093	148427	1410	169529	176273	-336
22:00	50.06	170701	6503	3076	30	13780	2092	147558	1409	167595	174448	-333
22:15	49.96	171167	6509	3055	32	13546	2091	148187	1386	168080	174806	-320
22:30	50.01	170846	6492	3052	33	12933	2083	148583	1393	167761	174569	-285
22:45	50.01	170009	6512	313								