



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 14.09.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 13.09.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 13-सितंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 13.09.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 14-Sep-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	62062	56982	48697	27170	3554	198465
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1378	1338	1235	623	71	4644
Hydro Gen (MU)	352	117	180	93	29	772
Wind Gen (MU)	59	157	177	-	-	392
Solar Gen (MU)*	167.31	81.38	136.51	2.83	1.17	389
Energy Shortage (MU)	0.48	0.48	0.00	0.54	0.00	1.50
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	63584	60639	58416	29227	3640	204090
Time Of Maximum Demand Met	19:26	18:58	09:56	00:01	18:29	19:23

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.049	0.00	0.06	6.90	6.96	72.43	20.61

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13785	0	295.6	179.1	-0.8	766	0.00
	Haryana	8699	0	180.8	125.2	-3.2	385	0.00
	Rajasthan	12162	0	279.8	58.0	-1.1	991	0.00
	Delhi	4848	0	99.0	92.4	-0.9	249	0.00
	UP	20989	0	385.4	181.3	-2.3	518	0.00
	Uttarakhand	1853	0	38.3	15.8	-1.1	77	0.00
	HP	1752	0	36.6	3.2	-0.2	113	0.00
	J&K(UT) & Ladakh(UT)	2728	0	52.7	31.5	5.2	526	0.48
	Chandigarh	281	0	5.9	6.3	-0.4	18	0.00
WR	Railways_NR ISTS	211	0	4.2	3.9	0.3	42	0.00
	Chhattisgarh	5043	0	114.4	61.8	-1.5	215	0.00
	Gujarat	18910	0	411.2	168.7	-4.6	561	0.00
	MP	10817	0	218.9	83.2	-2.2	617	0.00
	Maharashtra	24154	409	518.3	173.6	-1.1	844	0.48
	Goa	664	0	14.0	11.3	2.6	35	0.00
	DNHDDPDCL	1301	0	30.3	30.3	0.0	36	0.00
	AMNSIL	781	0	17.8	8.9	0.3	249	0.00
	BALCO	529	0	12.6	12.6	0.0	520	0.00
SR	Andhra Pradesh	10885	0	230.7	58.7	-0.1	1074	0.00
	Telangana	13590	0	266.8	121.9	0.1	508	0.00
	Karnataka	14040	0	252.1	69.2	4.0	960	0.00
	Kerala	4252	0	85.7	54.8	0.8	296	0.00
	Tamil Nadu	18191	0	388.2	173.1	-1.0	527	0.00
	Puducherry	522	0	11.4	10.8	0.0	52	0.00
ER	Bihar	7780	0	164.3	154.3	-1.4	248	0.09
	DVC	3501	0	74.7	-26.4	-0.1	291	0.00
	Jharkhand	2049	0	45.1	34.0	1.6	320	0.44
	Odisha	5201	0	116.3	37.3	-2.5	365	0.00
	West Bengal	11314	0	221.2	93.3	-3.1	272	0.00
	Sikkim	89	0	1.3	1.6	-0.2	10	0.00
	Railways_ER ISTS	19	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	173	0	3.2	2.9	0.0	45	0.00
	Assam	2593	0	49.4	42.9	0.6	144	0.00
	Manipur	193	0	2.7	2.6	0.1	31	0.00
	Meghalaya	252	0	4.5	0.7	-0.1	88	0.00
	Mizoram	105	0	2.2	0.6	-0.2	1	0.00
	Nagaland	171	0	3.1	2.7	-0.1	19	0.00
	Tripura	281	0	6.0	6.2	0.1	58	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	40.1	16.8	-18.6	-24.9
Day Peak (MW)	1865.0	841.6	-987.0	-1126.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	178.3	-213.3	79.7	-55.9	11.3	0.0
Actual(MU)	164.2	-207.5	80.0	-54.5	10.7	-7.1
O/D/U/D(MU)	-14.1	5.8	0.4	1.4	-0.6	-7.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5429	16959	5488	3736	259	31871	50
State Sector	6207	12712	9597	2779	155	31449	50
Total	11636	29671	15085	6515	414	63320	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	650	1172	568	636	14	3041	61
Lignite	22	11	48	0	0	81	2
Hydro	352	117	180	93	29	772	16
Nuclear	30	68	76	0	0	174	4
Gas, Naptha & Diesel	7	33	5	0	23	68	1
RES (Wind, Solar, Biomass & Others)	233	240	352	5	1	830	17
Total	1293	1643	1229	733	68	4965	100

Share of RES in total generation (%)	17.98	14.61	28.64	0.62	1.76	16.72
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	47.52	25.90	49.47	13.28	45.02	35.77

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.055
Based on State Max Demands	1.101

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	203734	11:40	85
Non-Solar hr	204090	19:23	552

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 14-Sep-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	701	0.0	17.0	-17.0
2	HVDC	PUSAULI B/B	-	0	112	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	1185	443	6.6	0.0	6.6
4	765 kV	SASARAM-FATEHPUR	1	535	266	2.5	0.0	2.5
5	765 kV	GAYA-BALIA	1	0	608	0.0	7.0	-7.0
6	400 kV	PUSAULI-VARANASI	1	0	189	0.0	3.5	-3.5
7	400 kV	PUSAULI -ALLAHABAD	1	79	0	1.0	0.0	1.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	257	496	0.0	2.4	-2.4
9	400 kV	PATNA-BALIA	2	331	543	0.0	3.9	-3.9
10	400 kV	NAUBATPUR-BALIA	2	162	147	0.0	0.4	-0.4
11	400 kV	BIHARSHARIFF-BALIA	2	299	16	4.5	0.0	4.5
12	400 kV	MOTIHARI-GORAKHPUR	2	128	326	0.0	2.2	-2.2
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	75	0.0	1.3	-1.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						15.1	40.2	-25.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	72	923	0.0	8.0	-8.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1808	75	24.1	0.0	24.1
3	765 kV	JHARSUGUDA-DURG	2	0	533	0.0	7.3	-7.3
4	400 kV	JHARSUGUDA-RAIGARH	4	5	522	0.0	5.8	-5.8
5	400 kV	RANCHI-SIPAT	2	491	40	5.8	0.0	5.8
6	220 kV	BUDHIPADAR-RAIGARH	1	1	105	0.0	1.5	-1.5
7	220 kV	BUDHIPADAR-KORBA	2	60	65	0.0	0.3	-0.3
ER-WR						29.9	22.9	7.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	731	0.0	17.4	-17.4
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	2	0.0	0.0	0.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2371	0.0	37.1	-37.1
4	400 kV	TALCHER-I/C	2	1865	0	38.6	0.0	38.6
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	54.5	-54.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	476	0.0	7.8	-7.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	619	0.0	10.9	-10.9
3	220 kV	ALIPURDUAR-SALAKATI	2	0	136	0.0	2.5	-2.5
ER-NER						0.0	21.1	-21.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	502	0.0	12.0	-12.0
NER-NR						0.0	12.0	-12.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2042	0.0	48.2	-48.2
2	HVDC	VINDHYACHAL B/B	-	0	60	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	979	0.0	24.2	-24.2
4	765 kV	GWALIOR-AGRA	2	69	1145	0.0	12.8	-12.8
5	765 kV	GWALIOR-PHAGI	2	1886	1201	10.4	13.2	-2.8
6	765 kV	JABALPUR-ORAI	2	133	639	0.0	12.4	-12.4
7	765 kV	GWALIOR-ORAI	1	602	407	7.0	1.7	5.3
8	765 kV	SATNA-ORAI	1	0	644	0.0	10.6	-10.6
9	765 kV	BANASKANTHA-CHITORGARH	2	1218	0	17.1	0.0	17.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	2993	0.0	47.8	-47.8
11	400 kV	ZERDA-KANKROLI	1	314	0	0.3	0.0	0.3
12	400 kV	ZERDA -BHINMAL	1	222	60	4.6	0.0	4.6
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	638	301	4.6	1.9	2.7
15	400 kV	NEEMUCH-Chittorgarh	2	505	395	3.0	3.2	-0.1
16	220 kV	BHANPURA-RANPUR	1	0	85	0.0	1.3	-1.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	58	33	0.2	0.2	0.0
19	220 kV	MALANPUR-AURAIYA	1	46	33	0.4	0.3	0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						47.4	180.4	-133.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	299	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	0	2011	0.0	41.5	-41.5
3	765 kV	SOLAPUR-RAICHUR	2	1045	1308	7.0	5.6	1.5
4	765 kV	WARDHA-NIZAMABAD	2	0	2418	0.0	32.4	-32.4
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2399	0.0	31.3	-31.3
6	400 kV	KOLHAPUR-KUDGI	2	1636	0	26.8	0.0	26.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	52	150	0.2	0.1	0.1
9	220 kV	XELDEM-AMBEWADI	1	0	131	2.6	0.0	2.6
WR-SR						43.8	110.8	-67.1

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	732	0	676	16.22	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	851	792	817	19.62	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	124	65	94	2.26	
	NER	132kV GELEPHU-SALAKATI	37	0	28	0.66	
	NER	132kV MOTANGA-RANGIA	68	0	58	1.39	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	0.87	
	ER	NEPAL IMPORT (FROM BIHAR)	73	3	34	0.83	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	704	478	629	15.09	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-905	0	-712	-17.08	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1126	-914	-1037	-24.89	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-82	0	-62	-1.48	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.02
Bangladesh	17.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.48
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	17.50	0.00	0.00	0.00	0.00	0.00	0.00	0.00	17.50

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.92	0.00	0.79	0.00	0.00	0.03	0.00	0.00	40.74
Nepal	7.07	0.00	10.40	0.00	0.00	0.00	0.00	0.00	17.47
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	46.99	0.00	11.19	0.00	0.00	0.03	0.00	0.00	58.21

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	39.92	0.00	0.79	0.00	0.00	0.03	0.00	0.00	40.74
Nepal	7.05	0.00	10.40	0.00	0.00	0.00	0.00	0.00	17.45
Bangladesh	-17.48	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-17.48
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	29.49	0.00	11.19	0.00	0.00	0.03	0.00	0.00	40.71