



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 10.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 09.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 9-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 09.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 10-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	71459	58384	50710	27102	3354	211009
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1695	1351	1252	599	68	4965
Hydro Gen (MU)	376	59	178	95	36	744
Wind Gen (MU)	36	180	276	-	-	491
Solar Gen (MU)*	175.23	105.03	125.23	1.38	0.84	408
Energy Shortage (MU)	0.00	0.00	0.00	0.29	0.00	0.29
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	77358	59784	58347	27709	3356	215836
Time Of Maximum Demand Met	00:14	19:33	09:54	19:36	20:07	14:57

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.057	0.61	0.86	6.46	7.93	65.06	27.01

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	14176	0	302.0	185.7	-3.9	653	0.00
	Haryana	13060	0	248.9	193.6	-6.1	319	0.00
	Rajasthan	13810	0	305.3	126.0	-4.8	492	0.00
	Delhi	7144	0	139.1	127.7	-1.9	367	0.00
	UP	28653	0	549.2	274.7	-1.5	579	0.00
	Uttarakhand	2347	0	51.9	21.7	-0.2	166	0.00
	HP	1756	0	37.2	-1.5	-0.4	168	0.00
	J&K(UT) & Ladakh(UT)	2390	0	49.9	26.1	-0.3	288	0.00
	Chandigarh	354	0	7.0	7.1	-0.1	31	0.00
	Railways NR ISTS	211	0	4.1	3.7	0.4	43	0.00
WR	Chhattisgarh	4425	0	96.2	61.5	-0.6	421	0.00
	Gujarat	17836	0	395.1	141.9	-6.5	394	0.00
	MP	11144	0	236.1	102.9	0.0	410	0.00
	Maharashtra	24520	0	538.8	178.4	-3.0	780	0.00
	Goa	624	0	14.8	12.4	1.9	116	0.00
	DNHDDPDCL	1402	0	32.3	32.3	0.0	76	0.00
	AMNSIL	917	0	19.7	9.4	-0.1	261	0.00
	BALCO	528	0	12.6	12.7	-0.1	4	0.00
	RIL JAMNAGAR	244	0	5.3	5.4	-0.1	0	0.00
	Andhra Pradesh	10759	0	230.3	17.6	-0.7	826	0.00
SR	Telangana	12798	0	239.7	104.0	1.4	1029	0.00
	Karnataka	14002	0	264.0	60.2	0.8	738	0.00
	Kerala	3635	0	72.8	26.5	-1.6	308	0.00
	Tamil Nadu	20152	0	433.8	176.4	0.6	733	0.00
	Puducherry	534	0	11.2	10.5	0.1	68	0.00
ER	Bihar	7940	185	159.8	154.7	-5.2	329	0.29
	DVC	3093	0	65.2	-47.0	-0.9	362	0.00
	Jharkhand	2046	0	42.1	34.2	-0.9	141	0.00
	Odisha	5877	0	128.7	54.6	-1.0	424	0.00
	West Bengal	9064	0	201.8	71.0	-0.7	531	0.00
	Sikkim	79	0	1.4	1.3	0.1	31	0.00
NER	Railways ER ISTS	26	0	0.3	0.3	0.1	2	0.00
	Arunachal Pradesh	179	0	3.5	3.5	-0.4	32	0.00
	Assam	2313	0	46.9	40.2	1.0	138	0.00
	Manipur	201	0	3.1	2.9	0.2	45	0.00
	Meghalaya	311	0	5.8	1.0	0.0	36	0.00
	Mizoram	124	0	2.0	0.8	-0.3	38	0.00
	Nagaland	164	0	3.0	2.7	-0.1	20	0.00
	Tripura	263	0	3.7	2.8	-0.1	55	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	45.5	14.4	-23.6	-22.2
Day Peak (MW)	2188.0	808.0	-1006.0	-1063.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	389.4	-289.3	-20.4	-80.3	0.6	0.0
Actual(MU)	368.0	-297.5	-0.9	-82.6	0.6	-12.4
OD/UD(MU)	-21.4	-8.2	19.5	-2.2	-0.1	-12.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4744	13229	8632	5555	582	32742	51
State Sector	8844	11442	9102	2059	199	31646	49
Total	13588	24671	17734	7614	781	64388	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	750	1315	583	652	14	3314	62
Lignite	18	10	34	0	0	62	1
Hydro	376	59	178	95	36	744	14
Nuclear	37	56	65	0	0	159	3
Gas, Naptha & Diesel	23	40	7	0	19	89	2
RES (Wind, Solar, Biomass & Others)	218	285	451	3	1	958	18
Total	1424	1766	1317	750	69	5326	100

Share of RES in total generation (%)	15.34	16.16	34.22	0.39	1.23	17.99
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	44.38	22.67	52.68	13.09	52.96	34.94

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.049
Based on State Max Demands	1.107

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	215836	14:57	0
Non-Solar hr	210634	19:39	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 10-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	310	0.0	7.4	-7.4
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	474	1003	0.0	6.7	-6.7
4	765 kV	SASARAM-FATEHPUR	1	149	452	0.0	3.9	-3.9
5	765 kV	GAYA-BALIA	1	0	793	0.0	11.7	-11.7
6	400 kV	PUSAULI-VARANASI	1	0	110	0.0	1.4	-1.4
7	400 kV	PUSAULI-ALLAHABAD	1	5	84	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	975	0.0	14.5	-14.5
9	400 kV	PATNA-BALIA	2	80	715	0.0	9.5	-9.5
10	400 kV	NAUBATPUR-BALIA	2	107	460	0.0	2.1	-2.1
11	400 kV	BIHARSHARIFF-BALIA	2	235	288	0.0	0.9	-0.9
12	400 kV	MOTIHARI-GORAKHPUR	2	0	572	0.0	8.0	-8.0
13	400 kV	BIHARSHARIFF-SAHUPURI	2	87	450	0.0	4.5	-4.5
14	220 kV	SAHUPURI-KARAMNESA	1	0	123	0.0	2.6	-2.6
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	77.0	-76.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	971	240	8.3	0.0	8.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1584	579	18.7	0.0	18.7
3	765 kV	JHARSUGUDA-DURG	2	144	429	3.1	0.0	-3.1
4	400 kV	JHARSUGUDA-RAIGARH	4	347	165	2.1	0.0	-2.1
5	400 kV	RANCHI-SIPAT	2	467	182	5.3	0.0	5.3
6	400 kV	JEYPORE-JAGDALPUR	2	136	390	0.3	3.4	-3.1
7	220 kV	BUDHIPADAR-RAIGARH	1	96	18	0.8	0.0	0.8
8	220 kV	BUDHIPADAR-KORBA	2	121	69	0.6	0.0	0.6
ER-WR						36.1	6.6	29.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	251	0	4.7	0.0	4.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1756	0.0	31.3	-31.3
3	765 kV	ANGUL-SRIKAKULAM	2	0	2769	0.0	34.5	-34.5
4	400 kV	TALCHER-I/C	2	211	617	0.4	0.0	0.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						4.7	65.8	-61.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	163	143	0.5	0.9	-0.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	447	0.0	6.5	-6.5
3	220 kV	ALIPURDUAR-SALAKATI	2	6	78	0.0	1.0	-1.0
ER-NER						0.5	8.4	-7.9
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.6	-8.6
NER-NR						0.0	8.6	-8.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4539	0.0	82.5	-82.5
2	HVDC	VINDHYACHAL-B/B	-	294	0	6.9	0.0	6.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1170	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	0	2615	0.0	42.4	-42.4
5	765 kV	GWALIOR-PHAGI	2	498	1753	1.2	23.1	-22.0
6	765 kV	JABALPUR-ORAI	2	0	1302	0.0	38.0	-38.0
7	765 kV	GWALIOR-ORAI	1	757	0	11.3	0.0	11.3
8	765 kV	SATNA-ORAI	1	0	1103	0.0	20.2	-20.2
9	765 kV	BANASKANTHA-CHITORGARH	2	855	1507	2.8	9.4	-6.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	3067	0.0	56.2	-56.2
11	400 kV	ZERDA-KANKROLI	1	211	138	0.8	0.7	0.0
12	400 kV	ZERDA-BHINMAL	1	145	96	0.5	0.5	0.0
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	248	616	1.1	5.7	-4.6
15	400 kV	NEEMUCH-Chittorgarh	2	148	705	0.4	6.8	-6.4
16	220 kV	BHANPURA-RANPUR	1	0	148	0.0	2.9	-2.9
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	98	50	0.6	0.2	0.4
19	220 kV	MALANPUR-AURAIYA	1	70	29	0.2	0.1	0.0
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						25.7	319.9	-294.2
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1003	0	21.7	0.0	21.7
2	HVDC	RAIGARH-PUGAULUR	2	0	2006	0.0	15.7	-15.7
3	765 kV	SOLAPUR-RAICHUR	2	2134	845	21.5	0.8	20.7
4	765 kV	WARDHAN-NIZAMABAD	2	35	2474	0.0	18.7	-18.7
5	765 kV	WARORA-WARANGAL(NEW)	2	192	2449	0.1	16.7	-16.6
6	400 kV	KOLHAPUR-KUDGI	2	2068	0	33.2	0.0	33.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	112	1.9	0.0	1.9
WR-SR						78.4	51.9	26.5

INTERNATIONAL EXCHANGES				Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1321	1035	1207	28.97
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	663	453	581	13.94
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	90	-33	58	1.40
	NER	132kV GELEPHU-SALAKATI	25	8	12	0.28
	NER	132kV MOTANGA-RANGIA	49	0	36	0.86
NEPAL	NR	NEPAL IMPORT (FROM UP)	-63	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-63	0	-2	-0.04
	ER	NEPAL IMPORT (FROM BIHAR)	143	58	122	2.92
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	627	306	479	11.50
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-968	-939	-953	-22.88
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1063	-850	-927	-22.24
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-38	0	-30	-0.72

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 10-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.15
Bangladesh	23.61	0.09	0.00	0.00	0.00	0.00	0.00	0.00	23.70
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.76	0.09	0.00	0.00	0.00	0.00	0.00	0.00	23.85

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	45.19	0.00	1.44	0.00	0.00	0.16	0.00	0.00	46.79
Nepal	8.43	0.09	1.61	0.00	0.00	4.82	0.00	0.00	14.95
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	53.62	0.09	3.05	0.00	0.00	4.98	0.00	0.00	61.74

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	45.19	0.00	1.44	0.00	0.00	0.16	0.00	0.00	46.79
Nepal	8.28	0.09	1.61	0.00	0.00	4.82	0.00	0.00	14.80
Bangladesh	-23.61	-0.09	0.00	0.00	0.00	0.00	0.00	0.00	-23.70
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	29.86	0.00	3.05	0.00	0.00	4.98	0.00	0.00	37.89

