



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 17.11.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.11.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 16-नवंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.11.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 17-Nov-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	52626	62000	43819	20664	2615	181724
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1157	1499	1025	422	50	4154
Hydro Gen (MU)	118	39	82	27	17	284
Wind Gen (MU)	4	28	53	-	-	85
Solar Gen (MU)*	125.40	87.60	101.56	3.45	1.10	319
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	57219	70189	47371	21902	2912	194384
Time Of Maximum Demand Met	18:11	10:39	10:00	17:49	17:35	18:24

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.040	0.23	1.87	4.93	7.04	79.76	13.20

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7142	0	139.3	63.0	0.7	529	0.00
	Haryana	7204	0	144.1	100.7	-0.6	202	0.00
	Rajasthan	16891	0	327.8	124.3	-1.5	918	0.00
	Delhi	3663	0	71.8	71.5	-0.9	250	0.00
	UP	18323	0	335.3	111.6	0.7	530	0.00
	Uttarakhand	2077	0	40.6	32.3	0.4	121	0.00
	HP	1929	0	35.0	26.1	-0.9	123	0.00
	J&K(UT) & Ladakh(UT)	2699	0	55.5	49.7	-0.3	217	0.00
	Chandigarh	201	0	3.5	3.5	0.0	45	0.00
WR	Railways_NR ISTS	211	0	4.5	3.9	0.6	46	0.00
	Chhattisgarh	4314	0	87.3	39.8	-0.9	252	0.00
	Gujarat	20926	0	419.2	223.7	-0.4	579	0.00
	MP	16463	0	323.9	207.1	-3.1	492	0.00
	Maharashtra	27196	0	591.5	232.3	5.5	594	0.00
	Goa	718	0	14.8	14.5	0.3	46	0.00
	DNHDDPDCL	1318	0	30.2	30.3	-0.1	44	0.00
	AMNSIL	878	0	19.4	9.8	0.1	252	0.00
SR	BALCO	532	0	12.7	12.6	0.1	56	0.00
	Andhra Pradesh	9167	0	200.5	59.2	-0.9	350	0.00
	Telangana	10181	0	204.3	111.3	-2.2	438	0.00
	Karnataka	11476	0	221.9	70.4	-0.3	546	0.00
	Kerala	4140	0	84.6	66.0	0.8	417	0.00
	Tamil Nadu	14856	0	304.5	181.9	-5.8	434	0.00
	Puducherry	435	0	9.5	9.0	-0.1	34	0.00
ER	Bihar	4634	0	85.4	73.4	1.5	453	0.00
	DVC	3138	0	63.0	-42.9	-0.4	395	0.00
	Jharkhand	1993	0	37.0	24.6	-1.4	149	0.00
	Odisha	4677	0	90.9	21.9	-3.7	432	0.00
	West Bengal	7463	0	144.4	17.7	-3.1	150	0.00
	Sikkim	94	0	1.5	1.7	-0.2	16	0.00
	Railways_ER ISTS	10	0	0.1	0.2	-0.1	8	0.00
NER	Arunachal Pradesh	147	0	2.8	2.6	0.0	32	0.00
	Assam	1688	0	30.1	22.5	0.8	90	0.00
	Manipur	226	0	2.6	2.6	-0.1	31	0.00
	Meghalaya	361	0	6.1	4.8	-0.3	72	0.00
	Mizoram	133	0	1.8	1.7	-0.4	14	0.00
	Nagaland	152	0	2.4	2.2	0.0	18	0.00
	Tripura	247	0	4.3	5.1	0.0	30	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.8	7.2	-23.6	-13.9
Day Peak (MW)	267.0	396.0	-1029.0	-760.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	225.2	-132.4	121.4	-217.8	3.6	0.0
Actual(MU)	233.6	-120.1	103.0	-225.0	2.7	-5.8
O/D/U/D(MU)	8.4	12.3	-18.3	-7.2	-0.9	-5.8

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4572	10944	6258	4016	655	26444	48
State Sector	9303	9929	9111	649	230	29222	52
Total	13875	20873	15369	4665	884	55666	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	680	1509	603	696	10	3497	77
Lignite	24	18	46	0	0	87	2
Hydro	118	39	82	27	17	284	6
Nuclear	31	53	76	0	0	160	4
Gas, Naptha & Diesel	3	10	5	0	23	41	1
RES (Wind, Solar, Biomass & Others)	149	119	181	5	1	456	10
Total	1005	1747	992	728	52	4524	100

Share of RES in total generation (%)	14.87	6.79	18.28	0.69	2.13	10.07
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.71	12.05	34.15	4.44	35.45	19.87

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.026
Based on State Max Demands	1.069

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	194223	9:59	0
Non-Solar hr	194384	18:24	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 17-Nov-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	301	0.0	7.2	-7.2
2	HVDC	PUSAULI B/B	-	0	297	0.0	7.3	-7.3
3	765 kV	GAYA-VARANASI	2	0	1111	0.0	18.8	-18.8
4	765 kV	SASARAM-FATEHPUR	1	0	533	0.0	8.6	-8.6
5	765 kV	GAYA-BALIA	1	0	731	0.0	13.0	-13.0
6	400 kV	PUSAULI-VARANASI	1	0	211	0.0	4.2	-4.2
7	400 kV	PUSAULI -ALLAHABAD	1	0	158	0.0	2.9	-2.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	547	0.0	8.8	-8.8
9	400 kV	PATNA-BALIA	2	0	741	0.0	12.8	-12.8
10	400 kV	NAUBATPUR-BALIA	2	0	246	0.0	4.2	-4.2
11	400 kV	BIHARSHARIFF-BALIA	2	99	146	0.0	2.4	-2.4
12	400 kV	MOTIHARI-GORAKHPUR	2	0	431	0.0	7.7	-7.7
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	104	0.0	0.7	-0.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.5	98.6	-98.2
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	359	602	0.0	5.8	-5.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	616	597	0.0	3.1	-3.1
3	765 kV	JHARSUGUDA-DURG	2	0	1042	0.0	21.0	-21.0
4	400 kV	JHARSUGUDA-RAIGARH	4	0	688	0.0	11.0	-11.0
5	400 kV	RANCHI-SIPAT	2	109	284	0.0	3.3	-3.3
6	220 kV	BUDHIPADAR-RAIGARH	1	0	82	0.0	1.3	-1.3
7	220 kV	BUDHIPADAR-KORBA	2	76	91	0.0	0.3	-0.3
ER-WR						0.0	45.7	-45.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	532	0.0	12.7	-12.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1991	0.0	41.6	-41.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	2712	0.0	53.6	-53.6
4	400 kV	TALCHER-I/C	2	470	415	1.9	0.0	1.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	107.9	-107.9
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	585	0.0	8.4	-8.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	479	0.0	8.0	-8.0
3	220 kV	ALIPURDUAR-SALAKATI	2	0	139	0.0	1.4	-1.4
ER-NER						0.0	17.7	-17.7
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	653	0.0	15.7	-15.7
NER-NR						0.0	15.7	-15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2034	0.0	31.7	-31.7
2	HVDC	VINDHYACHAL B/B	-	531	0	4.9	0.0	4.9
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1449	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	190	1411	0.0	19.0	-19.0
5	765 kV	GWALIOR-PHAGI	2	0	2078	0.0	32.0	-32.0
6	765 kV	JABALPUR-ORAI	2	0	834	0.0	28.5	-28.5
7	765 kV	GWALIOR-ORAI	1	937	0	16.5	0.0	16.5
8	765 kV	SATNA-ORAI	1	0	984	0.0	20.5	-20.5
9	765 kV	BANASKANTHA-CHITORGARH	2	1626	0	26.0	0.0	26.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	2102	0.0	35.0	-35.0
11	400 kV	ZERDA-KANKROLI	1	332	0	5.1	0.0	5.1
12	400 kV	ZERDA -BHINMAL	1	229	0	3.5	0.0	3.5
13	400 kV	VINDHYACHAL -RIHAND	1	973	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	484	148	2.1	0.9	1.2
15	400 kV	NEEMUCH-Chittorgarh	2	522	190	2.5	0.8	1.7
16	220 kV	BHANPURA-RANPUR	1	0	202	0.0	3.6	-3.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.3	-2.3
18	220 kV	MEHGAON-AURAIYA	1	135	0	1.7	0.0	1.7
19	220 kV	MALANPUR-AURAIYA	1	98	0	1.0	0.0	1.0
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						84.9	210.6	-125.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	313	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	604	0.0	14.7	-14.7
3	765 kV	SOLAPUR-RAICHUR	2	1428	691	10.9	1.8	9.1
4	765 kV	WARDHA-NIZAMABAD	2	0	1424	0.0	24.5	-24.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2167	0.0	32.5	-32.5
6	400 kV	KOLHAPUR-KUDGI	2	1661	0	27.7	0.0	27.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	128	2.3	0.0	2.3
WR-SR						40.9	80.7	-39.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	154	70	111	2.67	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	210	108	166	3.99	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-202	0	-102	-2.45	
	NER	132kV GELEPHU-SALAKATI	16	0	7	0.16	
	NER	132kV MOTANGA-RANGIA	42	0	20	0.47	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	1.29	
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	396	101	247	5.93	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-967	-926	-928	-22.28	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-760	-448	-578	-13.87	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-62	0	-53	-1.28	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.08
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.08

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.78
Nepal	0.00	0.00	0.00	0.00	0.00	6.72	0.00	0.00	6.72
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	2.78	0.00	0.00	0.00	0.00	6.72	0.00	0.00	9.50

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.78	0.00	0.00	0.00	0.00	0.00	0.00	0.00	2.78
Nepal	0.00	0.00	0.00	0.00	0.00	6.72	0.00	0.00	6.72
Bangladesh	-23.08	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.08
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.30	0.00	0.00	0.00	0.00	6.72	0.00	0.00	-13.58

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A- (C+D))	(J=B+C+D+E +F+G+H)	(+ve) Import, (-ve) (K)
0:00	50.05	154567	6297	2764	55	8749	1706	137098	1616	151748	158285	-444
0:15	50.00	153686	6309	2980	52	8219	1605	136379	1648	150654	157192	-396
0:30	50.00	153135	6301	3091	53	7963	1541	136087	1651	149991	156687	-383
0:45	50.00	152210	6306	3261	52	7739	1550	135226	1667	148897	155801	-351
1:00	50.00	150912	6300	3197	52	7670	1538	134130	1690	147663	154577	-343
1:15	49.95	149840	6316	3173	52	7379	1549	133260	1655	146615	153384	-367
1:30	50.00	148794	6347	3047	51	7155	1559	132530	1673	145696	152362	-319
1:45	50.00	148692	6329	3019	52	7368	1534	132050	1678	145621	152030	-341
2:00	50.05	147672	6343	2931	52	7336	1549	130890	1686	144689	150787	-328
2:15	50.00	145725	6307	2893	51	7980	1538	130567	1681	142781	151017	-350
2:30	50.05	147053	6314	2936	53	7986	1532	130240	1700	144064	150761	-362
2:45	50.05	146981	6304	2882	51	7976	1551	130031	1698	144048	150493	-348
3:00	50.00	146172	6303	2909	45	7503	1553	129697	1707	143218	149717	-342
3:15	50.00	146057	6325	2922	45	7410	1594	129481	1711	143090	149488	-331
3:30	50.05	145690	6321	3030	45	7293	1560	129322	1671	142615	149242	-326
3:45	50.05	145644	6320	3162	46	7005	1560	129344	1698	142436	149135	-297
4:00	50.15	145802	6315	3229	44	6906	1564	129608	1675	142529	149341	-342
4:15	50.05	146709	6320	3157	46	6968	1578	130436	1710	143506	150215	-347
4:30	50.00	148321	6307	3091	46	7181	1560	132084	1684	145184	151953	-341
4:45	50.05	149677	6302	3084	46	7474	1557	133191	1720	146547	153374	-338
5:00	50.05	151549	6311	3105	47	7920	1548	134666	1757	148397	155354	-392
5:15	49.95	154120	6308	3115	49	8444	1606	136755	1730	150956	158007	-422
5:30	50.00	157186	6314	3202	50	9765	1590	138570	1760	153934	161251	-494
5:45	50.05	159480	6308	3363	49	11075	1625	139534	1788	156068	163742	-519
6:00	50.10	161308	6310	3336	49	12394	1644	140093	1752	157923	165578	-583
6:15	50.05	165319	6307	3196	70	14764	1635	141832	1726	162053	169530	-599
6:30	50.00	170137	6309	3179	124	17551	1629	143503	1749	166834	174044	-586
6:45	49.95	173840	6302	3241	519	18680	1621	145238	1761	170080	177362	-515
7:00	50.00	176480	6306	3343	1327	19048	1628	146660	1763	171810	180075	-639
7:15	50.00	179088	6325	3238	2710	19098	1615	147120	1758	173140	181864	-651
7:30	50.05	180925	6330	3119	4564	18814	1617	147153	1803	173242	183400	-702
7:45	50.10	181489	6316	3091	6744	15466	1625	148293	1866	171654	183401	-695
8:00	50.15	181595	6327	3052	9445	13292	1633	147191	1814	169098	182754	-654
8:15	50.05	183730	6322	2961	12017	12126	1617	147035	1894	168752	183972	-651
8:30	50.10	185027	6332	2934	14872	11136	1635	145678	1890	167221	184477	-687
8:45	50.05	187680	6331	3081	17482	10347	1634	145078	1963	167117	185916	-677
9:00	50.05	188488	6318	3143	19675	9630	1767	144076	1955	165670	186564	-642
9:15	50.05	191662	6310	3213	22128	9384	1653	143803	2029	166321	188520	-593
9:30	50.00	193192	6309	3228	24189	8952	1635	142876	2010	165775	189199	-569
9:45	50.05	193728	6306	3281	34635	7919	1636	141714	2029	155812	197520	-523
10:00	50.00	194151	6309	3448	37049	7273	1644	140005	2048	153654	197776	-577
10:15	49.95	193340	6331	3540	39316	6848	1659	137213	2022	150484	196929	-544
10:30	50.00	193247	6298	3598	40728	6801	1667	135535	2037	148921	196664	-550
10:45	50.00	193642	6315	3706	43313	6839	1648	132959	2071	146623	196851	-534
11:00	50.00	192849	6321	3709	44772	6711	1661	130814	2155	144368	196143	-537
11:15	50.00	191713	6304	3693	45423	6099	1655	129841	2062	142597	195077	-532
11:30	50.05	191161	6315	3643	46142	6273	1694	128267	2073	141376	194407	-515
11:45	50.00	190489	6293	3639	46683	6139	1656	127201	2126	140167	193737	-517
12:00	50.05	189593	6307	3748	46998	6150	1640	125684	2087	138847	192614	-456
12:00	50.05	189593	6307	3748	46998	6150	1640	125684	2087	138847	192614	-456
12:15	50.00	187986	6290	3779	47480	6211	1648	123359	2062	136727	190829	-480
12:30	49.95	187760	6276	3785	47007	6380	1653	123227	2092	136968	190420	-492
12:45	49.95	186822	6299	3820	46801	6404	1661	122645	2081	136201	189711	-531
13:00	50.05	184916	6292	3839	45540	6535	1656	121650	2075	135537	187587	-478
13:15	50.00	181970	6297	3720	44788	6514	1653	119609	2093	133462	184674	-458
13:30	49.95	181637	6293	3499	44025	6617	1649	120275	2066	134113	184424	-511
13:45	49.90	183237	6275	3343	43302	6963	1663	122257	2039	136592	185842	-474
14:00	50.05	182652	6276	3282	42052	6842	1635	123426	2022	137318	185535	-475
14:15	49.95	182846	6282	3283	39937	6561	1639	125740	2044	139626	185486	-482
14:30	50.05	184742	6265	3221	38320	7175	1620	129059	1998	143201	187658	-493
14:45	50.00	186178	6280	3058	36095	7466	1630	132485	1966	147025	188980	-445
15:00	50.05	186408	6277	2873	33549	7478	1631	135252	1990	149986	189050	-446
15:15	50.05	186287	6277	2747	30820	7700	1634	137811	1924	152720	188913	-448
15:30	50.05	186682	6266	2763	27255	8631	1629	140753	1935	156664	189232	-452
15:45	49.95	185479	6280	2714	24057	8629	1742	143273	1858	158708	188553	-493
16:00	49.90	185393	6270	2655	20430	9788	1736	146035	1827	162308	188741	-518
16:15	49.74	183663	6261	2612	16490	10004	1620	147822	1859	164561	186668	-506
16:30	49.85	184671	6242	2680	12657	11703	1611	151022	1839	169334	187754	-528
16:45	49.85	185481	6269	2683	9187	13763	1724	153367	1850	173611	188843	-588
17:00	49.95	186615	6248	2563	6129	16512	1617	155215	1853	177923	190137	-631
17:15	49.80	187092	6277	2473	3769	18468	1619	156156	1781	180850	190543	-677
17:30	49.90	188395	6260	2544	1974	20862	1629	157061	1753	183877	192083	-726
17:45	49.90	191290	6254	2699	912	24302	1614	156942	1834	187679	194557	-731

18:00	49.80	192880	6239	2873	635	25563	1742	157135	1794	189372	195981	-669
18:15	49.90	194117	6256	3180	540	26659	1751	157324	1825	190397	197535	-681
18:30	50.05	193290	6269	3474	417	26736	1619	156435	1794	189399	196744	-646
18:45	50.00	192196	6293	3749	411	25782	1676	155651	1779	188036	195341	-637
19:00	50.05	189113	6310	3933	406	24667	1619	153661	1769	184774	192365	-621
19:15	50.05	186398	6300	4096	412	23941	1625	151503	1797	181890	189674	-620
19:30	50.10	183185	6306	4211	380	22065	1614	150232	1800	178594	186608	-592
19:45	50.05	179777	6302	4248	313	19692	1627	149378	1797	175216	183357	-576
20:00	50.05	175620	6302	4366	336	18578	1638	146523	1771	170918	179514	-578
20:15	50.05	172982	6322	4490	299	17601	1622	144797	1838	168193	176969	-523
20:30	50.05	170773	6312	4571	293	16818	1610	143219	1747	165909	174570	-506
20:45	50.00	169351	6307	4703	280	16198	1636	142457	1745	164368	173326	-642
21:00	50.05	166959	6314	4812	260	15307	1630	140798	1770	161887	170891	-637
21:15	50.00	165415	6323	4871	260	14599	1619	139977	1743	160284	169392	-510
21:30	50.00	163437	6323	4898	262	13639	1607	138757	1752	158277	167238	-452
21:45	50.05	161886	6306	4899	260	12304	1626	138373	1748	156727	165516	-425
22:00	50.05	160055	6323	4969	258	10541	1645	138114	1756	154828	163606	-414
22:15	49.95	160442	6316	4919	258	10547	1627	138546	1798	155265	164011	-369
22:30	50.00	160388	6316	4847	257	10234	1632	138884	1743	155284	163913	-372
22:45	50.00	159429	6317	4863	243	9637	1632	138447	1776	154323	162915	-346
23:00	50.00	157894	6318	4818	260	9441	1637	137575	1775	152816	161824	-301
23:00	50.00	157894	6318	4818	260	9441	1637	137575	1775	152816	161824	-301
23:15	49.95	157323	6316	4957	260	8941	1648	137093	1766	152106	160981	-311
23:30	49.95	156009	6314	4982	260	8717	1644	136107	1769	150767	159793	-287
23:45	50.00	154781	6308	4956	260	8571	1631	135108	1765	149565	158599	-297

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).

** Hydro generation is excluding Bhutan hydro.

***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:

1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.