



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 05.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 04.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 4-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 04.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 05-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	78142	59610	48835	27610	3454	217651
Peak Shortage (MW)	0	0	60	50	0	110
Energy Met (MU)	1792	1372	1186	618	70	5038
Hydro Gen (MU)	380	48	175	89	33	725
Wind Gen (MU)	14	138	268	-	-	420
Solar Gen (MU)*	188.02	79.01	116.56	2.18	0.90	387
Energy Shortage (MU)	0.42	0.00	0.27	0.69	0.00	1.38
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	80182	60225	55485	28081	3480	218386
Time Of Maximum Demand Met	22:23	19:29	07:27	21:37	18:55	11:12

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.055	0.05	1.23	5.37	6.64	67.54	25.82

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	17138	0	344.8	200.2	0.5	610	0.00
	Haryana	13526	0	283.2	209.0	-1.1	830	0.00
	Rajasthan	12903	0	282.8	113.9	-7.4	532	0.00
	Delhi	7144	0	150.6	136.9	-2.3	314	0.00
	UP	28274	0	570.2	275.3	-0.2	668	0.00
	Uttarakhand	2507	0	53.1	29.6	1.8	488	0.42
	HP	1762	0	38.4	-3.0	0.2	111	0.00
	J&K(UT) & Ladakh(UT)	2729	0	57.0	30.0	2.4	278	0.00
	Chandigarh	357	0	7.4	7.2	0.2	35	0.00
	Railways NR ISTS	199	0	4.2	3.8	0.4	40	0.00
WR	Chhattisgarh	4865	0	108.1	59.5	2.0	604	0.00
	Gujarat	17599	0	397.5	163.2	-3.6	753	0.00
	MP	11140	0	231.5	102.0	-0.1	596	0.00
	Maharashtra	25025	0	552.0	160.3	0.8	766	0.00
	Goa	569	0	14.2	11.6	2.2	70	0.00
	DNHDDPDCL	1350	0	31.6	31.8	-0.2	93	0.00
	AMNSIL	901	0	19.0	9.1	0.3	251	0.00
	BALCO	523	0	12.5	12.7	-0.2	0	0.00
	RIL JAMNAGAR	251	0	5.7	5.8	-0.1	0	0.00
	Andhra Pradesh	9561	0	207.9	10.5	-0.5	788	0.00
SR	Telangana	12144	0	228.6	109.0	1.7	807	0.00
	Karnataka	13199	0	250.5	42.4	1.8	869	0.00
	Kerala	3980	0	78.0	32.1	-1.6	216	0.00
	Tamil Nadu	18792	0	410.9	163.9	-3.7	906	0.00
	Puducherry	456	0	10.2	9.8	-0.1	45	0.27
	Bihar	7886	0	159.1	155.8	-2.8	393	0.09
ER	DVC	3058	0	65.7	-37.9	-0.8	411	0.60
	Jharkhand	2082	0	43.2	34.9	-0.8	201	0.00
	Odisha	5322	0	117.5	39.8	-0.9	465	0.00
	West Bengal	10731	0	230.9	103.1	-1.0	336	0.00
	Sikkim	85	0	1.5	1.4	0.1	31	0.00
	Railways ER ISTS	25	0	0.1	0.2	0.0	3	0.00
NER	Arunachal Pradesh	195	0	3.1	3.5	-0.8	16	0.00
	Assam	2270	0	46.5	38.8	0.7	282	0.00
	Manipur	220	0	3.1	3.2	-0.1	27	0.00
	Meghalaya	325	0	5.7	-0.2	0.0	71	0.00
	Mizoram	157	0	2.0	1.4	-0.3	26	0.00
	Nagaland	183	0	3.2	2.8	-0.1	13	0.00
	Tripura	317	0	6.2	4.4	0.2	41	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	44.5	15.7	-23.6	-25.6
Day Peak (MW)	2412.0	771.8	-1012.0	-1419.1

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	433.6	-292.6	-50.5	-95.0	4.4	0.0
Actual(MU)	408.4	-293.0	-38.4	-88.5	5.4	-6.0
OD/UD(MU)	-25.2	-0.4	12.1	6.5	1.0	-6.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3032	12034	9052	4490	732	29340	47
State Sector	7389	11732	10922	3119	199	33361	53
Total	10421	23766	19974	7609	931	62701	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	798	1400	537	683	13	3432	64
Lignite	22	13	35	0	0	70	1
Hydro	380	48	175	89	33	725	14
Nuclear	35	56	60	0	0	150	3
Gas, Naptha & Diesel	44	55	6	0	22	127	2
RES (Wind, Solar, Biomass & Others)	211	220	424	5	1	860	16
Total	1490	1791	1237	777	69	5364	100

Share of RES in total generation (%)	14.14	12.26	34.27	0.59	1.31	16.03
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	42.00	18.05	53.27	12.04	49.36	32.36

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.041
Based on State Max Demands	1.097

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	218386	11:12	0
Non-Solar hr	215816	19:47	110

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 05-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.4	-7.4
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	541	758	0.0	6.1	-6.1
4	765 kV	SASARAM-FATEHPUR	1	235	364	0.0	3.2	-3.2
5	765 kV	GAYA-BALIA	1	0	870	0.0	14.2	-14.2
6	400 kV	PUSAULI-VARANASI	1	0	149	0.0	2.3	-2.3
7	400 kV	PUSAULI-ALLAHABAD	1	50	47	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	27	763	0.0	10.5	-10.5
9	400 kV	PATNA-BALIA	2	63	797	0.0	11.5	-11.5
10	400 kV	NAUBATPUR-BALIA	2	86	536	0.0	3.2	-3.2
11	400 kV	BIHARSHARIFF-BALIA	2	268	258	0.0	0.8	-0.8
12	400 kV	MOTIHARI-GORAKHPUR	2	25	458	0.0	6.3	-6.3
13	400 kV	BIHARSARIFF-SAHUPURI	2	135	366	0.0	3.9	-3.9
14	220 kV	SAHUPURI-KARAMNESA	1	0	113	0.0	1.9	-1.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.3	0.0	0.3
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.4	74.1	-73.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1217	0.0	15.6	-15.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2083	334	29.1	0.0	29.1
3	765 kV	JHARSUGUDA-DURG	2	92	548	0.0	4.5	-4.5
4	400 kV	JHARSUGUDA-RAIGARH	4	315	198	1.6	0.0	1.6
5	400 kV	RANCHI-SIPAT	2	589	128	7.3	0.0	7.3
6	400 kV	JEYPORE-JAGDALPUR	2	86	527	0.0	5.3	-5.3
7	220 kV	BUDHIPADAR-RAIGARH	1	39	71	0.0	0.3	-0.3
8	220 kV	BUDHIPADAR-KORBA	2	110	70	0.6	0.0	0.6
ER-WR						38.6	25.7	12.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	306	0	7.3	0.0	7.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1196	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2269	0.0	27.5	-27.5
4	400 kV	TALCHER-I/C	2	229	163	3.8	0.0	3.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						7.3	56.4	-49.2
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	137	354	0.2	2.9	-2.7
2	400 kV	ALIPURDUAR-BONGAIGAON	2	31	625	0.0	8.3	-8.3
3	220 kV	ALIPURDUAR-SALAKATI	2	12	127	0.0	1.5	-1.5
ER-NER						0.2	12.8	-12.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	358	0.0	8.3	-8.3
NER-NR						0.0	8.3	-8.3
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	6011	0.0	112.9	-112.9
2	HVDC	VINDHYACHAL-B/B	-	0	56	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1453	0.0	36.3	-36.3
4	765 kV	GWALIOR-AGRA	2	0	3066	0.0	44.2	-44.2
5	765 kV	GWALIOR-PHAGI	2	308	1882	0.3	25.7	-25.4
6	765 kV	JABALPUR-ORAI	2	0	1464	0.0	42.1	-42.1
7	765 kV	GWALIOR-ORAI	1	621	0	10.0	0.0	10.0
8	765 kV	SATNA-ORAI	1	0	1155	0.0	21.0	-21.0
9	765 kV	BANASKANTHA-CHITORGARH	2	1631	549	13.2	1.1	12.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3564	0.0	59.5	-59.5
11	400 kV	ZERDA-KANKROLI	1	329	82	2.8	0.1	2.7
12	400 kV	ZERDA-BHINMAL	1	226	57	1.9	0.1	1.9
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	321	715	1.3	6.3	-5.0
15	400 kV	NEEMUCH-Chittorgarh	2	256	848	0.6	8.2	-7.6
16	220 kV	BHANPURA-RANPUR	1	0	139	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	97	19	0.4	0.3	0.2
19	220 kV	MALANPUR-AURAIYA	1	72	31	0.5	0.4	0.2
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						31.0	363.6	-332.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1002	0	15.0	0.0	15.0
2	HVDC	RAIGARH-PUGAULUR	2	0	1601	0.0	28.6	-28.6
3	765 kV	SOLAPUR-RAICHUR	2	2819	58	36.2	0.0	36.2
4	765 kV	WARDHAN-NIZAMABAD	2	610	1738	2.8	8.0	-5.2
5	765 kV	WARORA-WARANGAL(NEW)	2	839	1697	4.2	6.9	-2.7
6	400 kV	KOLHAPUR-KUDGI	2	2240	0	36.1	0.0	36.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	103	2.0	0.0	2.0
WR-SR						96.3	43.5	52.8

INTERNATIONAL EXCHANGES				Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1328	652	990	23.76
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	823	518	676	16.23
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	176	70	129	3.09
	NER	132kV GELEPHU-SALAKATI	52	11	25	0.60
	NER	132kV MOTANGA-RANGIA	61	0	34	0.82
NEPAL	NR	NEPAL IMPORT (FROM UP)	-32	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-32	0	-9	-0.21
	ER	NEPAL IMPORT (FROM BIHAR)	130	106	127	3.04
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	614	400	535	12.83
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-952	-946	-948	-22.75
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1419	-461	-1068	-25.64
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-60	0	-37	-0.88

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 05-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.49	0.11	0.00	0.00	0.00	0.00	0.00	0.00	23.60
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.49	0.11	0.00	0.00	0.00	0.00	0.00	0.00	23.60

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	44.42	0.00	1.51	0.00	0.00	0.33	0.00	0.00	46.26
Nepal	8.42	0.10	4.97	0.00	0.00	2.08	0.00	0.00	15.57
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	52.84	0.10	6.48	0.00	0.00	2.41	0.00	0.00	61.83

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	44.42	0.00	1.51	0.00	0.00	0.33	0.00	0.00	46.26
Nepal	8.42	0.10	4.97	0.00	0.00	2.08	0.00	0.00	15.57
Bangladesh	-23.49	-0.11	0.00	0.00	0.00	0.00	0.00	0.00	-23.60
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	29.35	-0.01	6.48	0.00	0.00	2.41	0.00	0.00	38.23

