



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 07.02.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 06.02.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 6-फरवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 06.02.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 07-Feb-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60423	71125	52416	24583	2843	211390
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1267	1609	1303	508	52	4739
Hydro Gen (MU)	111	36	83	23	11	264
Wind Gen (MU)	8	55	104	-	-	167
Solar Gen (MU)*	233.04	175.48	166.76	3.98	0.98	580
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69199	80496	65807	24676	2991	240039
Time Of Maximum Demand Met	10:12	10:21	09:42	08:34	17:42	09:43

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.031	0.00	0.06	2.90	2.96	79.71	17.32

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9024	0	165.8	73.6	-1.1	261	0.00
	Haryana	8355	0	164.7	115.9	-1.3	233	0.00
	Rajasthan	18841	0	344.0	108.9	-0.4	1123	0.00
	Delhi	5063	0	86.5	76.9	0.6	565	0.00
	UP	19803	0	349.4	68.6	0.0	690	0.00
	Uttarakhand	2594	0	45.9	38.2	0.2	70	0.00
	HP	2213	0	39.1	32.7	-0.7	111	0.00
	J&K(UT) & Ladakh(UT)	2995	0	63.5	57.5	-0.4	144	0.00
	Chandigarh	266	0	4.1	4.1	0.0	22	0.00
	Railways_NR ISTS	185	0	3.9	3.9	0.0	31	0.00
WR	Chhattisgarh	6095	0	124.3	58.6	-0.3	423	0.00
	Gujarat	24597	0	458.3	227.2	2.3	988	0.00
	MP	17865	0	320.9	198.4	0.0	594	0.00
	Maharashtra	29569	0	621.0	198.0	-4.7	990	0.00
	Goa	740	0	15.0	12.5	2.1	32	0.00
	DNHDDPDCL	1368	0	31.8	31.8	0.0	54	0.00
	AMNSIL	768	0	16.8	12.6	1.0	247	0.00
	BALCO	602	0	14.4	14.5	-0.1	33	0.00
	RIL JAMNAGAR	263	0	6.2	6.3	-0.1	0	0.00
	Andhra Pradesh	12676	0	237.9	61.6	-0.5	693	0.00
SR	Telangana	16183	0	286.9	136.2	-1.1	643	0.00
	Karnataka	17668	0	323.8	125.2	-0.5	672	0.00
	Kerala	4754	0	89.8	69.9	1.9	415	0.00
	Tamil Nadu	18271	0	355.6	206.7	-6.0	604	0.00
	Puducherry	417	0	9.1	8.7	-0.1	34	0.00
	Bihar	5894	0	109.8	86.0	1.7	354	0.00
ER	DVC	3247	0	68.7	-38.3	-1.1	602	0.00
	Jharkhand	2074	0	38.8	29.9	-0.5	187	0.00
	Odisha	5687	0	114.5	18.8	-1.8	287	0.00
	West Bengal	8359	0	174.3	63.1	-2.4	226	0.00
	Sikkim	118	0	2.0	2.0	0.0	13	0.00
	Railways_ER ISTS	21	0	0.2	0.2	0.0	0	0.00
NER	Arunachal Pradesh	177	0	3.2	3.2	-0.1	23	0.00
	Assam	1688	0	29.9	25.0	0.3	119	0.00
	Manipur	263	0	3.8	3.8	0.0	51	0.00
	Meghalaya	370	0	6.1	5.6	-0.1	36	0.00
	Mizoram	134	0	2.5	2.1	0.0	22	0.00
	Nagaland	163	0	2.8	2.6	0.1	26	0.00
	Tripura	237	0	4.0	4.8	0.0	40	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-15.5	-10.9	-24.4	-15.0
Day Peak (MW)	-1021.2	-697.9	-1055.4	-765.4

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	171.9	-204.2	172.6	-158.5	18.1	0.0
Actual(MU)	156.8	-181.9	148.2	-155.0	16.4	-15.5
O/D/U/D(MU)	-15.1	22.3	-24.4	3.5	-1.8	-15.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6170	9905	3948	3195	685	23903	45
State Sector	9124	11146	5846	3230	205	29551	55
Total	15294	21051	9794	6425	890	53453	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	737	1546	722	739	8	3752	73
Lignite	28	17	48	0	0	94	2
Hydro	111	36	83	23	11	264	5
Nuclear	43	64	71	0	0	177	3
Gas, Naptha & Diesel	12	22	9	0	21	64	1
RES (Wind, Solar, Biomass & Others)	266	234	306	7	1	814	16
Total	1197	1919	1240	769	41	5166	100

Share of RES in total generation (%)	22.22	12.20	24.68	0.94	2.44	15.76
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	35.05	17.38	37.11	3.95	29.55	24.31

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.013
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	240039	9:43	0
Non-Solar hr	212476	18:49	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export=(-ve) for NET (MU)
Date of Reporting: 07-Feb-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	453	1409	1.6	17.2	-15.6
4	765 kV	SASARAM-FATEHPUR	1	190	685	0.0	6.8	-6.8
5	765 kV	GAYA-BALIA	1	0	860	0.0	12.2	-12.2
6	400 kV	PUSAULI-VARANASI	1	10	138	0.0	1.3	-1.3
7	400 kV	PUSAULI-ALLAHABAD	1	42	109	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	691	469	3.6	3.7	-0.1
9	400 kV	PATNA-BALIA	2	87	1001	0.0	13.2	-13.2
10	400 kV	NAUBATPUR-BALIA	2	185	236	0.0	4.4	-4.4
11	400 kV	BIHARSHARIFF-BALIA	2	481	191	3.3	0.6	2.7
12	400 kV	MOTIHARI-GORAKHPUR	2	163	536	0.0	5.7	-5.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	214	519	0.0	3.6	-3.6
14	220 kV	SAHUPURI-KARAMNANA	1	21	18	0.0	1.9	-1.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						9.3	74.1	-64.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1362	0.0	17.4	-17.4
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1200	801	4.2	0.0	4.2
3	765 kV	JHARSUGUDA-DURG	2	0	1600	0.0	28.4	-28.4
4	400 kV	JHARSUGUDA-RAIGARH	4	116	443	0.0	3.9	-3.9
5	400 kV	RANCHI-SIPAT	2	228	349	0.0	1.3	-1.3
6	400 kV	JEYPORE-JAGDALPUR	2	367	166	2.8	0.0	2.8
7	220 kV	BUDHIPADAR-RAIGARH	1	0	159	0.0	2.5	-2.5
8	220 kV	BUDHIPADAR-KORBA	2	75	114	0.0	0.5	-0.5
ER-WR						7.0	54.1	-47.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	525	0.0	12.5	-12.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1650	0.0	44.2	-44.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1754	0.0	30.7	-30.7
4	400 kV	TALCHER-I/C	2	113	801	0.0	1.7	-1.7
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	87.4	-87.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOON	2	104	280	0.2	2.5	-2.3
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	260	222	0.7	0.0	0.7
3	220 kV	ALIPURDUAR-SALAKATI	2	18	69	0.0	0.5	-0.5
ER-NER						1.0	3.0	-2.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	664	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3528	0.0	61.8	-61.8
2	HVDC	VINDHYACHAL B/B	-	94	105	1.1	1.3	-0.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1740	0.0	32.4	-32.4
4	765 kV	GWALIOR-AGRA	2	1012	2134	2.5	17.4	-14.9
5	765 kV	GWALIOR-PHAGI	2	674	2287	1.8	28.7	-26.8
6	765 kV	JABALPUR-ORAI	2	410	938	0.0	18.9	-18.9
7	765 kV	GWALIOR-ORAI	1	1137	0	17.4	0.0	17.4
8	765 kV	SATNA-ORAI	1	0	1142	0.0	18.8	-18.8
9	765 kV	BANASKANTHA-CHITORGARH	2	2824	0	39.8	0.0	39.8
10	765 kV	VINDHYACHAL VARANASI	2	0	2176	0.0	29.7	-29.7
11	400 kV	ZERDA-KANKROLI	1	439	0	7.3	0.0	7.3
12	400 kV	ZERDA BHINMAL	1	303	0	5.1	0.0	5.1
13	400 kV	VINDHYACHAL -RIHAND	1	486	0	9.9	0.0	9.9
14	400 kV	RAPP-SHUJALPUR	2	938	275	7.1	0.9	6.2
15	400 kV	NEEMUCH-Chittorgarh	2	859	429	5.2	2.1	3.1
16	220 kV	BHANPURA-RANPUR	1	0	123	0.0	2.0	-2.0
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	161	15	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	129	24	0.7	0.1	0.6
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						98.8	215.4	-116.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1012	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	5013	0.0	69.1	-69.1
3	765 kV	SOLAPUR-RAICHUR	2	1719	551	12.9	1.6	11.3
4	765 kV	WARDHA-NIZAMABAD	2	146	2631	0.0	29.6	-29.6
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2790	0.0	35.3	-35.3
6	400 kV	KOLHAPUR-KUDGI	2	1933	0	32.7	0.0	32.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	119	0.0	2.3	-2.3
WR-SR						47.9	159.5	-111.7

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-346	16	-268	-6.43	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-419	101	-162	-3.88	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-190	-79	-157	-3.77	
	NER	132kV GELEPHU-SALAKATI	-74	-4	-45	-1.07	
	NER	132kV MOTANGA-RANGIA	-26	-1	-15	-0.36	
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	-0.70	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	0	0	0	-1.17	
	ER	NEPAL IMPORT (FROM BIHAR)	-127	-88	-116	-2.77	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-484	-185	-262	-6.29	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-914	-913	-913	-21.92	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-765	-410	-623	-14.96	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-131	0	-103	-2.48	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 07-Feb-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.36	18.87	0.00	0.00	0.00	0.00	0.00	19.23	
Nepal	3.18	1.75	1.46	0.00	0.00	0.00	3.25	0.00	0.00	9.64
Bangladesh	22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	26.13	2.11	20.33	0.00	0.00	0.00	3.25	0.00	0.00	51.82

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	-0.36	-18.87	0.00	0.00	0.00	0.00	0.00	-18.89
Nepal	-3.18	-1.75	-1.46	0.00	0.00	-3.25	0.00	0.00	-9.64
Bangladesh	-22.95	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.95
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-25.79	-2.11	-20.33	0.00	0.00	-3.25	0.00	0.00	-51.48

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-C+D)	(J=B+C+D+E+H)	(K) (+ve) Import, (-ve) Export
0:00	49.99	163551	6697	9530	0	6530	2192	140351	4152	154021	169452	-2241
0:15	49.96	163632	6698	9374	0	6948	2178	140538	4024	154258	169760	-2234
0:30	49.88	163531	6707	9287	0	7250	2185	140252	4025	154244	169706	-2250
0:45	49.98	163237	6707	9178	0	7239	2191	139841	4017	154059	169173	-2235
1:00	50.00	162074	6702	9092	0	6964	2189	139224	3959	152982	168130	-2239
1:15	49.96	161339	6717	9030	0	6499	2196	138783	3960	152309	167185	-2204
1:30	50.00	160890	6704	8959	0	6348	2205	138637	3968	151931	166821	-2178
1:45	49.96	160131	6700	8989	0	6242	2189	138350	3957	151142	166427	-2203
2:00	50.04	158341	6714	9043	0	6030	2178	136733	3949	149298	164647	-2202
2:15	50.06	158238	6712	8861	0	5764	2139	137078	4011	149377	164565	-2175
2:30	50.00	158524	6708	8706	0	5734	2153	137474	3999	149818	164774	-2205
2:45	49.98	158482	6710	8771	0	5627	2150	137519	4021	149711	164798	-2188
3:00	49.97	158245	6717	8587	0	5718	2140	137533	3960	149658	164655	-2207
3:15	49.96	158330	6708	8229	0	6180	2157	137631	3920	150101	164825	-2213
3:30	49.98	158821	6719	8182	0	6211	2145	137863	3985	150639	165105	-2174
3:45	49.96	159011	6719	8044	0	6309	2152	138253	3959	150967	165436	-2213
4:00	50.02	159423	6718	8046	0	6495	2159	138536	3954	151377	165908	-2165
4:15	49.95	161556	6708	7983	0	6940	2187	140359	3937	153573	168114	-2191
4:30	50.02	163462	6731	7814	0	7159	2200	142090	3982	155648	169976	-2195
4:45	49.99	165364	6716	7789	0	6723	2181	144612	3958	157575	171979	-2241
5:00	50.07	167790	6718	7847	176	7283	2192	146389	3951	159767	174556	-2286
5:15	50.07	172432	6704	7804	171	8004	2190	150039	3970	164457	178882	-2340
5:30	50.01	175622	6710	7762	161	8213	2276	153825	3963	167699	182910	-2292
5:45	49.96	180391	6711	7771	175	8679	2721	157194	4043	172445	187294	-2274
6:00	50.07	184370	6712	7570	212	9488	2943	160674	4009	176588	191608	-2335
6:15	49.87	190920	6702	7425	414	10030	3141	165995	3975	183081	197682	-2283
6:30	50.04	199119	6707	7110	399	12507	3634	170732	4005	191610	205094	-2250
6:45	49.99	205419	6731	6930	432	16186	3833	173050	4056	198057	211218	-1802
7:00	50.06	211949	6700	6707	669	20086	3830	175461	3967	204573	217420	-1324
7:15	49.85	216694	6720	6670	1563	22490	3932	176495	3993	208461	221863	-1353
7:30	49.90	220932	6733	6467	3351	24009	4031	177164	4013	211114	225768	-1295
7:45	50.03	223232	6704	6272	6640	23830	4043	176351	3959	210320	227799	-1257
8:00	50.10	223371	6721	6038	11399	22814	3720	173011	4007	205934	227710	-1276
8:15	50.06	225942	6728	5887	17665	21473	3392	172036	3964	202390	230145	-1334
8:30	50.14	227651	6716	5697	24874	19898	2157	168362	3972	197080	231676	-1324
8:45	50.07	229229	6719	5578	32245	16094	2162	165969	4016	191406	232783	-1318
9:00	50.08	230893	6719	5505	39614	13591	2169	162637	3967	185774	234202	-1504
9:15	50.03	235328	6705	5580	46644	11671	2199	163197	3980	183104	239976	-2403
9:30	50.01	237175	6724	5319	52467	10419	2173	160711	4022	179389	241835	-2446
9:45	50.03	239690	6684	4971	57526	10011	2202	158993	4067	177193	244454	-2478
10:00	50.02	238754	6704	4827	61752	8744	2223	155827	3977	172175	244054	-2501
10:15	49.96	239293	6688	4858	65760	7126	2226	154237	3957	168675	244852	-2498
10:30	50.02	238690	6697	5009	68844	6561	2230	150888	3910	164837	244139	-2466
10:45	49.99	237568	6678	5253	70713	6772	2271	147608	3923	161602	243218	-2486
11:00	50.00	235452	6694	5434	72744	6334	2270	143885	3925	157274	241286	-2565
11:15	49.93	232814	6691	5532	73690	5790	2239	140924	3895	153592	238761	-2502
11:30	49.92	231307	6696	5648	74501	6217	2256	137844	3835	151158	236997	-2544
11:45	49.95	229758	6697	5457	75109	5989	2231	135998	3911	149192	235392	-2541
12:00	50.08	227790	6690	5416	76449	5791	2231	133008	3876	145925	233461	-2548
12:15	49.94	224998	6688	5293	77530	5208	2213	129856	3852	142175	230640	-2600
12:30	50.01	223585	6689	2391	77830	5490	2216	128219	3891	143364	226726	-2615
12:45	49.96	221437	6688	2359	77908	5114	2191	126392	3858	141170	224510	-2596
13:00	50.07	217698	6694	4902	78437	5064	2125	122634	3796	134359	223652	-2609
13:15	50.00	212191	6700	4651	77642	5067	2121	118807	3889	129898	218877	-2576
13:30	50.06	210323	6685	4481	77652	4995	2084	116643	3813	128190	216353	-2577
13:45	50.02	211067	6699	4403	77347	5101	2122	117385	3901	129317	216958	-2632
14:00	50.10	211039	6699	4302	75977	5178	2113	118529	3845	130760	216643	-2612
14:15	50.03	210539	6694	4194	75150	4859	2145	118981	3888	131195	215911	-2614
14:30	50.03	211340	6694	4182	73461	5158	2196	121022	3874	133697	216587	-2579
14:45	49.94	211935	6697	4000	71852	5316	2188	123327	3916	136083	217296	-2587
15:00	50.00	212447	6689	3951	69463	5575	2121	126070	3858	139033	217727	-2565
15:15	49.97	210926	6701	3963	67021	5661	2165	127496	3876	139942	216883	-2575
15:30	50.04	211172	6695	3953	63598	5887	2228	130925	3639	143621	216925	-2581
15:45	49.99	210629	6707	4022	59321	6175	2387	133479	3832	147286	215923	-2605
16:00	50.02	210667	6690	4120	55045	6901	2288	136993	3892	151502	215929	-2616
16:15	50.00	207946	6702	4173	50270	7125	2346	138498	3899	153503	213013	-2408
16:30	50.01	208801	6712	4398	44708	8286	2262	143513	3867	159695	213746	-2428
16:45	49.96	208111	6711	4477	38360	8996	2251	148271	3853	165274	212919	-2391
17:00	50.06	208138	6703	4515	31046	10858	2138	153317	3914	172577	212491	-2441
17:15	50.06	205026	6704	4705	23488	11991	2139	155860	3870	176833	208757	-2194
17:30	50.09	206081	6697	4909	16298	14837	2143	161086	3819	184874	209789	-1629
17:45	50.00	207772	6694	4959	9417	17633	2141	166101	3878	193396	210823	-1440
18:00	50.11	208216	6715	5173	5138	20381	2140	168079	3947	197905	211573	-1336
18:15	50.08	208104	6720	5427	2412	21595	2216	169319	3917	200265	211606	-1283
18:30	50.00	210681	6721	5716	1030	23418	2253	172154	3892	203935	215184	-1281
18:45	50.03	212027	6730	6221	693	24060	2256	172551	3939	205113	216450	-1259
19:00	50.05	211314	6738	6645	501	24194	2246	171168	3883	204168	215375	-1288
19:15	50.08	209621	6732	6999	477	22908	2261	170429	3897	202145	213703	-1232
19:30	50.04	206822	6743	7313	0	20066	2209	170280	3878	199509	210489	-1222
19:45	50.04	204190	6738	7644	0	17930	2239	169430	3941	196546	207922	-1218
20:00	50.07	200754	6745	7917	0	15947	2166	168119	3906	192837	204800	-1264
20:15	49.99	197289	6747	7983	0	14112	2100	167222	3940	189306	202104	-1744
20:30	49.96	194470	6752	8185	0	13111	2088	165992	3937	186285	200065	-2293
20:45	49.99	192175	6741	8486	0	12288	2197	163989	3965	183689	197666	-2284
21:00	50.02	189195	6760	8754	0	11741	2183	161702	3901	180441	195041	-2270
21:15	50.04	186914	6761	8855	0	11094	2090	159946	3899	178059	192645	-2326
21:30	49.97	184349	6766	9023	0	10439	2179	158188	3946	175326	190541	-2297
21:45	50.02	181547	6766	9114	0	8941	2090	156626	3976	172433	187513	-2332
22:00	50.06	177913	6749	9060	0	7732	2194	154600	3879	168853	184214	-2337
22:15	49.94	178303	6756	9196	0	7619	2105	154778	3969	169107	184423	-2317
22:30	49.99	177336	6725	9047	0	7762	2196	153547	3964	168289	1	