



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 28.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 27.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 27-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 27.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 28-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	79372	55133	43089	28592	3420	209648
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1792	1276	1009	625	71	4773
Hydro Gen (MU)	404	84	174	105	35	802
Wind Gen (MU)	19	285	301	-	-	605
Solar Gen (MU)*	149.71	58.37	116.52	2.75	0.59	328
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	80998	55498	46456	29667	3441	209712
Time Of Maximum Demand Met	21:35	19:33	10:34	22:24	00:00	21:24

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.074	0.00	0.00	2.40	2.40	75.59	22.01

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	16545	0	355.9	213.9	1.0	838	0.00
	Haryana	12821	0	277.0	213.4	-1.6	434	0.00
	Rajasthan	12856	0	285.3	128.3	-2.8	894	0.00
	Delhi	7279	0	143.3	131.4	-1.4	322	0.00
	UP	29471	0	576.9	274.7	0.2	1290	0.00
	Uttarakhand	2418	0	52.0	26.2	0.7	219	0.00
	HP	1654	0	35.8	-5.6	0.0	137	0.00
	J&K(UT) & Ladakh(UT)	2689	0	54.5	29.2	0.4	168	0.00
	Chandigarh	335	0	7.0	7.0	0.0	30	0.00
	Railways NR ISTS	204	0	4.0	3.7	0.4	36	0.00
WR	Chhattisgarh	4591	0	100.7	56.9	1.0	300	0.00
	Gujarat	17930	0	400.6	128.7	-0.1	1253	0.00
	MP	10024	0	214.5	79.9	0.0	652	0.00
	Maharashtra	22144	0	477.2	130.9	-7.9	617	0.00
	Goa	557	0	13.2	12.3	0.4	95	0.00
	DNHDDPDCL	1324	0	30.6	30.5	0.1	39	0.00
	AMNSIL	927	0	21.0	11.8	-0.3	244	0.00
	BALCO	528	0	12.6	12.7	-0.1	4	0.00
	RIL JAMNAGAR	249	0	5.2	5.3	-0.1	0	0.00
	Andhra Pradesh	9431	0	203.4	15.9	0.2	789	0.00
SR	Telangana	10590	0	205.1	80.0	2.9	1239	0.00
	Karnataka	9609	0	177.1	-10.8	-2.7	585	0.00
	Kerala	3469	0	64.5	27.5	-0.5	408	0.00
	Tamil Nadu	15668	0	349.8	106.8	0.6	1914	0.00
	Puducherry	443	0	9.6	9.1	-0.2	32	0.00
	DVC	3286	0	68.9	-32.4	0.0	276	0.00
ER	Jharkhand	2082	0	42.1	33.4	0.1	129	0.00
	Odisha	6111	0	128.8	51.3	-1.2	710	0.00
	West Bengal	10363	0	215.4	84.6	-0.4	363	0.00
	Sikkim	57	0	0.9	1.0	-0.2	12	0.00
	Railways ER ISTS	23	0	0.2	0.2	0.1	4	0.00
	Arunachal Pradesh	210	0	3.9	3.7	-0.2	20	0.00
NER	Assam	2545	0	47.2	40.1	1.0	139	0.00
	Manipur	215	0	3.3	3.4	-0.1	62	0.00
	Meghalaya	302	0	5.3	1.2	-0.2	48	0.00
	Mizoram	105	0	1.8	1.8	-0.2	60	0.00
	Nagaland	164	0	3.0	2.8	-0.2	22	0.00
	Tripura	306	0	6.0	3.9	0.4	44	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	52.5	15.3	-23.0	-31.8
Day Peak (MW)	2428.4	819.8	-992.4	-1457.5

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	480.8	-313.1	-126.0	-47.4	5.6	0.0
Actual(MU)	476.4	-299.1	-158.5	-33.9	5.7	-9.4
OD/UD(MU)	-4.5	13.9	-32.5	13.5	0.1	-9.4

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5581	15978	7268	5690	447	34964	48
State Sector	9039	14250	12107	2142	199	37737	52
Total	14620	30228	19375	7832	646	72700	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	757	1195	487	609	12	3059	60
Lignite	23	10	33	0	0	66	1
Hydro	404	84	174	105	35	802	16
Nuclear	37	40	70	0	0	147	3
Gas, Naptha & Diesel	14	15	4	0	21	54	1
RES (Wind, Solar, Biomass & Others)	176	345	454	5	1	980	19
Total	1411	1688	1222	719	68	5108	100

Share of RES in total generation (%)	12.47	20.44	37.15	0.67	0.87	19.20
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	43.78	27.74	57.11	15.28	52.09	37.77

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.030
Based on State Max Demands	1.084

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	204047	10:37	0
Non-Solar hr	209712	21:24	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 28-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	751	0.0	17.2	-17.2
2	HVDC	PUSAULI-BB	2	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	492	676	0.0	4.3	-4.3
4	765 kV	SASARAM-FATEHPUR	1	262	291	0.0	1.0	-1.0
5	765 kV	GAYA-BALIA	1	0	947	0.0	14.6	-14.6
6	400 kV	PUSAULI-VARANASI	1	0	95	0.0	1.5	-1.5
7	400 kV	PUSAULI-ALLAHABAD	1	0	73	0.0	1.1	-1.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	34	804	0.0	11.3	-11.3
9	400 kV	PATNA-BALIA	2	142	626	0.0	7.2	-7.2
10	400 kV	NAUBATPUR-BALIA	2	93	177	0.0	1.4	-1.4
11	400 kV	BIHARSHARIFF-BALIA	2	234	216	0.0	0.5	-0.5
12	400 kV	MOTIHARI-GORAKHPUR	2	97	418	0.0	5.1	-5.1
13	400 kV	BIHARSARIFF-SAHUPURI	2	134	330	0.0	3.1	-3.1
14	220 kV	SAHUPURI-KARAMNASHA	1	0	106	0.0	1.7	-1.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASHA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASHA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	0.7	-71.9
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	432	466	0.0	1.3	-1.3
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2256	0	40.7	0.0	40.7
3	765 kV	JHARSUGUDA-DURG	2	348	225	0.6	0.0	0.6
4	400 kV	JHARSUGUDA-RAIGARH	4	498	41	5.1	0.0	5.1
5	400 kV	RANCHI-SIPAT	2	581	0	9.6	0.0	9.6
6	400 kV	JEYPORE-JAGDALPUR	2	0	563	0.0	7.6	-7.6
7	220 kV	BUDHIPADAR-RAIGARH	1	86	75	0.0	0.2	-0.2
8	220 kV	BUDHIPADAR-KORBA	2	118	71	0.1	0.0	0.1
						ER-WR	56.1	47.0
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	743	0	14.9	0.0	14.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1152	0.0	17.5	-17.5
3	765 kV	ANGUL-SRIKAKULAM	2	12	1766	0.0	22.8	-22.8
4	400 kV	TALCHER-I/C	2	977	0	10.4	0.0	10.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	14.9	-25.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	281	0.0	3.3	-3.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	522	0.0	7.7	-7.7
3	220 kV	ALIPURDUAR-SALAKATI	2	0	109	0.0	1.6	-1.6
						ER-NER	12.6	-12.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.5	-8.5
						NER-NR	8.5	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3930	0.0	94.0	-94.0
2	HVDC	VINDHYACHAL-B/B	2	46	256	1.1	0.6	0.5
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1915	0.0	37.5	-37.5
4	765 kV	GWALIOR-AGRA	2	0	3216	0.0	59.7	-59.7
5	765 kV	GWALIOR-PHAGI	2	228	1953	0.2	25.8	-25.6
6	765 kV	JABALPUR-ORAI	2	0	1521	0.0	53.8	-53.8
7	765 kV	GWALIOR-ORAI	1	533	0	8.4	0.0	8.4
8	765 kV	SATNA-ORAI	1	0	1124	0.0	20.3	-20.3
9	765 kV	BANASKANTHA-CHITORGARH	2	0	1940	0.0	20.9	-20.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	3580	0.0	69.5	-69.5
11	400 kV	ZERDA-KANKROLI	1	26	259	0.0	2.7	-2.7
12	400 kV	ZERDA-BHINMAL	1	15	179	0.0	1.9	-1.9
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	71	792	0.1	9.7	-9.6
15	400 kV	NEEMUCH-Chittorgarh	2	8	961	0.0	11.6	-11.6
16	220 kV	BHANPURA-RANPUR	1	0	142	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.3	-2.3
18	220 kV	MEHGAON-AURAIYA	1	12	71	0.0	1.0	-1.0
19	220 kV	MALANPUR-AURAIYA	1	0	79	0.0	1.3	-1.3
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	9.8	-405.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1001	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGALUR	2	2409	0	49.2	0.0	49.2
3	765 kV	SOLAPUR-RAICHUR	2	3093	0	46.5	0.0	46.5
4	765 kV	WARDHAN-NIZAMABAD	2	358	1157	0.5	7.6	-7.1
5	765 kV	WARORA-WARANGAL(NEW)	2	577	1079	1.3	5.9	-4.5
6	400 kV	KOLHAPUR-KUDGI	2	2268	0	44.6	0.0	44.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	99	0	0.5	0.0	0.5
9	220 kV	XELDEM-AMBEWADI	1	1	98	0.5	0.0	0.5
						WR-SR	167.1	153.6

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1369	1147	1180	28.31	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	870	818	842	20.21	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	126	70	95	2.28	
	NER	132kV GELEPHU-SALAKATI	52	27	33	0.80	
	NER	132kV MOTANGA-RANGIA	57	0	37	0.89	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-18	-0.42	
	ER	NEPAL IMPORT (FROM BIHAR)	163	101	130	3.11	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	600	420	526	12.63	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-948	-900	-922	-22.12	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1457	-1094	-1326	-31.81	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-48	0	-38	-0.90	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 28-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.17
Bangladesh	22.61	0.07	0.00	0.00	0.00	0.00	0.00	0.00	22.68
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.78	0.07	0.00	0.00	0.00	0.00	0.00	0.00	22.85

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.20	0.00	1.11	0.00	0.00	0.08	0.00	0.00	54.39
Nepal	8.45	0.07	3.36	0.00	0.00	3.96	0.00	0.00	15.84
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	61.65	0.07	4.47	0.00	0.00	4.04	0.00	0.00	70.23

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	53.20	0.00	1.11	0.00	0.00	0.08	0.00	0.00	54.39
Nepal	8.28	0.07	3.36	0.00	0.00	3.96	0.00	0.00	15.67
Bangladesh	-22.61	-0.07	0.00	0.00	0.00	0.00	0.00	0.00	-22.68
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	38.87	0.00	4.47	0.00	0.00	4.04	0.00	0.00	47.38

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.03	202597	5789	22415	0	32910	2481	137987	1632	180182	203214	2024
0:15	49.93	201936	5786	22229	0	32975	2378	138475	1607	179707	203450	1942
0:30	49.98	200978	5781	22385	0	32725	2257	137494	1604	178593	202246	1911
0:45	49.98	199848	5812	22744	0	33255	2292	135762	1624	177104	201489	2050
1:00	50.03	197902	5811	22795	0	33177	2284	133405	1641	175107	199113	2023
1:15	50.03	196360	5792	23086	0	33032	2196	131913	1622	173274	197641	1950
1:30	50.03	194907	5788	23659	0	32748	2288	130041	1624	171248	196148	1864
1:45	49.98	193851	5797	24066	0	32572	2309	128901	1605	169785	195250	1807
2:00	50.03	192790	5800	24493	0	32234	2304	127928	1609	168297	194368	1871
2:15	50.03	191838	5798	24721	0	31324	2197	127544	1614	167117	193198	1872
2:30	50.03	190994	5807	24661	0	31571	2199	127042	1565	166333	192845	1835
2:45	50.03	191361	5807	24699	0	31278	2195	127298	1557	166662	192834	1806
3:00	49.97	190666	5811	25057	0	31011	2199	126403	1542	165609	192023	1866
3:15	49.92	190037	5812	24765	0	30729	2194	126055	1567	165272	191122	1852
3:30	49.92	189289	5796	25182	0	30533	2191	125287	1583	164107	190572	1886
3:45	49.93	188781	5788	25108	0	30873	2193	124579	1539	163673	190080	1850
4:00	50.03	188131	5814	24910	0	30931	2194	124113	1552	163221	189514	1831
4:15	49.93	188670	5799	24806	0	31184	2202	124417	1543	163864	189951	1811
4:30	49.98	189037	5799	24771	0	31490	2199	124632	1568	164266	190459	1829
4:45	49.98	189059	5789	24431	0	31440	2203	124991	1545	164628	190399	1891
5:00	50.03	188807	5798	24183	107	30925	2209	125432	1576	164517	190230	1889
5:15	49.98	189211	5821	23874	104	30536	2208	126211	1573	165233	190327	1912
5:30	49.98	189647	5820	23867	104	30637	2206	126612	1590	165676	190836	1898
5:45	49.93	189476	5827	23787	102	30699	2195	126741	1639	165587	190990	1738
6:00	50.03	189776	5813	23903	152	30355	2210	127116	1571	165721	191120	1700
6:15	49.98	190588	5818	23806	667	30787	2202	127209	1595	166115	192084	1698
6:30	50.03	191398	5809	23909	1365	30985	2182	126817	1671	166124	192738	1671
6:45	50.03	191890	5829	24089	2557	30882	2184	125797	1568	165244	192906	1712
7:00	49.98	190858	5816	24046	4272	30392	2188	123562	1625	162540	191901	1688
7:15	50.02	191256	5824	24250	6457	29924	2180	121856	1638	160549	192129	1684
7:30	50.03	191287	5821	24136	9080	29485	2184	119702	1659	158071	192067	1701
7:45	50.08	191604	5817	24377	12200	29604	2288	116650	1659	155027	192595	1752
8:00	50.03	190463	5830	24581	14846	29348	2292	113727	1641	151036	192265	1787
8:15	49.98	191871	5817	24733	17422	29415	2286	112114	1684	149716	193471	1780
8:30	49.98	193782	5819	24688	20609	29254	2289	111194	1740	148485	195593	1733
8:45	49.98	195576	5819	24875	23317	29463	2288	110132	1710	147384	197604	1672
9:00	50.03	197307	5816	25061	26408	29274	2320	108901	1722	145838	199502	1643
9:15	49.97	200191	5817	24855	29041	29334	2294	109326	1721	146295	202388	1572
9:30	49.97	200684	5823	24311	30097	29124	2191	109593	1673	146276	202812	1630
9:45	49.92	201281	5820	24142	31219	28788	2300	109513	1700	145920	203482	1614
10:00	50.03	201581	5807	23945	33547	28321	2295	108380	1706	144089	204001	1569
10:15	50.03	202195	5811	23989	36688	27803	2200	106448	1696	141518	204635	1591
10:30	50.13	202965	5810	23960	38358	27637	2301	105370	1786	140647	205222	1578
10:45	50.28	203466	5825	23724	40837	26957	2294	104359	1724	138905	205720	1613
11:00	50.12	202139	5826	24508	39957	27400	2171	102629	1745	137674	204236	1655
11:15	49.97	200826	5815	24548	39168	27419	2302	101948	1785	137110	202985	1638
11:30	50.02	200507	5810	24927	39282	27153	2187	101625	1732	136298	202716	1663
11:45	50.08	200569	5824	25261	39511	27209	2295	101130	1746	135797	202976	1685
12:00	50.03	200590	5804	25414	39745	27240	2184	100497	1772	135431	202656	1684
12:15	49.98	199839	5803	25182	38828	27293	2311	100950	1765	135829	202132	1707
12:30	50.03	199802	5799	25279	38249	26868	2307	101581	1756	136274	201839	1662
12:45	49.93	198740	5807	25074	37867	26841	2299	101355	1727	135799	200970	1662
13:00	50.03	197536	5807	25258	38182	26622	2190	100299	1729	134096	200087	1493
13:15	50.18	195146	5816	25106	38098	26236	2173	98300	1753	131942	197482	1537
13:30	50.23	195105	5812	25419	37837	25967	2289	98368	1771	131849	197463	1609
13:45	50.28	195884	5815	25215	38590	26007	2281	98798	1740	132079	198446	1592
14:00	50.38	195262	5815	24885	38477	25613	2276	99018	1691	131900	197775	1627
14:15	50.18	193319	5817	24937	37320	25904	2175	98576	1717	131062	196446	1671
14:30	50.02	194057	5801	24705	36394	26681	2184	98841	1687	132958	196293	1620
14:45	50.02	194394	5793	25302	36564	26728	2298	98584	1700	132528	196969	1632
15:00	50.02	194459	5809	25735	34683	27179	2302	99251	1730	134041	196689	1729
15:15	49.97	193571	5813	26343	32246	27274	2174	99725	1724	134982	195299	1777
15:30	50.02	193705	5796	26521	31028	27283	2180	101147	1687	136156	195642	1778
15:45	50.02	193642	5795	26496	30767	28139	2188	100332	1681	136379	195398	1811
16:00	50.12	193088	5785	26782	29953	27975	2185	100467	1681	136353	194828	1802
16:15	50.12	191381	5812	26331	28040	27403	2178	101687	1668	137010	193119	1828
16:30	49.97	191840	5784	26532	25865	27868	2282	103631	1714	139443	193676	1764
16:45	49.92	191278	5774	26764	22904	28072	2184	104713	1644	141610	192055	1813
17:00	50.07	190379	5782	27021	19273	28747	2189	106083	1650	144085	190745	1866
17:15	50.02	189649	5792	26977	16408	28970	2184	108127	1646	146264	190104	1785
17:30	50.02	190278	5792	27151	13828	29957	2184	109947	1647	149299	190506	1876
17:45	50.02	189767	5778	27390	11634	30246	2277	111590	1573	150743	190488	1854
18:00	49.92	189749	5788	27175	8453	30668	2174	114054	1631	154121	189943	1907
18:15	49.82	190066	5776	26854	6139	31177	2181	116679	1603	157073	190409	1867
18:30	50.07	192222	5770	26709	3920	31565	2288	120780	1576	161593	192608	1751
18:45	49.97	194757	5662	26784	1990	32438	2285	124311	1590	165983	195060	1897
19:00	49.97	198056	5621	26742	1004	33375	2289	127754	1644	170310	198429	1869
19:15	49.92	201774	5451	26760	369	34296	2219	130257	1657	174645	201009	1914
19:30	49.92	204165	5486	26760	4	34835	2270	132553	1659	177401	203567	1949
19:45	49.92	205950	5477	26230	8	34761	2276	135004	1704	179712	205460	1937
20:00	49.92	206847	5481	25690	13	35001	2284	136017	1643	181144	206129	1938
20:15	49.92	206956	5492	24914	0	34862	2281	137213	1659	182042	206421	1893
20:30	49.92	207850	5477	24261	0	34920	2279	138845	1663	183589	207445	1913
20:45	50.02	208251	5483	23619	0	34851	2326	140029	1649	184632	207957	1883
21:00	50.02	208437	5480	23351	0	34484	2369	140629	1684	185086	207997	1910
21:15	50.02	209371	5482	23067	0	34400	2371	141829	1699	186304	208848	1935
21:30	50.02	209410	5480	23077	0	34360	2374	142159	1672	186333	209122	1924
21:45	50.02	209056	5483	22848	0	34518	2397	141892	1670	186208	208808	1959
22:00	50.02	208418	5491	22300	0	34402	2415	141825	1674	186118	208107	2028
22:15	50.02	209079	5476	22214	0	34488	2426	142458	1658	186865		