



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 06.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 05.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 5-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 05.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 06-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	57489	60536	40553	21807	2636	183021
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1199	1446	1098	448	47	4237
Hydro Gen (MU)	93	26	82	18	12	230
Wind Gen (MU)	15	69	55	-	-	139
Solar Gen (MU)*	120.40	91.91	141.99	2.63	1.08	358
Energy Shortage (MU)	0.00	0.00	0.00	1.66	0.00	1.66
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	62835	72160	56020	22645	2686	213661
Time Of Maximum Demand Met	10:47	10:29	10:07	18:17	17:42	10:26

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.069	1.37	2.66	2.82	6.85	63.37	29.78

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	7741	0	139.0	66.9	-0.9	401	0.00
	Haryana	6868	0	137.8	96.9	-1.2	544	0.00
	Rajasthan	17098	0	316.6	114.5	-1.5	572	0.00
	Delhi	5115	0	81.6	80.2	-1.2	379	0.00
	UP	20898	0	375.7	124.4	1.6	908	0.00
	Uttarakhand	2240	0	40.0	32.8	-0.6	80	0.00
	HP	1903	0	33.8	28.1	-1.1	159	0.00
	J&K(UT) & Ladakh(UT)	3089	0	66.7	65.8	-3.2	984	0.00
	Chandigarh	246	0	4.1	4.4	-0.3	19	0.00
WR	Railways_NR ISTS	174	0	3.8	3.5	0.3	37	0.00
	Chhattisgarh	5231	0	108.6	58.5	0.1	302	0.00
	Gujarat	21346	0	402.6	185.8	-2.5	575	0.00
	MP	15866	0	294.3	182.1	-2.9	552	0.00
	Maharashtra	27619	0	565.5	199.3	-4.2	714	0.00
	Goa	631	0	12.5	12.0	-0.1	59	0.00
	DNHDDPDCL	1257	0	29.3	29.4	-0.1	38	0.00
	AMNSIL	783	0	17.7	7.5	0.8	301	0.00
	BALCO	530	0	12.6	12.7	-0.1	4	0.00
SR	RIL JAMNAGAR	101	0	2.4	2.4	0.0	0	0.00
	Andhra Pradesh	10726	0	195.0	51.8	-1.0	404	0.00
	Telangana	13861	0	259.8	153.6	0.0	625	0.00
	Karnataka	15005	0	258.5	80.0	-0.1	470	0.00
	Kerala	3764	0	72.5	58.4	0.9	300	0.00
	Tamil Nadu	14496	0	303.8	162.9	-2.0	778	0.00
	Puducherry	354	0	8.0	7.7	-0.3	25	0.00
ER	Bihar	5539	0	101.9	89.4	0.5	765	1.66
	DVC	3195	0	69.6	-37.9	0.2	497	0.00
	Jharkhand	2016	0	36.5	26.5	0.1	171	0.00
	Odisha	4953	0	98.0	34.4	-3.4	353	0.00
	West Bengal	6562	0	140.9	-0.6	2.3	171	0.00
	Sikkim	103	0	1.4	1.6	-0.2	10	0.00
	Railways_ER ISTS	16	0	0.2	0.1	0.0	4	0.00
NER	Arunachal Pradesh	201	0	2.7	2.9	-0.3	11	0.00
	Assam	1470	0	26.1	19.4	0.2	102	0.00
	Manipur	252	0	3.9	3.9	0.0	30	0.00
	Meghalaya	342	0	6.3	5.6	-0.1	65	0.00
	Mizoram	126	0	2.0	1.7	-0.3	11	0.00
	Nagaland	157	0	2.3	2.3	0.0	41	0.00
	Tripura	214	0	3.8	2.9	0.1	49	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.3	-6.9	-20.8	-15.1
Day Peak (MW)	-399.0	-483.0	-1006.0	-767.6

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	248.1	-245.6	127.0	-135.6	6.2	0.0
Actual(MU)	252.0	-245.5	107.6	-128.1	4.8	-9.2
O/D/U/D(MU)	3.9	0.1	-19.3	7.5	-1.4	-9.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5271	6886	5148	7178	568	25051	46
State Sector	7823	11750	7274	2249	191	29286	54
Total	13094	18635	12422	9427	759	54337	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	725	1551	606	631	9	3523	76
Lignite	26	16	54	0	0	96	2
Hydro	93	26	82	18	12	230	5
Nuclear	32	54	70	0	0	156	3
Gas, Naptha & Diesel	3	11	5	0	25	44	1
RES (Wind, Solar, Biomass & Others)	162	165	232	6	1	566	12
Total	1041	1824	1048	655	47	4615	100

Share of RES in total generation (%)	15.53	9.05	22.12	0.94	2.35	12.26
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	27.51	13.45	36.59	3.68	27.41	20.63

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	213661	10:26	356
Non-Solar hr	191815	18:43	1023

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 06-Jan-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	1	0	0.0	6.1	-6.1
3	765 kV	GAYA-VARANASI	2	253	826	0.0	8.5	-8.5
4	765 kV	SASARAM-FATEHPUR	1	63	478	0.0	6.3	-6.3
5	765 kV	GAYA-BALIA	1	0	845	0.0	14.6	-14.6
6	400 kV	PUSAULI-VARANASI	1	0	207	0.0	4.0	-4.0
7	400 kV	PUSAULI -ALLAHABAD	1	0	107	0.0	2.0	-2.0
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	16	719	0.0	8.5	-8.5
9	400 kV	PATNA-BALIA	2	0	725	0.0	8.8	-8.8
10	400 kV	NAUBATPUR-BALIA	2	1	354	0.0	1.4	-1.4
11	400 kV	BIHARSHARIFF-BALIA	2	0	311	0.0	6.2	-6.2
12	400 kV	MOTIHARI-GORAKHPUR	2	18	448	0.0	4.7	-4.7
13	400 kV	BIHARSHARIFF-VARANASI	2	47	263	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	95	0.0	4.0	-4.0
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	75.1	-74.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	479	532	1.6	0.0	1.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	896	441	7.2	0.0	7.2
3	765 kV	JHARSUGUDA-DURG	2	0	930	0.0	16.7	-16.7
4	400 kV	JHARSUGUDA-RAIGARH	4	0	667	0.0	10.7	-10.7
5	400 kV	RANCHI-SIPAT	2	227	170	0.8	0.0	0.8
6	220 kV	BUDHIPADAR-RAIGARH	1	0	99	0.0	1.4	-1.4
7	220 kV	BUDHIPADAR-KORBA	2	90	70	0.5	0.0	0.5
ER-WR						10.0	28.8	-18.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	215	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1653	0.0	37.5	-37.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2786	0.0	50.1	-50.1
4	400 kV	TALCHER-I/C	2	626	0	6.2	0.0	6.2
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	92.7	-92.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	387	11	3.3	0.0	3.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	398	0	6.2	0.0	6.2
3	220 kV	ALIPURDUAR-SALAKATI	2	79	0	1.3	0.0	1.3
ER-NER						10.8	0.0	10.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2511	0.0	37.4	-37.4
2	HVDC	VINDHYACHAL B/B	-	269	103	0.0	1.2	-1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1913	0.0	36.4	-36.4
4	765 kV	GWALIOR-AGRA	2	0	2372	0.0	35.3	-35.3
5	765 kV	GWALIOR-PHAGI	2	0	1976	0.0	26.8	-26.8
6	765 kV	JABALPUR-ORAI	2	0	1294	0.0	38.9	-38.9
7	765 kV	GWALIOR-ORAI	1	994	0	16.3	0.0	16.3
8	765 kV	SATNA-ORAI	1	0	1082	0.0	20.4	-20.4
9	765 kV	BANASKANTHA-CHITORGARH	2	924	629	6.9	1.9	4.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	3109	0.0	49.3	-49.3
11	400 kV	ZERDA-KANKROLI	1	224	79	1.8	0.1	1.7
12	400 kV	ZERDA -BHINMAL	1	154	55	1.2	0.1	1.1
13	400 kV	VINDHYACHAL -RIHAND	1	983	0	21.3	0.0	21.3
14	400 kV	RAPP-SHUJALPUR	2	340	331	1.6	2.1	-0.5
15	400 kV	NEEMUCH-Chittorgarh	2	374	294	1.9	1.5	0.4
16	220 kV	BHANPURA-RANPUR	1	0	166	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	104	4	0.8	0.0	0.8
19	220 kV	MALANPUR-AURAIYA	1	65	21	0.4	0.1	0.3
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						52.1	255.7	-203.6
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	511	0.0	8.8	-8.8
2	HVDC	RAIGARH-PUGALUR	2	0	3002	0.0	25.9	-25.9
3	765 kV	SOLAPUR-RAICHUR	2	1973	1040	10.8	5.1	5.7
4	765 kV	WARDHA-NIZAMABAD	2	0	2530	0.0	32.5	-32.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2312	0.0	31.9	-31.9
6	400 kV	KOLHAPUR-KUDGI	2	1279	0	30.7	0.0	30.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	106	2.0	0.0	2.0
WR-SR						43.5	104.2	-60.7
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	213	2	94	2.26		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-214	94	-59	-1.43		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-242	-141	-195	-4.68		
	NER	132kV GELEPHU-SALAKATI	-29	-14	-18	-0.44		
	NER	132kV MOTANGA-RANGIA	-10	0	0	-0.01		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-65	0	-58	-1.40		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-65	0	-42	-1.02		
	ER	NEPAL IMPORT (FROM BIHAR)	-176	0	-73	-1.74		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-307	-6	-115	-2.77		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-939	-646	-818	-19.63		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-768	-410	-629	-15.09		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-67	0	-50	-1.20		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 06-Jan-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.00	5.81	0.00	0.00	0.00	0.00	0.00	5.81	
Nepal	1.76	0.00	0.66	0.00	0.00	0.00	1.92	0.00	0.00	4.34
Bangladesh	20.29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.29
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.05	0.00	6.47	0.00	0.00	0.00	1.92	0.00	0.00	30.44

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.04
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.04	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.04

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.04	0.00	-5.81	0.00	0.00	0.00	0.00	0.00	-4.77
Nepal	-1.76	0.00	-0.66	0.00	0.00	-1.92	0.00	0.00	-4.34
Bangladesh	-20.29	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.29
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.01	0.00	-6.47	0.00	0.00	-1.92	0.00	0.00	-29.40

Date of Reporting: 06-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.09	152715	5946	7461	95	6781	1679	130755	3278	145159	155995	-1482
0:15	50.09	151963	5954	7504	95	7116	1675	129614	3328	144364	155286	-1455
0:30	50.04	150910	5948	7549	88	7045	1829	128400	3292	143273	154151	-1461
0:45	50.04	149763	5955	7607	93	6480	1812	127904	3274	142063	153125	-1387
1:00	50.04	148678	5940	7601	93	6185	1680	126766	3334	140984	151599	-1270
1:15	50.04	147647	5951	7567	90	6020	1672	125961	3300	139990	150561	-1283
1:30	50.04	146678	5969	7526	91	5789	1818	125200	3306	139061	149699	-1278
1:45	50.04	145841	5965	7454	83	5740	1673	124592	3310	138304	148817	-1255
2:00	50.09	144954	5968	7462	81	5719	1837	123502	3317	137411	147886	-1256
2:15	50.09	144022	5938	7485	78	5438	1861	122778	3292	136459	146870	-1250
2:30	50.04	143491	5950	7419	75	5439	1856	122436	3332	135997	146507	-1235
2:45	49.99	143427	5948	7385	76	5393	1857	122302	3348	135966	146309	-1174
3:00	50.04	142852	5946	7382	75	5406	1804	121739	3325	135395	145677	-1181
3:15	50.04	143004	5956	7344	102	5145	1675	122221	3325	135558	145768	-1134
3:30	49.99	143266	5943	7348	102	5436	1864	122070	3370	135816	146133	-1120
3:45	49.99	143198	5962	7358	101	5455	1677	122078	3352	135739	145983	-1135
4:00	50.04	143771	5937	7351	100	5412	1678	122892	3316	136320	146686	-1155
4:15	50.04	145351	5954	7300	100	5677	1868	123970	3339	137951	148208	-1166
4:30	49.99	146975	5930	7267	108	5699	1895	125739	3347	139600	149985	-1185
4:45	49.99	148437	5981	7230	111	5956	1890	126900	3328	141096	151396	-1225
5:00	50.04	150181	5951	7340	116	6461	1667	128370	3326	142725	153231	-1177
5:15	49.94	153428	5957	7438	116	6468	1891	131465	3330	145874	156665	-1107
5:30	50.04	156795	5967	7448	117	6552	1926	134764	3338	149230	160112	-1082
5:45	50.04	159995	5978	7313	108	7124	1932	137606	3348	152574	163409	-1215
6:00	50.04	162095	5963	7332	115	7820	1945	139135	3269	154648	165579	-1308
6:15	50.04	165477	5972	7339	640	9093	1885	141345	3303	157498	169577	-1322
6:30	50.04	170762	5974	7219	645	10540	1897	145394	3286	162898	174955	-1297
6:45	50.04	176027	5990	7125	679	12417	1703	148755	3330	168223	179999	-1344
7:00	50.04	180226	5973	7003	894	14692	1905	150656	3314	172329	184437	-1345
7:15	49.99	184353	6024	6992	1583	16194	1703	152613	3319	175778	188428	-1358
7:30	49.99	188150	6013	6760	2848	17241	1919	154267	3323	178542	192371	-1292
7:45	49.94	191754	6028	6521	4626	17449	1700	155566	3448	180607	195338	-1315
8:00	49.99	194053	6031	6342	7231	17136	1925	156238	3393	180480	198296	-1325
8:15	49.89	197551	6055	5993	10290	17027	1680	156061	3412	181268	200518	-1208
8:30	49.79	199968	6045	5539	13754	16354	1930	156263	3421	180675	203306	-885
8:45	49.79	202670	6076	5189	17340	15288	1918	156525	3368	180141	205704	-907
9:00	49.89	204361	6068	4692	21304	13734	1698	155966	3405	178365	206867	-962
9:15	49.64	207883	6083	4295	24900	13296	1707	156409	3377	178688	210067	-971
9:30	49.74	209855	6089	3922	27198	12813	1698	156767	3465	178735	211952	-1006
9:45	49.94	211251	6087	3461	29535	12361	1703	156921	3421	178255	213489	-1032
10:00	49.99	212554	5888	3076	31604	11209	1694	156787	3444	177874	213702	-1046
10:15	49.94	213238	5911	2809	37193	9727	1676	155037	3440	173236	215793	-1255
10:30	50.04	213438	5915	2641	39968	8927	1685	153433	3482	170829	216051	-1355
10:45	49.99	213474	5897	2590	42602	8713	1632	150975	3423	168282	215832	-1342
11:00	50.04	213285	5897	2627	44415	8650	1617	149091	3422	166243	215719	-1323
11:15	50.04	211447	5897	2653	46248	7363	1601	146748	3414	162546	213924	-1320
11:30	50.04	210141	5909	2645	47867	6882	1600	143816	3519	159629	212238	-1411
11:45	50.04	208970	5922	2656	49293	6598	1621	141757	3427	157021	211274	-1537
12:00	50.09	207822	5902	2667	50388	6395	1611	139965	3462	154767	210390	-1680
12:15	50.04	206216	5904	2687	51624	5263	1617	138259	3417	151905	208771	-1746
12:30	50.04	205131	5899	2598	51779	5173	1606	137257	3416	150754	207728	-1767
12:45	50.04	203346	5922	2505	52144	5061	1620	135151	3376	148697	205779	-1783
13:00	50.04	201165	5899	2425	51983	5371	1620	132695	3391	146757	203384	-1769
13:15	49.99	197077	5895	2335	51417	5191	1616	129575	3376	143325	199405	-1790
13:30	50.04	196232	5892	2238	50948	5480	1593	128905	3372	143046	198428	-1825
13:45	50.09	195358	5882	2134	50580	5566	1602	128418	3402	142644	197584	-1852
14:00	50.09	193597	5887	2083	49087	5570	1614	128288	3398	142427	195927	-1783
14:15	50.09	192049	5894	2043	48122	5591	1608	127545	3380	141884	194183	-1814
14:30	50.09	192359	5880	2037	46292	6169	1602	129018	3368	144030	194366	-1815
14:45	50.14	191161	5902	2049	44174	5910	1653	130653	3295	144938	193636	-1837
15:00	50.04	190688	5893	2086	41814	5955	1675	132215	3287	146788	192925	-1885
15:15	50.04	188649	5870	2152	39453	5836	1673	132750	3334	147044	191068	-1748
15:30	50.04	188620	6013	2217	36420	6241	1677	135083	3237	149983	190888	-1767
15:45	49.99	187645	6000	2342	33126	6828	1669	136361	3297	152177	189623	-1751
16:00	49.99	186513	6094	2390	29659	6755	1666	138709	3382	154464	188655	-1604
16:15	49.99	184509	6029	2565	25569	6795	1761	140504	3281	156375	186504	-1500
16:30	49.99	184582	6043	2560	21402	7239	1679	144661	3198	160620	186782	-1402
16:45	49.94	185695	6089	2598	16795	9218	1667	148287	3228	166302	187882	-1307
17:00	49.94	185905	6084	2689	12222	10901	1698	151469	3189	170994	188252	-1316
17:15	49.99	184739	6084	2833	8158	12339	1668	152626	3144	173748	186852	-975
17:30	50.09	185290	6080	2993	4831	15045	1692	153626	3199	177466	187466	-855
17:45	50.04	187318	6097	3267	2632	18072	1661	154570	3204	181419	189503	-828
18:00	50.09	187635	6127	3739	1284	18721	1697	155140	3176	182612	189884	-851
18:15	50.04	189697	6132	4241	758	18826	1736	157380	3205	184698	192278	-788
18:30	50.04	191061	6126	4798	615	19511	1757	157514	3193	185648	193514	-777
18:45	50.04	191439	6107	5383	585	19496	1764	157161	3171	185471	193667	-772
19:00	50.04	189905	6097	5928	587	18047	1787	156508	3180	183390	192134	-760
19:15	50.09	187836	6118	6395	592	16020	1673	155640	3204	180849	189642	-746
19:30	50.04	185282	6152	6701	592	14538	1680	154432	3181	177989	187276	-747
19:45	50.04	182763	6117	6883	567	13043	1678	153061	3151	175313	184500	-739
20:00	50.09	178653	6137	7083	568	12131	1678	150265	3207	171002	181069	-735
20:15	49.99	176496	6139	7291	138	11515	1674	148810	3223	169067	178790	-963
20:30	50.04	173948	6140	7511	141	11291	1668	146237	3254	166296	176242	-1027
20:45	49.99	171543	6143	7698	106	11151	1701	143915	3257	163739	173971	-1058
21:00	49.99	168396	6151	7936	106	10225	1688	141439	3243	160354	170788	-1052
21:15	49.99	166660	6136	8282	112	9600	1699	139655	3234	158266	168718	-1060
21:30	49.99	164266	6155	8495	111	9270	1700	137529	3220	155660	166480	-1112
21:45	50.04	161727	6169	8458	121	8961	1688	135621	3221	153148	164239	-1217
22:00	50.04	158444	6175	8515	118	8302	1816	133229	3202	149811	161357	-1234
22:15	50.04	157461	6164	8563	116	8551	1680	131703	3224	148782	160001	-1285
22:30	49.98	155520	6158	8742	111	8408	1669	129995				