



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 06.09.2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 05.09.2024.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 05-सितंबर-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 05.09.2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 06-Sep-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	70492	56789	46958	28369	3532	206140
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1505	1330	1075	608	65	4582
Hydro Gen (MU)	403	114	180	90	31	818
Wind Gen (MU)	7	138	220	-	-	365
Solar Gen (MU)*	143.47	67.04	121.39	2.32	0.94	335
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	70680	59750	49068	28545	3552	209151
Time Of Maximum Demand Met	20:44	19:10	09:44	22:54	19:58	19:29

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.047	0.00	0.00	2.59	2.59	74.95	22.46

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	12376	0	268.7	172.0	0.3	513	0.00
	Haryana	9943	0	203.1	145.1	-1.0	548	0.00
	Rajasthan	11222	0	248.6	65.9	-2.9	229	0.00
	Delhi	5671	0	118.1	112.3	-3.0	136	0.00
	UP	26169	0	519.9	260.2	1.5	450	0.00
	Uttarakhand	2344	0	49.5	24.3	0.1	135	0.00
	HP	1703	0	35.1	-0.3	-3.4	0	0.00
	J&K(UT) & Ladakh(UT)	2664	0	51.5	25.2	1.9	334	0.00
	Chandigarh	322	0	6.6	7.1	-0.4	16	0.00
WR	Railways_NR ISTS	198	0	4.1	3.9	0.1	26	0.00
	Chhattisgarh	5720	0	127.4	79.4	-2.6	217	0.00
	Gujarat	16708	0	367.6	167.6	-5.7	353	0.00
	MP	11971	0	255.6	136.1	-1.3	500	0.00
	Maharashtra	23309	0	504.5	167.4	-6.2	700	0.00
	Goa	647	0	14.3	11.8	2.2	36	0.00
	DNHDDPDCL	1330	0	30.7	30.7	0.0	60	0.00
	AMNSIL	830	0	17.4	9.4	0.0	258	0.00
	BALCO	530	0	12.6	12.6	0.1	49	0.00
SR	Andhra Pradesh	9009	0	197.6	31.0	-1.6	890	0.00
	Telangana	9645	0	197.6	64.6	0.2	500	0.00
	Karnataka	12450	0	218.6	39.6	0.7	669	0.00
	Kerala	4255	0	83.9	54.8	1.0	295	0.00
	Tamil Nadu	17522	0	366.5	155.5	-1.3	912	0.00
	Puducherry	502	0	10.6	10.2	-0.2	44	0.00
ER	Bihar	7010	0	141.8	134.3	-3.7	177	0.00
	DVC	3405	0	70.2	-32.6	-2.1	519	0.00
	Jharkhand	2065	0	44.3	34.4	-0.2	235	0.00
	Odisha	5691	0	120.4	48.1	-1.1	452	0.00
	West Bengal	11010	0	229.4	103.4	-1.3	448	0.00
	Sikkim	98	0	1.4	1.8	-0.4	21	0.00
	Railways_ER ISTS	10	0	0.1	0.2	0.0	1	0.00
NER	Arunachal Pradesh	174	0	3.0	2.7	-0.2	38	0.00
	Assam	2418	0	43.8	37.2	-1.2	375	0.00
	Manipur	215	0	2.8	3.1	-0.3	23	0.00
	Meghalaya	270	0	4.5	0.2	0.0	114	0.00
	Mizoram	116	0	2.0	0.5	-0.1	13	0.00
	Nagaland	159	0	2.5	2.5	-0.3	22	0.00
	Tripura	335	0	6.0	4.9	0.3	103	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	40.7	18.4	-21.8	-28.9
Day Peak (MW)	2004.0	922.2	-974.0	-1480.5

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	258.7	-197.1	-26.4	-43.5	8.3	0.0
Actual(MU)	266.1	-189.8	-54.1	-37.1	4.8	-10.1
O/D/U/D(MU)	7.4	7.3	-27.8	6.4	-3.5	-10.1

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3489	12739	4138	4146	622	25134	43
State Sector	5297	13634	11847	2422	155	33353	57
Total	8786	26372	15985	6568	777	58487	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	707	1196	521	611	13	3048	62
Lignite	23	6	52	0	0	81	2
Hydro	403	114	180	90	31	818	17
Nuclear	34	65	66	0	0	165	3
Gas, Naptha & Diesel	10	44	5	0	20	79	2
RES (Wind, Solar, Biomass & Others)	156	208	373	5	1	743	15
Total	1333	1632	1198	706	65	4934	100
Share of RES in total generation (%)	11.70	12.74	31.18	0.67	1.47	15.06	
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	44.49	23.69	51.71	13.41	48.85	34.97	

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.011
Based on State Max Demands	1.051

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	197863	10:57	0
Non-Solar hr	209151	19:29	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 06-Sep-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	701	0.0	17.2	-17.2
2	HVDC	PUSAULI B/B	-	0	112	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	919	366	4.4	0.0	4.4
4	765 kV	SASARAM-FATEHPUR	1	352	257	0.6	0.0	0.6
5	765 kV	GAYA-BALIA	1	0	750	0.0	9.7	-9.7
6	400 kV	PUSAULI-VARANASI	1	0	128	0.0	2.3	-2.3
7	400 kV	PUSAULI -ALLAHABAD	1	17	57	0.0	0.3	-0.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	189	639	0.0	6.5	-6.5
9	400 kV	PATNA-BALIA	2	214	691	0.0	6.9	-6.9
10	400 kV	NAUBATPUR-BALIA	2	118	210	0.0	1.5	-1.5
11	400 kV	BIHARSHARIFF-BALIA	2	248	96	1.8	0.0	1.8
12	400 kV	MOTIHARI-GORAKHPUR	2	149	364	0.0	3.3	-3.3
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	229	0.0	0.2	-0.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	0	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	51	0.0	0.8	-0.8
ER-NR						7.4	51.4	-44.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	430	908	0.0	4.9	-4.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2632	0	42.5	0.0	42.5
3	765 kV	JHARSUGUDA-DURG	2	354	360	0.0	0.3	-0.3
4	400 kV	JHARSUGUDA-RAIGARH	4	32	577	0.0	6.9	-6.9
5	400 kV	RANCHI-SIPAT	2	603	35	8.6	0.0	8.6
6	220 kV	BUDHIPADAR-RAIGARH	1	27	123	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-KORBA	2	7	171	0.0	1.4	-1.4
ER-WR						51.1	14.5	36.6
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	301	0	4.1	0.0	4.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1396	0.0	22.4	-22.4
3	765 kV	ANGUL-SRIKAKULAM	2	0	2165	0.0	30.5	-30.5
4	400 kV	TALCHER-I/C	2	1579	0	15.8	0.0	15.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						4.1	52.9	-48.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	0	425	0.0	6.6	-6.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	658	0.0	9.7	-9.7
3	220 kV	ALIPURDUAR-SALAKATI	2	0	119	0.0	2.1	-2.1
ER-NER						0.0	18.3	-18.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	503	0.0	12.0	-12.0
NER-NR						0.0	12.0	-12.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2047	0.0	35.5	-35.5
2	HVDC	VINDHYACHAL B/B	-	0	203	0.0	1.6	-1.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	299	0.0	7.4	-7.4
4	765 kV	GWALIOR-AGRA	2	0	3045	0.0	41.5	-41.5
5	765 kV	GWALIOR-PHAGI	2	914	1753	5.0	16.4	-11.4
6	765 kV	JABALPUR-ORAI	2	0	1285	0.0	35.8	-35.8
7	765 kV	GWALIOR-ORAI	1	896	0	11.6	0.0	11.6
8	765 kV	SATNA-ORAI	1	0	958	0.0	15.6	-15.6
9	765 kV	BANASKANTHA-CHITORGARH	2	761	1063	3.6	5.3	-1.7
10	765 kV	VINDHYACHAL-VARANASI	2	0	3762	0.0	70.4	-70.4
11	400 kV	ZERDA-KANKROLI	1	180	110	1.1	0.5	0.5
12	400 kV	ZERDA -BHINMAL	1	566	269	4.0	1.0	3.1
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	392	621	1.9	4.3	-2.4
15	400 kV	NEEMUCH-Chittorgarh	2	301	668	1.0	5.3	-4.3
16	220 kV	BHANPURA-RANPUR	1	0	77	0.0	1.3	-1.3
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	87	44	0.4	0.1	0.4
19	220 kV	MALANPUR-AURAIYA	1	58	58	0.2	0.2	-0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						28.8	244.2	-215.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	500	0	12.0	0.0	12.0
2	HVDC	RAIGARH-PUGALUR	2	287	303	5.6	1.2	4.4
3	765 kV	SOLAPUR-RAICHUR	2	2370	775	24.1	1.1	23.0
4	765 kV	WARDHA-NIZAMABAD	2	920	1902	3.0	11.6	-8.6
5	765 kV	WARORA-WARANGAL(NEW)	2	793	1996	2.5	12.2	-9.6
6	400 kV	KOLHAPUR-KUDGI	2	2264	0	39.2	0.0	39.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	102	2.0	0.0	2.0
WR-SR						88.4	26.0	62.4

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	881	541	754	18.09	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	882	645	781	18.73	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	108	-53	64	1.53	
	NER	132kV GELEPHU-SALAKATI	57	0	34	0.82	
	NER	132kV MOTANGA-RANGIA	75	0	64	1.54	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-1	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	69	0	59	1.41	
	ER	NEPAL IMPORT (FROM BIHAR)	13	0	3	0.08	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	840	539	706	16.95	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-899	-709	-844	-20.24	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1481	-995	-1203	-28.87	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-75	0	-66	-1.58	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.05	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.05
Bangladesh	20.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.97
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.02	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.02

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.89	0.00	1.61	0.00	0.00	0.07	0.00	0.00	40.57
Nepal	5.47	0.00	11.46	0.00	0.00	0.00	0.00	0.00	16.93
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	44.36	0.00	13.07	0.00	0.00	0.07	0.00	0.00	57.50

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	38.89	0.00	1.61	0.00	0.00	0.07	0.00	0.00	40.57
Nepal	5.42	0.00	11.46	0.00	0.00	0.00	0.00	0.00	16.88
Bangladesh	-20.97	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.97
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	23.34	0.00	13.07	0.00	0.00	0.07	0.00	0.00	36.48