



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 28.06.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 27.06.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 27-जून-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 27.06.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 28-Jun-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	79745	59092	50017	27915	3781	220550
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1778	1355	1182	618	74	5007
Hydro Gen (MU)	384	55	136	92	36	703
Wind Gen (MU)	11	129	253	-	-	392
Solar Gen (MU)*	169.71	93.95	126.40	2.35	0.87	393
Energy Shortage (MU)	0.18	0.00	0.00	0.00	0.00	0.18
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	80721	59993	55004	29281	3748	219561
Time Of Maximum Demand Met	22:38	19:42	07:23	23:21	18:51	20:42

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.081	0.93	4.03	10.20	15.15	67.76	17.09

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15720	0	313.4	197.4	0.2	830	0.00
	Haryana	13351	0	275.9	204.5	0.4	676	0.00
	Rajasthan	13027	0	279.8	117.8	-4.5	658	0.00
	Delhi	7604	0	156.7	142.7	-1.5	313	0.00
	UP	29058	0	589.7	265.4	-0.2	541	0.00
	Uttarakhand	2673	0	56.3	28.5	2.0	354	0.00
	HP	1846	0	39.7	0.2	-0.6	98	0.00
	J&K(UT) & Ladakh(UT)	2672	180	53.9	29.2	-0.1	263	0.18
	Chandigarh	399	0	7.9	7.5	0.4	53	0.00
	Railways NR ISTS	207	0	4.3	3.9	0.4	39	0.00
WR	Chhattisgarh	5225	0	112.3	61.1	-5.4	410	0.00
	Gujarat	17245	0	393.5	192.2	-9.0	965	0.00
	MP	10560	0	225.1	116.0	0.1	968	0.00
	Maharashtra	24827	0	539.8	161.9	-4.7	690	0.00
	Goa	556	0	14.0	12.1	1.6	47	0.00
	DNHDDPDCL	1366	0	31.5	31.9	-0.4	72	0.00
	AMNSIL	888	0	19.9	9.4	0.0	273	0.00
	BALCO	544	0	12.7	12.7	0.0	27	0.00
	RIL JAMNAGAR	251	0	5.7	5.8	-0.1	0	0.00
	Andhra Pradesh	10046	0	212.9	30.7	0.6	860	0.00
SR	Telangana	11492	0	226.4	127.1	-0.2	728	0.00
	Karnataka	12867	0	248.9	63.6	0.4	719	0.00
	Kerala	4004	0	78.3	37.1	-1.6	254	0.00
	Tamil Nadu	18749	0	404.5	158.6	-4.5	970	0.00
	Puducherry	520	0	11.3	10.6	0.1	101	0.00
	Bihar	7612	0	155.3	143.8	0.4	346	0.00
ER	DVC	3627	0	68.2	-38.6	-0.1	343	0.00
	Jharkhand	2055	0	41.3	33.0	-0.4	218	0.00
	Odisha	6057	0	126.8	49.4	-2.2	455	0.00
	West Bengal	10577	0	224.8	94.3	-1.8	210	0.00
	Sikkim	94	0	1.4	1.4	0.0	46	0.00
	Railways ER ISTS	25	0	0.2	0.1	0.0	11	0.00
NER	Arunachal Pradesh	207	0	3.7	3.1	0.3	119	0.00
	Assam	2561	0	50.1	44.4	0.0	1714	0.00
	Manipur	217	0	3.4	3.3	0.0	131	0.00
	Meghalaya	327	0	5.6	-0.2	-0.1	57	0.00
	Mizoram	130	0	2.0	0.9	-0.2	15	0.00
	Nagaland	186	0	3.3	2.9	-0.1	114	0.00
	Tripura	330	0	5.7	5.2	-0.2	221	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	50.2	14.2	-21.1	-26.2
Day Peak (MW)	2412.0	681.3	-1028.0	-1454.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	438.3	-328.3	-4.1	-115.9	10.0	0.0
Actual(MU)	428.8	-332.3	10.9	-113.8	7.8	1.3
OD/UD(MU)	-9.5	-4.0	15.0	2.0	-2.2	1.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4147	8739	6672	3030	390	22977	38
State Sector	7384	13927	12935	3159	199	37604	62
Total	11531	22665	19607	6189	589	60581	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	785	1442	546	704	13	3490	65
Lignite	24	12	50	0	0	86	2
Hydro	384	55	136	92	36	703	13
Nuclear	37	56	59	0	0	152	3
Gas, Naptha & Diesel	25	45	9	0	21	101	2
RES (Wind, Solar, Biomass & Others)	189	224	416	4	1	834	16
Total	1444	1834	1217	800	70	5366	100

Share of RES in total generation (%)	13.10	12.21	34.17	0.51	1.26	15.54
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	42.24	18.28	50.18	12.04	52.03	31.48

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.041
Based on State Max Demands	1.091

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	215643	11:06	0
Non-Solar hr	219561	20:42	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 28-Jun-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	311	0.0	7.3	-7.3
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	486	933	0.0	9.4	-9.4
4	765 kV	SASARAM-FATEHPUR	1	156	551	0.0	6.0	-6.0
5	765 kV	GAYA-BALIA	1	0	895	0.0	14.5	-14.5
6	400 kV	PUSAULI-VARANASI	1	0	102	0.0	1.3	-1.3
7	400 kV	PUSAULI-ALLAHABAD	1	0	92	0.0	1.2	-1.2
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	844	0.0	13.4	-13.4
9	400 kV	PATNA-BALIA	2	0	1013	0.0	14.9	-14.9
10	400 kV	NAUBATPUR-BALIA	2	80	630	0.0	3.1	-3.1
11	400 kV	BIHARSHARIFF-BALIA	2	122	355	0.0	3.8	-3.8
12	400 kV	MOTIHARI-GORAKHPUR	2	0	534	0.0	8.8	-8.8
13	400 kV	BIHARSARIFF-SAHUPURI	2	40	434	0.0	5.7	-5.7
14	220 kV	SAHUPURI-KARAMNASHA	1	0	112	0.0	2.5	-2.5
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	0.6	-93.8
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	602	957	0.0	7.5	-7.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2082	162	30.8	0.0	30.8
3	765 kV	JHARSUGUDA-DURG	2	84	596	0.0	4.9	-4.9
4	400 kV	JHARSUGUDA-RAIGARH	4	259	265	0.0	0.2	-0.2
5	400 kV	RANCHI-SIPAT	2	488	127	6.2	0.0	6.2
6	400 kV	JEYPORE-JAGDALPUR	2	130	426	0.0	4.0	-4.0
7	220 kV	BUDHIPADAR-RAIGARH	1	28	67	0.0	0.3	-0.3
8	220 kV	BUDHIPADAR-KORBA	2	122	1	1.4	0.0	1.4
						ER-WR	38.4	16.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	507	0	10.1	0.0	10.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1758	0.0	36.6	-36.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	3218	0.0	37.5	-37.5
4	400 kV	TALCHER-I/C	2	224	1156	0.0	5.5	-5.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	10.1	-64.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	40	251	2.4	0.0	2.3
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	667	0.0	9.9	-9.9
3	220 kV	ALIPURDUAR-SALAKATI	2	0	123	0.0	1.7	-1.7
						ER-NER	2.4	-9.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.5	-8.5
						NER-NR	0.0	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4042	0.0	60.7	-60.7
2	HVDC	VINDHYACHAL-B/B	-	144	0	3.7	0.0	3.7
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1914	0.0	36.8	-36.8
4	765 kV	GWALIOR-AGRA	2	0	3315	0.0	54.1	-54.1
5	765 kV	GWALIOR-PHAGI	2	224	2149	0.1	30.5	-30.4
6	765 kV	JABALPUR-ORAI	2	0	1521	0.0	55.4	-55.4
7	765 kV	GWALIOR-ORAI	1	760	0	12.4	0.0	12.4
8	765 kV	SATNA-ORAI	1	0	1211	0.0	23.1	-23.1
9	765 kV	BANASKANTHA-CHITORGARH	2	1024	1343	4.8	9.7	-4.9
10	765 kV	VINDHYACHAL-VARANASI	2	0	3554	0.0	63.8	-63.8
11	400 kV	ZERDA-KANKROLI	1	248	228	1.4	1.3	0.1
12	400 kV	ZERDA-BHINMAL	1	171	158	0.9	0.9	0.0
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	279	725	1.0	8.1	-7.1
15	400 kV	NEEMUCH-Chittorgarh	2	257	821	0.6	10.0	-9.4
16	220 kV	BHANPURA-RANPUR	1	0	110	0.0	2.5	-2.5
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.9	-1.9
18	220 kV	MEHGAON-AURAIYA	1	82	58	0.3	0.3	0.0
19	220 kV	MALANPUR-AURAIYA	1	57	66	0.1	0.5	-0.4
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	25.3	-334.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1002	0	14.1	0.0	14.1
2	HVDC	RAIGARH-PUGALUR	2	0	3005	0.0	28.7	-28.7
3	765 kV	SOLAPUR-RAICHUR	2	2422	1415	29.1	1.8	27.3
4	765 kV	WARDHAN-NIZAMABAD	2	430	2773	0.4	15.4	-14.9
5	765 kV	WARORA-WARANGAL(NEW)	2	487	2904	0.8	14.8	-14.0
6	400 kV	KOLHAPUR-KUDGI	2	1975	0	32.1	0.0	32.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	101	2.1	0.0	2.1
						WR-SR	78.6	60.6

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1424	1110	1247	29.94
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	745	556	630	15.12
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	181	93	128	3.07
	NER	132kV GELEPHU-SALAKATI	51	4	40	0.96
	NER	132kV MOTANGA-RANGIA	72	1	48	1.16
NEPAL	NR	NEPAL IMPORT (FROM UP)	-48	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-48	0	-19	-0.46
	ER	NEPAL IMPORT (FROM BIHAR)	132	122	126	3.02
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	541	413	485	11.64
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-978	-440	-844	-20.25
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1454	-813	-1091	-26.19
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	50	0	-37	-0.88

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 28-Jun-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.03	0.00	0.00	0.03
Bangladesh	20.82	0.20	0.00	0.00	0.00	0.00	0.00	0.00	21.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.82	0.20	0.00	0.00	0.00	0.03	0.00	0.00	21.05

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.55	0.00	1.28	0.00	0.00	0.24	0.00	0.00	51.07
Nepal	8.35	0.20	0.00	0.00	0.00	5.69	0.00	0.00	14.24
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	57.90	0.20	1.28	0.00	0.00	5.93	0.00	0.00	65.31

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	49.55	0.00	1.28	0.00	0.00	0.24	0.00	0.00	51.07
Nepal	8.35	0.20	0.00	0.00	0.00	5.66	0.00	0.00	14.21
Bangladesh	-20.82	-0.20	0.00	0.00	0.00	0.00	0.00	0.00	-21.02
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	37.08	0.00	1.28	0.00	0.00	5.90	0.00	0.00	44.26

