



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इंस्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 24.02.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 23.02.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 23-फ़रवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 23.02.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 24-Feb-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	52992	66785	46948	22011	2449	191185
Peak Shortage (MW)	0	0	0	0	20	20
Energy Met (MU)	1163	1615	1303	456	45	4583
Hydro Gen (MU)	94	40	66	21	8	228
Wind Gen (MU)	11	41	51	-	-	103
Solar Gen (MU)*	201.72	134.04	144.47	3.45	0.92	485
Energy Shortage (MU)	0.00	0.00	0.00	0.12	0.19	0.31
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	59037	75307	63163	22735	2454	218010
Time Of Maximum Demand Met	10:18	10:10	09:25	18:54	17:57	09:49

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.00	3.84	3.84	78.19	17.97

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	6972	0	132.4	51.3	-0.5	439	0.00
	Haryana	6791	0	137.9	78.5	-1.1	284	0.00
	Rajasthan	17685	0	338.2	106.7	-1.5	559	0.00
	Delhi	3934	0	68.1	59.5	0.0	328	0.00
	UP	18579	0	343.6	79.5	-1.2	393	0.00
	Uttarakhand	2134	0	39.3	28.8	-0.1	91	0.00
	HP	2040	0	36.1	30.3	-0.7	293	0.00
	J&K(UT) & Ladakh(UT)	2895	0	60.3	58.9	-2.4	674	0.00
	Chandigarh	206	0	3.3	3.4	-0.1	13	0.00
WR	Railways_NR ISTS	207	0	4.3	3.9	0.3	39	0.00
	Chhattisgarh	5973	0	134.7	81.5	-0.2	218	0.00
	Gujarat	22113	0	433.1	215.4	-1.3	828	0.00
	MP	16616	0	338.7	221.3	-3.8	423	0.00
	Maharashtra	27940	0	628.2	214.5	-1.1	594	0.00
	Goa	719	0	15.5	14.1	0.9	40	0.00
	DNHDDPDCL	1289	0	29.8	29.8	0.0	20	0.00
	AMNSIL	765	0	17.4	10.4	-0.1	203	0.00
	BALCO	534	0	12.8	12.7	0.1	12	0.00
SR	RIL JAMNAGAR	194	0	4.7	4.7	0.0	0	0.00
	Andhra Pradesh	12311	0	238.4	63.1	-0.7	507	0.00
	Telangana	15586	0	303.4	176.9	-0.9	944	0.00
	Karnataka	16664	0	312.8	125.4	-1.4	662	0.00
	Kerala	4654	0	88.3	72.7	0.6	256	0.00
	Tamil Nadu	16115	0	351.0	206.2	-1.4	487	0.00
	Puducherry	385	0	9.0	8.7	-0.3	23	0.00
	Bihar	5016	0	97.0	94.4	-4.3	467	0.12
	DVC	3204	0	68.6	-35.5	0.0	429	0.00
ER	Jharkhand	1918	0	36.3	26.3	-1.4	284	0.00
	Odisha	5164	0	106.3	28.4	-1.1	434	0.00
	West Bengal	7074	0	146.7	20.8	-1.8	278	0.00
	Sikkim	94	0	1.5	1.8	-0.3	7	0.00
	Railways_ER ISTS	16	0	0.2	0.3	0.0	0	0.00
	Arunachal Pradesh	162	0	2.5	3.1	-0.6	9	0.00
	Assam	1405	0	28.8	21.7	2.3	110	0.00
NER	Manipur	198	24	2.7	3.0	-0.3	36	0.19
	Meghalaya	318	0	4.7	4.9	-1.0	124	0.00
	Mizoram	100	0	1.4	1.9	-0.8	1	0.00
	Nagaland	161	0	2.0	2.4	-0.4	23	0.00
	Tripura	233	0	3.4	3.6	-0.6	22	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-7.9	-12.9	-23.9	-17.6
Day Peak (MW)	-459.0	-679.0	-1020.0	-767.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	110.3	-191.5	224.9	-150.1	6.4	0.0
Actual(MU)	99.6	-172.8	229.8	-171.9	5.0	-10.3
O/D/U/D(MU)	-10.7	18.7	4.8	-21.8	-1.4	-10.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6086	6854	3248	4306	783	21277	46
State Sector	7983	10040	4517	2659	181	25380	54
Total	14069	16893	7765	6965	964	46656	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	765	1628	715	695	14	3817	76
Lignite	27	16	56	0	0	98	2
Hydro	94	40	66	21	8	228	5
Nuclear	21	51	71	0	0	143	3
Gas, Naptha & Diesel	9	11	4	0	23	47	1
RES (Wind, Solar, Biomass & Others)	239	180	231	7	1	657	13
Total	1155	1926	1143	723	46	4991	100

Share of RES in total generation (%)	20.72	9.32	20.21	0.92	1.82	13.17
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	30.65	14.06	32.17	3.83	19.12	20.61

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.047

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	218010	9:49	9
Non-Solar hr	196405	18:55	51

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 24-Feb-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.6	-2.6
3	765 kV	GAYA-VARANASI	2	0	643	0.0	13.6	-13.6
4	765 kV	SASARAM-FATEHPUR	1	128	526	0.0	7.8	-7.8
5	765 kV	GAYA-BALIA	1	0	440	0.0	10.6	-10.6
6	400 kV	PUSAULI-VARANASI	1	0	150	0.0	2.3	-2.3
7	400 kV	PUSAULI -ALLAHABAD	1	53	51	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	388	591	0.0	3.1	-3.1
9	400 kV	PATNA-BALIA	2	0	936	0.0	14.8	-14.8
10	400 kV	NAUBATPUR-BALIA	2	26	372	0.0	4.6	-4.6
11	400 kV	BIHARSHARIFF-BALIA	2	222	245	0.1	0.0	0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	53	498	0.0	6.7	-6.7
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	0	0.0	3.7	-3.7
14	220 kV	SAHUPURI-KARAMNASA	1	0	36	0.0	0.1	-0.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.6	69.9	-69.3
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1064	222	11.8	0.0	11.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	321	1123	0.0	11.0	-11.0
3	765 kV	JHARSUGUDA-DURG	2	0	1034	0.0	19.8	-19.8
4	400 kV	JHARSUGUDA-RAIGARH	4	0	1008	0.0	16.5	-16.5
5	400 kV	RANCHI-SIPAT	2	102	328	0.0	3.5	-3.5
6	220 kV	BUDHIPADAR-RAIGARH	1	0	110	0.0	1.6	-1.6
7	220 kV	BUDHIPADAR-KORBA	2	66	160	0.0	0.6	-0.6
ER-WR						11.8	52.9	-41.1
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	530	0.0	14.2	-14.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1647	0.0	39.8	-39.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2744	0.0	51.7	-51.7
4	400 kV	TALCHER-I/C	2	0	841	0.0	9.0	-9.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	105.7	-105.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	283	86	2.6	0.3	2.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	506	59	5.8	0.0	5.8
3	220 kV	ALIPURDUAR-SALAKATI	2	123	0	1.9	0.0	1.9
ER-NER						10.3	0.3	10.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	662	0	15.7	0.0	15.7
NER-NR						15.7	0.0	15.7
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	1512	0.0	31.2	-31.2
2	HVDC	VINDHYACHAL B/B	-	477	0	1.2	0.0	1.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1173	0.0	29.0	-29.0
4	765 kV	GWALIOR-AGRA	2	782	1584	3.7	7.9	-4.2
5	765 kV	GWALIOR-PHAGI	2	638	1821	2.0	20.4	-18.4
6	765 kV	JABALPUR-ORAI	2	281	974	0.0	10.5	-10.5
7	765 kV	GWALIOR-ORAI	1	847	0	14.4	0.0	14.4
8	765 kV	SATNA-ORAI	1	0	1024	0.0	16.3	-16.3
9	765 kV	BANASKANTHA-CHITORGARH	2	1833	0	26.3	0.0	26.3
10	765 kV	VINDHYACHAL-VARANASI	2	230	1551	0.0	14.7	-14.7
11	400 kV	ZERDA-KANKROLI	1	323	0	4.6	0.0	4.6
12	400 kV	ZERDA -BHINMAL	1	223	0	3.2	0.0	3.2
13	400 kV	VINDHYACHAL -RIHAND	1	485	0	10.5	0.0	10.5
14	400 kV	RAPP-SHUJALPUR	2	630	305	5.9	0.9	5.1
15	400 kV	NEEMUCH-Chittorgarh	2	692	294	7.1	0.8	6.3
16	220 kV	BHANPURA-RANPUR	1	0	186	0.0	3.2	-3.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.4	-2.4
18	220 kV	MEHGAON-AURAIYA	1	138	0	2.3	0.0	2.3
19	220 kV	MALANPUR-AURAIYA	1	102	0	1.5	0.0	1.5
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						82.8	137.1	-54.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1015	0.0	20.6	-20.6
2	HVDC	RAIGARH-PUGALUR	2	0	4007	0.0	68.2	-68.2
3	765 kV	SOLAPUR-RAICHUR	2	1066	1399	4.0	11.2	-7.2
4	765 kV	WARDHA-NIZAMABAD	2	0	2642	0.0	40.5	-40.5
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2829	0.0	46.4	-46.4
6	400 kV	KOLHAPUR-KUDGI	2	1502	0	21.0	0.0	21.0
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	127	2.4	0.0	2.4
WR-SR						27.4	186.9	-159.4
INTERNATIONAL EXCHANGES								
State	Region		Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)	
BHUTAN	ER		400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	366	4	163	3.92	
	ER		400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-292	68	-139	-3.33	
	ER		220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-386	-212	-320	-7.68	
	NER		132kV GELEPHU-SALAKATI	-19	3	-37	-0.89	
	NER		132kV MOTANGA-RANGIA	9	-3	4	0.09	
NEPAL	NR		NEPAL IMPORT (FROM UP)	-69	0	-52	-1.25	
	NR		132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-69	0	-46	-1.11	
	ER		NEPAL IMPORT (FROM BIHAR)	-210	-86	-162	-3.88	
	ER		400kV DHALKEBAR-MUZAFFARPUR 1&2	-469	-150	-279	-6.69	
BANGLADESH	ER		BHERAMARA B/B HVDC (B'DESH)	-942	-890	-932	-22.36	
	ER (Isolated from Indian Grid)		400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-767	-675	-735	-17.64	
	NER		132kV COMILLA-SURAJMANI NAGAR 1&2	-78	0	-63	-1.52	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	0.35	9.10	0.00	0.00	0.00	0.00	0.00	9.45	
Nepal	4.02	0.00	5.23	0.00	0.00	0.00	2.48	0.00	0.00	11.73
Bangladesh	23.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.17
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.19	0.35	14.33	0.00	0.00	0.00	2.48	0.00	0.00	44.35

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.16
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	1.16	0.00	0.00	0.00	0.00	0.00	0.00	0.00	1.16

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	1.16	-0.35	-9.10	0.00	0.00	0.00	0.00	0.00	-8.29
Nepal	-4.02	0.00	-5.23	0.00	0.00	-2.48	0.00	0.00	-11.73
Bangladesh	-23.17	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.17
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-26.03	-0.35	-14.33	0.00	0.00	-2.48	0.00	0.00	-43.19

