



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 18.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 17.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 17-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 17.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 18-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60886	66490	49227	22694	2804	202101
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1291	1560	1157	462	50	4520
Hydro Gen (MU)	130	44	98	20	11	302
Wind Gen (MU)	5	73	93	-	-	170
Solar Gen (MU)*	173.09	162.43	121.53	2.84	1.03	461
Energy Shortage (MU)	0.18	0.23	0.00	0.00	0.00	0.41
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	69735	76964	57756	23228	2977	226989
Time Of Maximum Demand Met	10:13	10:01	09:45	17:54	17:06	09:55

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.035	0.02	0.83	2.90	3.76	80.55	15.69

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8659	0	163.0	71.9	0.4	513	0.00
	Haryana	9427	0	172.9	122.1	-1.5	400	0.00
	Rajasthan	18084	0	337.0	127.1	1.3	990	0.00
	Delhi	4740	0	81.4	76.1	-0.5	399	0.00
	UP	20430	0	379.2	89.9	0.9	547	0.00
	Uttarakhand	2409	0	45.4	34.7	0.4	244	0.18
	HP	2188	0	38.8	30.9	-0.4	68	0.00
	J&K(UT) & Ladakh(UT)	3212	0	65.6	61.2	-1.0	316	0.00
	Chandigarh	251	0	4.2	4.0	0.1	19	0.00
	Railways_NR ISTS	196	0	4.1	3.7	0.4	32	0.00
WR	Chhattisgarh	5193	0	102.9	37.4	0.1	504	0.23
	Gujarat	22736	0	434.6	189.2	0.7	1051	0.00
	MP	18689	0	346.7	228.5	0.0	820	0.00
	Maharashtra	28315	0	587.3	180.4	1.2	582	0.00
	Goa	727	0	14.1	11.0	2.6	87	0.00
	DNHDDPDCL	1357	0	30.7	30.6	0.1	51	0.00
	AMNSIL	1040	0	23.7	12.1	0.6	305	0.00
	BALCO	579	0	13.8	13.8	0.0	25	0.00
	RIL JAMNAGAR	265	0	6.1	6.1	0.0	0	0.00
	Andhra Pradesh	10695	0	207.8	49.0	-0.5	499	0.00
SR	Telangana	13461	0	238.6	113.2	-0.6	603	0.00
	Karnataka	16202	0	290.5	98.7	1.8	780	0.00
	Kerala	4526	0	85.2	60.8	0.3	377	0.00
	Tamil Nadu	16570	0	326.7	218.1	-5.1	696	0.00
	Puducherry	414	0	8.7	8.2	-0.1	23	0.00
	Bihar	5453	0	100.7	95.4	-1.0	324	0.00
ER	DVC	3231	0	66.9	-40.7	0.0	387	0.00
	Jharkhand	2181	0	41.7	31.0	-2.6	259	0.00
	Odisha	5077	0	96.3	10.8	-1.4	415	0.00
	West Bengal	7855	0	154.5	19.7	-1.8	174	0.00
	Sikkim	119	0	1.9	1.9	0.0	25	0.00
	Railways_ER ISTS	12	0	0.1	0.1	0.0	0	0.00
NER	Arunachal Pradesh	186	0	3.0	3.0	-0.1	10	0.00
	Assam	1657	0	28.1	22.6	-0.7	54	0.00
	Manipur	263	0	3.6	3.8	-0.1	22	0.00
	Meghalaya	355	0	6.1	5.3	-0.1	28	0.00
	Mizoram	150	0	2.2	1.9	-0.2	12	0.00
	Nagaland	167	0	2.7	2.7	-0.2	14	0.00
	Tripura	233	0	3.9	4.8	-0.4	19	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-9.6	2.8	-22.9	-24.0
Day Peak (MW)	-809.5	435.5	-1054.3	-1434.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	231.8	-224.4	164.8	-183.4	11.2	0.0
Actual(MU)	227.4	-212.2	152.5	-190.4	7.6	-15.2
O/D/U/D(MU)	-4.4	12.2	-12.3	-7.0	-3.6	-15.2

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5739	11785	6938	4710	114	29286	46
State Sector	11409	11356	8494	2787	205	34250	54
Total	17148	23140	15432	7497	319	63536	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	753	1521	591	716	13	3595	74
Lignite	24	18	49	0	0	91	2
Hydro	130	44	98	20	11	302	6
Nuclear	33	52	43	0	0	128	3
Gas, Naptha & Diesel	12	26	4	0	22	64	1
RES (Wind, Solar, Biomass & Others)	204	238	243	7	1	692	14
Total	1157	1899	1027	743	47	4873	100

Share of RES in total generation (%)	17.64	12.51	23.63	0.93	2.22	14.21
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	31.74	17.56	37.34	3.64	24.48	23.04

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.045

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	226989	9:55	0
Non-Solar hr	209786	18:21	178

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 18-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	124	1170	0.0	15.7	-15.7
4	765 kV	SASARAM-FATEHPUR	1	0	708	0.0	5.6	-5.6
5	765 kV	GAYA-BALIA	1	0	753	0.0	10.7	-10.7
6	400 kV	PUSAULI-VARANASI	1	155	0	1.7	0.0	1.7
7	400 kV	PUSAULI-ALLAHABAD	1	0	150	0.0	1.7	-1.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	153	569	0.0	5.0	-5.0
9	400 kV	PATNA-BALIA	2	0	1049	0.0	14.8	-14.8
10	400 kV	NAUBATPUR-BALIA	2	0	449	0.0	4.4	-4.4
11	400 kV	BIHARSHARIFE-BALIA	2	312	239	0.0	0.1	-0.1
12	400 kV	MOTIHARI-GORAKHPUR	2	0	569	0.0	8.7	-8.7
13	400 kV	BIHARSARIFE-SAHUPURI	2	37	493	0.0	6.0	-6.0
14	220 kV	SAHUPURI-KARMANASA	1	0	45	0.0	1.1	-1.1
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	27	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	23	0.0	0.2	-0.2
ER-NR						2.3	73.9	-71.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	153	1239	0.0	11.9	-11.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	891	958	0.0	4.8	-4.8
3	765 kV	JHARSUGUDA-DURG	2	0	1389	0.0	24.5	-24.5
4	400 kV	JHARSUGUDA-RAIGARH	4	449	212	0.0	2.8	-2.8
5	400 kV	RANCHI-SIPAT	2	187	296	0.0	1.7	-1.7
6	400 kV	JEYPORE-JAGDALPUR	2	656	0	9.2	0.0	9.2
7	220 kV	BUDHIPADAR-RAIGARH	1	0	138	0.0	1.3	-1.3
8	220 kV	BUDHIPADAR-KORBA	2	50	68	0.1	0.0	0.1
ER-WR						9.3	47.1	-37.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	727	0.0	17.3	-17.3
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1622	0.0	44.6	-44.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	3025	0.0	44.2	-44.2
4	400 kV	TALCHER-I/C	2	0	1003	0.0	11.8	-11.8
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	0	0.0	0.0	0.0
ER-SR						0.0	106.1	-106.1
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	174	389	0.3	4.7	-4.4
2	400 kV	ALIPURDUAR-BONGAIGAON	2	356	518	0.0	4.0	-4.0
3	220 kV	ALIPURDUAR-SALAKATI	2	51	97	0.0	0.7	-0.7
ER-NER						0.3	9.4	-9.1
Import/Export of <null> (With <null>)								
No Records Found								
NER-NR						0.0	0.0	0.0
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3532	0.0	80.4	-80.4
2	HVDC	VINDHYACHAL B/B	-	1047	0	12.2	0.0	12.2
3	HVDC	MUNDRA-MOHINDERGARH	2	0	983	0.0	19.7	-19.7
4	765 kV	GWALIOR-AGRA	2	258	1767	0.0	16.3	-16.3
5	765 kV	GWALIOR-PHAGI	2	274	2109	0.0	30.3	-30.3
6	765 kV	JABALPUR-ORAI	2	0	1186	0.0	30.4	-30.4
7	765 kV	GWALIOR-ORAI	1	1208	0	20.9	0.0	20.9
8	765 kV	SATNA-ORAI	1	0	1443	0.0	25.5	-25.5
9	765 kV	BANASKANTHA-CHITORGARH	2	2543	0	26.2	0.0	26.2
10	765 kV	VINDHYACHAL-VARANASI	2	0	2518	0.0	43.4	-43.4
11	400 kV	ZERDA-KANKROLI	1	0	0	0.0	0.0	0.0
12	400 kV	ZERDA-BHINMAL	1	0	0	0.0	0.0	0.0
13	400 kV	VINDHYACHAL -RIHAND	1	967	0	21.6	0.0	21.6
14	400 kV	RAPP-SHUJALPUR	2	544	345	3.3	1.8	1.5
15	400 kV	NEEMUCH-Chittorgarh	2	594	384	1.4	0.0	1.4
16	220 kV	BHANPURA-RANPUR	1	0	135	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3
18	220 kV	MEHGAON-AURAIYA	1	165	6	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	128	18	0.9	0.0	0.9
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						88.0	251.3	-163.3
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1008	0.0	24.0	-24.0
2	HVDC	RAIGARH-PUGALUR	2	0	4008	0.0	43.5	-43.5
3	765 kV	SOLAPUR-RAICHUR	2	1001	1122	5.7	3.2	2.5
4	765 kV	WARDHA-NIZAMABAD	2	150	2287	0.0	21.8	-21.8
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2659	0.0	30.7	-30.7
6	400 kV	KOLHAPUR-KUDGI	2	1791	0	29.8	0.0	29.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	117	2.2	0.0	2.2
WR-SR						37.7	123.1	-85.4
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 L.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	-182	23	-90	-2.17		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) L.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	286	-200	32	0.76		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) L.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-321	-242	-285	-6.85		
	NER	132kV GELEPHU-SALAKATI	-53	-35	-43	-1.03		
	NER	132kV MOTANGA-RANGIA	-20	-5	-14	-0.33		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-23	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	34	0	12	0.29		
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	337	-184	103	2.46		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-920	-634	-847	-20.33		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1435	-819	-999	-23.97		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-132	0	-105	-2.52		

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 18-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	11.37	0.00	0.00	0.00	0.00	0.00	11.68
Nepal	0.08	0.00	0.00	0.00	0.00	0.72	0.00	0.00	0.80
Bangladesh	21.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	21.11
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	21.19	0.31	11.37	0.00	0.00	0.72	0.00	0.00	33.59

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.13
Nepal	0.00	0.00	0.00	0.00	0.00	3.95	0.00	0.00	3.95
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.13	0.00	0.00	0.00	0.00	3.95	0.00	0.00	4.08

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.13	-0.31	-11.37	0.00	0.00	0.00	0.00	0.00	-11.55
Nepal	-0.08	0.00	0.00	0.00	0.00	3.23	0.00	0.00	3.15
Bangladesh	-21.11	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-21.11
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.06	-0.31	-11.37	0.00	0.00	3.23	0.00	0.00	-29.51

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	49.99	151648	4995	10565	0	6984	2112	129127	3194	141083	156977	-1118
0:15	49.99	151529	4999	10534	0	7474	2116	128699	3203	140995	157025	-1324
0:30	49.94	150983	5000	10474	0	7821	2102	127805	3187	140509	156389	-1289
0:45	49.94	150612	5004	10280	0	7831	2114	127806	3209	140332	156244	-1231
1:00	49.94	149883	5000	10127	0	7679	2291	127418	3210	139756	155725	-1216
1:15	49.94	148570	4999	10007	0	7585	2119	126372	3239	138563	154321	-1259
1:30	49.94	148197	4999	9916	0	7575	2116	125988	3198	138281	153792	-1252
1:45	49.99	147692	5006	9701	0	7753	2111	125560	3256	137991	153387	-1267
2:00	50.05	146512	4995	9399	0	7797	2105	124508	3186	137113	151990	-1243
2:15	49.94	146790	5006	9235	0	7602	2119	125313	3214	137555	152489	-1293
2:30	49.94	146650	4988	9091	0	7639	2105	125358	3239	137559	152420	-1325
2:45	49.94	147094	4993	8842	0	7453	2104	126327	3212	138252	152931	-1257
3:00	50.00	146500	5012	8607	0	7526	2126	125757	3238	137893	152266	-1247
3:15	50.00	147063	4996	8369	0	7384	2113	126640	3256	138694	152758	-1200
3:30	50.00	147450	5017	8208	0	7492	2090	127139	3241	139242	153187	-1186
3:45	50.05	147895	5014	8085	0	7529	2257	127811	3219	139810	153915	-1210
4:00	50.05	148498	5007	7943	0	7732	2108	128460	3249	140555	154499	-1178
4:15	50.00	150175	5007	7847	0	7945	2174	129778	3183	142328	155934	-1161
4:30	50.00	152258	5006	7879	0	7991	2165	131734	3206	144379	157981	-1144
4:45	50.05	153683	5011	7896	0	8284	2185	133489	3230	145787	160095	-1289
5:00	50.10	155993	5016	7836	58	9047	2154	134893	3219	148099	162223	-1373
5:15	50.05	161464	4968	7874	58	9933	2330	138935	3239	153532	167337	-1249
5:30	50.05	166170	4880	7849	58	10849	2541	142734	3304	158263	172215	-1255
5:45	50.00	170870	4794	7786	58	11223	2842	146528	3347	163026	176578	-912
6:00	50.10	175525	4799	7820	54	12546	3120	149583	3329	167651	181251	-661
6:15	50.04	181865	4794	7841	125	14903	3248	153179	3270	173899	187360	-569
6:30	50.04	189558	4800	7912	128	19031	3407	156406	3307	181518	194991	-561
6:45	49.99	195525	4804	7888	231	21574	3531	159596	3267	187406	200891	-695
7:00	49.99	200295	4804	7848	580	23469	3586	162162	3297	191867	205746	-778
7:15	49.94	205222	4808	7880	1451	24923	4123	164010	3268	195891	210473	-747
7:30	49.94	209469	4787	8015	3147	25542	4211	165526	3292	198307	214520	-753
7:45	50.04	210920	4808	8217	5656	25273	3860	164702	3287	197047	215803	-835
8:00	50.04	211097	4808	8258	9765	22123	3417	164238	3295	193074	215904	-809
8:15	50.04	213503	4807	8177	15025	19876	2291	164893	3199	190301	218268	-800
8:30	50.04	215206	4810	7797	20508	17820	2259	163057	3244	186901	219495	-829
8:45	50.14	216535	4805	7559	26946	15454	2220	160460	3217	182030	220661	-808
9:00	50.20	217400	4800	7176	33012	13619	2119	157141	3230	177212	221097	-818
9:15	50.04	222972	4807	7031	39565	12536	2276	157429	3206	176376	226850	-886
9:30	50.05	224874	4781	6777	44548	11460	2100	156038	3213	173549	228917	-1245
9:45	50.05	226471	4774	6333	48565	11142	2115	154610	3200	171573	230739	-1555
10:00	50.05	226527	4759	6062	51905	9864	2098	152604	3235	168560	230527	-1558
10:15	50.00	226500	4760	5668	55351	8449	2104	151043	3202	165481	230577	-1699
10:30	50.00	225716	4761	5241	58347	8442	2116	148072	3223	162128	230202	-1814
10:45	49.95	224563	4757	4781	60624	8093	2088	145317	3246	159158	228906	-1871
11:00	50.05	223183	4762	4484	61948	7925	2083	142630	3237	156751	227069	-1865
11:15	49.99	221266	4778	4383	63288	7195	2062	140015	3180	153595	224901	-1945
11:30	49.95	220105	4765	4231	64210	6351	2066	139348	3171	151664	224142	-1915
11:45	49.95	218867	4752	4105	65539	5999	2064	137012	3196	149223	222667	-1741
12:00	49.95	217098	4741	3956	65927	6324	2064	135051	3199	147215	221262	-1697
12:15	49.96	214981	4740	3864	66342	6073	2063	132696	3218	144775	218996	-1698
12:30	49.96	213617	4752	3847	66435	6140	2065	131353	3210	143335	217802	-1724
12:45	49.96	212376	4744	3837	66609	6079	2062	130321	3205	141930	216857	-1697
13:00	49.91	209786	4748	3840	66197	5968	2059	128240	3234	139749	214286	-1693
13:15	50.11	206136	4738	3777	65888	5975	2055	124877	3261	136471	210571	-1806
13:30	50.06	205526	4747	3701	64916	6122	2054	125279	3220	136909	210039	-1847
13:45	50.01	205856	4806	3642	64307	6115	2058	126261	3214	137907	210403	-1796
14:00	50.06	206092	4812	3544	62976	6135	2053	127899	3181	139572	210600	-1791
14:15	50.01	206129	4814	3489	61829	5876	2056	129294	3244	140811	210602	-1799
14:30	50.01	207814	4800	3301	60059	6337	2043	132487	3189	144454	212216	-1821
14:45	49.96	208517	4810	3223	58081	6625	2053	134524	3164	147213	212480	-1816
15:00	50.01	209676	4814	3318	56101	7204	2047	137270	3231	150257	213985	-1852
15:15	49.96	206998	4812	3292	50860	7916	2070	134327	3147	152846	206424	-1721
15:30	49.96	208058	4806	3168	49242	8460	2291	141253	3264	155648	212484	-1718
15:45	49.96	209084	4817	3077	45210	9400	2605	144983	3257	160797	213349	-1710
16:00	50.01	209473	4804	3148	40396	11504	2914	147836	3331	165929	213933	-1639
16:15	49.91	206546	4819	3259	34418	12060	3255	149729	3277	168869	210817	-1460
16:30	49.81	206862	4007	3333	27637	14035	3626	154916	3251	175892	210805	-1147
16:45	49.96	206106	4820	3512	20757	15315	4082	159106	3332	181837	210924	-1013
17:00	49.91	207013	4821	3751	14241	18417	4396	163096	3294	189021	212016	-967
17:15	49.86	205981	4820	4051	9308	21669	4559	164000	3299	192622	211706	-928
17:30	50.01	207691	4826	4184	4289	25721	4915	164564	3306	199218	211805	-910
17:45	49.71	208536	4836	3762	1866	27455	5095	166612	3345	202908	212971	-876
18:00	50.01	209196	4820	4770	747	28444	5047	167026	3326	203679	214180	-839
18:15	49.91	209341	4768	5154	454	29246	5015	166334	3291	203733	214262	-808
18:30	49.91	209527	4763	5612	290	29911	4649	166195	3292	203625	214712	-812
18:45	50.01	208757	4828	5952	218	29483	4152	165940	3366	202587	213939	-795
19:00	50.01	207755	4839	6326	308	28805	3444	165557	3300	201121	212579	-800
19:15	50.06	205202	4835	6722	223	27182	3383	164407	3312	198257	210064	-796
19:30	50.01	202072	4828	7121	0	23786	3368	164439	3371	194951	206913	-782
19:45	49.96	198945	4843	7440	0	22411	2156	163662	3292	191505	203804	-767
20:00	50.06	194559	4855	7712	0	19566	2119	162259	3324	186847	199835	-740
20:15	50.01	191095	4837	8007	0	17093	2110	160791	3312	183088	196150	-728
20:30	50.01	187641	4851	8042	0	15518	2108	158782	3379	179599	192680	-705
20:45	50.01	185538	4858	8115	0	14309	2111	158010	3347	177423	190750	-753
21:00	50.06	182287	4857	8178	0	13280	2100	155897	3365	174109	187677	-743
21:15	50.06	179128	4855	8199	0	11556	2102	154195	3370	170929	184277	-760
21:30	50.05	176251	4855	8259	0	10697	2103	152422	3312	167992	181648	-759
21:45	50.00	173016	4859	8210	0	9671	2105	150421	3358	164806	178624	-982
22:00	50.05	168621	4852	8039	0	8917	2109	147208	3329	160582	174454	-1181
22:15	50.00	168480	4861	8028	0	8686	2112	147317	3337	160452	174341	-1198
22:30	50.05	167144	4855	8125	0	8330	2105	145993	3356	159019	172764	-1163
22:45	50.00	165238	4859									