



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 28.03.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 27.03.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 27-मार्च-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 27.03.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 28-Mar-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	59555	71104	55344	26770	2962	215735
Peak Shortage (MW)	221	0	0	0	0	221
Energy Met (MU)	1241	1665	1438	572	57	4973
Hydro Gen (MU)	135	50	99	28	11	323
Wind Gen (MU)	46	92	29	-	-	167
Solar Gen (MU)*	216.11	149.37	139.08	4.21	1.02	510
Energy Shortage (MU)	1.65	0.41	0.00	0.39	0.16	2.61
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	58799	73908	68542	27744	3200	224229
Time Of Maximum Demand Met	19:50	10:53	15:31	18:56	18:28	10:19

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.028	0.00	0.06	4.85	4.91	82.06	13.03

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8069	0	167.8	73.2	0.3	546	0.00
	Haryana	7657	0	159.8	107.9	-0.2	249	0.00
	Rajasthan	14226	0	287.6	48.4	-7.8	536	0.00
	Delhi	4362	0	89.8	81.2	-0.1	262	0.00
	UP	21176	76	395.9	101.6	-1.7	769	1.65
	Uttarakhand	2093	0	42.8	31.1	0.5	244	0.00
	HP	1791	0	34.5	21.9	-0.5	416	0.00
	J&K(UT) & Ladakh(UT)	2780	0	54.5	50.7	-4.1	446	0.00
	Chandigarh	209	0	4.0	4.0	0.0	22	0.00
	Railways_NR ISTS	205	0	4.3	3.8	0.4	42	0.00
	Chhattisgarh	6478	0	150.6	85.1	3.2	541	0.00
	Gujarat	23119	0	474.3	192.0	-5.9	369	0.00
WR	MP	14052	249	281.3	154.7	-3.6	516	0.41
	Maharashtra	29434	0	674.1	243.6	0.1	495	0.00
	Goa	784	0	16.6	15.8	0.2	51	0.00
	DNHDDPDCL	1345	0	31.4	31.7	-0.3	50	0.00
	AMNSIL	746	0	17.3	10.1	0.1	236	0.00
	BALCO	534	0	12.8	12.7	0.1	115	0.00
	RIL JAMNAGAR	268	0	6.4	6.5	-0.1	0	0.00
	Andhra Pradesh	12927	0	255.0	79.8	1.2	713	0.00
	Telangana	16168	0	324.5	166.8	1.3	763	0.00
	Karnataka	16585	0	332.7	137.2	-1.6	1026	0.00
SR	Kerala	4962	0	97.4	78.3	0.1	171	0.00
	Tamil Nadu	19372	0	418.2	267.4	0.1	694	0.00
	Puducherry	448	0	10.3	9.8	-0.1	49	0.00
	Bihar	6022	0	118.1	110.3	1.1	307	0.39
	DVC	3262	0	71.4	-35.0	-0.8	333	0.00
	Jharkhand	2128	0	41.4	30.5	0.1	342	0.00
	Odisha	5719	0	117.4	34.7	-1.4	499	0.00
ER	West Bengal	10201	0	221.9	73.8	-2.0	312	0.00
	Sikkim	101	0	1.7	1.8	-0.1	10	0.00
	Railways_ER ISTS	25	0	0.2	0.2	0.0	0	0.00
	Arunachal Pradesh	174	0	3.0	3.0	0.0	28	0.00
	Assam	1961	0	35.5	28.9	0.6	105	0.00
	Manipur	150	0	2.6	2.7	-0.1	40	0.16
	Meghalaya	351	0	6.1	4.8	-0.1	50	0.00
NER	Mizoram	143	0	2.2	1.8	0.0	21	0.00
	Nagaland	159	0	2.5	2.5	0.0	23	0.00
	Tripura	313	0	5.3	4.3	0.1	50	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-3.8	-12.3	-23.3	-31.0
Day Peak (MW)	-243.0	-836.1	-988.0	-1580.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	52.8	-239.2	263.6	-92.2	15.1	0.0
Actual(MU)	24.9	-232.7	283.9	-90.7	15.0	0.5
O/D/U/D(MU)	-27.9	6.5	20.4	1.5	0.0	0.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3383	6869	2422	3395	586	16656	43
State Sector	8499	7260	4366	1882	139	22145	57
Total	11882	14129	6788	5277	725	38801	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	821	1646	780	732	10	3988	74
Lignite	28	14	48	0	0	90	2
Hydro	135	50	99	28	11	323	6
Nuclear	30	57	76	0	0	162	3
Gas, Naptha & Diesel	10	31	9	0	25	75	1
RES (Wind, Solar, Biomass & Others)	278	245	213	6	1	743	14
Total	1302	2043	1225	766	48	5383	100

Share of RES in total generation (%)	21.35	12.01	17.36	0.82	2.17	13.81
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	33.99	17.26	31.64	4.43	26.22	22.83

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.035
Based on State Max Demands	1.072

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	224229	10:19	18
Non-Solar hr	214112	19:26	221

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 28-Mar-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)	
Import/Export of ER (With NR)									
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0	
2	HVDC	PUSAULI B/R	-	0	47	0.0	1.4	-1.4	
3	765 kV	GAYA-VARANASI	2	1044	394	2.0	0.0	2.0	
4	765 kV	SASARAM-FATEHPUR	1	4	362	0.0	3.0	-3.0	
5	765 kV	GAYA-BALIA	1	97	338	0.0	3.7	-3.7	
6	400 kV	PUSAULI-VARANASI	1	0	170	0.0	2.9	-2.9	
7	400 kV	PUSAULI-LALLAHABAD	1	81	34	0.5	0.0	0.5	
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	829	300	3.1	0.0	3.1	
9	400 kV	PATNA-BALIA	2	292	626	0.0	6.6	-6.6	
10	400 kV	NAUBATPUR-BALIA	2	136	298	0.0	2.3	-2.3	
11	400 kV	BIHARSHARIEF-BALIA	2	613	46	3.5	0.0	3.5	
12	400 kV	MOTIHARI-GORAKHPUR	2	279	356	0.0	2.4	-2.4	
13	400 kV	BIHARSARIEFF-SAHUPURI	2	0	0	6.2	0.0	6.2	
14	220 kV	SAHUPURI-KARAMNASA	1	23	64	0.0	0.7	-0.7	
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0	
16	132 kV	GARWAH-RIHAND	1	30	0	0.4	0.0	0.4	
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0	
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0	
						ER-NR	15.8	22.9	-7.1
Import/Export of ER (With WR)									
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	936	451	5.1	0.0	5.1	
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	943	842	2.2	0.0	2.2	
3	765 kV	JHARSUGUDA-DURG	2	0	1300	0.0	23.8	-23.8	
4	400 kV	JHARSUGUDA-RAIGARH	4	0	732	0.0	12.2	-12.2	
5	400 kV	RANCHI-SIPAT	2	204	315	0.0	1.6	-1.6	
6	220 kV	BUDHIPADAR-RAIGARH	1	0	127	0.0	1.9	-1.9	
7	220 kV	BUDHIPADAR-KORBA	2	37	82	0.0	0.8	-0.8	
						ER-WR	7.4	40.4	-33.1
Import/Export of ER (With SR)									
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	733	0.0	17.4	-17.4	
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1014	0.0	24.2	-24.2	
3	765 kV	ANGUL-SRIKAKULAM	2	0	3392	0.0	60.5	-60.5	
4	400 kV	TALCHER-I/C	2	841	0	17.5	0.0	17.5	
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0	
						ER-SR	0.0	102.1	-102.1
Import/Export of ER (With NER)									
1	400 kV	BINAGURI-BONGAIGAON	2	246	131	2.7	0.3	2.4	
2	400 kV	ALIPURDUAR-BONGAIGAON	2	429	147	4.8	0.0	4.8	
3	220 kV	ALIPURDUAR-SALAKATI	2	84	15	1.1	0.0	1.1	
						ER-NER	8.6	0.3	8.3
Import/Export of NER (With NR)									
1	HVDC	BISWANATH CHARIAL-AGRA	2	955	0	23.1	0.0	23.1	
						NER-NR	23.1	0.0	23.1
Import/Export of WR (With NR)									
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2017	0.0	35.9	-35.9	
2	HVDC	VINDHYACHAL B/R	-	49	56	0.4	0.8	-0.4	
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1454	0.0	33.3	-33.3	
4	765 kV	GWALIOR-AGRA	2	733	1664	2.7	9.2	-6.6	
5	765 kV	GWALIOR-PHAGI	2	1452	1096	7.8	9.4	-1.7	
6	765 kV	JABALPUR-ORAI	2	483	733	0.0	3.7	-3.7	
7	765 kV	GWALIOR-ORAI	1	654	0	0.0	9.9	-9.9	
8	765 kV	SATNA-ORAI	1	0	959	0.0	14.4	-14.4	
9	765 kV	BANASKANTHA-CHITORGARH	2	1951	0	28.6	0.0	28.6	
10	765 kV	VINDHYACHAL-VARANASI	2	0	2524	0.0	33.1	-33.1	
11	400 kV	ZERDA-KANKROLI	1	454	0	6.8	0.0	6.8	
12	400 kV	ZERDA-BHINMAL	1	318	0	4.7	0.0	4.7	
13	400 kV	VINDHYACHAL -RIHAND	1	966	0	21.6	0.0	21.6	
14	400 kV	RAPP-SHUJALPUR	2	825	87	9.7	0.1	9.7	
15	400 kV	NEEMUCH-Chitorgarh	2	766	219	8.3	0.5	7.8	
16	220 kV	BHANPURA-RANPUR	1	0	154	0.0	2.6	-2.6	
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.3	-1.3	
18	220 kV	MEHGAON-AURAIYA	1	112	0	1.3	0.0	1.3	
19	220 kV	MALANPUR-AURAIYA	1	90	3	0.9	0.0	0.9	
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0	
21	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0	
						WR-NR	102.7	144.3	-41.6
Import/Export of WR (With SR)									
1	HVDC	BHADRAWATI B/R	-	0	1006	0.0	24.0	-24.0	
2	HVDC	RAIGARH-PUGAULUR	2	0	6629	0.0	112.9	-112.9	
3	765 kV	SOJAPUR-RAIGARH	2	344	1536	0.6	16.6	-16.0	
4	765 kV	WARDHA-NIZAMABAD	2	0	3194	0.0	47.6	-47.6	
5	765 kV	WARORA-WARANGAL (NEW)	2	0	3097	0.0	49.7	-49.7	
6	400 kV	KOLHAPUR-KUDGI	2	1305	0	19.4	0.0	19.4	
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0	
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0	
9	220 kV	XELDEM-AMBEWADI	1	0	118	2.3	0.0	2.3	
						WR-SR	22.2	250.8	-228.5
INTERNATIONAL EXCHANGES									
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)			
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	290	60	179	4.29			
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-288	40	-126	-3.03			
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-228	-113	-202	-4.85			
	NER	132kV GELEPHU-SALAKATI	-23	-6	-14	-0.33			
	NER	132kV MOTANGA-RANGIA	24	-7	7	0.17			
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-50	-1.21			
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-34	-0.82			
	ER	NEPAL IMPORT (FROM BIHAR)	-285	-4	-172	-4.14			
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-551	19	-254	-6.10			
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-944	-912	-935	-22.44			
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1580	-1008	-1293	-31.04			
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-44	0	-35	-0.84			

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 28-Mar-2025

Export From India (in MU)

Export From India (in M\$)		T-GNA							TOTAL
Country	GNA (ISGS/PPA)	BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.39	6.91	0.00	0.00	0.00	0.00	0.00	7.30
Nepal	4.18	0.00	3.90	0.00	0.00	2.67	0.00	0.00	10.75
Bangladesh	23.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	23.07
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	27.25	0.39	10.81	0.00	0.00	2.67	0.00	0.00	41.12

Import by India(in MU)

Import by India(in MU)									
Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.53
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	3.53	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.53

Net from India(in MU)

-ve : Export / +ve : Import

Net from India(In mC)									-ve : Export / +ve : Import
Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.53	-0.39	-6.91	0.00	0.00	0.00	0.00	0.00	-3.77
Nepal	-4.18	0.00	-3.90	0.00	0.00	-2.67	0.00	0.00	-10.75
Bangladesh	-23.07	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-23.07
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.72	-0.39	-10.81	0.00	0.00	-2.67	0.00	0.00	-37.59

Date of Reporting: 28-Mar-2025

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSMISSIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	196050	5828	9091	505	12478	2518	165226	2244	186454	197890	-1001
0:15	50.00	195349	5842	8806	510	10999	2286	167000	2235	186033	197678	-1282
0:30	50.00	194762	5821	8670	512	11051	2218	166734	2267	185580	197273	-1346
0:45	50.00	194115	5855	8540	516	10894	2213	166354	2172	185059	196544	-1305
1:00	50.05	192821	5862	8343	520	10646	2208	165558	2189	183958	195326	-1299
1:15	50.05	191462	5858	8270	518	9627	2211	165212	2187	182674	193883	-1326
1:30	50.00	190315	5877	8275	516	8955	2214	164673	2155	181524	192665	-1330
1:45	50.05	189640	5851	8154	518	8467	2212	164393	2199	180968	191794	-1327
2:00	50.05	188003	5849	8053	517	7928	2202	163462	2187	179433	190198	-1322
2:15	50.00	187924	5842	8012	515	7902	2228	163351	2200	179397	190050	-1310
2:30	50.05	187287	5861	7914	513	8049	2223	162573	2174	178860	189307	-1321
2:45	50.05	186497	5873	7854	511	7876	2223	162083	2188	178132	188608	-1314
3:00	50.05	185582	5917	7883	506	7881	2208	161122	2170	177193	187687	-1309
3:15	50.00	185641	5974	7849	496	7822	2219	161082	2164	177296	187606	-1364
3:30	50.00	185380	5967	7740	494	7736	2216	160990	2161	177146	187304	-1383
3:45	50.00	185626	5977	7746	497	7781	2221	160986	2213	177383	187421	-1368
4:00	50.05	185868	6065	7725	497	8106	2211	160956	2230	177646	187790	-1384
4:15	50.00	187552	6103	7917	498	8527	2218	161662	2224	179137	189149	-1322
4:30	50.05	188076	6126	8087	499	8831	2209	161777	2211	179490	189740	-1222
4:45	50.05	188855	6170	8253	498	8873	2215	162089	2225	180104	190323	-1063
5:00	50.00	189440	6183	8280	495	9226	2228	162173	2275	180665	190860	-1053
5:15	50.00	191116	6169	8238	505	10397	2223	162598	2222	182373	192352	-1070
5:30	50.05	193122	6241	8216	502	11102	2231	163866	2246	184404	194404	-1037
5:45	50.05	194531	6260	8081	491	12249	2275	164210	2323	185959	195889	-1076
6:00	50.05	195277	6287	7965	476	13189	2296	164157	2329	186836	196609	-1226
6:15	50.00	196428	6254	7853	821	15722	2309	165203	2360	189754	200422	-1460
6:30	50.06	202456	6304	7540	1074	19476	2308	165554	2363	193842	204619	-1434
6:45	50.00	203942	6298	7606	1878	20223	2355	165474	2381	194458	206115	-1591
7:00	50.05	203780	6323	7517	3472	20226	2349	163768	2383	192791	206138	-1584
7:15	50.00	204516	6323	7289	6506	20263	2356	161768	2246	190721	206751	-1565
7:30	50.05	205042	6318	6984	10531	19575	2326	159069	2320	187527	207123	-1568
7:45	50.05	206121	6362	6497	15337	18304	2336	156904	2355	184287	208095	-1551
8:00	50.05	207077	6345	5796	20949	16595	2323	154185	2349	180332	208542	-1609
8:15	50.00	210231	6318	4866	26575	15975	2309	153269	2417	178790	211729	-1786
8:30	50.00	211713	6300	4248	31826	14072	2292	152015	2342	175639	213095	-1906
8:45	50.00	213337	6352	4236	36765	12203	2282	150583	2423	172336	214844	-1918
9:00	50.06	215105	6374	4461	41306	11264	2260	148717	2394	169338	216776	-1928
9:15	49.96	219034	6303	4454	45360	10223	2224	149573	2401	169220	220538	-1988
9:30	50.01	220814	6303	4322	48849	10006	2207	148443	2413	167643	222543	-1990
9:45	50.01	222145	6292	4220	51884	10087	2208	146700	2450	166041	223841	-1981
10:00	50.01	223008	6339	4158	55090	9771	2196	144853	2451	163760	224858	-1972
10:15	49.96	223803	6320	3993	57820	9350	2266	143196	2441	161990	225386	-1931
10:30	49.96	223493	6327	3779	59741	9100	2268	141830	2397	159973	225442	-1958
10:45	49.91	223929	6264	3641	61232	9018	2306	140819	2426	159056	225706	-1955
11:00	50.01	223314	6351	3514	62544	8970	2356	139102	2467	157256	225304	-1912
11:15	50.00	222241	6352	3531	63457	8375	2410	137875	2436	155253	224436	-1928
11:30	50.00	221425	6258	3595	64010	8243	2470	136612	2391	153820	223579	-1893
11:45	49.95	220413	6338	3502	64407	8279	2518	135008	2451	152504	222503	-1922
12:00	50.00	219850	6356	3384	64416	8142	2549	134640	2434	152050	221921	-1917
12:15	49.95	218588	6358	3357	64432	7794	2599	133855	2454	150799	220849	-1900
12:30	50.00	217382	6348	3088	64416	7835	2829	132350	2466	149878	219332	-1863
12:45	50.00	216139	5229	3097	64180	7990	2926	131492	2439	148862	217353	-1857
13:00	50.05	213696	6312	3148	63802	7837	2975	129335	2431	146746	215840	-1865
13:15	49.95	209407	6333	3271	63381	7777	3040	126255	2391	142755	212448	-1846
13:30	50.00	210298	6305	3377	62799	7752	3109	127091	2417	144122	212850	-1891
13:45	49.95	211213	6309	3570	62321	7688	3124	128656	2354	145322	214022	-1916
14:00	49.95	211655	6219	3739	61823	7866	3125	129331	2374	146093	214477	-1862
14:15	49.95	212291	6156	3952	60889	7861	3146	130647	2354	147450	215005	-1868
14:30	49.95	213337	6234	4095	59532	8267	3161	132466	2353	149710	216108	-1965
14:45	49.95	214161	6237	4237	57855	8449	3170	134431	2313	152069	216692	-1948
15:00	50.01	215177	6242	4379	56429	8709	3177	136096	2273	154369	217305	-1956
15:15	49.90	214646	6242	4410	53748	8659	3208	138724	2254	156488	217245	-1979
15:30	49.90	216183	6256	4561	50560	8869	3222	142838	2238	161062	218544	-1871
15:45	49.85	216408	6388	4843	47000	9693	3254	145303	2277	164565	218758	-1942
16:00	49.85	216704	6347	5070	43578	11227	3247	147308	2172	168056	218949	-1934
16:15	49.90	215741	6435	5034	39832	11012	3360	150755	2202	170875	218630	-1896
16:30	49.90	216428	6375	5028	36501	11392	3321	154208	2213	174899	219038	-1870
16:45	49.80	215134	6405	5157	31154	11570	3319	156583	2126	178823	216314	-1763
17:00	49.90	214181	6405	5212	30102	12062	3318	159293	2116	178867	218508	-1558
17:15	49.90	211717	6363	5187	26648	12742	3321	160688	2055	179882	217004	-1513
17:30	49.90	210706	6365	5247	22966	13669	3337	162879	2042	182493	216505	-1495
17:45	49.85	207565	6375	5295	19098	14670	3327	163903	2052	183172	214720	-1476
18:00	49.90	205226	6405	5757	8056	16806	3446	166059	2006	191413	208535	-1276
18:15	50.00	207220	6408	5908	4781	20460	3654	166655	2091	196531	209957	-960
18:30	50.06	210310	6453	6087	2362	23261	3866	167893	2051	201861	211973	-961
18:45	50.01	211627	6441	6389	981	24947	4149	168611	2111	204257	213629	-951
19:00	50.01	213629	6440	6585	448	25817	4302	169685	2122	206596	215399	-946
19:15	50.01	213292	6428	6847	370	26268	4163	169270	2062	206075	215408	-910
19:30	50.01	213773	6427	6941	341	26370	3972	169813	2147	206491	216011	-912
19:45	50.01	212865	6439	7070	337	25865	3772	169295	2068	205458	214846	-908
20:00	50.06	211221	6493	7239	221	25161	3636	168075	2075	203761	212900	-951
20:15	50.06	208557	6464	7558	257	22235	3605	168302	2136	200742	210557	-964
20:30	50.01	207024	6486	7632	272	20168	3561	168779	2097	199120	208995	-984
20:45	49.96	206850	6478	7688	279	19452	3554	169533	2137	198883	209121	-962
21:00	50.06	205218	6487	7699	268	18017	3529	168783	2123	197251	206906	-1019
21:15	49.96	204714	6548	7636	226	17485	3534	169149	2133	196852	206711	-1015
21:30	50.01	204035	6511	7648	224	16719	3541	169224	2086	196163	205953	-1011
21:45	50.01	204130	6479	7573	131	16663	3527	169478	2108	196426	205959	-1019
22:00	50.06	203672	6485	7617	130	16268	3538	169263	2102	195925	205403	-958
22:15	49.96	204899	6484	7566	132	16447	3566	171220	2102	197201	207517	-1009
22:30	50.											

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).

** Hydro generation is excluding Bhutan hydro.

***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:

1. The information provided is for general informational purposes only.

2. The data is provided "as is" without any guarantees or warranties.

3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.

4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.

5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.

6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.