



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 03.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 02.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 2-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 02.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 03-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	76526	58648	47503	27762	3712	214151
Peak Shortage (MW)	656	0	0	55	0	711
Energy Met (MU)	1689	1347	1159	620	75	4890
Hydro Gen (MU)	378	56	165	102	31	732
Wind Gen (MU)	26	193	265	-	-	484
Solar Gen (MU)*	171.52	78.80	85.35	1.80	0.85	338
Energy Shortage (MU)	2.41	0.00	0.00	1.29	0.00	3.70
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	79067	58841	55336	28581	3787	212393
Time Of Maximum Demand Met	22:40	19:40	09:49	22:59	20:17	21:49

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.066	0.49	3.22	12.48	16.18	76.96	6.86

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15665	0	317.6	192.2	1.3	643	0.00
	Harvana	12473	0	258.9	202.0	-0.5	539	2.41
	Rajasthan	12682	0	285.8	116.9	-5.5	587	0.00
	Delhi	7162	0	142.6	128.7	-0.6	288	0.00
	UP	27788	0	530.0	251.5	2.5	428	0.00
	Uttarakhand	2533	0	52.1	23.9	1.1	177	0.00
	HP	1655	0	36.0	-5.3	-0.6	88	0.00
	J&K(UT) & Ladakh(UT)	2707	0	55.2	28.5	1.9	410	0.00
	Chandigarh	344	0	6.6	6.5	0.1	20	0.00
	Railways NR ISTS	207	0	4.3	3.8	0.5	38	0.00
WR	Chhattisgarh	5100	0	108.8	59.3	-4.6	323	0.00
	Gujarat	17356	0	393.8	169.6	3.3	1948	0.00
	MP	10701	0	225.4	100.4	-0.1	451	0.00
	Maharashtra	24695	0	537.6	165.7	-4.3	601	0.00
	Goa	551	0	14.3	12.0	1.8	30	0.00
	DNHDDPDCL	1347	0	31.1	31.3	-0.2	59	0.00
	AMNSIL	804	0	18.0	8.5	0.1	264	0.00
	BALCO	525	0	12.5	12.7	-0.2	0	0.00
	RIL JAMNAGAR	249	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	9902	0	203.5	17.6	-1.6	496	0.00
SR	Telangana	10493	0	201.6	101.2	1.3	585	0.00
	Karnataka	14024	0	256.6	57.0	-1.6	736	0.00
	Kerala	3904	0	80.2	34.8	-1.8	333	0.00
	Tamil Nadu	18782	0	406.4	169.7	-2.9	700	0.00
	Puducherry	483	0	10.6	10.1	-0.1	50	0.00
	Bihar	7833	0	154.5	146.5	-3.2	288	0.00
ER	DVC	2898	55	65.7	-29.9	-0.9	298	1.29
	Jharkhand	2115	0	43.8	35.1	-0.1	228	0.00
	Odisha	5479	0	116.6	41.3	-0.2	378	0.00
	West Bengal	10871	0	238.1	106.4	-1.5	339	0.00
	Sikkim	88	0	1.4	1.5	-0.2	14	0.00
	Railways ER ISTS	25	0	0.1	0.2	-0.1	0	0.00
NER	Arunachal Pradesh	199	0	3.5	3.2	0.0	80	0.00
	Assam	2526	0	48.6	41.3	1.1	123	0.00
	Manipur	217	0	3.6	3.2	0.4	21	0.00
	Meghalaya	331	0	5.6	-0.4	-0.1	116	0.00
	Mizoram	129	0	3.6	0.9	1.4	3	0.00
	Nagaland	182	0	3.9	2.7	0.6	25	0.00
	Tripura	321	0	6.3	4.4	0.3	50	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	56.5	16.3	-23.9	-32.9
Day Peak (MW)	2434.0	857.4	-1028.0	-1465.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	406.7	-331.2	-9.3	-77.1	11.0	0.0
Actual(MU)	394.7	-327.0	-11.1	-76.9	11.7	-8.5
O/D/UD(MU)	-12.0	4.2	-1.8	0.3	0.7	-8.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4804	12584	8148	5300	732	31567	45
State Sector	9649	14795	9872	3419	258	37993	55
Total	14453	27378	18020	8719	990	69560	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	726	1367	557	658	16	3323	64
Lignite	21	13	39	0	0	73	1
Hydro	378	56	165	102	31	732	14
Nuclear	33	56	60	0	0	149	3
Gas, Naptha & Diesel	21	30	4	0	21	76	1
RES (Wind, Solar, Biomass & Others)	206	272	394	3	1	877	17
Total	1385	1794	1220	764	69	5230	100

Share of RES in total generation (%)	14.86	15.19	32.35	0.45	1.27	16.77
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	44.58	21.42	50.80	13.82	46.18	33.62

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.062
Based on State Max Demands	1.108

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	212180	10:58	55
Non-Solar hr	212393	21:49	724

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 03-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	310	0.0	7.4	-7.4
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.7	-2.7
3	765 kV	GAYA-VARANASI	2	503	848	0.0	7.0	-7.0
4	765 kV	SASARAM-FATEHPUR	1	172	438	0.0	3.8	-3.8
5	765 kV	GAYA-BALIA	1	0	905	0.0	12.9	-12.9
6	400 kV	PUSAULI-VARANASI	1	0	116	0.0	1.7	-1.7
7	400 kV	PUSAULI-ALLAHABAD	1	17	73	0.0	0.9	-0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	0	746	0.0	11.8	-11.8
9	400 kV	PATNA-BALIA	2	0	862	0.0	12.3	-12.3
10	400 kV	NAUBATPUR-BALIA	2	7	582	0.0	3.4	-3.4
11	400 kV	BIHARSHARIFF-BALIA	2	235	251	0.0	0.9	-0.9
12	400 kV	MOTIHARI-GORAKHPUR	2	83	466	0.0	5.3	-5.3
13	400 kV	BIHARSHARIFF-SAHUPURI	2	118	355	0.0	3.7	-3.7
14	220 kV	SAHUPURI-KARAMNESA	1	0	113	0.0	1.9	-1.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
						ER-NR	0.8	-74.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	579	832	0.0	0.1	-0.1
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1935	110	32.0	0.0	32.0
3	765 kV	JHARSUGUDA-DURG	2	161	455	0.0	2.9	-2.9
4	400 kV	JHARSUGUDA-RAIGARH	4	326	151	2.5	0.0	2.5
5	400 kV	RANCHI-SIPAT	2	554	52	8.0	0.0	8.0
6	400 kV	JEYPORE-JAGDALPUR	2	155	361	0.0	2.1	-2.1
7	220 kV	BUDHIPADAR-RAIGARH	1	40	68	0.0	0.4	-0.4
8	220 kV	BUDHIPADAR-KORBA	2	116	26	0.9	0.0	0.9
						ER-WR	43.3	37.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	305	0	7.2	0.0	7.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1407	0.0	36.1	-36.1
3	765 kV	ANGUL-SRIKAKULAM	0	0	2524	0.0	26.7	-26.7
4	400 kV	TALCHER-I/C	2	0	465	0.0	2.9	-2.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
						ER-SR	7.2	-55.6
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	47	351	0.0	3.6	-3.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	842	0.0	12.6	-12.6
3	220 kV	ALIPURDUAR-SALAKATI	2	0	145	0.0	2.0	-2.0
						ER-NER	18.2	-18.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	351	0	0.0	8.5	-8.5
						NER-NR	0.0	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4036	0.0	80.2	-80.2
2	HVDC	VINDHYACHAL-B/B	2	293	0	4.6	0.0	4.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1916	0.0	43.1	-43.1
4	765 kV	GWALIOR-AGRA	2	0	3438	0.0	49.4	-49.4
5	765 kV	GWALIOR-PHAGI	2	199	1702	0.6	16.4	-15.8
6	765 kV	JABALPUR-ORAI	2	0	1521	0.0	48.5	-48.5
7	765 kV	GWALIOR-ORAI	1	559	0	9.1	0.0	9.1
8	765 kV	SATNA-ORAI	1	0	1119	0.0	20.3	-20.3
9	765 kV	BANASKANTHA-CHITORGARH	2	918	846	2.8	5.2	-2.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3600	0.0	56.8	-56.8
11	400 kV	ZERDA-KANKROLI	1	231	74	1.3	0.3	1.0
12	400 kV	ZERDA-BHINMAL	1	160	51	0.9	0.2	0.7
13	400 kV	VINDHYACHAL-RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	186	749	0.4	7.4	-7.0
15	400 kV	NEEMUCH-Chittorgarh	2	214	862	0.5	8.2	-7.7
16	220 kV	BHANPURA-RANPUR	1	0	129	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.5	-1.5
18	220 kV	MEHGAON-AURAIYA	1	70	37	0.2	0.2	-0.1
19	220 kV	MALANPUR-AURAIYA	1	49	45	0.1	0.6	-0.4
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
						WR-NR	20.5	-319.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	303	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGAUR	2	0	2003	0.0	31.7	-31.7
3	765 kV	SOLAPUR-RAICHUR	2	2865	511	32.5	0.0	32.5
4	765 kV	WARDHAN-NIZAMABAD	2	1299	2225	3.9	11.8	-8.0
5	765 kV	WARORA-WARANGAL(NEW)	2	1373	2169	4.5	10.4	-5.9
6	400 kV	KOLHAPUR-KUDGI	2	2021	0	34.7	0.0	34.7
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	2	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	100	2.0	0.0	2.0
						WR-SR	84.8	30.8

INTERNATIONAL EXCHANGES							Import(+ve)/Export(-ve)
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	1357	1124	1293	31.04	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	863	686	798	19.15	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	175	116	144	3.46	
	NER	132kV GELEPHU-SALAKATI	48	0	43	1.02	
	NER	132kV MOTANGA-RANGIA	39	0	44	1.05	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-22	0	0	0.00	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	57	0	9	0.21	
	ER	NEPAL IMPORT (FROM BIHAR)	138	1	114	2.73	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	662	468	556	13.35	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-978	-945	-958	-22.99	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1465	-1238	-1370	-32.89	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-50	0	-39	-0.94	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 03-Jul-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	23.70	0.11	0.00	0.00	0.00	0.00	0.00	0.00	23.81
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	23.70	0.11	0.00	0.00	0.00	0.00	0.00	0.00	23.81

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	55.08	0.00	1.09	0.00	0.00	0.55	0.00	0.00	56.72
Nepal	8.42	0.10	3.01	0.00	0.00	4.53	0.00	0.00	16.06
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	63.50	0.10	4.10	0.00	0.00	5.08	0.00	0.00	72.78

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	55.08	0.00	1.09	0.00	0.00	0.55	0.00	0.00	56.72
Nepal	8.42	0.10	3.01	0.00	0.00	4.53	0.00	0.00	16.06
Bangladesh	-23.70	-0.11	0.00	0.00	0.00	0.00	0.00	0.00	-23.81
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	39.80	-0.01	4.10	0.00	0.00	5.08	0.00	0.00	48.97

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K) (+ve) Import, (-ve) Export
0:00	50.05	200211	5757	20330	0	28143	2389	140765	1731	179881	199115	1844
0:15	50.05	198966	5751	20403	0	28488	2386	139915	1771	178563	198714	1871
0:30	50.05	196711	5765	20265	0	28715	2359	138223	1707	176446	197034	1826
0:45	50.00	195718	5770	20205	0	28330	2359	137207	1710	175513	195581	1951
1:00	50.00	193457	5773	20410	0	28219	2345	134781	1753	173047	193281	2015
1:15	50.00	191963	5754	20509	0	27937	2348	133625	1692	171454	191865	1957
1:30	50.00	191020	5771	20685	0	27929	2345	132508	1702	170335	190940	1937
1:45	50.00	189692	5555	20493	0	27524	2351	131775	1748	169199	189446	1946
2:00	50.00	188077	5550	20654	0	27218	2282	130521	1702	167423	187927	1990
2:15	50.00	186917	5556	20038	0	27178	2275	129894	1720	166879	186661	1996
2:30	49.95	185813	5565	19764	0	27019	2293	129233	1702	166049	185576	1986
2:45	50.00	185274	5566	20012	0	26650	2295	128847	1645	165262	185015	1996
3:00	50.00	184176	5561	20382	0	26135	2297	127917	1712	163794	184004	1978
3:15	49.94	183741	5532	20459	0	25555	2289	127846	1689	163282	183370	2007
3:30	50.05	182854	5557	20765	0	25677	2301	126717	1666	162089	182683	1998
3:45	50.05	182715	5553	20544	0	25847	2298	126714	1661	162171	182617	2002
4:00	50.00	182318	5545	19813	0	25786	2289	127182	1645	162505	182260	1979
4:15	49.97	183121	5557	19194	0	26610	2298	127873	1652	163927	183184	1983
4:30	49.97	183306	5557	18521	0	26833	2291	128179	1678	164785	183059	1984
4:45	49.97	183782	5551	18053	0	27094	2285	129007	1654	165729	183644	1968
5:00	49.97	183400	5549	17789	-21	26943	2299	129121	1656	165632	183336	2013
5:15	49.87	183997	5549	17455	-21	26936	2291	129794	1645	166563	183649	1991
5:30	49.88	185402	5547	17127	-22	27134	2284	131350	1647	168297	185067	1998
5:45	49.93	186665	5557	16756	-15	27211	2297	132919	1689	169924	186414	2009
6:00	49.93	188059	5565	16365	37	26967	2285	134625	1714	171657	187558	2013
6:15	49.88	189745	5551	16178	909	27232	2264	135447	1653	172658	189234	1997
6:30	50.03	192083	5549	16417	2071	27096	2262	136484	1635	173595	191514	1929
6:45	50.03	193177	5559	16298	3748	27233	2256	135916	1697	173131	192707	1977
7:00	50.03	193799	5556	16171	5788	27100	2266	134830	1725	171840	193436	2001
7:15	49.98	195040	5569	15941	8191	27148	2369	133800	1711	170908	194729	1952
7:30	49.93	194379	5562	15582	10578	27224	2360	131381	1700	168219	194387	1932
7:45	49.98	194416	5564	15575	13112	26701	2365	129481	1706	165729	194504	1903
8:00	50.03	194963	5556	15993	16433	26456	2367	126770	1781	162537	195356	1913
8:15	49.88	194999	5550	16295	18964	26048	2369	124785	1699	159740	195710	1896
8:30	49.93	197424	5555	16664	21899	25860	2442	123806	1738	158861	197964	1906
8:45	49.93	200461	5546	17157	24524	25794	2457	123538	1724	158780	200740	1912
9:00	50.03	202939	5546	17960	27715	25818	2458	122217	1704	157264	203418	1933
9:15	49.98	205046	5556	18578	31290	25547	2476	120355	1659	155178	205461	1939
9:30	49.98	207283	5517	19032	33923	25712	2558	119306	1686	154328	207734	1900
9:45	49.98	208824	5527	19670	35927	25967	2557	118050	1691	153227	209389	1886
10:00	49.98	209279	5523	20342	36798	26247	2553	116595	1701	152139	209759	1895
10:15	49.98	208863	5532	20808	36875	26205	2568	115644	1733	151180	209365	1873
10:30	49.98	209400	5520	20782	37516	26208	2683	115489	1703	151102	209901	1851
10:45	49.93	210998	5520	21190	38358	25962	2708	115947	1701	151450	211386	1871
11:00	49.93	211802	5512	21547	39037	25780	2720	115878	1785	151218	212259	1875
11:15	49.93	211804	5542	21983	40004	25729	2716	114407	1701	149817	212082	1916
11:30	49.88	209902	5521	22039	38237	25407	2732	114203	1708	149626	209847	1957
11:45	49.93	209889	5512	22201	39403	25306	2792	113555	1705	148285	210474	1935
12:00	49.98	209048	5515	22222	39840	25128	2770	112720	1695	146986	209890	1863
12:15	49.93	208247	5455	22231	40577	24687	2719	111506	1685	145439	208860	1919
12:30	49.88	209664	5499	21893	41927	24529	2727	112047	1702	145844	210274	1869
12:45	49.88	208899	5494	21507	40826	25398	2743	112023	1699	146566	209690	1884
13:00	50.03	206374	5528	21025	39727	25142	2749	111236	1688	145622	207095	1902
13:15	49.93	204450	5526	20789	39698	25210	2755	109319	1689	143963	204986	1963
13:30	49.93	204133	5521	20774	39380	24780	2750	109739	1700	143979	204644	1900
13:45	49.98	205612	5517	21259	38893	24625	2764	111450	1715	145460	206223	1949
14:00	50.08	205517	5527	21508	38508	24393	2644	111775	1690	145501	206045	1957
14:15	50.03	206380	5531	21815	38493	23980	2645	112824	1717	146072	207005	1922
14:30	49.98	208469	5521	21820	37185	24303	2653	115752	1782	149464	209016	1945
14:45	49.98	209005	5536	21837	36715	24188	2660	117045	1709	150453	209690	1962
15:00	50.03	209771	5531	21606	35519	24659	2619	118720	1688	152646	210342	1937
15:15	49.98	208497	5531	21560	34060	24419	2565	119248	1706	152877	209089	1973
15:30	49.98	209986	5524	22064	32484	24778	2559	121481	1713	155438	210603	1996
15:45	49.98	208201	5528	22129	30457	25009	2557	121688	1707	155615	209075	2092
16:00	50.08	207225	5472	22175	28738	25255	2512	121268	1657	156312	207077	2093
16:15	50.03	205176	5541	22092	27372	25429	2520	120908	1647	155712	205509	2038
16:30	49.88	205536	5544	22074	23983	26027	2566	124173	1645	159479	206012	2035
16:45	49.77	204021	5535	21605	20710	26393	2638	126255	1635	161706	204771	1946
17:00	49.88	204025	5523	21302	17716	26294	2640	129207	1660	165007	204342	2072
17:15	50.03	202184	5537	21195	15098	25532	2708	130777	1634	165891	202481	2127
17:30	49.93	201019	5548	21097	12165	26031	2718	131950	1605	167757	201114	1966
17:45	49.72	200660	5532	21036	8839	26773	2730	134245	1592	170785	200747	1965
18:00	49.87	200660	5515	21044	6607	26558	2731	136347	1593	173009	200395	2098
18:15	50.03	200293	5547	21318	5149	26619	2756	137130	1619	173826	200138	2104
18:30	50.08	202394	5527	21632	3664	27805	2948	138618	1608	177098	201802	2100
18:45	50.03	203506	5537	21236	1825	29046	3008	140245	1659	180445	202556	1961
19:00	49.98	207206	5532	20786	947	30687	3056	143398	1636	185473	206042	1918
19:15	49.98	209312	5535	20724	284	31587	3075	145107	1689	188304	208001	1853
19:30	49.93	211633	5535	20619	0	32765	3267	146500	1725	191014	210411	1783
19:45	49.98	212152	5544	20273	-58	33197	3570	146825	1694	191937	211045	1748
20:00	49.92	211353	5522	19538	-86	33216	3732	146710	1696	191901	210328	1690
20:15	50.03	211418	5546	18941	0	33067	3916	147280	1711	192477	210461	1727
20:30	50.03	211397	5538	18155	0	33449	4159	147285	1737	193242	210323	1737
20:45	50.03	210787	5515	17572	0	33655	4694	146458	1711	193215	209605	1733
21:00	50.03	211617	5527	17176	0	34533	4830	146946	1747	194441	210759	1816
21:15	49.67	211529	5532	16788	0	34754	4917	146934	1778	194741	210703	1840
21:30	49.87	211503	5538	16468	0	34367	4883	147755	1713	195035	210724	1817
21:45	49.92	212022	5545	16515	0	34562	4900	147788	1724	195507	211034	1796
22:00	50.03	211627	5530	16529	0	34145	4985	147859	1693	195098	210741	1783
22:15	50.03	211410	5527	17106	0	33643	5136</					