



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 13.02.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 12.02.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 12-फ़रवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 12.02.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 13-Feb-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	59387	69657	52503	24067	2859	208473
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1264	1654	1305	509	52	4784
Hydro Gen (MU)	110	43	85	24	12	273
Wind Gen (MU)	21	115	84	-	-	220
Solar Gen (MU)*	208.04	178.65	172.21	4.03	1.03	564
Energy Shortage (MU)	0.04	0.56	0.00	0.00	0.00	0.60
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	66781	82907	64075	25140	2987	238802
Time Of Maximum Demand Met	10:13	09:58	09:40	18:22	18:02	09:56

B. Frequency Profile (%)

Region	FV1	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.052	0.00	0.25	6.99	7.24	71.87	20.89

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9376	0	165.9	70.3	0.0	974	0.00
	Haryana	8580	0	168.3	117.9	-0.9	392	0.00
	Rajasthan	18561	0	342.1	108.6	-0.3	978	0.00
	Delhi	4407	0	78.3	69.8	-0.6	306	0.00
	UP	19132	0	361.9	61.5	0.3	377	0.00
	Uttarakhand	2437	0	43.9	34.1	0.2	77	0.00
	HP	2134	0	37.4	31.7	-0.1	160	0.00
	J&K(UT) & Ladakh(UT)	2817	0	58.6	55.8	-1.3	119	0.04
	Chandigarh	244	0	3.9	3.9	0.0	11	0.00
	Railways_NR ISTS	206	0	4.1	3.8	0.2	32	0.00
WR	Chhattisgarh	6152	0	128.4	62.6	1.4	396	0.00
	Gujarat	24302	0	459.3	193.6	-0.5	1072	0.00
	MP	19030	0	345.7	219.4	0.0	1393	0.56
	Maharashtra	30140	0	633.6	205.5	-6.4	1178	0.00
	Goa	742	0	14.6	12.9	1.2	36	0.00
	DNHDDPDCL	1376	0	31.8	31.8	0.0	57	0.00
	AMNSIL	917	0	19.5	13.9	0.2	260	0.00
	BALCO	604	0	14.4	14.5	-0.1	28	0.00
	RIL JAMNAGAR	267	0	6.2	6.3	-0.1	0	0.00
	Andhra Pradesh	12690	0	238.1	67.2	1.0	824	0.00
SR	Telangana	16392	0	291.1	135.9	-0.9	769	0.00
	Karnataka	17268	0	324.7	124.1	-4.1	633	0.00
	Kerala	4168	0	79.7	60.6	1.6	400	0.00
	Tamil Nadu	18339	0	362.6	195.8	-0.4	1237	0.00
	Puducherry	415	0	9.0	8.6	-0.2	32	0.00
	Bihar	5805	0	106.5	85.9	-1.3	207	0.00
ER	DVC	3272	0	69.0	-28.6	-0.1	569	0.00
	Jharkhand	2162	0	40.0	28.3	0.3	267	0.00
	Odisha	5698	0	115.6	34.3	-1.3	524	0.00
	West Bengal	8394	0	176.0	64.8	-2.2	278	0.00
	Sikkim	119	0	2.0	2.0	-0.1	10	0.00
	Railways_ER ISTS	31	0	0.2	0.2	0.0	4	0.00
NER	Arunachal Pradesh	187	0	3.3	3.3	0.0	31	0.00
	Assam	1667	0	29.5	24.1	0.3	70	0.00
	Manipur	271	0	3.8	3.7	0.1	38	0.00
	Meghalaya	370	0	6.3	5.7	-0.1	94	0.00
	Mizoram	146	0	2.2	2.1	-0.1	18	0.00
	Nagaland	175	0	2.7	2.7	0.0	15	0.00
	Tripura	230	0	4.2	4.3	-0.1	36	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-19.6	-11.3	-10.5	-19.8
Day Peak (MW)	-1071.6	-785.8	-822.4	-876.1

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	163.0	-180.6	160.0	-155.2	12.8	0.0
Actual(MU)	154.3	-167.3	144.5	-152.3	11.6	-9.3
O/D/U/D(MU)	-8.7	13.3	-15.5	2.9	-1.3	-9.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5595	10224	4558	3154	990	24520	45
State Sector	8489	11726	5136	4390	306	30047	55
Total	14084	21949	9694	7544	1296	54566	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	761	1494	748	726	8	3738	72
Lignite	25	22	44	0	0	92	2
Hydro	110	43	85	24	12	273	5
Nuclear	48	65	71	0	0	184	4
Gas, Naptha & Diesel	11	18	10	0	22	62	1
RES (Wind, Solar, Biomass & Others)	254	297	290	8	1	850	16
Total	1209	1940	1248	758	44	5198	100

Share of RES in total generation (%)	20.98	15.33	23.21	1.05	2.37	16.34
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	34.01	20.90	35.66	4.18	30.42	25.14

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.012
Based on State Max Demands	1.043

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	238802	9:56	42
Non-Solar hr	213917	17:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 13-Feb-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	62	1426	0.0	20.0	-20.0
4	765 kV	SASARAM-FAITEHPUR	1	14	584	0.0	8.1	-8.1
5	765 kV	GAYA-BALIA	1	0	729	0.0	10.7	-10.7
6	400 kV	PUSAULI-VARANASI	1	0	117	0.0	1.7	-1.7
7	400 kV	PUSAULI-ALLAHABAD	1	22	79	0.0	0.6	-0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	531	438	0.0	0.5	-0.5
9	400 kV	PATNA-BALIA	2	2	891	0.0	12.3	-12.3
10	400 kV	NAUBATPUR-BALIA	2	132	180	0.0	3.9	-3.9
11	400 kV	BIHARSHARIFF-BALIA	2	401	165	2.3	0.0	2.3
12	400 kV	MOTIHARI-GORAKHPUR	2	88	462	0.0	5.4	-5.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	143	422	0.0	4.0	-4.0
14	220 kV	SAHUPURI-KARAMNANA	1	17	14	0.0	1.8	-1.8
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.2	0.0	0.2
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						3.0	71.1	-68.1
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	555	492	2.0	0.0	2.0
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1177	953	1.0	0.0	1.0
3	765 kV	JHARSUGUDA-DURG	2	0	1227	0.0	21.1	-21.1
4	400 kV	JHARSUGUDA-RAIGARH	4	157	306	0.0	2.0	-2.0
5	400 kV	RANCHI-SIPAT	2	257	329	0.0	1.4	-1.4
6	400 kV	JEYPORE-JAGDALPUR	2	269	330	0.4	0.0	0.4
7	220 kV	BUDHIPADAR-RAIGARH	1	0	151	0.0	2.2	-2.2
8	220 kV	BUDHIPADAR-KORBA	2	68	107	0.0	0.2	-0.2
ER-WR						3.4	26.9	-23.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	525	0.0	7.5	-7.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1619	0.0	42.1	-42.1
3	765 kV	ANGUL-SRIKAKULAM	2	0	3111	0.0	54.7	-54.7
4	400 kV	TALCHER-I/C	2	0	868	0.0	10.0	-10.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	104.3	-104.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAOON	2	178	128	1.3	0.4	0.9
2	400 kV	ALIPURDUAR-BONGAIGAOON	2	502	0	5.6	0.0	5.6
3	220 kV	ALIPURDUAR-SALAKATI	2	76	14	0.8	0.0	0.8
ER-NER						7.7	0.4	7.2
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	957	0	20.8	0.0	20.8
NER-NR						20.8	0.0	20.8
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3022	0.0	70.0	-70.0
2	HVDC	VINDHYACHAL B/B	-	0	106	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1459	0.0	36.4	-36.4
4	765 kV	GWALIOR-AGRA	2	483	1335	1.7	11.1	-9.5
5	765 kV	GWALIOR-PHAGI	2	558	1891	1.0	21.6	-20.7
6	765 kV	JABALPUR-ORAI	2	167	861	0.0	18.9	-18.9
7	765 kV	GWALIOR-ORAI	1	883	0	15.1	0.0	15.1
8	765 kV	SATNA-ORAI	1	0	1001	0.0	15.4	-15.4
9	765 kV	BANASKANTHA-CHITTOORGARH	2	2418	333	23.9	0.2	23.7
10	765 kV	VINDHYACHAL VARANASI	2	940	1270	0.0	5.1	-5.1
11	400 kV	ZERDA-KANKROLI	1	401	0	4.9	0.0	4.9
12	400 kV	ZERDA BHINMAL	1	277	0	3.4	0.0	3.4
13	400 kV	VINDHYACHAL -RIHAND	1	479	0	10.3	0.0	10.3
14	400 kV	RAPP-SHUJALPUR	2	831	60	8.1	0.0	8.1
15	400 kV	NEEMUCH-Chittorgarh	2	814	247	5.7	0.7	5.0
16	220 kV	BHANPURA-RANPUR	1	0	132	0.0	2.2	-2.2
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	152	0	1.5	0.0	1.5
19	220 kV	MALANPUR-AURAIYA	1	119	6	0.8	0.0	0.8
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						76.2	185.6	-109.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1003	0.0	11.5	-11.5
2	HVDC	RAIGARH-PUGALUR	2	0	3005	0.0	30.3	-30.3
3	765 kV	SOLAPUR-RAICHUR	2	1483	1506	7.5	7.8	-0.3
4	765 kV	WARDHA-NIZAMABAD	2	228	2617	0.2	33.2	-33.0
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2658	0.0	36.3	-36.3
6	400 kV	KOLHAPUR-KUDGI	2	1859	0	28.8	0.0	28.8
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	1	120	1.6	0.0	1.6
WR-SR						38.2	119.1	-80.9

INTERNATIONAL EXCHANGES

					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-315	12	-296	-7.10	
	ER	400kV TALA-BINAGURI 1,2,400kV MALBASE - BINAGURI & 400kV NORBUGANG - BINAGURI I.e. BINAGURI RECEIPT (from TALA HEP)	-375	150	-237	-5.69	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-258	-94	-202	-4.86	
	NER	132kV GELEPHU-SALAKATI	-80	-53	-70	-1.67	
	NER	132kV MOTANGA-RANGIA	-27	6	-11	-0.26	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-68	0	-40	-0.96	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-68	0	-51	-1.22	
	ER	NEPAL IMPORT (FROM BIHAR)	-160	-80	-119	-2.84	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-510	-152	-262	-6.28	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-806	-144	-423	-10.16	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-876	-813	-826	-19.84	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-18	0	-15	-0.36	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 13-Feb-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.36	19.07	0.00	0.00	0.57	0.00	0.00	20.00
Nepal	3.00	1.49	1.39	0.00	0.00	3.64	0.00	0.00	9.52
Bangladesh	10.64	0.00	0.00	0.00	0.00	0.00	0.00	0.00	10.64
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	13.64	1.85	20.46	0.00	0.00	4.21	0.00	0.00	40.16

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.34	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.34

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.34	-0.36	-19.07	0.00	0.00	-0.57	0.00	0.00	-19.66
Nepal	-3.00	-1.49	-1.39	0.00	0.00	-3.64	0.00	0.00	-9.52
Bangladesh	-10.64	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-10.64
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-13.30	-1.85	-20.46	0.00	0.00	-4.21	0.00	0.00	-39.82

