



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: POSOCO/NLDC/SO/Daily PSP Report

दिनांक: 31-May-2024

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 30.05.2024.

महोदय/Dear Sir,

आईईजीसी-2010 की धारा स.-5.5.1 के प्रावधान के अनुसार, दिनांक 30-मई-2024 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 5.5.1 of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 30-May-2024, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 31-May-2024

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	76386	67482	51705	28033	2485	226091
Peak Shortage (MW)	0	118	0	0	0	118
Energy Met (MU)	1877	1645	1232	664	48	5466
Hydro Gen (MU)	352	70	49	33	37	541
Wind Gen (MU)	51	206	180	-	-	437
Solar Gen (MU)*	181.96	97.02	137.45	3.45	0.62	421
Energy Shortage (MU)	0.00	0.63	0.00	0.69	0.00	1.32
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	86785	74854	58890	31013	2554	250070
Time Of Maximum Demand Met	14:15	15:02	15:19	00:18	18:49	14:57

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.030	0.00	0.00	1.15	1.15	69.81	29.05

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13905	0	279.6	142.4	0.5	532	0.00
	Haryana	12164	0	259.3	198.3	-1.1	259	0.00
	Rajasthan	17460	0	379.1	121.5	0.1	483	0.00
	Delhi	8017	0	162.7	131.1	-0.3	312	0.00
	UP	28584	0	629.7	326.3	-1.7	920	0.00
	Uttarakhand	2726	0	60.3	33.5	1.0	258	0.00
	HP	1818	0	39.2	3.3	0.2	162	0.00
	J&K(UT) & Ladakh(UT)	2708	0	54.4	30.4	-2.1	393	0.00
	Chandigarh	432	0	8.6	8.3	0.3	38	0.00
WR	Railways_NR ISTS	215	0	4.3	3.9	0.4	62	0.00
	Chhattisgarh	5508	0	125.9	70.4	-0.8	404	0.00
	Gujarat	24208	0	497.2	136.2	-1.2	653	0.00
	MP	14309	0	310.4	159.4	-0.9	472	0.63
	Maharashtra	28024	0	635.3	194.7	1.9	655	0.00
	Goa	797	0	17.1	15.2	1.8	40	0.00
	DNHDDPDCL	1348	0	31.2	31.1	0.1	93	0.00
	AMNSIL	718	0	15.2	4.7	0.8	307	0.00
	BALCO	524	0	12.5	12.5	0.0	10	0.00
SR	Andhra Pradesh	13231	0	258.3	71.1	1.5	850	0.00
	Telangana	11041	0	225.6	104.7	0.8	385	0.00
	Karnataka	13099	0	253.1	71.3	-1.8	823	0.00
	Kerala	3969	0	80.4	50.4	1.4	692	0.00
	Tamil Nadu	19299	0	403.6	192.3	-2.5	1092	0.00
	Puducherry	512	0	11.4	11.0	-0.2	35	0.00
ER	Bihar	7298	157	156.0	148.1	-3.0	492	0.34
	DVC	3564	0	75.2	-37.4	0.8	455	0.00
	Jharkhand	2312	0	49.7	36.5	0.3	394	0.35
	Odisha	6969	0	147.1	62.1	0.4	609	0.00
	West Bengal	11524	0	234.8	95.3	-1.2	262	0.00
	Sikkim	86	0	1.5	1.6	-0.1	17	0.00
	Railways_ER ISTS	12	0	0.3	0.1	0.1	1	0.00
NER	Arunachal Pradesh	138	0	2.7	2.5	-0.2	45	0.00
	Assam	1611	0	29.2	21.1	0.0	174	0.00
	Manipur	151	0	2.3	2.5	-0.2	16	0.00
	Meghalaya	194	0	3.6	-0.2	0.2	87	0.00
	Mizoram	100	0	1.5	1.8	-0.6	12	0.00
	Nagaland	152	0	2.4	2.5	-0.1	25	0.00
	Tripura	281	0	5.7	5.3	0.0	45	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.4	-5.9	-22.6	-28.5
Day Peak (MW)	463.0	-642.8	-1033.0	-1440.8

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	409.6	-413.9	38.9	-13.7	-20.9	0.0
Actual(MU)	381.9	-428.2	56.8	-0.3	-21.3	-11.0
O/D/U/D(MU)	-27.7	-14.3	18.0	13.4	-0.4	-11.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	1498	3465	2752	3856	551	12121	43
State Sector	3601	6021	4070	2064	120	15875	57
Total	5099	9485	6822	5920	671	27996	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	887	1661	729	721	12	4010	68
Lignite	21	13	68	0	0	102	2
Hydro	352	70	49	33	37	541	9
Nuclear	29	53	51	0	0	134	2
Gas, Naptha & Diesel	63	110	11	0	24	209	4
RES (Wind, Solar, Biomass & Others)	241	305	341	4	1	891	15
Total	1594	2212	1249	758	75	5887	100

Share of RES in total generation (%)	15.12	13.78	27.28	0.56	0.83	15.14
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	39.07	19.32	35.30	4.85	51.04	26.59

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.016
Based on State Max Demands	1.035

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	250070	14:57	0
Non-Solar hr	231972	22:49	135

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 07:00 to 17:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 31-May-2024

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	2	0	0.0	0.0	0.0
3	765 kV	GAYA-VARANASI	2	654	727	1.8	0.0	1.8
4	765 kV	SASARAM-FATEHPUR	1	139	473	0.0	2.8	-2.8
5	765 kV	GAYA-BALIA	1	0	536	0.0	8.9	-8.9
6	400 kV	PUSAULI-VARANASI	1	55	73	0.0	0.6	-0.6
7	400 kV	PUSAULI -ALLAHABAD	1	70	58	0.6	0.0	0.6
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	145	1000	0.0	8.5	-8.5
9	400 kV	PATNA-BALIA	2	0	818	0.0	9.0	-9.0
10	400 kV	NAUBATPUR-BALIA	2	45	249	0.0	2.0	-2.0
11	400 kV	BIHARSHARIFF-BALIA	2	291	197	1.6	0.0	1.6
12	400 kV	MOTIHARI-GORAKHPUR	2	0	708	0.0	7.6	-7.6
13	400 kV	BIHARSHARIFF-VARANASI	2	330	366	0.0	0.9	-0.9
14	220 kV	SAHUPURI-KARAMNASA	1	32	81	0.0	0.4	-0.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						4.8	40.8	-36.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	944	863	0.0	3.9	-3.9
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2029	0	39.0	0.0	39.0
3	765 kV	JHARSUGUDA-DURG	2	25	494	0.0	4.5	-4.5
4	400 kV	JHARSUGUDA-RAIGARH	4	155	262	0.0	0.0	0.0
5	400 kV	RANCHI-SIPAT	2	600	0	10.7	0.0	10.7
6	220 kV	BUDHIPADAR-RAIGARH	1	54	96	0.0	1.0	-1.0
7	220 kV	BUDHIPADAR-KORBA	2	150	87	0.1	0.0	0.1
ER-WR						49.9	9.4	40.5
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	1	0.0	0.0	0.0
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1693	0.0	40.9	-40.9
3	765 kV	ANGUL-SRIKAKULAM	2	0	2058	0.0	30.5	-30.5
4	400 kV	TALCHER-I/C	2	0	587	0.0	10.4	-10.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	71.4	-71.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	784	0	12.8	0.0	12.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	1198	0	20.1	0.0	20.1
3	220 kV	ALIPURDUAR-SALAKATI	2	239	0	4.1	0.0	4.1
ER-NER						37.1	0.0	37.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	653	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	6061	0.0	128.6	-128.6
2	HVDC	VINDHYACHAL B/B	-	0	254	0.0	8.6	-8.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1662	0.0	41.1	-41.1
4	765 kV	GWALIOR-AGRA	2	0	3059	0.0	48.9	-48.9
5	765 kV	GWALIOR-PHAGI	2	838	1474	4.2	12.7	-8.6
6	765 kV	JABALPUR-ORAI	2	0	1353	0.0	33.8	-33.8
7	765 kV	GWALIOR-ORAI	1	518	0	7.5	0.0	7.5
8	765 kV	SATNA-ORAI	1	0	1239	0.0	21.9	-21.9
9	765 kV	BANASKANTHA-CHITORGARH	2	237	2237	0.1	22.2	-22.1
10	765 kV	VINDHYACHAL-VARANASI	2	0	3638	0.0	71.1	-71.1
11	400 kV	ZERDA-KANKROLI	1	104	332	0.4	2.6	-2.1
12	400 kV	ZERDA -BHINMAL	1	104	331	0.4	2.6	-2.1
13	400 kV	VINDHYACHAL -RIHAND	1	968	0	20.9	0.0	20.9
14	400 kV	RAPP-SHUJALPUR	2	321	592	2.0	4.5	-2.6
15	400 kV	NEEMUCH-Chittorgarh	2	414	607	2.7	4.4	-1.7
16	220 kV	BHANPURA-RANPUR	1	0	116	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.5	-2.5
18	220 kV	MEHGAON-AURAIYA	1	63	12	0.6	0.0	0.6
19	220 kV	MALANPUR-AURAIYA	1	39	26	0.3	0.1	0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						39.0	407.5	-368.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	301	0	7.2	0.0	7.2
2	HVDC	RAIGARH-PUGALUR	2	0	2312	0.0	53.5	-53.5
3	765 kV	SOLAPUR-RAICHUR	2	1759	271	21.2	0.2	21.0
4	765 kV	WARDHA-NIZAMABAD	2	66	1341	0.0	12.9	-12.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	1553	0.0	16.9	-16.9
6	400 kV	KOLHAPUR-KUDGI	2	1856	0	32.1	0.0	32.1
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	84	1.7	0.0	1.7
9	220 kV	XELDEM-AMBEWADI	1	0	128	2.5	0.0	2.5
WR-SR						64.8	83.5	-18.7

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	387	186	266	6.39
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	176	-3	74	1.77
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-214	-107	-160	-3.83
	NER	132kV GELEPHU-SALAKATI	-21	0	-12	-0.28
	NER	132kV MOTANGA-RANGIA	29	0	14	0.34
NEPAL	NR	NEPAL IMPORT (FROM UP)	-73	0	-8	-0.18
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-73	0	-50	-1.19
	ER	NEPAL IMPORT (FROM BIHAR)	-203	0	-79	-1.90
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-440	-19	-109	-2.61
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-941	-654	-859	-20.61
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1441	-993	-1189	-28.54
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-92	0	-84	-2.02

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.16	0.00	0.46	0.00	0.00	3.25	0.00	0.00	3.87
Bangladesh	20.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.59
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.75	0.00	0.46	0.00	0.00	3.25	0.00	0.00	24.46

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	2.80	0.00	0.16	0.00	0.00	0.00	0.00	0.00	2.96	
Nepal	0.00	0.00	4.74	0.00	0.00	0.00	0.78	0.00	0.00	5.52
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	2.80	0.00	4.90	0.00	0.00	0.00	0.78	0.00	0.00	8.48

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	2.80	0.00	0.16	0.00	0.00	0.00	0.00	0.00	2.96
Nepal	-0.16	0.00	4.28	0.00	0.00	-2.47	0.00	0.00	1.65
Bangladesh	-20.59	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.59
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-17.95	0.00	4.44	0.00	0.00	-2.47	0.00	0.00	-15.98