



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 30.07.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 29.07.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 29-जुलाई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 29.07.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 30-Jul-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	77485	56699	50638	27847	3687	216356
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1728	1341	1216	605	73	4963
Hydro Gen (MU)	401	85	197	92	37	813
Wind Gen (MU)	64	319	289	-	-	673
Solar Gen (MU)*	187.29	59.83	117.96	1.46	1.03	368
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	78720	58642	58080	28162	3696	216397
Time Of Maximum Demand Met	00:00	09:26	09:26	19:31	19:57	10:24

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.00	0.00	2.37	2.37	74.47	23.16

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	15180	0	334.8	215.2	-2.3	960	0.00
	Haryana	11790	0	266.0	212.2	-3.5	301	0.00
	Rajasthan	13654	0	298.2	104.8	-13.3	212	0.00
	Delhi	6939	0	140.1	129.0	-1.2	267	0.00
	UP	27050	0	537.0	255.2	-1.1	337	0.00
	Uttarakhand	2428	0	51.6	28.9	0.5	319	0.00
	HP	1722	0	37.2	-3.3	-0.4	41	0.00
	J&K(UT) & Ladakh(UT)	2550	0	52.4	28.1	-0.6	209	0.00
	Chandigarh	316	0	7.2	7.0	0.1	39	0.00
WR	Railways_NR ISTS	203	0	4.0	3.7	0.3	40	0.00
	Chhattisgarh	4792	0	104.9	61.4	-0.5	175	0.00
	Gujarat	18970	0	420.7	118.3	-4.6	837	0.00
	MP	10445	0	215.6	76.7	0.0	717	0.00
	Maharashtra	24222	0	517.9	154.2	-3.2	726	0.00
	Goa	560	0	14.4	11.9	2.0	82	0.00
	DNHDDPDCL	1397	0	31.8	32.0	-0.2	55	0.00
	AMNSIL	894	0	18.9	9.2	0.2	327	0.00
	BALCO	531	0	12.7	12.7	0.0	9	0.00
SR	RIL JAMNAGAR	248	0	4.0	4.1	-0.1	0	0.00
	Andhra Pradesh	11042	0	235.1	36.5	0.1	721	0.00
	Telangana	14487	0	262.7	122.0	0.6	718	0.00
	Karnataka	12274	0	223.0	20.2	-0.5	593	0.00
	Kerala	4091	0	77.7	35.0	-1.3	248	0.00
	Tamil Nadu	18882	0	407.0	166.9	-4.6	1282	0.00
	Puducherry	518	0	10.4	9.8	-0.1	63	0.00
ER	Bihar	7249	0	145.5	139.3	-4.0	260	0.00
	DVC	3265	0	68.1	-28.1	0.4	398	0.00
	Jharkhand	2147	0	42.7	32.4	0.2	78	0.00
	Odisha	5948	0	129.1	53.5	-1.9	455	0.00
	West Bengal	10081	0	217.8	91.1	-1.4	331	0.00
	Sikkim	78	0	1.4	1.1	0.3	37	0.00
NER	Railways_ER ISTS	10	0	0.1	0.2	-0.1	10	0.00
	Arunachal Pradesh	220	0	3.9	3.4	-0.1	46	0.00
	Assam	2469	0	49.5	42.9	-0.1	150	0.00
	Manipur	219	0	3.2	3.1	0.1	49	0.00
	Meghalaya	328	0	5.8	1.4	-0.1	139	0.00
	Mizoram	122	0	1.8	1.6	-0.7	6	0.00
	Nagaland	184	0	3.0	2.8	-0.2	21	0.00
	Tripura	305	0	6.0	4.3	0.2	37	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	49.9	17.1	-22.9	-27.6
Day Peak (MW)	2269.6	842.7	-970.8	-1466.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	403.8	-353.6	-4.8	-52.6	7.2	0.0
Actual(MU)	372.7	-330.8	-10.2	-44.2	7.3	-5.3
O/D/U/D(MU)	-31.1	22.8	-5.4	8.4	0.1	-5.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	4934	14791	6768	5340	447	32280	47
State Sector	9469	13675	10797	2642	259	36842	53
Total	14403	28466	17565	7982	706	69121	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	720	1253	540	618	12	3142	59
Lignite	22	10	34	0	0	66	1
Hydro	401	85	197	92	37	813	15
Nuclear	37	35	69	0	0	142	3
Gas, Naptha & Diesel	13	19	4	0	20	56	1
RES (Wind, Solar, Biomass & Others)	259	380	437	3	1	1080	20
Total	1451	1782	1282	713	70	5299	100

Share of RES in total generation (%)	17.83	21.34	34.11	0.42	1.48	20.39
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	48.02	28.06	54.92	13.36	54.27	38.40

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.050
Based on State Max Demands	1.098

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	216397	10:24	0
Non-Solar hr	215814	19:44	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 30-Jul-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	752	0.0	17.8	-17.8
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.5	-2.5
3	765 kV	GAYA-VARANASI	2	697	678	0.0	1.6	-1.6
4	765 kV	SASARAM-FATEHPUR	1	291	373	0.0	1.3	-1.3
5	765 kV	GAYA-BALIA	1	0	862	0.0	12.0	-12.0
6	400 kV	PUSAULI-VARANASI	1	0	106	0.0	1.5	-1.5
7	400 kV	PUSAULI-ALLAHABAD	1	8	66	0.0	0.9	-0.9
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	90	533	0.0	5.6	-5.6
9	400 kV	PATNA-BALIA	2	260	608	0.0	6.2	-6.2
10	400 kV	NAUBATPUR-BALIA	2	128	179	0.0	1.2	-1.2
11	400 kV	BIHARSHARIFF-BALIA	2	323	240	0.3	0.0	0.3
12	400 kV	MOTIHARI-GORAKHPUR	2	157	436	0.0	4.2	-4.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	123	297	0.0	2.6	-2.6
14	220 kV	SAHUPURI-KARAMNASA	1	0	98	0.0	1.2	-1.2
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	0	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAUJI	1	0	0	0.0	0.0	0.0
ER-NR						0.9	58.6	-57.6
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	1448	217	14.6	0.0	14.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2016	0	33.4	0.0	33.4
3	765 kV	JHARSUGUDA-DURG	2	200	345	0.0	1.0	-1.0
4	400 kV	JHARSUGUDA-RAIGARH	4	444	176	3.9	0.0	3.9
5	400 kV	RANCHI-SIPAT	2	484	86	6.7	0.0	6.7
6	400 kV	JEYPORE-JAGDALPUR	2	152	402	0.0	3.1	-3.1
7	220 kV	BUDHIPADAR-RAIGARH	1	41	115	0.0	1.0	-1.0
8	220 kV	BUDHIPADAR-KORBA	2	71	114	0.0	0.8	-0.8
ER-WR						58.7	5.8	52.9
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZIWAKA B/B	2	303	0	7.2	0.0	7.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1755	0.0	27.8	-27.8
3	765 kV	ANGUL-SRIKAKULAM	2	0	2958	0.0	38.2	-38.2
4	400 kV	TALCHER-I/C	2	804	1049	1.4	0.0	1.4
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						7.2	66.0	-58.8
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	10	419	0.0	4.1	-4.1
2	400 kV	ALIPURDUAR-BONGAIGAON	2	0	656	0.0	8.3	-8.3
3	220 kV	ALIPURDUAR-SALAKATI	2	0	121	0.0	1.7	-1.7
ER-NER						0.0	14.1	-14.1
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	0	353	0.0	8.5	-8.5
NER-NR						0.0	8.5	-8.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3926	0.0	61.8	-61.8
2	HVDC	VINDHYACHAL B/B	-	0	156	0.0	3.6	-3.6
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2365	0.0	46.6	-46.6
4	765 kV	GWALIOR-AGRA	2	0	2998	0.0	46.0	-46.0
5	765 kV	GWALIOR-PHAGI	2	1066	1804	5.6	20.5	-14.9
6	765 kV	JABALPUR-ORAI	2	0	1487	0.0	39.6	-39.6
7	765 kV	GWALIOR-ORAI	1	612	154	7.0	0.4	6.6
8	765 kV	SATNA-ORAI	1	0	1135	0.0	15.1	-15.1
9	765 kV	BANASKANTHA-CHITORGARH	2	0	1217	0.0	15.6	-15.6
10	765 kV	VINDHYACHAL-VARANASI	2	0	3529	0.0	63.0	-63.0
11	400 kV	ZERDA-KANKROLI	1	158	139	0.7	0.9	-0.2
12	400 kV	ZERDA -BHINMAL	1	109	96	0.5	0.7	-0.2
13	400 kV	VINDHYACHAL -RIHAND	1	0	1	0.0	0.0	0.0
14	400 kV	RAPP-SHUJALPUR	2	417	644	2.5	6.1	-3.6
15	400 kV	NEEMUCH-Chittorgarh	2	390	742	2.1	7.1	-5.1
16	220 kV	BHANPURA-RANPUR	1	0	131	0.0	2.6	-2.6
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.1	-2.1
18	220 kV	MEHGAON-AURAIYA	1	68	48	0.2	0.4	-0.2
19	220 kV	MALANPUR-AURAIYA	1	46	58	0.1	0.6	-0.6
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						18.7	332.7	-314.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1003	0	12.1	0.0	12.1
2	HVDC	RAIGARH-PUGALUR	2	1157	0	21.4	0.0	21.4
3	765 kV	SOLAPUR-RAICHUR	2	2121	1273	20.9	2.1	18.9
4	765 kV	WARDHA-NIZAMABAD	2	12	3132	0.0	27.0	-27.0
5	765 kV	WARORA-WARANGAL(NEW)	2	42	3116	0.0	26.5	-26.5
6	400 kV	KOLHAPUR-KUDGI	2	2198	0	35.3	0.0	35.3
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	109	2.0	0.0	2.0
WR-SR						91.7	55.6	36.2
INTERNATIONAL EXCHANGES								
						Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	1206	0	1145	27.47		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	864	785	831	19.95		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	153	93	102	2.44		
	NER	132kV GELEPHU-SALAKATI	41	23	33	0.79		
	NER	132kV MOTANGA-RANGIA	54	14	41	0.99		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-56	0	0	0.00		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	38	0	12	0.30		
	ER	NEPAL IMPORT (FROM BIHAR)	153	97	131	3.15		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	632	488	571	13.69		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-944	-908	-912	-21.89		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1466	-901	-1150	-27.60		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-60	0	-41	-0.98		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.26	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.26
Bangladesh	22.51	0.14	0.00	0.00	0.00	0.00	0.00	0.00	22.65
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	22.77	0.14	0.00	0.00	0.00	0.00	0.00	0.00	22.91

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	51.41	0.00	1.95	0.00	0.00	0.24	0.00	0.00	53.60
Nepal	8.40	0.14	4.97	0.00	0.00	2.90	0.00	0.00	16.41
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	59.81	0.14	6.92	0.00	0.00	3.14	0.00	0.00	70.01

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	51.41	0.00	1.95	0.00	0.00	0.24	0.00	0.00	53.60
Nepal	8.14	0.14	4.97	0.00	0.00	2.90	0.00	0.00	16.15
Bangladesh	-22.51	-0.14	0.00	0.00	0.00	0.00	0.00	0.00	-22.65
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	37.04	0.00	6.92	0.00	0.00	3.14	0.00	0.00	47.10

Date of Reporting: 30-Jul-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E +F+G+H)	(K)
0:00	50.02	207767	5499	23256	0	32671	2350	142152	1896	184511	207824	1833
0:15	50.02	206406	5487	23118	0	32908	2322	141475	1921	183288	207231	1814
0:30	50.02	205456	5505	23295	0	33322	2307	140054	1920	182161	206403	1812
0:45	50.02	204122	5506	23735	0	33209	2338	138390	1897	180387	205075	1809
1:00	50.02	202265	5508	23546	0	32949	2332	136559	1899	178719	202793	1868
1:15	50.02	200417	5515	23643	0	32490	2310	135213	1903	176774	201074	1850
1:30	50.02	198939	5522	23871	0	31848	2195	134123	1893	175068	199452	1854
1:45	50.02	197253	5511	24143	0	31255	2187	132945	1909	173110	197950	1873
2:00	50.02	196510	5497	24263	0	31285	2188	131942	1888	172247	197063	1874
2:15	49.97	195674	5528	24428	0	31005	2188	131352	1857	171246	196358	1911
2:30	50.02	194842	5528	24754	0	30893	2183	130525	1863	170088	195746	1903
2:45	49.97	194552	5513	24445	0	31041	2189	130096	1856	170107	195140	1881
3:00	49.97	194138	5516	24253	0	30825	2191	130334	1861	169885	194980	1889
3:15	49.97	193604	5519	24101	0	30879	2189	130069	1875	169503	194632	1847
3:30	50.02	192763	5512	24301	0	30760	2188	129313	1852	168462	193926	1894
3:45	50.07	191972	5521	24917	0	30359	2193	127983	1943	167055	192916	1909
4:00	50.07	191337	5521	25633	0	29836	2201	127251	1830	165704	192272	1939
4:15	50.03	191808	5516	25743	0	29968	2200	127374	1865	166065	192666	1941
4:30	50.03	192120	5526	25738	0	30084	2197	127747	1845	166382	193137	1898
4:45	50.03	192605	5505	25827	0	30476	2195	127773	1643	166778	193419	1884
5:00	50.08	192388	5504	26077	116	30483	2196	127588	1658	166195	193622	1876
5:15	50.03	192897	5508	26258	117	30226	2204	128106	1656	166522	194075	1915
5:30	50.03	194018	5509	26113	118	30505	2198	129041	1655	167787	195139	1943
5:45	49.98	195086	5524	25865	116	30678	2199	130070	1630	169105	196082	1954
6:00	49.98	197034	5517	25957	128	30705	2209	131614	1614	170949	197744	1823
6:15	49.98	199936	5517	26032	646	31210	2208	133406	1680	173258	200699	1852
6:30	49.98	202628	5516	25894	1500	31984	2206	134707	1646	175234	203453	1912
6:45	49.98	203608	5517	26076	2907	32238	2200	134001	1585	174625	204524	1894
7:00	50.08	203258	5522	26122	4752	31780	2193	132346	1622	172384	204337	1883
7:15	50.03	204294	5521	26472	7307	31376	2185	130751	1890	170515	205502	1873
7:30	50.03	204315	5525	26428	10043	30935	2178	127959	1940	167844	205008	1854
7:45	50.03	205033	5527	26958	12910	30826	2180	125747	1863	165165	206011	1845
8:00	50.09	204737	5527	27642	16314	30433	2187	122021	1887	160781	206011	1874
8:15	50.09	205645	5525	27980	19249	29653	2173	120697	1886	158416	207163	1906
8:30	50.14	207333	5507	28527	21806	29693	2157	119754	1659	157000	209103	1856
8:45	50.08	209232	5520	29267	24733	29789	2168	117771	1675	155232	210923	1860
9:00	50.08	210829	5515	29970	27339	29821	2167	116018	1719	153520	212549	1879
9:15	50.03	213579	5493	30189	31368	29524	2288	114888	1781	152022	215531	1866
9:30	50.03	214340	5489	30170	34121	29546	2179	113018	1710	150049	216233	1866
9:45	50.03	215592	5501	30361	36155	29704	2174	111514	1749	149076	217158	1886
10:00	50.03	215212	5487	30039	38691	30005	2236	109031	1724	146482	217213	1882
10:15	49.98	215740	5483	30119	39798	29985	2250	107084	1754	145823	216473	1850
10:30	50.13	215393	5516	30215	42727	29348	2269	104938	1781	142451	216794	1812
10:45	49.98	214154	5492	30191	43566	30502	2261	102197	1746	140397	215955	1828
11:00	50.03	214695	5501	30083	45241	29753	2265	101973	1729	139371	216545	1802
11:15	49.98	212854	5516	30184	44885	29110	2273	100845	1762	137785	214575	1859
11:30	50.03	212982	5498	30012	45876	29104	2245	100116	1770	137094	214621	1875
11:45	49.93	212616	5486	30007	44305	29609	2245	100761	1774	138304	214187	1901
12:00	49.98	211767	5505	30204	44628	29525	2248	99837	1748	136935	213695	1852
12:15	49.94	210423	5500	30228	43742	29100	2244	99599	1782	136453	212195	1867
12:30	50.04	210164	5508	30392	45149	28515	2249	98437	1807	134623	212057	1887
12:45	50.04	209373	5508	29868	45770	28154	2213	97527	1765	133735	210805	1895
13:00	50.14	205633	5492	29801	44988	28209	2217	95915	1776	130845	208398	1890
13:15	50.14	202917	5515	29480	43805	27277	2248	95572	1739	129632	205636	1908
13:30	50.09	202502	5505	29663	40604	27377	2258	97115	1764	132235	204286	1914
13:45	49.93	203543	5514	29765	38586	28273	2195	98936	1872	135192	205141	1896
14:00	50.03	204294	5507	29699	39116	28733	2249	98798	1852	135479	205954	1903
14:15	49.93	206248	5500	29939	39491	28646	2230	99611	1835	136818	207252	1904
14:30	49.93	206245	5495	29904	39858	28718	2244	100944	1844	136483	209007	1958
14:45	50.08	208146	5490	28914	41681	28831	2244	100820	1845	137551	209825	1869
15:00	50.19	208810	5509	29971	40619	28809	2235	101646	1813	138220	210602	1866
15:15	50.19	209080	5511	29930	39021	28780	2239	103545	1841	140129	210867	1879
15:30	50.19	208913	5511	29787	37856	28988	2297	104177	1834	141270	210450	1915
15:45	50.08	208766	5504	29415	35261	29438	2315	106362	1876	144090	210171	1890
16:00	49.98	208690	5482	29675	33415	29605	2301	108016	1864	145600	210358	1891
16:15	49.93	208447	5498	29935	30764	29465	2325	110130	1775	147748	209892	1887
16:30	49.88	209191	5491	30224	27957	30054	2241	112587	1759	151010	210313	1932
16:45	49.93	208727	5499	30121	25231	29450	2257	114706	1686	153375	208950	1939
17:00	50.03	206869	5506	29916	22036	29434	2207	116356	1666	154917	207121	1870
17:15	49.98	205226	5508	30046	18420	29571	2221	117621	1650	156760	205037	1950
17:30	49.98	204111	5500	29638	15098	29965	2326	119951	1658	159375	204136	1942
17:45	49.98	203741	5497	29617	11999	31064	2350	121468	1630	162125	203625	1941
18:00	50.08	203531	5495	30027	9296	31329	2347	123262	1677	164208	203433	1926
18:15	50.03	203351	5513	30177	7226	31006	2437	125047	1658	165948	203064	1917
18:30	50.08	205779	5506	29848	5182	31986	2521	128729	1580	170749	205352	1857
18:45	50.08	207708	5508	29843	3113	32599	2567	131564	1644	174752	206838	1813
19:00	50.03	209593	5505	29463	1932	32908	2606	134521	1712	178198	208647	1776
19:15	49.93	213111	5494	28636	943	34307	2610	138837	1728	183532	212555	1775
19:30	49.98	215323	5510	28305	409	34732	2593	141499	1897	186609	214945	1728
19:45	49.93	215721	5515	27918	182	35153	2600	142193	1860	187621	215421	1698
20:00	49.88	214579	5496	27165	170	35338	2613	141657	1860	187244	214299	1768
20:15	49.93	213946	5503	27024	0	34851	2602	141797	1874	186922	213651	1750
20:30	49.93	214314	5509	26746	0	34423	2581	142826	1875	187568	213960	1758
20:45	49.88	214149	5501	26372	0	35020	2611	142504	1868	187777	213876	1763
21:00	50.03	213907	5503	26018	0	34721	2580	142968	1865	187889	213655	1730
21:15	49.98	213458	5509	25557	0	34470	2535	143395	1859	187901	213325	1744
21:30	50.03	213879	5491	25544	0	33784	2560	144161	1941	188335	213481	1809
21:45	50.03	213031	5517	25280	0	34261	2621	143466	1898	187751	213043	1799
22:00	50.03	212519	5513	25537	0	33880	2617	143022	1900	186982	212469	1845
22:15	49.98	212870	5501	25108	0	34365	2578	143045	1891			