



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 02.12.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 01.12.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 1-दिसंबर-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 01.12.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 02-Dec-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	54044	63093	46436	21331	2721	187625
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1190	1483	1044	437	50	4203
Hydro Gen (MU)	122	46	110	25	14	317
Wind Gen (MU)	5	38	30	-	-	73
Solar Gen (MU)*	165.61	139.55	110.96	1.77	0.91	419
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	62811	70725	51909	22207	2931	206206
Time Of Maximum Demand Met	10:25	09:58	10:58	17:49	17:12	10:14

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.070	0.81	1.42	11.55	13.78	72.10	14.12

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8893	0	157.4	68.9	-0.4	704	0.00
	Haryana	8511	0	156.8	129.8	-1.8	512	0.00
	Rajasthan	17600	0	323.0	122.0	-0.4	1035	0.00
	Delhi	4157	0	75.6	68.8	0.9	339	0.00
	UP	18430	0	328.1	77.9	-1.1	575	0.00
	Uttarakhand	2146	0	39.8	30.1	0.2	126	0.00
	HP	2104	0	36.8	26.9	-0.6	104	0.00
	J&K(UT) & Ladakh(UT)	3078	0	64.6	59.3	-0.4	320	0.00
	Chandigarh	221	0	3.7	3.8	0.0	17	0.00
	Railways_NR ISTS	204	0	4.1	3.8	0.3	36	0.00
WR	Chhattisgarh	4514	0	88.7	28.0	0.2	407	0.00
	Gujarat	22308	0	432.1	202.9	-3.9	913	0.00
	MP	18013	0	331.3	208.3	0.0	797	0.00
	Maharashtra	25886	0	549.6	187.2	-0.7	989	0.00
	Goa	715	0	14.1	11.7	2.2	69	0.00
	DNHDDPDCL	1269	0	28.7	28.8	-0.1	42	0.00
	AMNSIL	929	0	19.3	11.8	0.4	318	0.00
	BALCO	557	0	13.3	13.2	0.1	163	0.00
	RIL JAMNAGAR	253	0	5.9	6.0	-0.1	0	0.00
	Andhra Pradesh	8987	0	188.3	47.6	1.5	552	0.00
SR	Telangana	11242	0	203.9	86.0	-1.0	522	0.00
	Karnataka	15620	0	274.0	112.0	0.9	1183	0.00
	Kerala	4441	0	82.6	64.4	-0.9	184	0.00
	Tamil Nadu	14943	0	287.7	178.6	2.2	1153	0.00
	Puducherry	360	0	7.6	7.2	-0.2	48	0.00
	Bihar	4895	0	90.2	76.0	0.2	137	0.00
ER	DVC	3056	0	62.1	-47.7	-1.1	272	0.00
	Jharkhand	2041	0	39.1	28.6	-1.0	254	0.00
	Odisha	4983	0	96.0	16.0	-3.2	437	0.00
	West Bengal	7489	0	147.5	34.4	-1.9	175	0.00
	Sikkim	102	0	1.6	1.6	0.0	28	0.00
	Railways_ER ISTS	27	0	0.1	0.2	0.0	4	0.00
NER	Arunachal Pradesh	169	0	3.0	2.9	-0.1	21	0.00
	Assam	1606	0	27.6	21.1	0.2	115	0.00
	Manipur	259	0	3.8	3.7	0.1	28	0.00
	Meghalaya	347	0	5.9	5.0	-0.1	34	0.00
	Mizoram	148	0	2.1	1.8	-0.4	23	0.00
	Nagaland	158	0	2.7	2.6	-0.1	15	0.00
	Tripura	233	0	4.5	4.8	0.2	32	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.3	12.1	-21.9	-26.3
Day Peak (MW)	-464.9	735.8	-1013.6	-1345.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	226.5	-186.6	155.8	-201.3	5.6	0.0
Actual(MU)	208.8	-177.7	159.2	-208.6	4.0	-14.3
O/D/U/D(MU)	-17.7	9.0	3.5	-7.4	-1.7	-14.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5879	13270	8278	5720	105	33252	48
State Sector	12534	12030	9282	2187	205	36237	52
Total	18413	25299	17560	7907	310	69489	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	681	1468	606	693	13	3461	75
Lignite	25	13	38	0	0	76	2
Hydro	122	46	110	25	14	317	7
Nuclear	37	53	46	0	0	136	3
Gas, Naptha & Diesel	9	21	4	0	23	58	1
RES (Wind, Solar, Biomass & Others)	191	179	166	4	1	542	12
Total	1066	1781	970	722	51	4590	100

Share of RES in total generation (%)	17.96	10.07	17.10	0.61	1.83	11.81
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	32.91	15.65	33.18	4.09	28.57	21.69

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.021
Based on State Max Demands	1.071

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	206206	10:14	0
Non-Solar hr	197416	17:54	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve)/Export =(-ve) for NET (MU)
Date of Reporting: 02-Dec-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYAVARANASI	2	0	1450	0.0	23.3	-23.3
4	765 kV	SASARAM-FATEHPUR	1	0	732	0.0	12.6	-12.6
5	765 kV	GAYA-BALIA	1	0	660	0.0	10.4	-10.4
6	400 kV	PUSAULI-VARANASI	1	47	42	0.3	0.0	0.3
7	400 kV	PUSAULI-ALLAHABAD	1	0	150	0.0	2.3	-2.3
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	9	802	0.0	10.3	-10.3
9	400 kV	PATNA-BALIA	2	0	985	0.0	16.3	-16.3
10	400 kV	NAUBATPUR-BALIA	2	39	275	0.0	5.4	-5.4
11	400 kV	BIHARSHARIFF-BALIA	2	163	367	0.0	3.3	-3.3
12	400 kV	MOTIHARI-GORAKHPUR	2	0	567	0.0	8.4	-8.4
13	400 kV	BIHARSARIFF-SAHUPURI	2	0	559	0.0	8.1	-8.1
14	220 kV	SAHUPURI-KARMANASA	1	26	3	0.0	1.7	-1.7
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.5	0.0	0.5
17	132 kV	KARMANASA-SAHUPURI	1	0	1	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	2	0	0.0	0.0	0.0
ER-NR						0.8	104.5	-103.7
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1334	0.0	20.5	-20.5
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	221	1317	0.0	15.1	-15.1
3	765 kV	JHARSUGUDA-DURG	2	0	1318	0.0	25.2	-25.2
4	400 kV	JHARSUGUDA-RAIGARH	4	106	346	0.0	2.8	-2.8
5	400 kV	RANCHI-SIPAT	2	75	374	0.0	4.0	-4.0
6	400 kV	JEYPORE-JACDALPUR	2	284	197	2.5	0.0	2.5
7	220 kV	BUDHIPADAR-RAIGARH	1	0	140	0.0	2.0	-2.0
8	220 kV	BUDHIPADAR-KORBA	2	72	56	0.4	0.0	0.4
ER-WR						2.9	69.6	-66.7
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	320	0.0	7.5	-7.5
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1613	0.0	37.5	-37.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2726	0.0	50.4	-50.4
4	400 kV	TALCHER I/C	2	673	316	6.0	0.0	6.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	95.5	-95.5
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	340	67	2.6	0.1	2.5
2	400 kV	ALIPURDUAR-BONGAIGAON	2	609	0	5.9	0.0	5.9
3	220 kV	ALIPURDUAR-SALAKATI	2	119	0	1.4	0.0	1.4
ER-NER						9.9	0.1	9.8
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	661	0	15.6	0.0	15.6
NER-NR						15.6	0.0	15.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3036	0.0	62.3	-62.3
2	HVDC	VINDHYACHAL B/B	-	242	0	6.1	0.0	6.1
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1456	0.0	25.7	-25.7
4	765 kV	GWALIOR-AGRA	2	67	1567	0.0	19.3	-19.3
5	765 kV	GWALIOR-PHAGI	2	41	2165	0.0	35.1	-35.0
6	765 kV	JABALPUR-ORAI	2	0	981	0.0	28.5	-28.5
7	765 kV	GWALIOR-ORAI	1	1044	0	18.2	0.0	18.2
8	765 kV	SATNA-ORAI	1	0	1103	0.0	21.1	-21.1
9	765 kV	BANASKANTHA-CHITORGARH	2	2694	0	35.0	0.0	35.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	1924	0.0	26.0	-26.0
11	400 kV	ZERDA-KANKROLI	1	420	0	6.1	0.0	6.1
12	400 kV	ZERDA -BHINMAL	1	289	0	4.2	0.0	4.2
13	400 kV	VINDHYACHAL -RIHAND	1	980	0	20.9	0.0	20.9
14	400 kV	RAPP-SHUJALPUR	2	501	310	2.2	1.7	0.5
15	400 kV	NEEMUCH-Chittorgarh	2	520	391	2.2	2.8	-0.6
16	220 kV	BHANPURA-RANPUR	1	0	135	0.0	2.1	-2.1
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.4	-1.4
18	220 kV	MEHGAON-AURAIYA	1	104	0	1.0	0.0	1.0
19	220 kV	MALANPUR-AURAIYA	1	76	11	0.6	0.0	0.6
20	132 kV	RAIGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						96.5	225.8	-129.4
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	512	0.0	8.0	-8.0
2	HVDC	RAIGARH-PUGALUR	2	0	4007	0.0	70.6	-70.6
3	765 kV	SOLAPUR-RAICHUR	2	553	1402	1.2	7.5	-6.2
4	765 kV	WARDHA-NIZAMABAD	2	0	1541	0.0	18.9	-18.9
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2517	0.0	36.0	-36.0
6	400 kV	KOLHAPUR-KUDGI	2	1427	0	22.9	0.0	22.9
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	108	2.1	0.0	2.1
WR-SR						26.3	141.1	-114.8

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 I.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-142	73	6	0.15
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) I.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	287	-25	154	3.70
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) I.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-294	-244	-275	-6.61
	NER	132kV GELEPHU-SALAKATI	-61	0	-55	-1.31
	NER	132kV MOTANGA-RANGIA	-15	0	-8	-0.20
NEPAL	NR	NEPAL IMPORT (FROM UP)	0	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	58	0	40	0.97
	ER	NEPAL IMPORT (FROM BIHAR)	0	0	0	0.00
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	636	211	463	11.11
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-901	-652	-816	-19.58
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1345	-817	-1095	-26.27
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-119	0	-98	-2.34

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 02-Dec-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.31	4.40	0.00	0.00	0.00	0.00	0.00	4.71
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	20.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	20.40
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	20.40	0.31	4.40	0.00	0.00	0.00	0.00	0.00	25.11

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	0.00	0.00	0.81	0.00	0.00	10.72	0.00	0.00	11.53
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.00	0.00	0.81	0.00	0.00	10.72	0.00	0.00	11.53

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL	
		BILATERAL TOTAL	COLLECTIVE							
			IDAM			RTM				
			IEX	PXIL	HPX	IEX	PXIL	HPX		
Bhutan	0.00	-0.31	-4.40	0.00	0.00	0.00	0.00	0.00	-4.71	
Nepal	0.00	0.00	0.81	0.00	0.00	0.00	10.72	0.00	0.00	11.53
Bangladesh	-20.40	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-20.40
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-20.40	-0.31	-3.59	0.00	0.00	0.00	10.72	0.00	0.00	-13.58

15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	50.05	138617	5045	4445	0	6899	2000	121348	2851	134172	142588	-518
0:15	50.00	138579	5051	4279	0	7052	1989	121280	2846	134300	142497	-515
0:30	50.00	138433	5054	4210	0	7647	1996	120358	2858	134223	142123	-473
0:45	49.95	137622	5060	4247	0	7564	2012	119410	2926	133375	141219	-514
1:00	49.95	137342	5048	4279	0	7754	2011	119069	2846	133063	141007	-474
1:15	49.95	137113	5066	4188	0	7849	2011	118789	2812	132925	140715	-424
1:30	49.95	136524	5054	4089	0	7534	2001	118530	2852	132435	140060	-398
1:45	49.90	136304	5051	4035	0	7402	1989	118447	2822	132269	139746	-423
2:00	49.95	135220	5061	3996	0	7350	1993	117486	2819	131224	138705	-413
2:15	49.95	134763	5062	3792	0	7350	1989	117205	2869	130971	138267	-388
2:30	49.95	134703	5067	3669	0	7067	1989	117481	2839	131034	138112	-347
2:45	49.95	134958	5063	3613	0	7060	2010	117847	2869	131345	138462	-395
3:00	49.95	134471	5067	3487	0	7046	2007	117751	2824	130984	138182	-386
3:15	49.89	134865	5080	3382	0	6818	1999	118411	2843	131483	138533	-365
3:30	49.95	135174	5064	3333	0	6941	2005	118587	2858	131841	138788	-371
3:45	50.00	135375	5076	3251	0	6955	2010	118757	2877	132124	138926	-374
4:00	50.00	135401	5076	3120	0	7057	2022	118976	2793	132281	139044	-389
4:15	49.89	136849	5061	2992	0	7536	2061	119895	2878	133857	140423	-377
4:30	49.94	138819	5072	2856	0	7545	2080	122058	2795	135963	142406	-354
4:45	49.94	140574	5083	2735	0	7880	2069	123523	2835	137839	144125	-369
5:00	50.04	142920	5066	2775	214	8235	2076	125458	2855	139931	146679	-251
5:15	49.89	147825	5075	2770	220	9091	2101	129552	2925	144835	151734	-243
5:30	49.99	152600	5063	2777	191	9885	2130	133526	2867	149632	156439	-188
5:45	49.99	157375	5069	2701	225	11406	2164	137343	2940	154449	161848	-181
6:00	50.09	161127	5085	2642	166	13346	2119	139761	2903	158319	166022	-203
6:15	49.99	166248	5088	2635	292	15054	2176	143601	2837	163321	171683	-272
6:30	50.04	173428	5057	2693	308	18360	2179	147785	2880	170427	179262	-258
6:45	49.94	179054	5077	2782	540	21485	2194	150682	2860	175732	185620	-330
7:00	49.99	183785	5081	2881	1131	22315	2226	153819	2895	179773	190348	-366
7:15	49.69	188204	5085	2930	1928	23412	2263	156019	2970	182346	194607	-479
7:30	49.89	191887	5076	3040	3668	24109	2242	157104	2959	185179	198198	-454
7:45	50.04	193612	5088	3079	6760	23669	2231	155745	2926	183773	199498	-465
8:00	50.09	192937	5077	3091	10874	20506	2240	153536	3004	178972	198328	-441
8:15	50.09	195231	5091	2985	15839	18378	2236	153041	2976	176407	200546	-599
8:30	50.14	196642	5084	2866	20930	15699	2234	151586	2898	172846	201297	-574
8:45	50.14	198337	5078	2710	27566	13413	2241	149687	2883	168061	203578	-522
9:00	50.34	199622	5096	2572	32723	11226	2226	147665	2863	164327	204371	-638
9:15	50.09	202972	5090	2524	37768	10754	2195	146791	2847	162680	207969	-661
9:30	50.04	204698	5085	2381	42652	10926	2171	143506	2810	159665	209531	-751
9:45	50.04	205761	5059	2228	47085	10643	2177	140674	2893	156448	210759	-779
10:00	50.04	205331	4746	2035	50641	9970	2168	137693	2859	152655	210112	-868
10:15	49.99	206145	5062	1977	53072	8519	2173	137252	2861	151096	210916	-976
10:30	49.89	205365	5064	1905	54722	8067	2175	135543	2852	148738	210328	-1001
10:45	49.89	205001	5042	1832	56706	7953	2185	134456	2854	146463	211028	-1038
11:00	49.89	204706	5040	1800	58183	7932	2146	133125	2824	144723	211050	-1001
11:15	50.04	202637	5049	1789	59103	7656	2141	131042	2863	141745	209643	-1057
11:30	50.04	201912	5058	1738	60115	7403	2125	129373	2839	140059	208651	-1143
11:45	49.99	200719	5063	1733	60710	7203	2133	127758	2841	138276	207441	-1108
12:00	49.99	199833	5050	1717	60690	7194	2129	126764	2886	137426	206430	-1113
12:15	49.94	197689	5040	1675	61256	6864	2130	123676	2862	134758	203503	-1135
12:30	49.99	196829	5045	1688	61205	7130	2120	122869	2820	133936	202877	-1150
12:45	49.89	197187	5039	1663	61306	7072	2131	122599	2896	134218	202706	-1149
13:00	50.09	194787	5048	1632	60885	7136	2116	121443	2787	132270	201047	-1128
13:15	50.04	192018	5043	1638	60361	6904	2139	119976	2806	130019	198867	-1128
13:30	49.98	190917	5051	1386	59480	6578	2113	119672	2975	130051	197255	-1094
13:45	49.93	192247	5038	1428	56904	6626	2110	122271	2830	133915	197207	-1062
14:00	49.98	192612	5028	1423	54677	7222	2085	124422	2867	136512	197724	-1114
14:15	49.88	193313	5014	1408	52158	7802	2095	127109	2905	139747	198491	-1106
14:30	49.93	194012	5038	1384	50130	8261	2092	129418	2869	142498	199192	-1137
14:45	49.88	194422	5034	1371	48474	8529	2077	131135	2925	144577	199545	-1080
15:00	49.98	195315	5029	1395	45806	8690	2092	134814	2896	148114	200722	-931
15:15	49.98	194631	5047	1466	42378	8847	2073	136977	2824	150787	199612	-833
15:30	49.98	195325	5033	1527	38356	9768	2076	140917	2831	155442	200508	-673
15:45	49.93	195600	5041	1553	34175	10594	2407	144101	2822	159872	200693	-706
16:00	50.03	194365	5049	1646	29572	11732	2659	146370	2861	163147	199889	-712
16:15	49.98	192265	5043	1698	24510	12963	2994	148141	2856	166057	198205	-683
16:30	50.03	192375	5038	1796	19370	15518	3143	150708	2836	171209	198409	-665
16:45	50.03	192911	5053	1900	14445	18103	3345	153234	2860	176566	198940	-669
17:00	50.08	193328	5051	2131	9182	21618	3836	154966	2894	182015	199678	-550
17:15	49.98	191987	5058	2300	5382	23957	4032	154693	2963	184305	198385	-589
17:30	50.03	195235	5062	2478	2946	28421	4119	156297	2918	189811	202241	-667
17:45	49.93	196249	5056	2677	1247	29918	4101	157272	2876	192325	203147	-638
18:00	49.98	197207	5051	3007	757	30168	4098	158173	2938	193443	204192	-552
18:15	49.88	196899	5066	3241	658	30254	3779	158137	2908	193000	204043	-502
18:30	50.03	196277	5064	3510	673	29781	3982	157274	2954	192094	203238	-529
18:45	50.03	194320	5078	3773	381	28725	3775	156488	2980	190166	201200	-507
19:00	50.03	191961	5070	3936	351	27134	2563	156754	2889	187674	198697	-491
19:15	50.03	188800	5066	4007	337	25557	2417	155285	2875	184456	195544	-471
19:30	49.98	185562	4883	3948	0	23401	2420	154642	2897	181614	192191	-463
19:45	50.03	182161	4874	3891	0	21796	2452	152815	2890	178270	188718	-451
20:00	50.08	178199	4890	3901	0	19942	2450	150410	2919	174298	184512	-441
20:15	50.03	175809	4893	4050	0	17448	2568	149855	3046	171759	181860	-374
20:30	50.03	173868	5070	3987	0	15726	2386	148675	2970	169881	178814	-379
20:45	49.95	171813	5066	3953	0	14429	2341	147762	2961	167860	176512	-355
21:00	50.00	168887	5078	3907	0	13632	2417	145416	3023	164980	173473	-356
21:15	50.00	167122	5070	4044	0	13541	2504	143168	2978	163078	171305	-357
21:30	50.05	164862	5079	4055	0	12428	2513	142038	2977	160807	169090	-332
21:45	50.05	162015	5076	4029	0	10797	2425	140955	2987	157986	166269	-298
22:00	50.05	158479	5075	4057	0	10017	2367	138608	2976	154422	163100	-428
22:15	50.00	158345	5070	3975	0	9836	2329	138876	3045	154370	163131	-526
22:30	50.00	156604	5072	4003	0	8825	2231	138467	2990	152601	161588	-489
22:45	49.95	154711	5073	3942	0	8122	2200					