



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 25.05.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापालंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 24.05.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 24-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 24.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 25-May-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	66147	62283	44478	27282	3502	203692
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1634	1472	1001	598	65	4771
Hydro Gen (MU)	354	46	70	42	25	537
Wind Gen (MU)	25	156	209	-	-	390
Solar Gen (MU)*	213.08	128.83	102.21	3.11	0.87	448
Energy Shortage (MU)	0.00	0.00	0.00	0.00	0.00	0.00
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	78130	64060	45015	28641	3583	215361
Time Of Maximum Demand Met	00:00	00:01	11:54	23:49	18:52	00:00

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.036	0.00	0.00	2.06	2.06	71.36	26.58

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	13149	0	229.0	131.6	-7.4	601	0.00
	Haryana	11323	0	231.4	167.7	-1.1	510	0.00
	Rajasthan	17037	0	362.5	143.0	-0.9	660	0.00
	Delhi	6755	0	136.0	127.1	-3.1	186	0.00
	UP	28216	0	532.6	233.9	-0.5	558	0.00
	Uttarakhand	2668	0	56.0	33.8	0.8	242	0.00
	HP	1791	0	36.7	2.9	-2.7	104	0.00
	J&K(UT) & Ladakh(UT)	2640	0	54.8	25.1	14.8	1264	0.00
	Chandigarh	349	0	6.9	6.9	0.0	80	0.00
	Railways NR ISTS	222	0	4.5	3.9	0.5	53	0.00
WR	Chhattisgarh	5006	0	111.8	58.4	3.2	327	0.00
	Gujarat	23423	0	486.7	170.5	-8.5	752	0.00
	MP	12498	0	277.0	172.0	-2.3	625	0.00
	Maharashtra	23830	0	515.9	173.4	-1.9	835	0.00
	Goa	702	0	14.5	12.5	1.7	42	0.00
	DNHDDPDCL	1337	0	30.1	30.2	-0.1	184	0.00
	AMNSIL	859	0	19.4	9.1	0.1	238	0.00
	BALCO	535	0	12.8	12.7	0.1	15	0.00
	RIL JAMNAGAR	184	0	3.4	3.5	-0.1	0	0.00
	Andhra Pradesh	9209	0	199.7	41.6	-2.5	763	0.00
SR	Telangana	8745	0	188.1	87.9	2.3	1971	0.00
	Karnataka	9183	0	188.1	48.4	-1.1	763	0.00
	Kerala	3423	0	75.1	55.5	-2.2	461	0.00
	Tamil Nadu	15877	0	340.2	174.0	-5.6	1344	0.00
	Puducherry	471	0	10.2	10.4	-0.2	45	0.00
	Bihar	7097	0	139.0	138.4	-5.0	321	0.00
ER	DVC	3260	0	71.0	-21.7	0.5	415	0.00
	Jharkhand	2033	0	44.3	36.3	-0.7	169	0.00
	Odisha	5957	0	126.7	56.8	-1.0	493	0.00
	West Bengal	10505	0	215.9	86.7	-2.1	250	0.00
	Sikkim	77	0	1.2	1.5	-0.2	15	0.00
	Railways ER ISTS	22	0	0.2	0.2	0.0	3	0.00
NER	Arunachal Pradesh	197	0	2.8	2.8	-0.2	56	0.00
	Assam	2248	0	42.9	34.5	0.4	49	0.00
	Manipur	228	0	3.1	3.3	-0.3	67	0.00
	Meghalaya	341	0	5.7	0.7	-0.2	30	0.00
	Mizoram	131	0	2.1	1.9	-0.2	35	0.00
	Nagaland	187	0	2.8	2.9	-0.2	5	0.00
	Tripura	331	0	6.1	5.0	0.2	20	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	18.7	-1.1	-23.0	-28.3
Day Peak (MW)	1125.0	26.2	-992.0	-1476.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	287.9	-311.2	34.6	-21.4	10.2	0.0
Actual(MU)	287.6	-298.9	9.7	-13.9	10.9	-4.6
O/D/UD(MU)	-0.4	12.3	-24.9	7.6	0.7	-4.6

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3804	8050	6318	3435	335	21942	42
State Sector	5554	9969	12601	1909	179	30212	58
Total	9358	18018	18919	5344	514	52153	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	787	1458	514	646	11	3416	66
Lignite	26	15	36	0	0	77	2
Hydro	354	46	70	42	25	537	10
Nuclear	30	58	71	0	0	159	3
Gas, Naptha & Diesel	12	20	4	0	22	59	1
RES (Wind, Solar, Biomass & Others)	247	286	353	5	1	891	17
Total	1456	1884	1049	692	59	5140	100

Share of RES in total generation (%)	16.95	15.18	33.66	0.68	1.48	17.34
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	43.31	20.70	47.17	6.70	43.72	30.89

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.018
Based on State Max Demands	1.077

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	210319	15:18	0
Non-Solar hr	215361	0:00	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours > 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 25-May-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI-BB	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	780	316	3.9	0.0	3.9
4	765 kV	SASARAM-FATEHPUR	1	284	218	0.3	0.0	0.3
5	765 kV	GAYA-BALIA	1	0	712	0.0	10.4	-10.4
6	400 kV	PUSAULI-VARANASI	1	0	119	0.0	2.1	-2.1
7	400 kV	PUSAULI-ALLAHABAD	1	24	31	0.0	0.1	-0.1
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	277	470	0.0	3.1	-3.1
9	400 kV	PATNA-BALIA	2	0	605	0.0	6.0	-6.0
10	400 kV	NAUBATPUR-BALIA	2	103	305	0.0	1.0	-1.0
11	400 kV	BIHARSHARIFF-BALIA	2	277	137	1.2	0.0	1.2
12	400 kV	MOTIHARI-GORAKHPUR	2	99	355	0.0	3.2	-3.2
13	400 kV	BIHARSARIFF-SAHUPURI	2	109	122	0.0	1.1	-1.1
14	220 kV	SAHUPURI-KARAMNESA	1	0	103	0.0	2.4	-2.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						5.8	31.8	-26.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	812	824	0.0	4.2	-4.2
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2117	0	35.2	0.0	35.2
3	765 kV	JHARSUGUDA-DURG	2	67	474	0.0	5.9	-5.9
4	400 kV	JHARSUGUDA-JAIGARH	4	309	297	0.0	0.7	-0.7
5	400 kV	RANCHI-SIPAT	2	526	0	9.3	0.0	9.3
6	220 kV	BUDHIPADAR-RAIGARH	1	123	46	0.8	0.0	0.8
7	220 kV	BUDHIPADAR-KORBA	2	116	0	1.3	0.0	1.3
ER-WR						46.5	10.9	35.7
Import/Export of ER (With SR)								
1	HVDC	JEYPURE-GAZUWAKA B/B	2	714	0	7.2	0.0	7.2
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1615	0.0	33.5	-33.5
3	765 kV	ANGUL-SRIKAKULAM	2	0	2631	0.0	37.4	-37.4
4	400 kV	TALCHER-I/C	2	1365	592	4.0	0.0	4.0
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						7.2	70.9	-63.7
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	256	121	2.2	0.2	2.0
2	400 kV	ALIPURDUAR-BONGAIGAON	2	205	266	0.0	0.8	-0.8
3	220 kV	ALIPURDUAR-SALAKATI	2	60	38	0.2	0.0	0.2
ER-NER						2.4	1.0	1.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	461	0	11.2	0.0	11.2
NER-NR						11.2	0.0	11.2
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	4021	0.0	73.6	-73.6
2	HVDC	VINDHYACHAL B/B	-	160	146	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1449	0.0	27.2	-27.2
4	765 kV	GWALIOR-AGRA	2	0	2717	0.0	44.1	-44.1
5	765 kV	GWALIOR-PHAGI	2	795	1342	3.6	14.4	-10.8
6	765 kV	JABALPUR-ORAI	2	0	1199	0.0	34.4	-34.4
7	765 kV	GWALIOR-ORAI	1	614	0	10.0	0.0	10.0
8	765 kV	SATNA-ORAI	1	0	1115	0.0	19.3	-19.3
9	765 kV	BANASKANTHA-CHITORGARH	2	0	1177	0.0	16.5	-16.5
10	765 kV	VINDHYACHAL-VARANASI	2	0	3285	0.0	66.5	-66.5
11	400 kV	ZERDA-KANKROLI	1	58	221	0.1	1.8	-1.7
12	400 kV	ZERDA-BHINMAL	1	0	354	0.0	5.5	-5.5
13	400 kV	VINDHYACHAL-RIHAND	1	965	0	19.0	0.0	19.0
14	400 kV	RAPP-SHUJALPUR	2	325	510	1.5	3.9	-2.4
15	400 kV	NEEMUCH-Chittorgarh	2	289	416	1.3	3.3	-2.0
16	220 kV	BHANPURA-RANPUR	1	0	157	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	2.4	-2.4
18	220 kV	MEHGAON-AURAIYA	1	55	16	0.3	0.1	0.2
19	220 kV	MALANPUR-AURAIYA	1	31	28	0.1	0.2	-0.2
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						35.8	318.5	-282.7
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	1001	0	24.0	0.0	24.0
2	HVDC	RAIGARH-PUGALUR	2	0	1103	0.0	20.7	-20.7
3	765 kV	SOLAPUR-RAICHUR	2	1707	240	13.4	0.2	13.2
4	765 kV	WARDHAN-NIZAMABAD	2	686	1832	1.7	17.9	-16.2
5	765 kV	WARORA-WARANGAL(NEW)	2	411	1409	0.8	14.7	-13.8
6	400 kV	KOLHAPUR-KUDGI	2	2337	0	31.2	0.0	31.2
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	96	2.0	0.0	2.0
WR-SR						73.1	53.4	19.6

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHHU HEP 4*180MW)	905	300	695	16.67
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	213	41	127	3.05
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-123	-43	-88	-2.12
	NER	132kV GELEPHU-SALAKATI	19	-4	11	0.26
	NER	132kV MOTANGA-RANGIA	43	20	33	0.79
NEPAL	NR	NEPAL IMPORT (FROM UP)	-63	0	0	0.00
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-63	0	-42	-1.00
	ER	NEPAL IMPORT (FROM BIHAR)	-134	0	-47	-1.13
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	160	-14	42	1.01
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-948	-697	-923	-22.14
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1476	-811	-1177	-28.25
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-44	0	-38	-0.90

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 25-May-2025

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	1.34	0.00	0.00	0.00	0.00	0.44	0.00	0.00	1.78
Bangladesh	22.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.21	0.00	0.00	0.00	0.00	0.44	0.00	0.00	24.65

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	18.97	0.00	0.83	0.00	0.00	0.09	0.00	0.00	19.89
Nepal	0.00	0.00	0.00	0.00	0.00	1.11	0.00	0.00	1.11
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	18.97	0.00	0.83	0.00	0.00	1.20	0.00	0.00	21.00

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	18.97	0.00	0.83	0.00	0.00	0.09	0.00	0.00	19.89
Nepal	-1.34	0.00	0.00	0.00	0.00	0.67	0.00	0.00	-0.67
Bangladesh	-22.87	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.87
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-5.24	0.00	0.83	0.00	0.00	0.76	0.00	0.00	-3.65

