



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 11.05.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 10.05.2025.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 10-मई-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 10.05.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 11-May-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 20:00 hrs; from RLDCs)	65706	63191	52223	29747	2474	213341
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1408	1488	1260	668	62	4886
Hydro Gen (MU)	264	30	84	29	14	421
Wind Gen (MU)	6	72	66	-	-	144
Solar Gen (MU)*	206.29	131.63	139.08	4.12	1.08	482
Energy Shortage (MU)	0.00	0.00	0.00	0.05	0.00	0.05
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	65717	63943	59142	31977	3073	216414
Time Of Maximum Demand Met	20:21	23:36	15:21	23:41	18:41	14:57

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.057	0.32	2.21	3.31	5.84	66.77	27.38

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	9280	0	176.5	89.0	-4.9	849	0.00
	Haryana	8846	0	191.7	149.3	-2.6	453	0.00
	Rajasthan	13184	0	276.9	93.7	-1.8	598	0.00
	Delhi	5539	0	114.3	106.0	-4.2	201	0.00
	UP	26134	0	520.4	189.1	-0.5	444	0.00
	Uttarakhand	2207	0	49.4	32.1	0.1	259	0.00
	HP	1771	0	33.9	8.0	-0.7	190	0.00
	J&K(UT) & Ladakh(UT)	2695	0	35.5	24.1	-2.4	1537	0.00
	Chandigarh	248	0	4.9	5.1	-0.2	19	0.00
WR	Railways_NR ISTS	203	0	4.4	3.9	0.4	50	0.00
	Chhattisgarh	5559	0	125.7	63.6	1.3	299	0.00
	Gujarat	18670	0	402.8	164.3	-8.0	659	0.00
	MP	12392	0	276.3	164.0	-0.7	400	0.00
	Maharashtra	26246	0	603.0	207.6	0.6	723	0.00
	Goa	800	0	15.7	15.7	0.0	88	0.00
	DNHDDPDCL	1335	0	30.8	30.8	0.0	61	0.00
	AMNSIL	853	0	18.4	8.8	0.1	257	0.00
	BALCO	534	0	12.8	12.7	0.1	23	0.00
SR	RIL JAMNAGAR	180	0	2.3	2.4	-0.1	0	0.00
	Andhra Pradesh	11828	0	230.9	84.0	1.9	1020	0.00
	Telangana	9921	0	209.7	82.9	-0.1	439	0.00
	Karnataka	15450	0	311.3	114.1	0.6	1186	0.00
	Kerala	4979	0	98.9	69.5	0.7	358	0.00
	Tamil Nadu	18494	0	398.8	248.9	-0.9	671	0.00
	Puducherry	529	0	10.4	10.7	-0.3	33	0.00
ER	Bihar	7542	0	153.9	143.9	-1.6	331	0.05
	DVC	3195	0	70.9	-29.4	0.4	612	0.00
	Jharkhand	2206	0	47.6	39.2	-0.2	307	0.00
	Odisha	6882	0	138.2	58.4	1.3	765	0.00
	West Bengal	12781	0	256.2	118.1	-2.3	195	0.00
	Sikkim	74	0	1.2	1.5	-0.3	52	0.00
	Railways_ER ISTS	19	0	0.0	0.1	-0.1	10	0.00
NER	Arunachal Pradesh	183	0	3.1	3.1	-0.2	41	0.00
	Assam	1972	0	38.1	32.4	-1.0	97	0.00
	Manipur	222	0	3.1	3.2	-0.1	61	0.00
	Meghalaya	310	0	5.4	3.3	-0.1	37	0.00
	Mizoram	134	0	2.5	2.0	0.2	18	0.00
	Nagaland	158	0	2.9	2.9	0.0	3	0.00
	Tripura	342	0	6.8	5.6	0.5	57	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	4.5	-12.3	-23.0	-32.7
Day Peak (MW)	563.0	-793.0	-1000.0	-1381.0

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	155.9	-336.4	171.7	-7.6	16.3	0.0
Actual(MU)	133.0	-330.7	178.1	3.1	15.0	-1.5
O/D/U/D(MU)	-22.9	5.7	6.4	10.7	-1.3	-1.5

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	3020	4494	3978	2660	356	14509	36
State Sector	6904	10342	5866	2594	179	25885	64
Total	9924	14836	9844	5254	535	40394	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	806	1588	710	729	13	3847	73
Lignite	27	15	52	0	0	93	2
Hydro	264	30	84	29	14	421	8
Nuclear	32	65	71	0	0	167	3
Gas, Naptha & Diesel	18	53	4	0	22	98	2
RES (Wind, Solar, Biomass & Others)	223	206	236	5	1	671	13
Total	1369	1957	1157	763	51	5297	100

Share of RES in total generation (%)	16.27	10.51	20.40	0.69	2.13	12.66
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	37.88	15.36	33.82	4.46	29.00	23.77

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.034
Based on State Max Demands	1.080

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	216414	14:57	0
Non-Solar hr	215112	23:22	84

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES								
Import=(+ve) /Export =(-ve) for NET (MU)								
Date of Reporting: 11-May-2025								
Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.0	-2.0
3	765 kV	GAYA-VARANASI	2	1343	448	7.2	0.0	7.2
4	765 kV	SASARAM-FATEHPUR	1	530	230	2.0	0.0	2.0
5	765 kV	GAYA-BALIA	1	75	470	0.0	5.7	-5.7
6	400 kV	PUSAULI-VARANASI	1	0	148	0.0	2.1	-2.1
7	400 kV	PUSAULI -ALLAHABAD	1	94	20	0.5	0.0	0.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	840	325	5.5	0.0	5.5
9	400 kV	PATNA-BALIA	2	625	446	0.0	0.9	-0.9
10	400 kV	NAUBATPUR-BALIA	2	409	219	0.8	0.0	0.8
11	400 kV	BIHARSHARIEFF-BALIA	2	785	0	9.9	0.0	9.9
12	400 kV	MOTIHARI-GORAKHPUR	2	340	328	0.0	1.2	-1.2
13	400 kV	BIHARSARIEFF-SAHUPURI	2	266	69	3.2	0.0	3.2
14	220 kV	SAHUPURI-KARAMNASA	1	0	89	0.0	1.3	-1.3
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.6	0.0	0.6
17	132 kV	KARMANASA-SAHUPURI	1	0	0	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						29.7	13.2	16.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	965	589	0.0	1.6	-1.6
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	2118	0	28.3	0.0	28.3
3	765 kV	JHARSUGUDA-DURG	2	0	566	0.0	7.6	-7.6
4	400 kV	JHARSUGUDA-RAIGARH	4	250	329	0.0	0.6	-0.6
5	400 kV	RANCHI-SIPAT	2	520	36	5.7	0.0	5.7
6	220 kV	BUDHIPADAR-RAIGARH	1	58	58	0.0	0.1	-0.1
7	220 kV	BUDHIPADAR-KORBA	2	209	0	2.1	0.0	2.1
ER-WR						36.1	9.8	26.3
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	113	0.0	2.7	-2.7
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1769	0.0	39.6	-39.6
3	765 kV	ANGUL-SRIKAKULAM	2	0	2461	0.0	43.1	-43.1
4	400 kV	TALCHER-I/C	2	787	658	1.9	0.0	1.9
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	85.3	-85.3
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	330	385	1.5	2.6	-1.2
2	400 kV	ALIPURDUAR-BONGAIGAON	2	509	547	3.2	0.0	3.2
3	220 kV	ALIPURDUAR-SALAKATI	2	139	114	0.3	0.0	0.3
ER-NER						5.0	2.6	2.3
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	469	0	11.5	0.0	11.5
NER-NR						11.5	0.0	11.5
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3027	0.0	58.5	-58.5
2	HVDC	VINDHYACHAL B/B	-	0	105	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1171	0.0	29.1	-29.1
4	765 kV	GWALIOR-AGRA	2	0	1886	0.0	23.3	-23.3
5	765 kV	GWALIOR-PHAGI	2	1268	1083	6.2	9.5	-3.4
6	765 kV	JABALPUR-ORAI	2	158	825	0.0	18.0	-18.0
7	765 kV	GWALIOR-ORAI	1	647	0	9.3	0.0	9.3
8	765 kV	SATNA-ORAI	1	0	960	0.0	16.1	-16.1
9	765 kV	BANASKANTHA-CHITORGARH	2	741	1114	3.3	7.3	-4.0
10	765 kV	VINDHYACHAL-VARANASI	2	0	3040	0.0	54.0	-54.0
11	400 kV	ZERDA-KANKROLI	1	223	128	2.0	0.4	1.6
12	400 kV	ZERDA -BHINMAL	1	217	155	1.4	0.0	1.4
13	400 kV	VINDHYACHAL -RIHAND	1	975	0	20.8	0.0	20.8
14	400 kV	RAPP-SHUJALPUR	2	669	142	5.9	0.2	5.7
15	400 kV	NEEMUCH-Chittorgarh	2	692	113	5.3	0.2	5.1
16	220 kV	BHANPURA-RANPUR	1	0	155	0.0	2.7	-2.7
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.8	-1.8
18	220 kV	MEHGAON-AURAIYA	1	68	3	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	52	17	0.5	0.0	0.4
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						55.4	223.4	-167.9
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	309	0.0	7.2	-7.2
2	HVDC	RAIGARH-PUGALUR	2	0	5010	0.0	102.8	-102.8
3	765 kV	SOLAPUR-RAICHUR	2	1241	961	4.8	4.4	0.3
4	765 kV	WARDHA-NIZAMABAD	2	0	1972	0.0	23.2	-23.2
5	765 kV	WARORA-WARANGAL(NEW)	2	0	2315	0.0	30.6	-30.6
6	400 kV	KOLHAPUR-KUDGI	2	1593	0	24.6	0.0	24.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	130	2.7	0.0	2.7
WR-SR						32.1	168.3	-136.2
INTERNATIONAL EXCHANGES								
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Import(+ve)/Export(-ve) Energy Exchange (MU)		
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	449	37	271	6.51		
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	414	-200	8	0.20		
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-197	91	-100	-2.39		
	NER	132kV GELEPHU-SALAKATI	-20	0	-5	-0.11		
	NER	132kV MOTANGA-RANGIA	20	1	12	0.28		
NEPAL	NR	NEPAL IMPORT (FROM UP)	-73	0	-42	-1.01		
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-73	0	-48	-1.16		
	ER	NEPAL IMPORT (FROM BIHAR)	-265	0	-111	-2.66		
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-528	-18	-310	-7.44		
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-948	-796	-911	-21.87		
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1381	-1331	-1361	-32.68		
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-52	0	-45	-1.08		

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Nepal	2.52	0.00	3.70	0.00	0.00	3.54	0.00	0.00	9.76
Bangladesh	22.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.57
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	25.09	0.00	3.70	0.00	0.00	3.54	0.00	0.00	32.33

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.94
Nepal	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	3.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.94

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	3.94	0.00	0.00	0.00	0.00	0.00	0.00	0.00	3.94
Nepal	-2.52	0.00	-3.70	0.00	0.00	-3.54	0.00	0.00	-9.76
Bangladesh	-22.57	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.57
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-21.15	0.00	-3.70	0.00	0.00	-3.54	0.00	0.00	-28.39

Date of Reporting: 11-May-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATION (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve) Export
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E+F+G+H)	(K)
0:00	49.96	207952	6091	7640	298	21222	4400	170837	1997	200014	212485	-1004
0:15	49.96	207135	6116	7527	293	20431	4481	170970	2014	199315	211832	-1202
0:30	49.96	205933	6119	7511	285	20175	4054	170585	2010	198137	210739	-1252
0:45	49.96	205018	6091	7410	277	19728	4037	170020	1964	197331	209527	-1234
1:00	49.96	203125	6138	7355	274	19582	3984	168340	1931	195496	207604	-1201
1:15	49.96	201609	6131	7434	272	18774	3985	167374	1924	193903	205894	-1199
1:30	49.96	198410	6127	7443	282	18418	3991	164729	1939	190685	202929	-1208
1:45	49.96	196352	6221	7072	282	17832	3997	163583	1948	188998	200935	-1188
2:00	49.96	194287	6245	6704	273	17483	4024	162448	1926	187310	199103	-1243
2:15	49.96	193173	6238	6425	267	16252	3911	163011	1891	186481	197995	-1389
2:30	49.96	192310	6233	6178	268	16095	3953	162636	1917	185864	197280	-1405
2:45	49.96	191085	6221	5900	267	16135	3916	161816	1911	184918	196166	-1458
3:00	49.96	190584	6217	5651	271	16254	3996	161468	1907	184662	195764	-1353
3:15	49.96	190622	6225	5641	275	16288	3874	161657	1861	184706	195821	-1397
3:30	49.96	190310	6246	5555	276	16031	3936	161673	1850	184479	195567	-1423
3:45	49.96	189291	6260	5455	280	15814	3925	161252	1852	183556	194838	-1419
4:00	49.96	188386	6232	5350	280	15793	3836	160412	1851	182756	193754	-1432
4:15	49.96	189356	6221	5150	276	16170	3408	161317	1911	183930	194453	-1440
4:30	49.96	189435	6242	5086	278	15803	3460	162227	1907	184071	195003	-1448
4:45	49.96	189898	6220	5123	276	15914	3406	162493	1936	184499	195368	-1443
5:00	49.96	189120	6234	5020	277	16082	3458	161802	1946	183823	194819	-1464
5:15	49.96	189521	6168	4979	275	16450	3395	161940	1909	184267	195116	-1438
5:30	49.96	190578	6213	4840	269	16517	3213	163170	1911	185469	196133	-1413
5:45	49.96	190803	6237	4839	281	16922	3099	162964	1911	185683	196253	-1391
6:00	49.96	189402	6273	4732	426	16938	2977	161400	1904	184244	194650	-1439
6:15	49.96	189734	6297	4895	1512	16187	3112	161348	1900	183327	195251	-1472
6:30	49.96	190706	6274	5055	2930	17316	3092	159605	1913	182721	196185	-1485
6:45	49.96	189386	6297	4592	5154	17179	3084	156531	1909	179640	194746	-1412
7:00	49.96	188856	6286	4124	8175	16624	3099	154004	1943	176557	194255	-1388
7:15	49.96	189317	6311	3721	11584	16188	2878	151745	1968	174012	194395	-1396
7:30	49.96	190191	6278	3511	15547	16236	3122	148644	1973	171133	195311	-1418
7:45	49.96	190403	6303	3165	20173	15789	2902	145131	2006	167065	195469	-1421
8:00	49.96	190576	6317	3006	25808	15391	2901	140036	2022	161762	195481	-1439
8:15	49.96	192103	6313	2968	30267	15375	3090	137508	2031	158868	197552	-1422
8:30	49.96	193512	6296	2971	34558	15106	3107	134652	2020	155983	198710	-1429
8:45	49.96	194575	6281	2939	38679	14770	3107	132270	2092	152957	200138	-1449
9:00	49.96	195289	6299	2823	42015	14563	3096	129221	2117	150451	200134	-1478
9:15	49.96	199658	6248	2667	45392	14765	2904	130237	2089	151599	204302	-1347
9:30	49.96	202016	6254	2574	48377	14723	3116	129337	2119	151065	206500	-1384
9:45	49.96	204030	6253	2506	51770	14166	3113	128729	2116	149754	208653	-1368
10:00	49.96	204895	6247	2396	54487	13577	3105	127317	2113	148012	209242	-1387
10:15	49.96	205406	6232	2370	56873	13014	3118	126111	2092	146163	209810	-1404
10:30	49.96	207470	6222	2287	58728	13106	3111	126034	2103	146455	211591	-1375
10:45	49.96	208581	6167	2211	59094	12620	2901	127359	2138	147276	212490	-1348
11:00	50.01	208846	6228	2141	60148	12393	2893	127160	2085	146557	213048	-1326
11:15	49.91	209554	6183	2154	60452	11991	3112	128306	2105	146948	214303	-1633
11:30	49.91	210411	6204	2191	60489	12442	3086	128715	2091	147731	215218	-1624
11:45	49.91	210952	6129	2252	60416	12139	2882	129092	2162	148284	215072	-1636
12:00	50.01	209807	6228	2370	59674	11977	3090	128778	2097	147763	214214	-1626
12:15	50.01	209912	6189	2541	59020	11830	2890	129319	2151	148351	213940	-1616
12:30	49.96	210107	6203	2822	58785	11151	3087	130938	2141	148500	215127	-1695
12:45	49.96	210074	6190	3028	57716	11058	2885	131460	2110	149330	214447	-1597
13:00	50.06	208373	6212	3248	57151	11330	3115	129897	2111	147974	213064	-1600
13:15	49.96	206393	6175	3655	56115	10985	3108	128595	2113	146623	210746	-1609
13:30	50.01	207017	6189	3920	55208	11350	2956	129523	2109	147889	211255	-1613
13:45	49.91	209684	6142	4088	53937	11735	3113	132991	2082	151659	214088	-1628
14:00	50.01	211965	6187	4368	53113	12316	3102	135267	2089	154484	216442	-1642
14:15	50.01	213997	6234	4847	52957	12655	3080	136611	2090	156193	218474	-1580
14:30	50.01	215135	6177	4759	51033	13153	3088	139352	2103	159343	219665	-1594
14:45	49.96	215865	6156	4728	49917	13752	3089	141125	2032	161220	220799	-1222
15:00	50.01	216182	6196	4694	47720	14168	3102	143170	2024	163768	221074	-1412
15:15	50.01	215312	6217	4961	45531	14236	3187	144514	2017	164820	220663	-1464
15:30	50.06	215004	6185	5287	43013	14354	3189	146172	2009	166704	220209	-1490
15:45	50.06	213534	6207	5550	40364	14211	3054	147471	1977	167620	218834	-1449
16:00	50.06	212788	6206	5655	37325	14477	3167	149364	1950	169808	218144	-1465
16:15	50.06	210700	6217	5794	34462	14037	3044	150238	1984	170444	215776	-1314
16:30	50.11	210694	6220	5817	30294	13853	3175	154232	1960	174583	215551	-1287
16:45	50.11	209397	6243	6071	27118	14170	3167	155253	1934	176208	213956	-1267
17:00	50.11	207088	6235	6059	24121	14446	3915	155076	1946	176908	211798	-1103
17:15	50.06	203467	6241	6264	20304	14772	4167	154262	1906	176899	207916	-900
17:30	50.06	202922	6196	6298	17806	15940	4435	156078	1873	178818	208626	-917
17:45	50.01	201590	6231	6495	12936	16349	4638	157760	1879	182159	206288	-772
18:00	50.06	200370	6225	7030	9404	16818	5130	158195	1829	183936	204631	-888
18:15	50.11	198073	6230	7661	6803	16944	4882	157445	1903	183609	201868	-806
18:30	50.06	200982	6244	8254	4183	18350	4809	160596	1949	188545	204385	-815
18:45	50.06	204783	6235	8368	2533	21080	4904	163344	1941	193882	208405	-765
19:00	50.06	207328	6251	8633	1392	23412	4882	164228	1947	197303	210745	-815
19:15	49.96	210037	6224	8577	783	24061	4965	166421	1921	200677	212952	-722
19:30	49.91	211735	6203	8602	619	24319	5212	167799	1907	202514	214661	-692
19:45	50.01	212753	6245	8676	620	24719	4962	168578	1906	203457	215706	-615
20:00	50.01	212605	6225	8658	624	25009	5326	168282	1927	203323	216051	-616
20:15	50.01	211769	6260	8903	373	24592	5168	167446	1908	202493	214650	-591
20:30	50.06	211197	6242	8648	380	24142	5165	167784	1979	202169	214340	-595
20:45	49.96	210887	6231	8599	387	22785	5039	168818	1896	201901	213755	-609
21:00	50.06	209519	6293	8568	381	21798	5219	168235	1894	200570	212388	-248
21:15	50.11	208519	6299	8882	379	21882	5114	167123	1907	199258	211586	-272
21:30	50.06	209038	6267	8638	378	21593	5110	167733	1921	200022	211640	-289
21:45	50.06	208669	6265	8645	350	22257	5142	166775	1923	199674	211357	-304
22:00	50.06	208699	6217	8819	371	22088	5277	166739	1898	199509	211409	-320
22:15	49.96	211758	6205	8763	377	23016	5223	168980	1923	202618	214487	-439</