



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 25.01.2026

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई -400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु -560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 24.01.2026.

महोदय/Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 24-जनवरी-2026 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 24.01.2026, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 25-Jan-2026

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	61652	66163	49113	24086	2830	203844
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1222	1577	1250	494	51	4594
Hydro Gen (MU)	101	48	82	22	12	265
Wind Gen (MU)	40	148	79	-	-	267
Solar Gen (MU)*	199.72	162.24	126.19	3.10	1.11	492
Energy Shortage (MU)	0.00	0.00	0.00	0.24	0.00	0.24
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	62925	80637	64427	24318	2962	232815
Time Of Maximum Demand Met	18:55	09:50	09:29	18:27	18:15	09:41

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.034	0.00	0.31	3.96	4.27	77.41	18.32

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8258	0	159.1	82.4	-0.7	911	0.00
	Haryana	8432	0	157.9	114.8	-1.7	223	0.00
	Rajasthan	17152	0	319.5	101.0	-9.0	619	0.00
	Delhi	5043	0	85.7	78.4	-0.9	449	0.00
	UP	20091	0	362.6	83.0	-0.2	701	0.00
	Uttarakhand	2461	0	46.0	36.9	0.3	129	0.00
	HP	1923	0	36.7	30.0	-1.5	149	0.00
	J&K(UT) & Ladakh(UT)	2893	0	46.1	46.3	-4.2	174	0.00
	Chandigarh	267	0	4.7	4.6	0.0	39	0.00
WR	Railways_NR ISTS	206	0	4.1	3.7	0.4	45	0.00
	Chhattisgarh	5757	0	114.7	65.1	0.5	335	0.00
	Gujarat	23032	0	432.0	180.4	-11.9	1844	0.00
	MP	19398	0	346.9	222.4	0.0	651	0.00
	Maharashtra	29298	0	598.3	180.3	-11.1	745	0.00
	Goa	710	0	14.3	12.1	2.1	74	0.00
	DNHDDPDCL	1389	0	31.5	31.3	0.2	39	0.00
	AMNSIL	880	0	19.0	12.0	0.1	282	0.00
	BALCO	609	0	14.4	14.5	-0.1	11	0.00
SR	RIL JAMNAGAR	249	0	5.7	5.7	0.0	0	0.00
	Andhra Pradesh	12497	0	229.4	63.4	2.1	1103	0.00
	Telangana	15632	0	274.2	130.6	0.6	599	0.00
	Karnataka	17380	0	311.9	103.6	0.0	1691	0.00
	Kerala	4434	0	83.5	63.8	1.3	409	0.00
	Tamil Nadu	16550	0	342.3	205.6	-1.5	898	0.00
	Puducherry	408	0	9.1	8.4	-0.1	37	0.00
ER	Bihar	5912	0	108.6	90.0	1.1	333	0.24
	DVC	3228	0	69.6	-12.1	0.1	430	0.00
	Jharkhand	2150	0	38.8	30.5	-2.9	137	0.00
	Odisha	5541	0	110.8	20.6	-1.0	423	0.00
	West Bengal	7994	0	164.3	46.6	-2.9	173	0.00
	Sikkim	110	0	1.9	1.9	0.0	8	0.00
	Railways_ER ISTS	20	0	0.2	0.2	-0.1	4	0.00
NER	Arunachal Pradesh	193	0	3.0	3.1	-0.2	46	0.00
	Assam	1649	0	29.7	25.7	0.3	74	0.00
	Manipur	259	0	3.9	4.2	-0.3	34	0.00
	Meghalaya	371	0	6.2	5.6	0.1	91	0.00
	Mizoram	160	0	2.4	2.2	-0.2	21	0.00
	Nagaland	173	0	2.2	2.6	-0.5	7	0.00
	Tripura	229	0	3.6	6.0	-0.2	42	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-16.6	-5.6	-14.2	-17.0
Day Peak (MW)	-965.7	-412.7	-623.5	-1151.7

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	182.2	-241.0	194.0	-150.5	15.3	0.0
Actual(MU)	179.7	-246.0	193.8	-142.6	12.1	-3.0
O/D/U/D(MU)	-2.5	-5.1	-0.1	7.9	-3.2	-3.0

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	5727	10990	5538	2994	719	25967	43
State Sector	10374	12878	5875	4493	205	33825	57
Total	16101	23868	11413	7486	924	59792	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	692	1500	700	692	11	3593	72
Lignite	25	20	44	0	0	90	2
Hydro	101	48	82	22	12	265	5
Nuclear	53	48	66	0	0	167	3
Gas, Naptha & Diesel	10	17	9	0	19	55	1
RES (Wind, Solar, Biomass & Others)	263	313	242	7	1	826	17
Total	1145	1946	1143	720	43	4996	100

Share of RES in total generation (%)	23.02	16.09	21.19	0.91	2.58	16.54
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	36.51	21.01	34.10	3.95	29.88	25.17

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.010
Based on State Max Demands	1.043

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	232815	9:41	0
Non-Solar hr	208754	18:54	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)
Date of Reporting: 25-Jan-2026

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	0	47	0.0	2.4	-2.4
3	765 kV	GAYA-VARANASI	2	601	1312	0.0	14.7	-14.7
4	765 kV	SASARAM-FATEHPUR	1	274	578	0.0	4.7	-4.7
5	765 kV	GAYA-BALIA	1	0	923	0.0	12.7	-12.7
6	400 kV	PUSAULI-VARANASI	1	0	138	0.0	1.6	-1.6
7	400 kV	PUSAULI -ALLAHABAD	1	44	84	0.0	0.7	-0.7
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	480	579	0.0	2.7	-2.7
9	400 kV	PATNA-BALIA	2	0	1174	0.0	15.3	-15.3
10	400 kV	NAUBATPUR-BALIA	2	39	378	0.0	5.1	-5.1
11	400 kV	BIHARSHARIFF-BALIA	2	316	377	0.0	0.8	-0.8
12	400 kV	MOTIHARI-GORAKHPUR	2	115	525	0.0	5.9	-5.9
13	400 kV	BIHARSARIEFF-SAHUPURI	2	242	428	0.0	3.5	-3.5
14	220 kV	SAHUPURI-KARAMNASA	1	13	53	0.0	1.9	-1.9
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.0	0.0	0.0
16	132 kV	GARWAH-RIHAND	1	30	0	0.0	0.0	0.0
17	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						0.0	72.0	-72.0
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	0	1430	0.0	14.8	-14.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	1085	507	8.3	0.0	8.3
3	765 kV	JHARSUGUDA-DURG	2	0	1242	0.0	21.6	-21.6
4	400 kV	JHARSUGUDA-RAIGARH	4	245	450	0.0	1.1	-1.1
5	400 kV	RANCHI-SIPAT	2	270	254	0.5	0.0	0.5
6	400 kV	JEYPORE-JAGDALPUR	2	404	144	2.9	0.0	2.9
7	220 kV	BUDHIPADAR-RAIGARH	1	24	116	0.0	1.1	-1.1
8	220 kV	BUDHIPADAR-KORBA	2	25	213	0.0	1.9	-1.9
ER-WR						11.7	40.5	-28.8
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	629	0.0	12.9	-12.9
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1379	0.0	36.2	-36.2
3	765 kV	ANGUL-SRIKAKULAM	2	0	1920	0.0	31.3	-31.3
4	400 kV	TALCHER-I/C	2	394	668	0.0	1.5	-1.5
5	220 kV	BALIMELA-UPPER-SILERRU	1	1	2	0.0	0.0	0.0
ER-SR						0.0	80.4	-80.4
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	77	244	0.3	1.9	-1.6
2	400 kV	ALIPURDUAR-BONGAIGAON	2	312	204	1.4	0.0	1.4
3	220 kV	ALIPURDUAR-SALAKATI	2	48	52	0.0	0.2	-0.2
ER-NER						1.7	2.1	-0.4
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	570	0	13.6	0.0	13.6
NER-NR						13.6	0.0	13.6
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	2948	0.0	50.3	-50.3
2	HVDC	VINDHYACHAL B/B	-	0	106	0.0	2.5	-2.5
3	HVDC	MUNDRA-MOHINDERGARH	2	0	1460	0.0	29.5	-29.5
4	765 kV	GWALIOR-AGRA	2	1363	2050	3.6	18.8	-15.2
5	765 kV	GWALIOR-PHAGI	2	809	1730	2.8	16.8	-14.0
6	765 kV	JABALPUR-ORAI	2	537	934	0.0	17.4	-17.4
7	765 kV	GWALIOR-ORAI	1	933	0	13.2	0.0	13.2
8	765 kV	SATNA-ORAI	1	0	893	0.0	14.3	-14.3
9	765 kV	BANASKANTHA-CHITORGARH	2	1480	1007	13.9	3.0	10.9
10	765 kV	VINDHYACHAL-VARANASI	2	94	1879	0.0	26.3	-26.3
11	400 kV	ZERDA-KANKROLI	1	325	27	3.8	0.0	3.8
12	400 kV	ZERDA -BHINMAL	1	224	19	2.6	0.0	2.6
13	400 kV	VINDHYACHAL -RIHAND	1	474	0	9.8	0.0	9.8
14	400 kV	RAPP-SHUJALPUR	2	1247	160	9.6	0.3	9.3
15	400 kV	NEEMUCH-Chittorgarh	2	1136	354	5.6	0.0	5.6
16	220 kV	BHANPURA-RANPUR	1	0	119	0.0	1.8	-1.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.7	-1.7
18	220 kV	MEHGAON-AURAIYA	1	99	4	1.1	0.0	1.1
19	220 kV	MALANPUR-AURAIYA	1	75	19	0.8	0.1	0.7
20	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						66.7	182.7	-116.0
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	0	1009	0.0	21.2	-21.2
2	HVDC	RAIGARH-PUGALUR	2	0	5014	0.0	74.9	-74.9
3	765 kV	SOLAPUR-RAICHUR	2	1761	1573	5.5	10.7	-5.2
4	765 kV	WARDHA-NIZAMABAD	2	588	2700	0.7	36.6	-35.9
5	765 kV	WARORA-WARANGAL(NEW)	2	62	3212	0.0	45.5	-45.5
6	400 kV	KOLHAPUR-KUDGI	2	1506	0	22.6	0.0	22.6
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	112	2.0	0.0	2.0
WR-SR						30.7	188.8	-158.0

INTERNATIONAL EXCHANGES						Import(+ve)/Export(-ve)	
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	-314	55	-226	-5.42	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-296	142	-145	-3.48	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-298	-176	-242	-5.81	
	NER	132kV GELEPHU-SALAKATI	-70	-30	-56	-1.35	
	NER	132kV MOTANGA-RANGIA	-50	-3	-22	-0.52	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-57	0	-22	-0.52	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-57	0	-30	-0.72	
	ER	NEPAL IMPORT (FROM BIHAR)	-102	-73	-91	-2.17	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-192	-13	-91	-2.19	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-488	-414	-483	-11.60	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	-1152	-210	-710	-17.03	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-138	0	-110	-2.65	

CROSS BORDER EXCHANGE SCHEDULE

Date of Reporting: 25-Jan-2026

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.33	17.07	0.00	0.00	0.18	0.00	0.00	17.58
Nepal	2.35	1.75	0.97	0.00	0.00	0.43	0.00	0.00	5.50
Bangladesh	12.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	12.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	14.50	2.08	18.04	0.00	0.00	0.61	0.00	0.00	35.23

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.15
Nepal	0.00	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.60
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.15	0.00	0.00	0.00	0.00	0.60	0.00	0.00	0.75

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.15	-0.33	-17.07	0.00	0.00	-0.18	0.00	0.00	-17.43
Nepal	-2.35	-1.75	-0.97	0.00	0.00	0.17	0.00	0.00	-4.90
Bangladesh	-12.15	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-12.15
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-14.35	-2.08	-18.04	0.00	0.00	-0.01	0.00	0.00	-34.48

Date of Reporting: 25-Jan-2026												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A-(C+D))	(J=B+C+D+E +F+G+H)	(+ve) Import, (-ve) Export
0:00	50.00	156356	6076	6319	0	5756	2038	136447	3634	150037	160270	-1502
0:15	50.00	156598	6078	6487	0	6175	2042	136056	3598	150111	160436	-1588
0:30	49.92	156175	6124	6637	0	6833	2032	134649	3629	149538	159904	-1613
0:45	49.98	155321	6108	6666	0	6652	2032	134140	3601	148655	159199	-1591
1:00	49.98	153883	6129	6621	0	6422	2022	133028	3628	147262	157850	-1605
1:15	50.05	152996	6119	6624	0	6307	2040	132215	3642	146372	156947	-1572
1:30	49.98	153024	6127	6765	0	6052	2038	132188	3653	146259	156823	-1562
1:45	50.01	152300	6148	6707	0	5985	2038	131571	3673	145593	156122	-1593
2:00	50.03	151270	6158	6810	0	5942	2039	130720	3673	144460	155342	-1595
2:15	49.96	151282	6160	6948	0	5652	2029	130614	3707	144334	155110	-1609
2:30	49.99	151142	6166	7293	0	5635	2032	130072	3718	143849	154916	-1605
2:45	50.00	151408	6173	7539	0	5721	2034	129754	3701	143869	154922	-1596
3:00	50.03	151408	6162	7747	0	5585	2030	129837	3689	143661	155050	-1584
3:15	49.99	151463	6179	7735	0	5569	2032	129992	3697	143728	155204	-1568
3:30	49.97	148818	6173	7263	0	5369	2039	128003	3613	141555	152460	-1580
3:45	49.99	152169	6181	8128	0	5526	2042	130115	3708	144041	155700	-1502
4:00	50.02	152468	6188	8675	0	5537	2025	129672	3707	143793	155804	-1563
4:15	50.00	154643	6179	9148	0	6006	2062	130954	3718	145495	158067	-1513
4:30	50.03	155994	6189	9540	0	5785	2051	131991	3727	146454	159283	-1527
4:45	50.06	157728	6183	9973	0	5514	2032	133606	3751	147755	161059	-1530
5:00	50.09	159541	6206	10596	274	5540	2044	134669	3781	148671	163110	-1528
5:15	50.03	163762	6176	11093	208	5712	2030	138212	3775	152461	167206	-1517
5:30	50.05	167272	6181	11895	228	5885	2035	140837	3776	155149	170837	-1578
5:45	50.08	171703	6180	12565	245	6682	2035	143946	3812	158893	175465	-1586
6:00	50.15	176196	6188	13278	247	7493	2296	146538	3830	162671	179870	-1606
6:15	50.03	181245	6164	13629	300	9029	2407	150235	3809	167316	185573	-1661
6:30	49.98	188570	6150	13796	324	10637	2416	154974	3838	174450	192135	-1455
6:45	49.95	194921	6157	14161	360	12757	2395	158719	3879	180400	198428	-1188
7:00	50.06	200032	6149	14475	407	14675	2379	161382	3867	185150	203334	-663
7:15	50.04	205789	6134	14464	937	17086	2415	163742	3876	190388	208654	-633
7:30	49.98	210526	6141	14527	1983	18516	2395	165895	3881	194016	213338	-741
7:45	50.04	213474	6134	14433	4149	18835	2417	166146	3878	194892	215992	-733
8:00	50.07	214894	6154	14354	8037	18528	2379	164120	3896	192503	217468	-748
8:15	49.95	220051	6165	13852	13800	18213	2394	163752	3886	192399	222062	-770
8:30	50.03	223273	6189	13426	20741	18020	2385	160820	3879	189106	225460	-752
8:45	50.07	225992	6230	12616	28358	17681	2393	156765	3817	185018	227860	-717
9:00	50.09	226143	6243	11653	35549	14841	2371	153436	3839	178941	227932	-716
9:15	49.98	229760	6257	10828	41577	14615	2380	152486	3759	177355	231902	-1069
9:30	49.96	231771	6237	9709	46779	13980	2428	151127	3766	175283	234026	-1647
9:45	49.95	232684	6244	10050	51074	12611	2376	149635	3769	171560	235759	-1739
10:00	49.98	231760	6271	10114	55669	10893	2378	145960	3778	145977	235063	-1753
10:15	49.98	231252	6298	10276	58974	9959	2381	142600	3777	162002	234265	-1726
10:30	49.92	228349	6308	10223	60679	9817	2375	138194	3794	157447	231390	-1763
10:45	49.92	226501	6293	10336	62610	8701	2411	135705	3794	153555	229850	-1798
11:00	50.02	224771	6288	10281	64984	7767	2405	133384	3771	149506	228880	-1789
11:15	49.93	222396	6323	10234	64965	7280	2387	131687	3785	147197	226661	-1790
11:30	49.90	221394	6309	10014	65611	7128	2410	130139	3786	145769	225397	-1838
11:45	49.92	220208	6309	9672	66221	7374	2376	128180	3757	144315	223889	-1787
12:00	50.09	217246	6333	8994	67701	7232	2410	125309	3824	140551	221803	-1816
12:15	50.04	215909	6336	8838	68017	7138	2376	123711	3755	139054	220171	-1864
12:30	50.00	214625	6348	8558	67731	7120	2365	122864	3691	138336	218677	-1840
12:45	49.94	212651	6334	8185	66291	6874	2353	122515	3744	138175	216296	-1882
13:00	50.11	210856	6351	7752	66583	7054	2342	120108	3751	136521	213941	-1883
13:15	50.05	207411	6371	7547	66534	6648	2365	115835	3685	133330	208985	-1907
13:30	50.03	206135	6372	7336	65754	6482	2365	115962	3662	133045	207933	-1883
13:45	50.03	206569	6339	7284	65059	6510	2334	116970	3668	134226	208164	-1893
14:00	50.02	205898	6336	7121	63639	6502	2367	117804	3744	135138	207513	-1883
14:15	49.99	206008	6344	6995	62756	6550	2377	121224	3692	136257	209938	-1884
14:30	49.99	207175	6330	6996	60889	6903	2317	123775	3653	139290	210863	-1847
14:45	50.01	208390	6293	7111	59745	7206	2364	125605	3646	141534	211970	-1851
15:00	50.04	208576	6293	7240	57650	7377	2388	127673	3675	143686	212296	-1845
15:15	50.03	207731	6301	7360	55037	7658	2361	129115	3573	145334	211405	-1882
15:30	49.98	206371	6301	7567	50661	7716	2289	131952	3598	148143	210084	-1871
15:45	49.99	206553	6283	7844	47588	7967	2347	134846	3627	151121	210502	-1877
16:00	50.09	207293	6273	8143	43186	8344	2354	138868	3641	155964	210809	-1791
16:15	50.05	204247	6253	8297	38624	8517	2358	140106	3627	157326	207782	-1782
16:30	50.11	205597	6249	8410	34641	10106	2376	143443	3683	162546	208908	-1757
16:45	50.00	205604	6243	8376	28983	11775	2416	147511	3663	168245	208967	-1742
17:00	50.01	204243	6172	8490	22064	13535	2484	152050	3648	173689	208443	-1757
17:15	49.92	202738	6110	8360	15415	15486	2477	154898	3628	178963	206374	-1778
17:30	50.04	204186	6077	8400	10010	18059	2507	158109	3681	185776	206843	-1773
17:45	50.03	207553	6065	8570	6453	19231	2457	163044	3694	192530	209514	-1224
18:00	50.07	207581	6043	8589	2878	19538	2510	166612	3691	196114	209861	-766
18:15	50.00	207164	6042	8565	948	20098	2503	167553	3696	197651	209405	-828
18:30	49.98	208258	6038	8783	393	20495	2487	168580	3776	199082	210552	-859
18:45	49.92	208340	6076	9137	201	20936	2158	168384	3754	199002	210646	-874
19:00	50.03	207818	6084	9950	178	20306	2117	167710	3706	197690	210051	-848
19:15	50.00	205094	6094	11013	149	17829	2135	166511	3761	193932	207492	-782
19:30	50.03	203002	6083	11836	0	16791	2026	165110	3718	191166	205564	-802
19:45	50.01	200690	6098	12670	0	16725	1953	161947	3705	188020	203098	-707
20:00	50.00	198435	6116	13445	0	15809	1984	159437	3795	184990	200586	-709
20:15	50.04	195692	6118	14297	0	15192	1859	156588	3764	181395	197818	-700
20:30	50.07	192979	6135	14836	0	14476	1768	154142	3790	178143	195147	-719
20:45	50.03	190528	6145	15340	0	13581	1779	152243	3754	175188	192842	-1086
21:00	49.98	187298	6154	15747	0	13251	1779	149189	3795	171551	189915	-1291
21:15	50.02	184358	6153	15913	0	12291	1766	147081	3774	168445	186978	-1301
21:30	50.00	181850	6181	16030	0	12089	1772	144826	3724	165820	184622	-1324
21:45	49.99	179335	6177	16546	0	10584	1779	143210	3770	162789	182066	-1306
22:00	50.02	175321	6170	16643	0	9744	1802	140059	3683	158678	178101	-1294
22:15	49.93	174659	6192	16998	0	9571	1800	139045	3706	157661	177312	-1302
22:30	50.00	172907	6168	17215	0	9387	1804	137615	3			