



National Load Despatch Centre
राष्ट्रीय भार प्रेषण केंद्र
GRID CONTROLLER OF INDIA LIMITED
ग्रिड कंट्रोलर ऑफ इंडिया लिमिटेड

(Government of India Enterprise/ भारत सरकार का उद्यम)
B-9, QUTUB INSTITUTIONAL AREA, KATWARIA SARAI, NEW DELHI -110016
बी-9, कुतुब इन्स्टीट्यूशनल एरिया, कटवारिया सराये, न्यू दिल्ली-110016

Ref: GRID-INDIA/NLDC/SO/Daily PSP Report

दिनांक: 17.01.2025

To,

- कार्यकारी निदेशक, पू.क्षे.भा.प्रे.के., 14, गोल्फ क्लब रोड, कोलकाता - 700033
Executive Director, ERLDC, 14 Golf Club Road, Tollygunge, Kolkata, 700033
- कार्यकारी निदेशक, ऊ.क्षे.भा.प्रे.के., 18/ए, शाहीद जीत सिंह सनसनवाल मार्ग, नई दिल्ली - 110016
Executive Director, NRLDC, 18-A, Shaheed Jeet Singh Marg, Katwaria Sarai, New Delhi - 110016
- कार्यकारी निदेशक, प.क्षे.भा.प्रे.के., एफ3, एम आई डी सी क्षेत्र, अंधेरी, मुंबई - 400093
Executive Director, WRLDC, F-3, M.I.D.C. Area, Marol, Andheri (East), Mumbai-400093
- कार्यकारी निदेशक, ऊ.पू.क्षे.भा.प्रे.के., डोंगतेह, लोअर नोंग्रह, लापलंग, शिलोंग - 793006
Executive Director, NERLDC, Dongteih, Lower Nongrah, Lapalang, Shillong - 793006, Meghalaya
- कार्यकारी निदेशक, द.क्षे.भा.प्रे.के., 29, रेस कोर्स क्रॉस रोड, बंगलुरु - 560009
Executive Director, SRLDC, 29, Race Course Cross Road, Bangalore-560009

Sub: Daily PSP Report for the date 16.01.2025.

महोदय/Dear Sir,

आईईजीसी-2023 की धारा स.-38(1) के प्रावधान के अनुसार, दिनांक 16-जनवरी-2025 की अखिल भारतीय प्रणाली की दैनिक ग्रिड निष्पादन रिपोर्ट रांभांप्रेके की वेबसाइट पर उपलब्ध है।

As per article 38(1) of the Indian Electricity Grid Code, the daily report pertaining power supply position of All India Power System for the date 16.01.2025, is available at the NLDC website.

धन्यवाद,
Thanks

Report for previous day

Date of Reporting: 17-Jan-2025

A. Power Supply Position at All India and Regional level

	NR	WR	SR	ER	NER	TOTAL
Demand Met during Evening Peak hrs(MW) (at 19:00 hrs; from RLDCs)	60916	63898	42817	22584	2718	192933
Peak Shortage (MW)	0	0	0	0	0	0
Energy Met (MU)	1224	1503	1097	464	49	4335
Hydro Gen (MU)	90	47	92	23	11	263
Wind Gen (MU)	14	129	97	-	-	240
Solar Gen (MU)*	153.26	94.50	111.47	2.98	1.18	363
Energy Shortage (MU)	0.11	1.10	0.00	0.27	0.00	1.48
Maximum Demand Met During the Day (MW) (From NLDC SCADA)	63745	76019	57421	23527	3000	220355
Time Of Maximum Demand Met	10:29	10:14	09:27	18:43	17:35	09:54

B. Frequency Profile (%)

Region	FVI	< 49.7	49.7 - 49.8	49.8 - 49.9	< 49.9	49.9 - 50.05	> 50.05
All India	0.025	0.00	0.00	2.22	2.22	80.07	17.71

C. Power Supply Position in States

Region	States	Max.Demand Met during the day (MW)	Shortage during maximum Demand (MW)	Energy Met (MU)	Drawal Schedule (MU)	OD(+)/UD(-) (MU)	Max OD (MW)	Energy Shortage (MU)
NR	Punjab	8164	0	151.4	84.1	-0.3	314	0.00
	Haryana	7821	0	148.9	102.6	-0.6	512	0.00
	Rajasthan	16898	0	314.3	100.2	-7.1	486	0.00
	Delhi	5244	0	88.3	87.8	-1.7	503	0.00
	UP	20541	0	358.1	132.1	-2.3	426	0.00
	Uttarakhand	2345	0	45.8	37.9	-0.1	252	0.00
	HP	2159	0	40.4	34.1	-0.5	215	0.00
	J&K(UT) & Ladakh(UT)	3092	0	68.1	65.0	-0.8	1098	0.11
	Chandigarh	281	0	4.8	4.8	0.0	58	0.00
WR	Railways_NR ISTS	207	0	4.4	3.6	0.8	71	0.00
	Chhattisgarh	5438	0	110.0	59.8	0.8	256	0.00
	Gujarat	22021	0	399.1	161.3	-7.0	387	0.00
	MP	17584	291	327.2	217.4	-1.5	620	1.10
	Maharashtra	28496	0	591.0	227.7	-0.3	881	0.00
	Goa	732	0	15.5	14.6	0.3	48	0.00
	DNHDDPDCL	1270	0	29.0	29.7	-0.7	89	0.00
	AMNSIL	760	0	17.2	7.5	0.6	249	0.00
	BALCO	533	0	12.6	12.7	-0.1	116	0.00
SR	RIL JAMNAGAR	110	0	1.1	1.1	0.0	0	0.00
	Andhra Pradesh	10893	0	197.9	48.9	0.0	667	0.00
	Telangana	14314	0	259.7	151.4	-2.4	634	0.00
	Karnataka	16145	0	283.6	92.5	-0.5	685	0.00
	Kerala	4422	0	87.1	67.8	1.1	439	0.00
	Tamil Nadu	13080	0	261.4	131.9	-1.9	931	0.00
	Puducherry	301	0	6.9	6.7	-0.4	11	0.00
ER	Bihar	5370	0	100.3	89.4	-1.3	294	0.27
	DVC	3201	0	69.0	-34.5	-0.6	261	0.00
	Jharkhand	1986	0	39.2	29.9	0.5	207	0.00
	Odisha	5169	0	101.2	35.5	-3.1	461	0.00
	West Bengal	7513	0	151.5	29.0	-2.4	229	0.00
	Sikkim	125	0	2.2	2.0	0.1	19	0.00
	Railways_ER ISTS	24	0	0.1	0.2	0.0	3	0.00
NER	Arunachal Pradesh	180	0	3.0	3.1	-0.2	23	0.00
	Assam	1511	0	26.4	19.4	0.3	169	0.00
	Manipur	276	0	3.5	4.0	-0.5	53	0.00
	Meghalaya	374	0	6.5	5.3	-0.1	139	0.00
	Mizoram	152	0	2.6	1.9	0.0	25	0.00
	Nagaland	159	0	2.5	2.4	0.0	17	0.00
	Tripura	229	0	4.1	3.3	0.1	147	0.00

D. Transnational Exchanges (MU) - Import(+ve)/Export(-ve)

	Bhutan	Nepal	Bangladesh	Godda -> Bangladesh
Actual (MU)	-4.7	-8.3	-22.5	0.1
Day Peak (MW)	-381.7	-486.4	-998.0	50.9

E. Import/Export by Regions (in MU) - Import(+ve)/Export(-ve); OD(+)/UD(-)

	NR	WR	SR	ER	NER	TOTAL
Schedule(MU)	283.4	-254.1	109.6	-143.3	4.4	0.0
Actual(MU)	273.7	-245.9	99.6	-141.7	3.0	-11.3
O/D/U/D(MU)	-9.8	8.3	-10.0	1.6	-1.4	-11.3

F. Generation Outage(MW)

	NR	WR	SR	ER	NER	TOTAL	% Share
Central Sector	6169	6969	5208	3930	698	22973	40
State Sector	9833	13210	7043	4349	221	34655	60
Total	16002	20178	12251	8279	918	57628	100

G. Sourcewise generation (Gross) (MU)

	NR	WR	SR	ER	NER	All India	% Share
Coal	697	1513	607	665	14	3496	74
Lignite	29	19	41	0	0	89	2
Hydro	90	47	92	23	11	263	6
Nuclear	26	54	68	0	0	149	3
Gas, Naptha & Diesel	3	13	12	0	24	52	1
RES (Wind, Solar, Biomass & Others)	194	226	235	6	1	662	14
Total	1039	1872	1055	694	50	4710	100

Share of RES in total generation (%)	18.64	12.06	22.29	0.90	2.34	14.06
Share of Non-fossil fuel (Hydro,Nuclear and RES) in total generation(%)	29.88	17.48	37.43	4.16	24.25	22.76

H. All India Demand Diversity Factor

Based on Regional Max Demands	1.015
Based on State Max Demands	1.039

I. All India Peak Demand and shortage at Solar and Non-Solar Hour

	Max Demand Met(MW)	Time	Shortage(MW)
Solar hr	220355	9:54	387
Non-Solar hr	199601	18:44	0

Diversity factor = Sum of regional or state maximum demands / All India maximum demand

**Note: All generation MU figures are gross

***Godda (Jharkhand) -> Bangladesh power exchange is through the radial connection (isolated from Indian Grid)

Solar Hours -> 06:00 to 18:00hrs and rest are Non-Solar Hours

*Source: RLDCs for solar connected to ISTS; SLDCs for embedded solar. Limited visibility of embedded solar data.

Executive Director-NLDC

INTER-REGIONAL EXCHANGES

Import=(+ve) /Export =(-ve) for NET (MU)

Date of Reporting: 17-Jan-2025

Sl No	Voltage Level	Line Details	No. of Circuit	Max Import (MW)	Max Export (MW)	Import (MU)	Export (MU)	NET (MU)
Import/Export of ER (With NR)								
1	HVDC	ALIPURDUAR-AGRA	2	0	0	0.0	0.0	0.0
2	HVDC	PUSAULI B/B	-	3	47	0.0	1.2	-1.2
3	765 kV	GAYA-VARANASI	2	179	1028	0.0	12.6	-12.6
4	765 kV	SASARAM-FATEHPUR	1	0	624	0.0	9.2	-9.2
5	765 kV	GAYA-BALIA	1	0	890	0.0	14.2	-14.2
6	400 kV	PUSAULI-VARANASI	1	7	69	0.0	0.6	-0.6
7	400 kV	PUSAULI -ALLAHABAD	1	65	26	0.5	0.0	0.5
8	400 kV	MUZAFFARPUR-GORAKHPUR	2	41	715	0.0	8.4	-8.4
9	400 kV	PATNA-BALIA	2	0	930	0.0	15.3	-15.3
10	400 kV	NAUBATPUR-BALIA	2	0	635	0.0	4.8	-4.8
11	400 kV	BIHARSHARIFF-BALIA	2	41	292	0.0	5.5	-5.5
12	400 kV	MOTIHARI-GORAKHPUR	2	0	568	0.0	8.6	-8.6
13	400 kV	BIHARSHARIFF-VARANASI	2	0	0	0.0	0.0	0.0
14	220 kV	SAHUPURI-KARAMNASA	1	0	127	0.0	2.4	-2.4
15	132 kV	NAGAR UNTARI-RIHAND	1	0	0	0.1	0.0	0.1
16	132 kV	GARWAH-RIHAND	1	30	0	0.7	0.0	0.7
17	132 kV	KARMANASA-SAHUPURI	1	0	1	0.0	0.0	0.0
18	132 kV	KARMANASA-CHANDAULI	1	0	0	0.0	0.0	0.0
ER-NR						1.3	82.8	-81.5
Import/Export of ER (With WR)								
1	765 kV	JHARSUGUDA-DHARAMJAIGARH	4	459	945	0.0	1.8	-1.8
2	765 kV	NEW RANCHI-DHARAMJAIGARH	2	825	430	6.1	0.0	6.1
3	765 kV	JHARSUGUDA-DURG	2	0	960	0.0	16.9	-16.9
4	400 kV	JHARSUGUDA-RAIGARH	4	0	680	0.0	10.0	-10.0
5	400 kV	RANCHI-SIPAT	2	198	194	0.6	0.0	0.6
6	220 kV	BUDHIPADAR-RAIGARH	1	0	109	0.0	1.2	-1.2
7	220 kV	BUDHIPADAR-KORBA	2	114	43	0.9	0.0	0.9
ER-WR						7.6	29.9	-22.4
Import/Export of ER (With SR)								
1	HVDC	JEYPORE-GAZUWAKA B/B	2	0	214	0.0	5.1	-5.1
2	HVDC	TALCHER-KOLAR BIPOLE	2	0	1197	0.0	29.0	-29.0
3	765 kV	ANGUL-SRIKAKULAM	2	0	2950	0.0	48.9	-48.9
4	400 kV	TALCHER-I/C	2	230	438	2.1	0.0	2.1
5	220 kV	BALIMELA-UPPER-SILERRU	1	0	0	0.0	0.0	0.0
ER-SR						0.0	83.0	-83.0
Import/Export of ER (With NER)								
1	400 kV	BINAGURI-BONGAIGAON	2	269	0	3.8	0.0	3.8
2	400 kV	ALIPURDUAR-BONGAIGAON	2	466	0	7.2	0.0	7.2
3	220 kV	ALIPURDUAR-SALAKATI	2	106	0	1.6	0.0	1.6
ER-NER						12.6	0.0	12.6
Import/Export of NER (With NR)								
1	HVDC	BISWANATH CHARIALI-AGRA	2	663	0	16.1	0.0	16.1
NER-NR						16.1	0.0	16.1
Import/Export of WR (With NR)								
1	HVDC	CHAMPA-KURUKSHETRA	2	0	3019	0.0	51.5	-51.5
2	HVDC	VINDHYACHAL B/B	-	223	300	0.0	2.4	-2.4
3	HVDC	MUNDRA-MOHINDERGARH	2	0	2372	0.0	38.9	-38.9
4	765 kV	GWALIOR-AGRA	2	0	2793	0.0	34.2	-34.2
5	765 kV	GWALIOR-PHAGI	2	458	1834	0.7	20.7	-20.0
6	765 kV	JABALPUR-ORAI	2	0	1354	0.0	34.0	-34.0
7	765 kV	GWALIOR-ORAI	1	780	0	13.3	0.0	13.3
8	765 kV	SATNA-ORAI	1	0	1204	0.0	20.3	-20.3
9	765 kV	BANASKANTHA-CHITORGARH	2	797	980	3.5	5.8	-2.4
10	765 kV	VINDHYACHAL-VARANASI	2	0	3232	0.0	52.0	-52.0
11	400 kV	ZERDA-KANKROLI	1	181	123	1.1	0.5	0.7
12	400 kV	ZERDA -BHINMAL	1	125	85	0.8	0.3	0.4
13	400 kV	VINDHYACHAL -RIHAND	1	982	0	21.5	0.0	21.5
14	400 kV	RAPP-SHUJALPUR	2	605	512	3.8	2.0	1.8
15	400 kV	NEEMUCH-Chittorgarh	2	681	503	5.0	1.4	3.6
16	220 kV	BHANPURA-RANPUR	1	0	175	0.0	2.8	-2.8
17	220 kV	BHANPURA-MORAK	1	0	30	0.0	1.6	-1.6
18	220 kV	MEHGAON-AURAIYA	1	119	8	0.9	0.0	0.9
19	220 kV	MALANPUR-AURAIYA	1	37	28	0.2	0.1	0.1
20	132 kV	GWALIOR-SAWAI MADHOPUR	1	0	0	0.0	0.0	0.0
21	132 kV	RAJGHAT-LALITPUR	2	0	0	0.0	0.0	0.0
WR-NR						50.7	268.4	-217.8
Import/Export of WR (With SR)								
1	HVDC	BHADRAWATI B/B	-	305	338	4.7	2.6	2.1
2	HVDC	RAIGARH-PUGALUR	2	0	904	0.0	21.8	-21.8
3	765 kV	SOLAPUR-RAICHUR	2	1231	925	6.0	4.0	2.1
4	765 kV	WARDHA-NIZAMABAD	2	242	2453	0.2	32.8	-32.6
5	765 kV	WARORA-WARANGAL(NEW)	2	194	2214	0.1	30.7	-30.6
6	400 kV	KOLHAPUR-KUDGI	2	1649	0	28.4	0.0	28.4
7	220 kV	KOLHAPUR-CHIKODI	2	0	0	0.0	0.0	0.0
8	220 kV	PONDA-AMBEWADI	1	0	0	0.0	0.0	0.0
9	220 kV	XELDEM-AMBEWADI	1	0	104	2.1	0.0	2.1
WR-SR						41.4	91.7	-50.3

INTERNATIONAL EXCHANGES					Import(+ve)/Export(-ve)		
State	Region	Line Name	Max (MW)	Min (MW)	Avg (MW)	Energy Exchange (MU)	
BHUTAN	ER	400kV MANGDECHHU-ALIPURDUAR 1,2&3 i.e. ALIPURDUAR RECEIPT (from MANGDECHU HEP 4*180MW)	176	-10	76	1.82	
	ER	400kV TALA-BINAGURI 1,2,4 (& 400kV MALBASE - BINAGURI) i.e. BINAGURI RECEIPT (from TALA HEP 6*170MW)	-225	90	-73	-1.74	
	ER	220kV CHUKHA-BIRPARA 1&2 (& 220kV MALBASE - BIRPARA) i.e. BIRPARA RECEIPT (from CHUKHA HEP 4*84MW)	-248	-99	-183	-4.39	
	NER	132kV GELEPHU-SALAKATI	-24	0	-18	-0.43	
	NER	132kV MOTANGA-RANGIA	10	0	2	0.05	
NEPAL	NR	NEPAL IMPORT (FROM UP)	-67	0	-57	-1.37	
	NR	132kV MAHENDRANAGAR-TANAKPUR(NHPC)	-67	0	-42	-1.00	
	ER	NEPAL IMPORT (FROM BIHAR)	-172	-41	-82	-1.97	
	ER	400kV DHALKEBAR-MUZAFFARPUR 1&2	-314	-27	-163	-3.91	
BANGLADESH	ER	BHERAMARA B/B HVDC (B'DESH)	-939	-652	-887	-21.28	
	ER (Isolated from Indian Grid)	400kV GODDA_TPS-RAHANPUR (B'DESH) D/C	51	0	6	0.14	
	NER	132kV COMILLA-SURAJMANI NAGAR 1&2	-59	0	-51	-1.22	

Export From India (in MU)

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.00	0.30	5.49	0.00	0.00	0.23	0.00	0.00	6.02
Nepal	2.12	0.00	3.52	0.00	0.00	0.58	0.00	0.00	6.22
Bangladesh	22.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	22.13
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Export	24.25	0.30	9.01	0.00	0.00	0.81	0.00	0.00	34.37

Import by India(in MU)

Country	GNA (ISGA/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.77	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.77
Nepal	0.00	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.05
Bangladesh	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Import	0.77	0.00	0.00	0.00	0.00	0.05	0.00	0.00	0.82

Net from India(in MU)

-ve : Export / +ve : Import

Country	GNA (ISGS/PPA)	T-GNA							TOTAL
		BILATERAL TOTAL	COLLECTIVE						
			IDAM			RTM			
			IEX	PXIL	HPX	IEX	PXIL	HPX	
Bhutan	0.77	-0.30	-5.49	0.00	0.00	-0.23	0.00	0.00	-5.25
Nepal	-2.12	0.00	-3.52	0.00	0.00	-0.53	0.00	0.00	-6.17
Bangladesh	-22.13	0.00	0.00	0.00	0.00	0.00	0.00	0.00	-22.13
Myanmar	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
Total Net	-23.48	-0.30	-9.01	0.00	0.00	-0.76	0.00	0.00	-33.55

Date of Reporting: 17-Jan-2025												
15 Min (INSTANTANEOUS) ALL INDIA GRID FREQUENCY, GENERATION & DEMAND MET (SCADA DATA)												
TIME	FREQUENCY (Hz)	DEMAND MET (MW)	NUCLEAR (MW)	WIND (MW)	SOLAR (MW)	HYDRO** (MW)	GAS (MW)	THERMAL (MW)	OTHERS* (MW)	NET DEMAND MET (MW)	TOTAL GENERATIO N (MW)	NET TRANSNATIONAL EXCHANGE (MW) (+ve) Import, (-ve)
		(A)	(B)	(C)	(D)	(E)	(F)	(G)	(H)	(I=A- (C+D))	(J=B+C+D+E +F+G+H)	(K)
0:00	50.03	147234	5917	11319	226	6959	1937	122858	2564	135689	151780	-1571
0:15	50.03	146841	5906	11099	229	6560	1940	122796	2564	135513	151094	-1574
0:30	49.93	145997	5914	10880	225	6456	1949	122634	2581	134892	150639	-1620
0:45	49.98	144875	5928	10780	232	6442	1946	121542	2611	133863	149481	-1485
1:00	49.98	143834	5925	10539	228	6443	1943	120544	2614	133067	148236	-1394
1:15	49.98	142965	5924	10462	222	6190	1942	119871	2682	132281	147293	-1394
1:30	50.03	142151	5918	10320	219	6027	1941	119367	2716	131612	146508	-1381
1:45	50.08	141169	5905	10271	219	6135	1934	118575	2654	130679	145693	-1382
2:00	50.08	139634	5927	10384	217	5786	1947	117188	2669	129033	144118	-1374
2:15	50.03	139513	5935	10419	215	5477	1936	117059	2742	128879	143783	-1356
2:30	50.03	138794	5917	10468	216	5485	1941	116596	2707	128110	143330	-1359
2:45	50.03	138699	5919	10279	218	5636	1951	116324	2763	128202	143090	-1350
3:00	50.03	138297	5928	10236	213	5613	1943	116120	2753	127848	142806	-1339
3:15	50.03	138490	5924	10324	211	5726	1939	115995	2719	127955	142838	-1259
3:30	50.03	138192	5922	10294	202	5600	1944	115953	2715	127696	142630	-1262
3:45	49.98	138558	5925	9977	193	5571	1943	116508	2738	128388	142855	-1317
4:00	50.08	138841	5908	9801	188	5571	1951	116909	2808	128852	143136	-1283
4:15	50.03	140526	5917	9678	193	5793	1942	118810	2713	130655	145046	-1310
4:30	50.08	141761	5938	9674	198	6315	1939	119447	2704	131889	146215	-1295
4:45	49.98	143162	5929	9633	196	6016	1944	121381	2641	133333	147740	-1369
5:00	50.03	145094	5919	9451	208	6085	1950	123576	2626	135435	149815	-1459
5:15	49.93	148727	5907	9488	216	6033	1944	126901	2579	139023	153068	-1441
5:30	49.93	152776	5909	9543	214	6130	1944	131330	2621	143019	157691	-1462
5:45	49.93	157161	5906	9455	213	6744	1952	135002	2652	147493	161924	-1435
6:00	50.08	160282	5923	9579	220	7339	1987	137400	2676	150483	165124	-1501
6:15	49.98	165513	5920	9574	246	8540	1995	141343	2686	155693	170304	-1648
6:30	50.03	172199	5919	9552	353	10817	2003	145661	2645	162294	176950	-1488
6:45	50.08	177960	5916	9621	369	13227	2000	148778	2694	167970	182605	-1382
7:00	50.03	183818	5926	9857	497	15593	2009	151986	2784	173464	188652	-1322
7:15	49.98	190100	5917	10132	979	17803	2004	155187	2737	178989	194759	-1289
7:30	50.03	195341	5934	10237	1949	19683	2001	157064	2731	183155	199599	-1236
7:45	49.98	198382	5928	10217	3418	21027	2030	157279	2734	184747	202633	-1187
8:00	50.03	202012	5934	9915	5640	21827	2286	157509	2753	186457	205864	-1155
8:15	49.98	206569	5925	9664	8777	22548	2040	158683	2792	188128	210429	-1119
8:30	50.03	210262	5916	9410	12473	22298	2043	158851	2806	188379	213797	-1139
8:45	50.03	211473	5923	9212	16625	20187	2039	158159	2856	185636	215001	-1077
9:00	50.08	213040	5919	9359	20886	18643	2044	156222	2936	182795	216009	-1064
9:15	50.03	217324	5927	9253	25430	17061	2047	158173	2967	182641	220858	-1183
9:30	50.08	219152	5923	9037	29431	15763	2051	157532	2942	180684	222679	-1186
9:45	50.08	220171	5922	8789	33114	14729	2052	156220	2969	178268	223795	-1362
10:00	50.08	219962	5910	8509	36799	12404	2252	155129	3003	174654	224006	-1423
10:15	50.03	219533	5903	8597	39654	10535	2054	153693	3005	171282	223441	-1411
10:30	50.03	218953	5923	8603	42376	8962	1922	152196	2990	167974	222972	-1407
10:45	49.98	218062	5922	8667	44538	8384	1874	149816	3004	164857	222205	-1435
11:00	49.98	216497	5910	8884	46522	8380	1871	146274	3021	161091	220862	-1441
11:15	49.98	214634	5909	9068	48153	7748	1875	143186	3011	157413	218950	-1610
11:30	49.98	213887	5911	9336	49378	7811	1873	140675	3060	155173	218044	-1806
11:45	49.93	212272	5919	9408	50368	7448	1873	138258	3129	152496	216403	-1810
12:00	49.93	210755	5901	9361	50845	7032	1864	136576	3123	150549	214702	-1772
12:15	49.88	209175	5912	9397	51218	6577	1865	135361	3082	148560	213412	-1774
12:30	49.93	208322	5898	9503	51387	7014	1857	133769	3044	147432	212472	-1800
12:45	49.93	206137	5899	9332	51605	7269	1866	131284	3089	145200	210344	-1754
13:00	50.03	202773	5910	9199	51897	7242	1861	127813	3075	141677	206997	-1768
13:15	49.98	199346	5897	9147	51524	6889	1868	124933	3048	138675	203306	-1776
13:30	50.03	197663	5890	9083	50943	6335	1856	124662	3060	137637	201829	-1777
13:45	49.93	197690	5875	8859	50550	6279	1877	124917	3054	138281	201411	-1852
14:00	50.03	197358	5883	8777	49533	6566	1863	125284	3056	139048	200962	-1875
14:15	49.98	197173	5883	8619	48293	6542	1863	126826	3014	140261	201040	-1855
14:30	49.93	197391	5887	8581	46524	6854	1861	128172	3021	142286	200900	-1882
14:45	49.98	197690	5858	8539	44625	7054	1845	130660	2967	144526	201548	-1844
15:00	50.08	197833	5956	8419	42490	7735	1842	132172	2941	146924	201555	-1795
15:15	50.03	197078	5964	8243	40078	7536	1832	134593	2980	148757	201226	-1732
15:30	49.98	197299	5952	8245	37300	8522	1931	136761	2960	151754	201671	-1689
15:45	50.03	196638	5962	8394	34565	8886	1946	138119	2948	153679	200820	-1707
16:00	50.03	195705	5964	8211	30971	9268	1943	140487	2920	156523	199764	-1702
16:15	49.98	194704	5962	8220	27503	8995	2247	142539	2935	158981	198401	-1613
16:30	50.04	196208	5958	8251	23235	9921	2137	147436	2900	164722	199838	-1380
16:45	49.99	196295	6004	8143	18933	11272	2176	151098	2867	169219	200493	-1279
17:00	49.99	195832	5851	7983	14477	13323	2205	152748	2800	173372	199387	-1278
17:15	49.99	194764	6046	7869	10382	15624	2239	154208	2795	176513	199163	-1081
17:30	50.04	195923	6044	7663	6658	19429	2249	155450	2826	181602	200319	-1016
17:45	49.94	196845	6078	7388	3921	21683	2266	157128	2805	185536	201269	-1063
18:00	50.04	197218	6092	7184	2087	22503	2100	158996	2830	187947	201792	-1062

18:15	49.94	197015	6100	7305	1292	22614	1962	159737	2895	188418	201905	-1062
18:30	49.94	198663	6103	7619	1084	23137	2026	160552	2893	189960	203414	-1068
18:45	50.04	199069	6107	7879	972	22813	2040	160974	2878	190218	203663	-1016
19:00	50.04	197344	6114	8190	973	21139	2033	160558	2913	188181	201920	-1040
19:15	50.04	196417	6085	8638	978	19459	1949	160904	2909	186801	200922	-1023
19:30	50.04	194363	6065	9036	976	18357	1941	159811	2896	184351	199082	-1042
19:45	50.04	192064	6039	9559	897	16514	1936	159025	2874	181608	196844	-1047
20:00	50.09	187966	5978	9968	835	15035	1945	155874	2890	177163	192525	-1023
20:15	49.99	184708	5910	10436	803	12876	1946	154457	2916	173469	189344	-1028
20:30	50.04	182665	5876	10881	809	12160	1935	152637	2859	170975	187157	-1042
20:45	49.99	180151	5502	11218	784	10194	1943	151721	2905	168149	184267	-1077
21:00	50.04	177156	5394	11694	765	9327	2124	149826	2888	164697	182018	-1117
21:15	49.98	174654	5234	11943	764	8704	1936	148206	2872	161947	179659	-1400
21:30	49.98	171920	5243	12110	766	8092	1945	145856	2923	159044	176935	-1528
21:45	49.93	169434	5235	12335	765	7608	1912	143621	2882	156334	174358	-1537
22:00	50.03	165648	5246	12584	761	7260	1934	140007	2919	152303	170711	-1518
22:15	49.98	164785	5229	12769	761	7715	1924	137956	2910	151255	169264	-1604
22:30	49.98	162689	5212	12819	760	7633	1933	136096	2917	149110	167370	-1620
22:45	49.97	160860	5201	12745	758	7407	1940	134970	2932	147357	165953	-1592
23:00	49.97	158847	5181	12802	761	7035	1926	133191	2909	145284	163805	-1588
23:15	49.97	157395	5170	12880	761	6912	1927	131696	2929	143754	162275	-1564
23:30	50.02	155336	5211	12734	761	6337	1935	130468	2932	141841	160378	-1623
23:45	50.02	153204	5213	12898	760	6047	1933	128431	2914	139546	158196	-1596

*Others include (i) Biomass from Punjab (ii) Some of the state sector IPP & non-conventional generation in SR (small capacity) (iii) Solar generation in Odisha(manually punched).

** Hydro generation is excluding Bhutan hydro.

***Bhutan hydro is accounted for in net transnational exchange.

Disclaimer:

1. The information provided is for general informational purposes only.
2. The data is provided "as is" without any guarantees or warranties.
3. All Data is operational SCADA data telemetered and reporting at NLDC through RLDC/SLDC.
4. Data is subject to errors due to telemetry loss/freeze/garbage value etc.
5. Demand met and RE generation data is incident on transmission system. Resources in distribution system plus behind the meter (BTM) generation excluded.
6. Users are advised to ensure its accuracy, completeness and relevance for their purposes, and, in this respect, GRID-INDIA shall not be responsible for any errors or omissions.